

Coal Creek Prototype Fluidized Bed Coal Dryer: Performance Improvement, Emissions Reduction, and Operating Experience

Charles Bullinger and Mark Ness
*Great River Energy, Coal Creek Station
Underwood, ND 58576-9659*

Nenad Sarunac
*Energy Research Center, Lehigh University
Bethlehem, PA 18015*

**31st International Technical Conference on Coal Utilization and Fuel Systems,
Clearwater FL, May 21-25, 2006.**



Introduction

- ☐ *Coal moisture has a large negative effect on boiler efficiency, station service power and unit heat rate.*
- ☐ *For a 600 MW lignite-fired unit, fuel moisture is responsible for:*
 - ▣ *9% higher coal flow rate*
 - ▣ *20 MW of station service power*
 - ▣ *20% higher flue gas flow rate*
 - ▣ *Increased operating and maintenance cost*
- ☐ *Can a low-temperature waste heat be used to reduce fuel moisture?*



GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative


Copyright 2006 Great River Energy - All Rights Reserved

Project Goals and Schedule

Goals and Objectives:


- Reduce moisture content of lignite, PRB, and other high-moisture coals.
- Use waste heat from the power plant.
- Modify existing coal handling systems.
- Increase competitive position of lignite-, PRB-, and other high moisture coal-fired power plants.
- Reduce environmental impact of lignite-, PRB-, and other high-moisture coal-fired power plants

Project Phases and Schedule:



GREAT RIVER
ENERGY®

Lignite Fuel Enhancement: Incremental Moisture Reduction Project



GREAT RIVER ENERGY®

Previous Work



1997-1998

- ▣ *Preliminary studies and concept development*



1999

- ▣ *Lignite-drying tests at Coal Creek using low-temperature fixed-bed dryer.*



2000

- ▣ *Coal Creek boiler modeling*
- ▣ *Laboratory lignite drying tests.*
- ▣ *Full-scale test burns (20,000 tons of lignite dried using low-temperature air, and burned at Coal Creek).*



2001

- ▣ *Fluidized bed selected for coal drying*
- ▣ *Laboratory drying tests at Lehigh University*



2002

- ▣ *Application filed with DOE under the Clean Coal Power Initiative (CCPI).*



GREAT RIVER
ENERGY®

Previous Work

2003

- Project selected for negotiation with DOE.
- 2 ton/hr pilot fluidized bed dryer built at Coal Creek with NDIC funding.
- Pilot coal dryer testing at Coal Creek

2004

- Contract signed with DOE (Clean Coal Power Initiative).
- DOE joined partnership under collaborative agreement.
- Design of a prototype coal dryer and associate equipment.

2005

- Construction begins of a prototype coal dryer at Coal Creek Unit 2.

2006

- Prototype coal dryer checkout and start-up
- Prototype coal dryer performance testing (in progress)
- Unit performance testing (in progress)
- August: **Phase 1 Milestone**



GREAT RIVER
ENERGY®

Pilot Coal Dryer at Coal Creek

- ☐ *Pilot fluidized bed dryer was designed and operated to determine drying rates of North Dakota lignite.*
- ☐ *Low-temperature lignite drying process.*
- ☐ *No appreciable carbon oxidation, and devolatilization.*
- ☐ *No operational difficulties.*
- ☐ *Results showed it is possible to remove substantial fraction of S and Hg from the coal.*



GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative

Copyright 2006 Great River Energy - All Rights Reserved

Description of Host Unit

☐ **Coal Creek Station:**

- ▣ *1,200 MW lignite-fired*
- ▣ *Two T-fired CE boilers*
- ▣ *2,400 psig @ 1,000 °F /1,000 °F*
- ▣ *Two single reheat GE G-2 turbines*
- ▣ *3 Cooling towers*
- ▣ *Fuel HHV = 6,200 BTU/lb*
- ▣ *Fuel moisture = 38 percent*
- ▣ *Coal fired = 900,000 lb/hr per unit*



GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative

Copyright 2006 Great River Energy - All Rights Reserved

Coal Creek Station



GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative

Copyright 2006 Great River Energy - All Rights Reserved

Prototype Coal Drying System at Coal Creek



GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative 


Prototype Coal Dryer

- ☐ *Maximum capacity **112.5 t/hr.***
- ☐ *Remove approx. $\frac{1}{4}$ of coal moisture.*
 - ▣ *Dry lignite from **38%** to **29.5%**.*
 - ▣ *Improve HHV from **6,200** to **7,045** BTU/lb*
- ☐ *Fully automated operation, integrated into the plant control system.*
- ☐ *Four patent applications on dryer design and control filed by GRE.*



GREAT RIVER
ENERGY®

Prototype Dryer: Unit 2 East



GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative

Copyright 2006 Great River Energy - All Rights Reserved

Prototype Dryer Installation



GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative

Copyright 2006 Great River Energy - All Rights Reserved

Prototype CDS: Vibrating Coal Feeder



GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative

Copyright 2006 Great River Energy - All Rights Reserved

Prototype CDS: Feed Conveyer to Dryer



GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative

Copyright 2006 Great River Energy - All Rights Reserved

Prototype CDS: Fluidized Bed Coal Dryer



GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative

Copyright 2006 Great River Energy - All Rights Reserved

Prototype CDS Checkout, Start-Up, and Operation Summary

- ☉ *Checkout and “shakedown” in December 2005.*
 - ▣ *No problems*
- ☉ *1st coal on January 30th 2006.*
- ☉ *7-hour daily tests*
- ☉ *Inspection on Feb 11th,*
 - ▣ *No accumulation of material in the dryer*
- ☉ *Drying to 29.5%*
- ☉ *Segregator optimization Feb 27th to Mar 3rd 2006.*
- ☉ *Operator training before 24/7 operation*
- ☉ *Performance testing in March and April 2006.*



GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative

Copyright 2006 Great River Energy - All Rights Reserved

Prototype Coal Dryer (CD26) Performance




GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative 

CD26 Performance

Prototype Coal Dryer Performance: March to April, 2006




GREAT RIVER ENERGY®

A Touchstone Energy® Cooperative

CD26 Performance

Prototype Coal Dryer Performance: March to April, 2006



GREAT RIVER ENERGY®

A Touchstone Energy® Cooperative

CD26 Performance

☐ Feed rate: 75 tons/hr (14% of total)

Parameter	Feed	Product	Change	Change
	TM %	TM %	TM % Abs	TM % Rel
Average Total Moisture, TM	36.78	28.55	8.23	22.4
Std. Deviation	1.26	1.00	1.07	
Std. Deviation of the Mean	0.34	0.27	0.30	

Parameter	Feed	Product	Change	Change
	HHV [BTU/lb]	HHV [BTU/lb]	HHV [BTU/lb]	HHV [%]
Average HHV	6,290	7,043	752	12.0
Std. Deviation	159	121	131	
Std.Deviation of the Mean	43	33	37	



GREAT RIVER
ENERGY®

Unit Performance



GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative 

Unit Performance: Summary

Parameter	Units	Coal Dryer in Service	Coal Dryer Out of Service	Change	Units of Change
Gross Power Output	MW	589	590	NC	
Throttle Steam Temperature	Deg. F	988	989	NC	
Reheat Steam Temperature	Deg. F	1,002	1,002	NC	
SHT Spray Flow	klbs/hr	46	52	-6.4	klbs/hr
Total Coal Flow Rate	klbs/hr	953	972	-2.02	%
Dried Coal	% of Total	14.62	0.00		
Stack Flow Rate	kscfm	1,611	1,626	-0.96	%
Specific Pulverizer Work	kJ/klb	4.09	4.29	-4.65	%
Total Pulverizer Power	kW	4,057	4,206	-3.53	%
NOx Mass Emissions	lb/hr	1,345	1,470	-8.52	%
SOx Mass Emissions	lb/hr	3,618	3,692	-2.00	%
APH 21 Gas Exit Temperature	Deg. F	353	362	-8.6	Deg. F
APH 22 Gas Exit Temperature	Deg. F	368	377	-9.3	Deg. F
Stack Temperature	Deg. F	180	184	-4.2	Deg. F




GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative

Copyright 2006 Great River Energy - All Rights Reserved

Mill Power Reduction


CD26: 75 t/hr



GREAT RIVER ENERGY®

Decrease in APH Gas Outlet Temperature

Improvement in Unit Performance




GREAT RIVER ENERGY

A Touchstone Energy Cooperative

Copyright 2006 Great River Energy - All Rights Reserved

Boiler Efficiency Improvement



GREAT RIVER ENERGY®

A Touchstone Energy® Cooperative

Test Data




GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative 

Test Data: Coal Flow Rate

Prototype Dryer Performance Tests: March-April, 2006




GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative

Copyright 2006 Great River Energy - All Rights Reserved

Test Data: Total Mill Power


Prototype Dryer Performance Tests: March-April, 2006



GREAT RIVER
ENERGY®

Test Data: NO_x Emissions

Prototype Dryer Performance Tests: March-April, 2006



GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative

Copyright 2006 Great River Energy - All Rights Reserved

Evaporated Coal Moisture Discharged into the Atmosphere



GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative

Copyright 2006 Great River Energy - All Rights Reserved

Conclusions

- ☉ *Prototype coal dryer (CD26) in service at Coal Creek since early spring 2006.*
 - ▀ *No operating issues*
 - ▀ *Nominal coal flow rate 75/t/hr.*
- ☉ *Inlet moisture level reduced by* **8.25% Abs.**
- ☉ *Coal flow rate reduction:* **2.0%**
- ☉ *Mill power reduction:* **4.5%**
- ☉ *Boiler efficiency improvement:* **0.27% Abs.**
- ☉ *Net unit heat rate improvement:* **0.34%**
- ☉ *NO_x mass emissions reduction:* **8.5%**
- ☉ *SO_x mass emissions reduction:* **2.0%.**



GREAT RIVER
ENERGY®

Future Work

- ☉ *Operate CD26 at maximum capacity.*
 - ▣ *Determine operating conditions required to reduce inlet moisture level by 8.5% Abs.*
- ☉ *Determine effect on unit performance*
- ☉ *Construct and install additional three dryers in Phase 2.*
 - ▣ *Test to determine effect on unit performance, emissions, and operation.*



GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative

Copyright 2006 Great River Energy - All Rights Reserved

Questions ?



GREAT RIVER
ENERGY®

A Touchstone Energy® Cooperative

Copyright 2006 Great River Energy - All Rights Reserved