

Chapter 2.
Proposed Action and Alternatives

2 PROPOSED ACTION AND ALTERNATIVES

This chapter describes DOE's Proposed Action and No Action Alternative, and it describes Summit's proposed TCEP and alternatives considered by Summit but eliminated from further consideration. Along with an overview of the TCEP, this chapter provides detailed technical information on the proposed project that forms the basis for the analyses in this EIS. This information includes detailed descriptions of the polygen plant, linear facility options, CO₂ capture and sequestration methods, resources required for the proposed project, by-products and wastes, construction and operation plans, measures to reduce potential impacts, and post-operation activities. The chapter also describes the operational options considered by the project.

2.1 Introduction

The TCEP would be located approximately 15 miles (mi) (24 kilometer [km]) southwest of the city of Odessa in Ector County, Texas. The proposed 600-ac (243-ha) polygen plant site is located in the community of Penwell, just north of Interstate (I)-20 and a Union Pacific Railroad (UPRR) line. The land has historically been used for ranching and limited oil and gas activities.

As proposed by Summit, the TCEP would consist of the polygen plant and the linear facilities that would be constructed and operated to serve the plant. The polygen plant would use a commercial IGCC system and would be integrated with CO₂ capture and geologic *storage* through EOR. The proposed linear facilities would consist of an electric transmission line, one or more process waterlines, a natural gas pipeline, a CO₂ pipeline connector, a rail line connector, and two access roads that would connect the plant to existing roads.

Figure 2.1 shows the plant site and associated linear facilities, which consist of the *six* waterline options (WL1–**WL6**), six transmission line options (TL1–TL6), the CO₂ pipeline connector (CO₂), *three* natural gas pipeline *options* (NG1–**NG3**), *four* access roads (AR1–**AR4**), and one rail spur (RR1).

EOR refers to techniques that allow increased recovery of oil in partially depleted or high viscosity oil fields. CO₂ flooding (CO₂/EOR) has the potential to not only increase the yield of residual or high viscosity oil, but also to sequester CO₂ that would normally be released to the atmosphere.

In general terms, CO₂ is injected into an oil field through injection wells drilled near producing wells. The CO₂ and oil mix together and form a mixture that more easily flows to the production well. To sweep out residual oil, CO₂ is cycled through the oil field one or more times, with each cycle resulting in a part of the CO₂ becoming trapped in the spaces that were previously occupied by oil. The CO₂ that comes up the well with the oil is recovered and re-injected into the field. Maturing oil fields and rising oil prices have made this method of resource recovery increasingly attractive to industry.

Currently, CO₂/EOR comprises approximately 37 percent of all EOR being performed in the United States (water is also used). The United States has been a leader in developing and using technologies for CO₂/EOR by performing approximately 96 percent of worldwide CO₂/EOR.

CO₂/EOR has been used by the oil and gas industry for more than 40 years, but only recently has its potential as a CO₂ sequestration method been realized and investigated. The CO₂ used to increase oil production is an expensive commodity, and for this reason, oil companies are highly motivated to ensure that CO₂ does not escape to the atmosphere.




Figure 2.1. Polygen plant site and associated linear facilities.

The polygen plant is being designed to use low-sulfur, Powder River Basin sub-bituminous coal from Wyoming as the feedstock for the gasification island, which would use two Siemens gasifiers to convert that feedstock into syngas for downstream use. After further cleaning, chemical conversion and processing of the syngas, followed by capture and removal of CO₂, the H₂-rich syngas would be used in the power island to generate 400 MW (gross) of electrical power.

The TCEP would contribute approximately **130–213 MW net (1.0–1.7 billion net kilowatt-hours)** of electricity per year to the electric grid system, which would help meet future demand. The remainder of the gross generation would be used to run the plant. In addition, the polygen plant would be designed to capture, as CO₂, 90 percent or more of the total carbon in the fossil fuel used in the plant under almost all operating conditions. The captured CO₂ would be sold under binding commercial contracts and subsequently injected deep underground for EOR. The plant would also produce urea for fertilizer. Argon and H₂SO₄ would be by-products of the gasification and syngas cleanup processes and would be made available for commercial sale. Slag (an inert by-product of the gasification process) could be sold as a raw material for manufacturing cement and other products.

Interconnections for supplies of natural gas and process water would all be required. Potable water would be trucked to the site, **obtained from the process water supply after on-site treatment, or provided through an on-site water well.** The **polygen plant** would **interconnect with one or more** existing **power** transmission lines. Captured CO₂ would be transported from the plant site by pipeline to an existing Kinder Morgan CO₂ pipeline. Coal would be delivered to the plant site by the UPRR line adjacent to the site. Chemical products produced by the plant would be transported off-site by rail or by truck.

Industrial waste water would be **reused after on-site treatment in the process water treatment system** to minimize overall water demand. Disposal of **residual industrial waste** water would be through **a mechanical crystallizer and filter press system or solar evaporation ponds, with an option to deep well inject the waste water depending on its quality. Disposal of reverse osmosis reject water, however, would only be through a combination of on-site solar evaporation ponds and deep well injection.** Slag that could not be sold for commercial use would be sent by truck or rail to a licensed off-site landfill. Sanitary wastes would be collected and discharged directly to an on-site septic system.

The primary access to the plant would **connect either Farm-to-Market Road (FM) 866 or the I-20 frontage road to** the northern border of the plant site. **An alternate access route for** emergency vehicles, **the plant's** administrative workforce, and visitors **would connect to** FM 1601 at the southeastern border of the plant site. Use of FM 1601 to access the plant site would require construction of an underpass, overpass, or at-grade intersection with the UPRR line.

2.2 DOE's Proposed Action

DOE's Proposed Action is to provide a total of approximately \$450 million in financial assistance for Summit's proposed TCEP through a cooperative agreement. The money would be provided on a cost-share basis for the planning, design, construction, and demonstration-phase testing and operation of the project. Under the terms of the cooperative agreement, DOE has made available approximately \$37 million on a cost-share basis for the project definition phase, which includes completion of the EIS. This is 80 percent of the estimated \$46.3 million cost of the project-definition phase. The activities eligible for cost sharing during this phase include preliminary design and environmental studies that provide the basis for this EIS. Making these funds available does not

prejudice DOE's ultimate decision on the Proposed Action and is consistent with DOE and Council on Environmental Quality regulations (10 C.F.R. § 1021.211 and 40 C.F.R. § 1506.1, respectively), which restrict DOE from taking action that would have an adverse environmental impact or limit the choice of reasonable alternatives until the Record of Decision has been issued.

Summit's application for DOE financial assistance indicated that the TCEP "is readily expandable with gasifiers and other components in modules" (Summit 2009). However, Summit has no plans for expansion at this time. Thus, such activities are speculative and not within the scope of this EIS. Any future expansion, were it to occur, would remain in the current 600-ac (243-ha) site, and no modifications to any linear facilities would be required. If a future expansion involved federal funds or federal lands or required a federal permit or approval, the potential impacts of such an expansion would be subject to the appropriate level of NEPA analysis and disclosure.

2.3 Development of Summit's Proposed Project

2.3.1 Technology Selection

Summit's primary business is the development of power projects having low- to zero-CO₂ emissions, including wind power projects, solar power projects, and combined-cycle gas-fueled power plant projects. Summit has more than \$5 billion in commercially operating projects, most of them using Siemens power-generation equipment.

In the early 2000s, Summit began considering the development of an IGCC plant with the intention of providing CO₂ capture when the technology became available. In 2007, Siemens acquired and began testing a gasification technology. Subsequently, the TCEP began as a joint Summit and Siemens concept, building on the development of the proposed REC project in Butte, Montana. The REC project was conceived as a means of supplying electric power, H₂, argon, and other chemicals to REC Silicon, a large manufacturer of polysilicon for solar power and computer applications. Fluor was selected as the REC project's design engineer. Fluor began work under Summit's direction in the configuration and preliminary design engineering of the two-gasifier Siemens reference plant that is the model for the TCEP.

The TCEP's size was based on technology considerations and transmission limitations in West Texas. Summit and Siemens selected a two-gasifier configuration using Siemens SFG-500 gasifiers, with one **gas** turbine and one steam turbine. Siemens has designed these gasifiers into a "twin pack" with all the surrounding feedstock, waste water, and product processing equipment to maximize efficiency. However, with two gasifiers and one **gas** turbine, the polygen plant would produce excess syngas but not enough to support two **gas** turbines (one gasifier would be insufficient for one **gas** turbine). Although the excess syngas could be used to make several types of products, market research revealed that the production of urea for fertilizer would have the most financial benefit. A three-gasifier and two **gas** turbine configuration was eliminated from consideration because the amount of electricity that would be generated as a result would likely exceed the transmission capacity available in the area.

While the basic configuration of the plant and its technology selections were specified in Summit's proposal submitted to DOE and accepted under the CCPI Round 3 program, two technology options remain under consideration by Summit. For disposal of **waste water**, Summit is considering 1) **on-site** solar evaporation ponds, 2) **on-site** deep **well** injection, or 3) a **mechanical crystallizer** and filter press system. To meet the cooling needs for the chemical process portion of the plant, Summit

is considering either wet or dry cooling towers, depending on the degree of cooling required and on system economics. These technology options are described in subsequent sections of Chapter 2, and their potential impacts are described where appropriate in Chapter 3.

2.3.2 Alternative Sites

Because of its desire to integrate IGCC technology with CO₂ capture, Summit focused its siting efforts in Texas, which has both a market for CO₂ for use in EOR and existing infrastructure for transporting CO₂ to oil fields. Oil producers in Texas have used CO₂ for many years, and the Texas Bureau of Economic Geology was willing to assist the project.

Summit considered several sites in Texas, including Corpus Christi, Oak Grove, Big Brown, and the two sites—Jewett and Odessa—that had been considered for DOE’s FutureGen project, which also would have used IGCC with CO₂ capture. ***The Corpus Christi sites that were investigated are located in the port/harbor area of Corpus Christi. There were several drawbacks to the sites, which ultimately eliminated them from consideration. The drawbacks included the following:***

- ***Lack of any existing CO₂/EOR infrastructure in or connecting the sites to the target oil fields***
- ***Potentially extensive site work required to make the sites suitable for the project***
- ***Location of the polygen plant just a few feet above sea level, which could have made project investors or lenders concerned about the project’s ability to withstand hurricanes and/or sea level rise***

Summit also investigated two sites in North-Central Texas—Oak Grove and Big Brown—as well as the Jewett site in East Texas, which was one of the two “finalist” sites in Texas considered for the FutureGen Project. None of these sites had existing CO₂/EOR operations or infrastructure, which made the timing and cost of development of these CO₂/EOR possibilities uncertain. These sites were ultimately judged by Summit to be commercially unfeasible.

Summit ultimately selected the Odessa site primarily because of its proximity to an existing CO₂ pipeline and multiple EOR sites. The Odessa site also has close access to rail, natural gas, transmission lines, and available sources of water, which the other Texas sites lacked in varying degrees. Finally, the Odessa site enjoys significant community support for the TCEP.

2.3.3 Linear Facility Options

Summit ***identified*** options for ***the*** required linear facilities based on the most direct routes from the polygen plant site to the closest interconnection points, taking into account the need to minimize adverse impacts to residences and the environment and to minimize construction issues. The linear facilities selected would use existing linear facilities or ROWs to the fullest extent possible.

With respect to the process water needed for the plant, Summit sought to avoid water sources that would cause a conflict with municipal drinking water needs. Thus, Summit is ***considering two optional water sources: 1)*** the use of some of the city of Midland’s ***municipal*** waste water effluent with ***treatment being provided*** at the GCA Odessa South Facility in Odessa, ***and 2)*** the use of brackish (highly saline and nonpotable) ground water from the Capitan Reef Complex Aquifer through an existing pipeline system owned by Oxy USA-W Texas Water Supply (Oxy Permian). In addition, FSH has proposed the development of a water pipeline to provide raw water for municipal

use in Midland and Odessa. Should such a pipeline be constructed, Summit would also consider it as a potential process water source.

DOE received a comment on the draft EIS requesting that DOE consider the use of the Pecos Alluvium Aquifer for the TCEP's process water source as an alternative to the proposed FSH water source option, which would use the Edwards-Trinity (Plateau Aquifer). In response to the comment, Summit contacted one large property holder and investigated the possibility of tapping the Pecos Alluvium Aquifer on this property. This opportunity was dismissed from further consideration because of the lack of existing well field and pipeline infrastructure, the aquifer's slow recharge rate, thinness of the aquifer, and the potential future use of this aquifer by municipalities.

2.4 Summit's Proposed Project

2.4.1 Process Description

The TCEP would integrate coal gasification, combined-cycle power generation, CO₂ capture, and urea production. These four processes are described below, and a diagram of how these technologies are integrated is shown in Figure 2.2. Unless otherwise noted, the source for the process description is the *Texas Clean Energy Project Final Conceptual Design Report* dated **June 2011** (Summit **2011b**).

2.4.1.1 COAL GASIFICATION, SYNGAS PROCESSING, AND CARBON DIOXIDE CAPTURE

Gasification is a thermo-chemical process that converts carbon-based materials, such as coal, into syngas, which is composed primarily of H₂ and carbon monoxide (CO). The conversion occurs in a reduced oxygen (O₂) atmosphere and at temperatures up to 3,000 degrees Fahrenheit (1,648 degrees Celsius). For the TCEP, coal feedstock would be pulverized and transferred to two Siemens gasifiers along with limited amounts of nearly pure O₂ gas. In the gasifiers, controlled reactions would take place, converting the coal into syngas. Along with the H₂ and CO, varying amounts of CO₂, nitrogen (N₂), sulfur species, methane, volatilized metals, and PM would also be in the raw syngas. The syngas would then be cooled and cleaned of PM.




Figure 2.2. TCEP gasification, power generation, and urea production.

Next, the syngas would flow through a water-gas shift reactor. In that system, steam would be injected in the syngas over a catalyst bed, initiating a reaction where the CO in the syngas would be converted to CO₂ and the steam would be converted to additional H₂ in the syngas stream. This would provide a syngas stream that is concentrated in both CO₂ and H₂. Subsequently, the syngas would pass through a Hg removal system and then an acid gas removal system where first the sulfur species would be removed. Next, the CO₂ would be removed, creating a clean, H₂-rich concentration syngas upon exiting the acid gas removal unit. The captured CO₂ would be further cleaned and compressed, and then transported by a short pipeline to an existing regional CO₂ pipeline or, potentially, to a nearby EOR field. A portion of the captured CO₂ would also be used to produce urea. The H₂-rich syngas stream would be split, where part would be used to produce electricity and the other part would be used to produce urea for fertilizer.

Argon and H₂SO₄ are by-products of the gasification process and would be made available for commercial sale. Inert slag, another by-product of the gasification process, would be sold for manufacturing and construction uses or disposed of off-site.

2.4.1.2 POWER GENERATION

For the TCEP, the clean, H₂-rich, low-CO₂ syngas would be combusted in a *gas* turbine-generator, generating electricity. **Combustion** of the H₂-rich fuel gas would produce water vapor and a low-CO₂ exhaust gas with significantly lower CO₂ emissions than would occur if the coal itself, or the raw syngas, had been combusted. The exhaust gas would be ducted through an HRSG, which would generate high-temperature, high-pressure steam. This steam would be piped into a steam turbine-generator, which would generate additional electricity. This integration of the *gas* turbine-generator, HRSG, and steam turbine-generator is known as a combined-cycle power plant, and is presently one of the most efficient means for generating electricity because two opportunities are used to produce electricity from coal, instead of one steam turbine-generator alone.

The combined power generation from the *gas* turbine-generator and the steam turbine-generator would be **up to** approximately 400 MW (gross) with **130–213 MW** sent to the grid, on average, and the remainder being used to run the plant's equipment. The electricity sold would be transmitted to the regional electrical grid by a high voltage transmission line system. Natural gas would be used to start up the polygen plant and as a backup fuel (natural gas would also be used during operations to heat drying gases, supply an auxiliary boiler, and provide burner pilot flames such as for flares).

2.4.1.3 Fertilizer Production

With two Siemens gasifiers, the TCEP would produce more syngas than could be used for electricity production. The additional syngas produced would be converted to NH₃ using the Haber process. In that process, the H₂ in the syngas is reacted with N₂ from the air separation unit, forming NH₃. Downstream, the NH₃ is reacted with a portion of the CO₂ from a syngas cleanup system, thereby forming urea in a Bosch-Meiser process. The urea is produced as a granular product common in the fertilizer industry.

2.4.2 Process Components and Major Equipment

The site layout of the polygen plant is shown in Figure 2.3. A process flow diagram for the TCEP is shown in Figure 2.4. The process components and major equipment shown in the process flow diagram are described below.

2.4.2.1 COAL RECEIVING, STORAGE, AND HANDLING SYSTEM

At full load, the TCEP would consume approximately 5,800 tn per day (5,262 t per day) of Powder River Basin sub-bituminous coal, which would be delivered to the site by rail from Wyoming. A single system for receiving, storing, and handling coal would feed both gasifiers. The coal handling system would consist of a railcar unloading facility, a coal storage system, a reclaim system, a coal crushing system, and a silo fill system. The function of this system would be to unload coal from unit trains, convey it to the active storage pile, recover the coal from the storage pile, crush the coal, and convey it to the coal silos in the coal grinding and drying building.

The railcar unloading system would consist of rapid-discharge, bottom-dumping railcars with an automatic continuous dumping system. The rail unloading hopper would be capable of unloading coal from the railcars at a rate of 4,000 tn (3,628 t) per hour. Belt feeders would transfer coal from the unloading hoppers to a conveyor, which would transfer coal to the coal storage piles.




Figure 2.3. Polygen plant layout.

This page intentionally blank




Figure 2.4. TCEP process flow diagram (Summit 2011b).

This page intentionally blank

From the coal pile, coal would be gravity-fed into the reclaim hoppers located below the pile. Reclaim belt feeders would transfer coal from the reclaim hoppers at a rate of 1,000 tn (907 t) per hour. **The feed** conveyors would transfer **the** coal to the coal grinding and drying feed silos. All conveyors would be **enclosed** to reduce **fugitive emissions**, and **the** coal handling **and drying** building would be fully enclosed with dust suppression sprays and collection systems used to control dust and noise.

2.4.2.2 COAL DRYING AND GRINDING SYSTEM

The coal would be simultaneously dried to approximately 8 weight percent moisture and ground to less than 200 micrometers in diameter in two bowl mills. A traveling trip conveyor would feed each of the **two** grinding trains, distributing the coal into feed bins serving each train. Hot drying gases (heated by combusting natural gas) would also enter the mill from the bottom, and then carry the dried, crushed coal and gases out of the mill and to a cyclone classifier, which would return particles larger than the desired size to the mill. A portion of the spent hot drying gas would be purged through a dust collector (fabric filter) and vented to the atmosphere. Collected dust would be combined with the coal from the cyclone. The dry, ground coal would then be pneumatically conveyed (using N₂ gas) to the individual storage bins that serve each gasifier.

2.4.2.3 AIR SEPARATION UNIT

A single air separation unit would provide O₂ gas and N₂ gas for the entire TCEP plant. The air separation unit would produce 99.5 percent pure O₂ gas for use as an oxidant in the gasifiers, and 99 percent pure N₂ gas for use as a diluent in the **gas** turbine and for producing urea fertilizer. In addition, N₂ gas at various pressure levels would also be used as a carrier gas for feeding the dried, pulverized coal to the gasifiers and for purging purposes in the gasification island. Producing high-purity O₂ gas in the air separation unit would also allow for a high-purity stream of argon gas to be recovered. This is a commercially marketable product.

For startup and shutdown purposes, and to enhance overall plant availability, liquid O₂ and liquid N₂ storage would be provided for 12 hours of plant operation.

2.4.2.4 GASIFICATION ISLAND

The gasification island would use two Siemens SFG-500 entrained flow, O₂-blown gasifiers to produce a raw syngas from the pulverized coal. The gasification island includes a pulverized coal feeding system, two gasifiers (including the quench sections), raw syngas scrubbers, black water treatment, and a slag discharge unit. The Siemens gasification island is shown in Figure 2.5.

Gasifiers

The coal feeding system would receive the pulverized and dried coal from the drying and grinding system described above, and feed it into the gasification reactors where the gasification reactions would take place. The coal would be almost totally gasified in this high-temperature environment to form raw syngas consisting principally of H₂, CO, CO₂, and water. The inorganic materials in the coal would be converted to a hot, molten slag. The hot raw syngas and the molten slag would leave the gasifier (shown as the reactor in Figure 2.5) and flow downward into the quench section. There, the raw syngas would be cooled by the injection of water, and the molten slag would solidify in the bottom of the quench section.

The mixture of granulated slag, quench water, and some unreacted char forms a mixture referred to as *black water*. The black water stream would be removed from the quench chamber and treated in the black water treatment plant. A portion of that stream would be recycled for use as quench water, with the remainder being cleaned further for use in other areas of the plant. The slag removed from the quench sump would be dewatered and conveyed to the slag handling, storage, and loadout system (see description below). Water carried out of the slag discharge system would be collected and pumped to the black water treatment plant. Water needed in the slag discharge system would be recycled from the black water treatment plant.

The raw syngas from the quench section would be sent to a venturi scrubber system for removal of fine ash, chlorides, and char. A portion of the scrubber water would be directed to the black water treatment plant. To reduce fine particles in the raw syngas, a partial condenser would be installed downstream of the scrubber unit. A flash flare port with emergency depressurization would be located immediately downstream of the **knockout drum**. During startup, **shutdown**, and in emergency situations, the raw syngas would be burned in a flare, with the exhaust gases vented to the atmosphere.

Black Water Treatment Plant

The black water treatment system would include one flash vessel for each of the two gasifiers, chemical dosing (for precipitation and flocculation to remove suspended solids), a settling basin, the waste water vessel, and a sludge filter press.

Liquid effluents from the quench chambers, the slag discharge units and overflow scrubbing water from the syngas scrubbers, as well as remaining syngas condensate, would contain fine PM, soot, salts, and condensed heavy metal sulfides removed from the syngas stream. The pressurized black water would be sent to the flash vessels to remove excess gases and to cool the black water.

The pretreated black water would then pass through the precipitation and flocculation steps, where flocculants would be added to stimulate coagulation and settlement of soot and fines. Fine slag and precipitate would be removed in a settlement basin, thickened and dewatered using a fabric filter to separate the precipitate (solids) from the black water stream. Most of the dried filter cake (containing a large fraction of carbon) would be mixed with coal and recycled in the gasifiers to produce more syngas, and the remainder would be containerized for appropriate off-site disposal. A portion of the clear effluent of the settlement basin (< 0.1 percent dry solids) and the filtrate of the filter unit would be collected and mixed with softened water for recycle to the gasification island for use in the quench and slag discharge systems. The remaining effluent, which would contain a high concentration of chloride salts, would be piped to the **residual industrial waste disposal** system for **disposal**.

Slag Handling, Storage, and Loading

This system would remove and collect inert gasifier slag and convey it to storage for the loadout system. The inert slag would be collected in the slag trough and conveyed to a covered storage area. The storage area would be periodically emptied by front-end loaders moving the slag to chain reclaimers. The chain reclaimers would convey the slag onto belt conveyors that transfer the slag to a loadout for rail or truck.




Figure 2.5. Siemens gasification island (Siemens 2010).

Slag from coal gasification and IGCC plants can be used in the manufacture of cement, as a road base, for manufacturing roofing tiles, as an asphalt filler, and as a sandblasting agent. The TCEP plans to sell the slag for such uses. Should the slag not be sold, it would be trucked or sent by rail to a permitted off-site solid waste landfill.

2.4.2.5 WATER-GAS SHIFT, LOW-TEMPERATURE GAS COOLING, AND MERCURY REMOVAL UNITS

The hot raw syngas would be further cooled and cleaned for use downstream for power generation and urea production. The main process units are described below.

Water-gas Shift Unit

To increase the H₂ content and decrease the CO content of the syngas for low-CO₂ power generation and for production of urea, the water-gas shift reaction would be used to shift the syngas composition. In the shift process, CO present in the raw syngas from the gasification island would react with steam over a catalyst bed to produce CO₂ and H₂. Once the syngas is shifted to a high concentration of CO₂, the CO₂ could be efficiently removed downstream, thereby removing most of the carbon from the syngas used in the *gas* turbine.

The water-gas shift unit is also called a sour shift unit because the water-gas shift reactions would be accomplished prior to the acid gas removal, meaning that the syngas would still contain large amounts of hydrogen sulfide (H₂S) and carbonyl sulfide (COS). Because the shift reaction would release energy in the form of heat, the reaction equilibrium would favor high CO conversion at lower temperatures, and low CO conversion at higher temperatures. The heat from the shift reaction would be used to generate steam for use in other areas in the polygen plant.

In addition to converting CO, the shift catalyst would convert COS in the syngas to H₂S, which would be much easier to remove in the acid gas removal system than COS. After H₂S removal, there would be a low-sulfur syngas, which would minimize sulfur dioxide (SO₂) emissions in the *gas* turbine exhaust and would reduce sulfur in the feed stream sent to the urea plant.

Low-temperature Gas Cooling Unit

Effluent from the water-gas shift unit would be cooled further in the low-temperature gas cooling unit. Water would condense from the syngas as it was cooled. This condensate would be collected, heated, and returned to the gasification island for use in the syngas scrubber. The cooled scrubber gases, which would contain sulfur gases, would be sent to the H₂SO₄ plant. The cooled syngas would be sent to the Hg removal unit.

Mercury Removal Unit

Hg removal would be accomplished by passing the syngas through sulfur-impregnated activated carbon beds, where the Hg compounds would be adsorbed and converted to stable mercuric sulfide. The system is expected to achieve greater than 95 percent Hg removal from the syngas, based on the performance of this technology in other coal gasification plants. At the end of their useful life, the carbon beds would be removed and transported off-site to appropriate facilities for disposal or recovery of the Hg compounds.

2.4.2.6 ACID GAS REMOVAL

The clean, shifted syngas stream would be sent to a Rectisol® acid gas removal system, which would use concentrated methanol (greater than 99 percent by weight) as a solvent in a recirculating wash column to physically dissolve and remove the acid gas components (H₂S, COS, and CO₂), produce two syngas streams of different qualities for downstream use, and produce concentrated streams of H₂S and CO₂ for downstream processing.

The H₂S and COS would be removed in the lower section of the Rectisol® wash column, with the CO₂ being removed in the upper section. Clean syngas streams would exit the Rectisol® system for downstream use. The first syngas stream would be rich in H₂ with a very low content of CO₂ and a total sulfur concentration of less than 0.1 parts per million by volume (ppmv). ***In the maximum power generation case***, approximately **86** percent of the syngas would be sent to the power block as a fuel for the ***gas*** turbine. The remainder of the H₂-rich syngas would be sent to the N₂ wash unit for final purification before going to NH₃ synthesis and production of urea. The second syngas stream would contain a very low concentration of CO₂ in a range of 0.5 to 1 percent by volume, and would be used as a fuel gas in the duct burners in the power block. The sulfur-containing gases that are captured and removed would be sent to the H₂SO₄ plant.

The captured CO₂ would exit the acid gas removal system in low-purity and high-purity streams. The high-purity CO₂ stream would be sent to the urea synthesis plant. The low-purity stream and the remaining part of the high-purity CO₂ stream that could not be used in the urea production plant would be combined, dried, and compressed for off-site use in EOR.

The methanol storage tank for the Rectisol® system would be designed to store about 535,000 gallon (gal) (2,025,195 liters [L]), which is the total liquid methanol inventory of the Rectisol® unit plus the solvent make-up requirement for a minimum of three months. The methanol storage tank would be equipped with an appropriate fire protection system.

2.4.2.7 SOUR WATER TREATMENT

The coal gasification process would generate the following sour (sulfur-bearing) ***industrial*** waste water streams:

- Gray water effluent from the black water clarifiers
- Black water clarifier sludge from the gasification block
- Syngas condensate from the raw syngas stream in the piping and in the syngas coolers upstream of the acid gas removal unit

The TCEP would incorporate a sour water stripper to treat sour waste water streams from the gasification process. The sour water stripper column would remove both H₂S and NH₃ from the sour water stream and return the treated water back to the gasification island for reuse.

The combined feed (from the sources listed above) would first enter a degassing drum, where dissolved gases would be released, and entrained oil and solids would be removed. The overhead from the degassing drum would be combined with the overhead from the downstream sour water stripper and sent to the H₂SO₄ plant. After degassing, the water temperature would be increased by heat exchange with the stripped sour water from the sour water stripper. The heated sour water would be fed to the steam reboiled sour water stripper. Most of the NH₃ in the sour water feed would be removed in this column. Sodium hydroxide would be injected as needed to facilitate the

release of NH_3 from the condensate. Stripped sour water would then be sent to the *process water treatment system* for cleaning.

2.4.2.8 SULFURIC ACID PLANT

Acid gas streams from the acid gas removal and sour water treatment units, along with flash gas from the gasification island, would be sent to the H_2SO_4 plant (a single 100-percent capacity unit). The H_2SO_4 plant would be recovered using a catalytic process to generate commercial-grade, concentrated H_2SO_4 . The feed streams would be combusted with air to convert the sulfur compounds to SO_2 . Natural gas would be used in normal operations for startup, support, and burner pilot flames.

Flue gas from the burner would be cooled by generating superheated steam in a waste heat boiler. The cooled process gas would be sent to a selective catalytic reduction system to reduce nitrogen oxides (NO_x) formed during combustion. After NO_x reduction, the gas would enter a catalytic SO_2 converter, where SO_2 would be oxidized to sulfur trioxide. Between each stage of the converter, the gas would be cooled through inter-bed coolers to maximize the conversion in each reactor. Heat from the gas exiting the SO_2 converter would be used to boil water, thereby cooling the effluent gas. During the cooling, most of the sulfur trioxide would react with water in the process gas to form gaseous H_2SO_4 . Cooled process gas would condense in the form of concentrated H_2SO_4 , and the remaining cleaned gas would exit as tail gas. Hot acid leaving the condenser would be cooled prior to being sent to storage. Concentrated H_2SO_4 product would be stored in a carbon steel tank coated with a fluorinated polymer. The on-site storage tank would hold approximately 36,000 gal (136,275 L) of H_2SO_4 , or about four days of production. The product would be pumped from the storage tank to either rail tank cars or trucks for transportation off-site.

The tail gas from the condenser section would be routed to a tail gas scrubbing system consisting of a quench tower, scrubber column, mist filter, and clean gas blower. The gas would first enter a quench tower, where the temperature of the stream would be reduced by evaporating water into the gas. After being cooled, the gas would be routed to a packed scrubber tower to be treated with hydrogen peroxide to remove any residual SO_2 . Finally, the overhead vapor would pass through an electrostatic mist filter to remove entrained acid mist. The cleaned gas would be sent to the H_2SO_4 plant stack.

2.4.2.9 CARBON DIOXIDE COMPRESSION AND DRYING

The CO_2 captured by the Rectisol® process would be dried, compressed, and split into two streams. The acid gas removal system would provide CO_2 at several pressure levels. CO_2 recovered at lower pressure would be routed to a low-pressure CO_2 compressor to be compressed in multiple stages with cooling between each stage. After exiting the low-pressure CO_2 compressor, the compressed gas would be mixed with the flash gas recovered from the high-pressure drum and sent to a drying package. Residual water would then be removed using molecular sieve technology. This CO_2 stream would be further compressed in the high-pressure CO_2 compressor. Some of the intermediate-pressure CO_2 would be passed through two catalytic reactors to remove residual H_2S and COS . After purification, this stream would be compressed and the majority of the CO_2 would be transported off-site for EOR, whereas the remainder would go to the urea facility.

2.4.2.10 LIQUID NITROGEN WASH

The H₂-rich syngas stream exiting the Rectisol® acid gas removal system, along with high-pressure N₂ from the air separation unit, would be fed to the liquid N₂ wash unit. Traces of water, CO₂, and acid gas removal solvent (methanol) would be removed in the adsorber unit. Both incoming streams of H₂-rich fuel gas and high-pressure N₂ would be cooled against product gas. The syngas stream would be fed to the bottom of the N₂ wash column, and high-pressure N₂ would be fed at the top of the column. Trace components (offgas) would be removed and separated at the bottom of the column as a fuel that would be used in the duct burners (direct fired gas burner located in the *gas* turbine exhaust stream) in the combined-cycle power block (see Section 2.4.2.14). The pure H₂ product gas would exit at the top of the column, then through the heat exchanger (against the incoming H₂-rich fuel gas and high-pressure N₂).

2.4.2.11 AMMONIA SYNTHESIS UNIT

The hydrogen stream from the N₂ wash would be compressed and cooled, then mixed with N₂ from the air separation unit. This combined hydrogen and N₂ stream would be sent to a multi-bed catalytic reactor in which the NH₃ concentration would be increased using an iron-based catalyst. Liquid NH₃ from the bottom of the separator would be fed to another separator operating at a lower pressure. The liquid recovered from this vessel would be sent directly to a receiver in the refrigeration section of the NH₃ synthesis plant. Liquid NH₃ would enter the receiver, where it would be split into two streams. Multiple heat exchangers would be used to cool the liquid streams before routing them to one of two separators. Vapor from these separators would combine with the compressed NH₃ vapor from the storage tank and would be recycled back to the receiver at the front of the refrigeration section. Liquid NH₃ product from the bottom of the separators would be pumped to storage.

2.4.2.12 UREA SYNTHESIS UNIT

The urea synthesis unit would take the NH₃ product and convert it to urea. CO₂ from the acid gas removal unit would be compressed and sent to a urea reactor where it would combine with liquid NH₃ from the NH₃ synthesis unit. Ammonium carbamate would be formed and then would be allowed to decompose to urea.

The concentrated urea solution would be sprayed by a liquid jet into a granulator bed. The bed of particles would be fluidized with fluidization air. When the particles reached a desired size, they would fall through a bottom grid on the bed. The urea granules would be subsequently cooled. A fraction of the particles leaving the granulation bed would be sent to a crusher. The finer particles would act as seeds for growing urea granules in the granulation bed. The air exiting the granulator would be scrubbed with water to remove traces of urea before being directly vented to the atmosphere. The plant would include storage facilities for 40 days of urea production, not including railcars. **At minimum capacity**, the urea synthesis unit would produce 1,485 tn (1,347 t) per day of urea, requiring **a minimum** of 1,080 tn (980 t) per day of CO₂.

Summit is considering an option to increase the urea production by up to 40 percent to accommodate fluctuation in urea and electricity sales. This option would be a swing option, allowing the TCEP to vary the production of electricity and urea depending on market conditions. As a result, urea, electricity, and CO₂ outputs could vary at any given time. At maximum capacity, the urea synthesis unit could produce a maximum of 2,079 tn (1,886 t) per day, requiring a maximum of 1,512 tn (1,372 t) per day of CO₂. Net electrical output would be

decreased under this option due to the use of additional syngas for the production of NH₃, a precursor for the production of urea. Air emissions output would also decrease when the generation of electricity decreases.

2.4.2.13 UREA HANDLING

The urea handling system would transfer urea from the urea synthesis unit to the rail loadout. A transfer conveyor would deliver urea from the plant to the tripper conveyor, which would transfer the urea to four storage domes at a rate of 150 tn (136 t) per hour. Another conveyor would pick up and transfer the urea from the storage domes to the urea loadout conveyor, which would then carry the urea to the loadout bin. Urea would be loaded into railcars for shipment to market at a rate of 400 tn (362 t) per hour, using a telescoping chute. The conveyors would be fully enclosed for weather protection and to control fugitive dust. All urea handling buildings would be fully enclosed or would have dust collection or control systems.

2.4.2.14 COMBINED-CYCLE POWER BLOCK

The IGCC power block would consist of a Siemens SGT6-5000F3 **gas** turbine-generator configured to use either H₂-rich syngas or natural gas (as a startup and backup fuel), an HRSG, a duct burner using a mixture of syngas and liquid N₂ wash system offgas as a fuel, a reheat steam turbine-generator, an air-cooled condenser, flash drums, condensate pumps, and boiler feed water pumps.

The **gas** turbine would be specially designed to combust a preheated H₂-rich syngas as the primary fuel with natural gas as the startup and backup fuel. The H₂-rich syngas would be diluted with high-pressure N₂ from the air separation unit. The addition of N₂ to the syngas, along with injection of additional N₂ at certain locations in the **combustion** zone inside the **gas** turbine, would accomplish two key goals: 1) cooling the **combustion** flame which reduces the formation of thermal NO_x, and 2) increasing the mass flow through the **gas** turbine, boosting the **gas** turbine power output. The **gas** turbine would have a nominal electric generating capacity of 230 MW.

The HRSG would **recover** heat **from** the **gas** turbine exhaust **by generating** steam, which would then be piped to the steam turbine, where it would be used to generate additional power. This configuration, which integrates the **gas** turbine with the HRSG and a steam turbine-generator, is called a combined-cycle power plant and is one of the most efficient technologies for generating electricity. When conditions required additional power-generation capacity, duct burners fired with syngas and offgas would augment the energy contained in the **gas** turbine exhaust, producing additional steam for the steam turbine.

The feed water system would move and control water flow through the HRSG to generate steam. The steam system would consist of three sections: high-pressure steam, reheat steam, and low-pressure steam. Some steam would be transferred to other locations in the plant to support functions other than driving the steam turbine. Superheated high-pressure steam would be supplied to the high-pressure section of the steam turbine by the HRSG. The exhaust from the high-pressure section of the steam turbine is called cold reheat steam because it is reduced in temperature and pressure. This steam would be returned to the HRSG, then reheated and combined with additional intermediate-pressure steam produced in the HRSG, and then sent to the intermediate-pressure section of the steam turbine as hot reheat steam. Exhaust from the intermediate-pressure section of the steam turbine (low-pressure steam) would be combined with low-pressure steam from the HRSG to supply the low-pressure portion of the steam turbine.

Exhaust from the low-pressure portion of the steam turbine would be cooled in the air-cooled condenser.

2.4.3 Plant Utility Systems

The following plant facilities would also be components of the TCEP.

2.4.3.1 WATER TREATMENT SYSTEMS

Source Water Treatment System

Source water would be delivered to the polygen plant site from one or more of the various waterline options under consideration. If source water from the GCA water option (either WL1 or WL5) is chosen, municipal waste water piped from the city of Midland would receive secondary biological treatment followed by low pressure membrane filtration (microfiltration or ultrafiltration) to remove particulate matter at the GCA Odessa South Facility. The source water would then be piped to the polygen plant site where the water would receive additional treatment using a reverse osmosis system to remove dissolved solids and other constituents prior to use in the various facility processes. For all other water sources under consideration (Oxy Permian and FSH), low pressure membrane filtration and additional treatment using reverse osmosis membranes would both occur at the polygen plant site. This initial on-site treatment of the source water using reverse osmosis is known as the source water treatment system. A flow diagram of the source water treatment system is identified in Figure 2.6. The by-product of this system is the reverse osmosis reject water, which contains the concentrated constituents that did not pass through the reverse osmosis membrane. This reject water would be sent to the reverse osmosis reject water disposal system (Disposal System 1), as described in Section 2.4.3.5.

Process Water Treatment System

After the source water has been treated by the polygen plant source water treatment system, it would be used as process water in the various plant processes, including the chemical block cooling tower makeup, power block steam cycle makeup, gasification process, ammonia and urea production, sulfuric acid production, and other minor plant uses.

Once the process water has been used in the various processes, it would be industrial waste water, which would go through the process water treatment system for cleanup and reuse in the polygen plant. The industrial waste water would be processed through one or more initial treatment systems depending on the specific power block and chemical block process waste stream characteristics. Initial waste water treatment processes could include biological treatment using activated sludge to treat high levels of ammonium and formate compounds in the waste stream, electro-deionization for removal of ions, and cold lime softening to treat all of the cooling tower blowdown in order to remove calcium, magnesium, alkalinity, and silica.

After initial treatment, the industrial waste water would be further treated using a reverse osmosis system, recycling much of the waste water stream. This system would be separate from and smaller than the reverse osmosis system used to desalinate the incoming source water for the polygen plant, as described above. The reverse osmosis system for industrial waste water would clean this water so that most of it could be reused in the polygen plant as process water. A flow diagram of the process water treatment system is shown in Figure 2.6.




Figure 2.6. TCEP water treatment system and waste disposal system flow diagram.

Residual industrial waste water that could no longer be cleaned and recycled would be sent to the residual industrial waste water disposal system (Disposal System 2), as described in Section 2.4.3.5.

2.4.3.2 COOLING SYSTEM

Two types of cooling systems would be used at the polygen plant, wet and dry cooling. An air-cooled condenser would be used for the combined-cycle power block. For the chemical process portion of the polygen plant, units requiring cooling to temperatures less than 140 degrees Fahrenheit (60 degrees Celsius) may use wet cooling if other chilled process fluids are not available for heat transfer cooling. Air cooling (using the dry cooling tower) may be used for the chemical process portions of the polygen plant where less cooling is required. Makeup water for the wet cooling tower would be obtained from treated municipal waste water or ***from one of the other water source options under consideration***. Cooling tower blowdown from the wet cooling tower would be directed ***back to the process water treatment system for reuse in the polygen plant***. The cooling tower would be equipped with a drift eliminator designed to limit drift losses to 0.001 percent of the circulation rate.

2.4.3.3 FLARE SYSTEMS

Flare systems would be provided to allow for the safe venting of gases produced during startup, shutdown, and upset conditions. ***The TCEP would require four flares: a small, warm/sour gas flare; a large, warm flare; a cold flare; and a NH₃ flare. Each flare would be approximately 200 ft (61 m) high and co-located on one structure. The small, warm/sour gas flare would be designed to ensure adequate flare tip velocity and complete combustion during minor relief loads of low-heating-value gases. The large, warm flare would handle large relief loads that would begin in the small flare and shift to the large flare when enough back pressure is reached. The cold flare would be dedicated to cold, dry gases so that thermal shock and ice formation would not occur in the flares used for warm, wet gases. The NH₃ flare, which would have a considerably higher flame temperature as compared to the other flares, would be needed to ensure complete combustion of relief streams with high NH₃ concentration.***

Syngas sent to the flare during normal flaring events would be filtered, water-scrubbed, and further treated in the acid gas removal system to remove regulated contaminants prior to flaring. Flaring of untreated syngas or other streams would only occur as an emergency safety measure during unplanned plant upsets or equipment failures.

As part of the design of the flare systems, a natural gas-fueled pilot would remain lit on each flare during normal operation to ensure the flares are available if needed. During normal operation, heat input to each flare would include 300 standard cubic ft (ft³) per hour (27.8 cubic m [m³]) of natural gas used for pilot lights. The maximum estimated air pollutant emissions (in pounds per hour) are based on flaring the entire raw syngas flow from one gasifier operating at 60 percent capacity. This peak flaring rate would occur during planned gasifier startups. Annual emissions are based on the equivalent of 60 startups and shutdowns per gasifier each year, and three hours of flaring at the maximum hourly flow rate to the flare. The total raw syngas flow during a flaring event could either go to one flare or it could be split between the two flares.

The primary air contaminants in the raw syngas stream would be CO and H₂S, with trace amounts of COS and NH₃. Estimated CO emissions from the flares are based on 98 percent destruction of the

CO (by combustion with air) in the flared stream. NO_x emissions are based on the TCEQ-approved factor for flares plus 50 percent conversion of the NH₃ to NO_x. H₂S and SO₂ emissions are based on 98 percent conversion of the H₂S and COS in the stream being converted (by combustion with air) to SO₂.

2.4.3.4 AUXILIARY BOILER

An auxiliary boiler using *either* natural gas *or syngas* for fuel would be included. The boiler would have a maximum firing capacity of 250 trillion British thermal units (Btu) per hour (higher heating value). The boiler would be primarily used during startup and shutdown. ***On initial startup, the auxiliary boiler would use natural gas for fuel. Once the gasification system is in service and is making clean syngas, that syngas could be used as a fuel in the auxiliary boiler to assist in the startup of other processes, such as the second sulfuric acid plant.*** The auxiliary boiler would be equipped with ultra-low NO_x burners and flue gas recirculation to control NO_x emissions.

2.4.3.5 WASTE DISPOSAL SYSTEMS

There would be two types of waste water streams that would require disposal: 1) reverse osmosis reject water (i.e., brine water) from the source water treatment system and 2) residual industrial waste water from the process water treatment system. Three on-site options are under consideration for disposal of these streams. These options consist of evaporation ponds, deep well injection, and a mechanical crystallizer and filter press system. The reverse osmosis reject water from the source water treatment system would only be disposed of through the combination of evaporation ponds and deep well injection because of the larger volume of liquid. However, residual industrial waste water would be disposed of using either evaporation ponds alone or the mechanical crystallizer and filter press system followed by evaporation of any remaining non-recyclable liquids in a solar evaporation pond, with the solid filter cake being disposed of in an off-site landfill. Depending on the quality of the residual industrial waste water, this waste stream could also be disposed of using an on-site, designated deep injection well that would be permitted specifically for this purpose. There would be no surface discharge of either type of waste water stream from the polygen plant site. A flow diagram of the two waste disposal systems is identified in Figure 2.6, with further description found below.

Disposal of Reverse Osmosis Reject Water (Disposal System 1)

The proposed on-site source water treatment system, consisting of reverse osmosis filtration, would be designed to remove dissolved solids and other constituents in the source water prior to its use as process water in the polygen plant (see Section 2.4.3.1 for details). The reverse osmosis reject water would contain the concentrated constituents that did not pass through the membrane. Originating from either treated municipal waste water or saline ground water, which would be processed through an on-site desalination process (source water treatment system), this reject water would be brine or salt water, which would be similar to sea water. The volume of reject water would be dependent on the water source ultimately selected for the TCEP. A minimum of 0.76 million gal (2.88 million L) per day of reject water would require disposal if source water from GCA (WL1 or WL5) is selected, whereas a maximum of 1.43 million gal (5.41 million L) per day would require disposal if source water from Oxy Permian (WL2) is selected. These quantities are estimated and may change based on actual water quality conditions.

Reverse osmosis reject water from the source water treatment system would be disposed of using a combination of solar evaporation ponds and on-site deep injection wells. Summit intends to maximize the use of on-site deep well injection to the extent practicable and limit the use of solar evaporation ponds to the excess reject water that cannot be disposed of through the on-site injection wells. A Class V test injection well would be drilled on the polygen plant site and tested to determine the on-site subsurface characteristics of the potential injection zone(s). The results of this testing would be used to determine the amount of waste water that could be injected into deep saline formations and thus, the remaining volume of reject water that would require disposal in the solar evaporation ponds. Although the exact number of injection wells is currently unknown, it is anticipated that up to eight on-site Class I injection wells could be installed at the polygen plant site. Based on this information, the number and size of the evaporation ponds would also be determined to optimize the overall waste disposal system for the polygen plant. A more detailed description of the solar evaporation ponds and the injection wells is provided below.

Class I injection wells are used for deep injection of non-hazardous industrial waste and are regulated by the TCEQ.

Class II injection wells are related to oil and gas production and are regulated by the Railroad Commission of Texas (RRC).

Class III injection wells are used to extract minerals other than oil and gas and are regulated by the TCEQ or the RRC, depending on the type of well.

Class IV injection wells are generally banned but may be authorized by the TCEQ or EPA in certain environmental cleanup operations.

Class V injection wells are used for many different activities and are regulated by either the TCEQ or the RRC, depending on the type of well.

Class VI injection wells are used for injection of CO₂ into subsurface geologic formations for long-term storage or geologic sequestration.

Solar Evaporation Ponds

Solar evaporation ponds provide a sustainable method of disposing of waste water on-site without any off-site waste water discharge. Evaporation ponds can accommodate between 2 and 3 gal (8–11 L) per minute per acre (per 0.4 ha) depending on site conditions. Summit is also considering the use of turbomisters to enhance evaporation. Turbomisters can pump up to 90 gal (341 L) per minute of brine water into the air, which can evaporate an annual average of approximately 35 percent of the pumped flow of waste water, with the remaining 65 percent being evaporated through the evaporation ponds.

The design under consideration for the proposed TCEP includes the use of up to seven lined solar evaporation ponds, spanning a maximum of 160 ac (65 ha) on the polygen plant site. The actual size and number of the evaporation ponds would be dependent in part on the volume of brine water that could be disposed of through the on-site injection wells. Each pond would consist of multiple cells that would be lined with a 2-in (60-mm) thick, high-density polyethylene synthetic liner with an associated leak detection system. The high-density polyethylene liner would restrict flow into the ground. For leak detection, a series of perforated pipes would be installed beneath the liner so that any water flow from liner leaks would be directed by the pipes to a sump in the corner of the ponds. This sump would be periodically inspected. If a leak occurred, the affected pond would be drained and repaired.

Precipitated solids would remain in the ponds throughout the 30-year life of the project. The annual loading of precipitated solids could range from a maximum of 22,000 tn (19,958 t) per year if WL1 or WL5 is selected to a maximum of 43,000 tn (39,009 t) per year if WL2 is selected (assuming all reverse osmosis reject water is disposed of using solar evaporation ponds). Daily disposal of the waste water would keep the solids damp to reduce the potential for wind

dispersion. After the polygen plant is decommissioned, precipitated solids would be transported to a landfill for disposal.

It is estimated that up to 22 turbomisters could be used at the polygen plant site. Turbomisters would be equipped with a wind sensor that would automatically shut down the system when wind blew at a rate that would carry the mist beyond the ponds. This would ensure any entrained salts fall within the lined area.

A bird deterrent system for the evaporation ponds could be installed, depending on discussions with the State of Texas. One typical approach is the placement of bird netting over the evaporation ponds. Typical bird netting material includes polypropylene, polyethylene, and nylon with typical mesh sizes of 0.5 in (1.2 cm) through 2 in (5 cm). Bird netting is firmly secured on the pond sides to prevent birds from gaining access to the ponds from underneath the netting. The need for a bird deterrent system, the type of system, and the specific design details would be determined in consultation with the State of Texas.

Deep Well Injection

To determine the potential for deep well injection at the polygen plant site, Summit conducted a site characterization study for the subsurface disposal of reject water (Summit 2011c). The study found that subsurface conditions beneath the polygen plant site are favorable for long-term injection and permanent sequestration of reject water. There are several permeable geologic formations encountered between 3,000 and 7,500 ft (914–2,286 m) below the polygen plant site that have been identified as possible candidates for injection zones. The potential injection zones include the Queen Formation, Clear Fork Formation, and the Wichita Formation (see Section 3.5.4.2, Geology, for details). These formations are believed to have favorable thickness (850–1,500 ft [259–457 m]), lithology (e.g., sandy and/or dolomitic), porosity, and permeability to accept and store within their pore spaces most of the reject water (Summit 2011c). The potential injection zones are also overlain by three low-permeability confining zones and underlain by one low-permeability confining zone that would separate them from formations that contain underground sources of drinking water and petroleum production.

The projected volume of reverse osmosis reject water from the source water treatment system would require the use of multiple injection wells. Although Summit anticipates that up to eight injection wells would be needed, the exact number would be dependent on the volume of reject water that can be injected into each well. This would be determined through the Class V test injection well, which would be an exploratory well used to test the injectivity and storage capacity of the three identified formations beneath the polygen plant site. Depending on the results of the test injection well, a combination of all three formations could be used for the injection of the reject water. Once the detailed subsurface characteristics had been identified, Summit would be able to determine the number of formations that could be used, the number of wells that could inject into each formation, and the rate at which the reject water would be injected into the wells. All injection wells would be located on the polygen plant site.

Class I underground injection wells in Texas are regulated by the TCEQ. All injection wells installed at the polygen plant site would be constructed and operated in accordance with TCEQ underground injection control regulations and industry-approved practices for Class I injection wells. Summit anticipates that an authorization would be permissible under the Texas Underground Injection Control General Permit (WDWG01000) for disposal of nonhazardous brine from a desalination operation into a Class I Well in accordance with the Texas Water Code, Chapter 27 and the Texas Health and Safety Code, Chapter 361. Summit

would submit an NOI to the TCEQ under this General Permit. TCEQ has indicated that the reject water from the on-site reverse osmosis system using either the Oxy Permian or the GCA source water options could be permitted under the General Permit process for injection wells, if all applicable requirements are met. Summit currently believes the injected reject water would be considered the “desalination” concentrate as described in the General Permit. Summit also believes that deep well injection would be the only practical, economic, and feasible alternative reasonably available for disposal of at least part of the reject water stream.

The wells would be properly constructed using protective casing and appropriate cements; these precautions would isolate the injection zone from formations that contain underground sources of drinking water. Injection tubing would be installed along with an injection packer; and the space between the wellhead, the tubing, and the packer would be pressurized and continuously monitored for leaks during the life of the well. Annual mechanical integrity tests, as required by the TCEQ, would be conducted to monitor for certain types of well failures that could impact the integrity of the wells and potentially impact surface or ground waters.

Disposal of Residual Industrial Waste Water (Disposal System 2)

The primary industrial waste water sources for the TCEP would be the oil water separator, urea condensate, gasification gray water purge, sulfuric acid plant tail gas scrubber effluent, shift stripper purge, Rectisol® waste water, cooling tower blowdown, contact and noncontact storm water, and miscellaneous IGCC plant washdown wastes. The largest volume of industrial waste water would be generated by the wet cooling tower blowdown, which would be treated using lime softening, ultrafiltration, and reverse osmosis filtration to recover most of the water for reuse at the plant site. These industrial waste water streams would be processed through the process water treatment system, as described in Section 2.4.3.2, for reuse in the polygen plant. Residual industrial waste water that could no longer be cleaned and recycled would be disposed of through either the mechanical crystallizer and filter press system, evaporation ponds, deep well injection, or a combination of the three options. Under the current plan, residual industrial waste water would flow to a mechanical crystallizer and filter press system, and from there the residual water could either flow into an evaporation pond or, depending on the quality of the residual water, be injected deep underground in a designated well that would be permitted specifically for this waste stream. A more detailed description of the mechanical crystallizer and filter press system, solar evaporation ponds, and the injection wells is provided below.

Mechanical Crystallizer and Filter Press System (Disposal System 2-A)

Liquids from the initial treatment system and reject water from the process water reverse osmosis system could be treated using a mechanical crystallizer and filter press system. This system evaporates the reverse osmosis reject water to form a slurry (Disposal System 2-A1). A filter press or centrifuge is then used to remove water from the slurry and form a solid filter cake. This cake would be collected in bins and transported to a licensed landfill for disposal. The filter cake would be nonhazardous but would be tested to confirm its characteristics. Overhead condensate from the mechanical crystallizer would be cooled with cooling water and then recycled to the polygen plant.

Solar Evaporation Ponds and Deep Well Injection (Disposal System 2-B)

Disposal of the residual industrial waste water would likely occur using evaporation ponds. These would be the same ponds as described above for the disposal of excess reverse osmosis reject water from the source water treatment system. For residual industrial waste water, Summit prefers disposal using evaporation ponds.

Depending on the quality of the residual industrial waste water, however, Summit could seek a permit to inject the waste water deep underground using a well that is permitted specifically for this waste water stream. In this case, Summit anticipates that an Individual Class I Underground Injection Control Permit for injection of nonhazardous waste water into Class I wells would be required. If residual industrial waste water were deep well injected, it may be injected into the same injection zones as described above for the disposal of excess reverse osmosis reject water from the source water treatment system. Residual industrial waste water would be analyzed to confirm its characteristics (e.g., as hazardous or nonhazardous) and would be permitted accordingly. This option would be an alternative to the use of the mechanical crystallizer and filter press system and solar evaporation ponds.

2.4.3.6 EMERGENCY DIESEL ENGINES

One 350-horsepower, diesel-fueled fire-water pump and two 2,205-horsepower, diesel-fueled emergency generators would be located at the TCEP. The pumps and generators would only operate during emergencies and on regularly scheduled intervals for testing. It is estimated that these engines would be operated a maximum of 52 nonemergency hours per year each for testing. The engines would not operate during normal polygen plant operations.

2.4.3.7 STORM WATER MANAGEMENT

Storm water runoff would be directed to on-site retention/settling ponds to control peak discharge. The ponds would be sized based on the area of impervious surface on the polygen site and the maximum design storm-flow volumes. There would be no discharge from the storm water runoff ponds.

Any storm water runoff that came into contact with an area that had the potential for the presence of oil (such as water runoff from parking lots) would be directed to a separate retention pond and then on to an oil/water separator.

2.4.3.8 CONTROL SYSTEMS

The TCEP control system would allow monitoring and control of the plant to be accomplished from a central control room. From work stations, operators would monitor the plant processes and manipulate controls as needed to maintain efficient and safe plant operations. Engineering work stations would give the plant engineering workforce the ability to monitor plant operations and update software and control schemes as needed.

2.4.4 Disposition of Carbon Dioxide

2.4.4.1 PIPELINE NETWORKS

The TCEP's captured CO₂ up to a maximum of approximately 3 million tn (2.7 million t) per year would be transported by a 12-inch (in) (30-centimeter [cm]) steel pipeline to an interconnection with the existing Kinder Morgan Central Basin pipeline, which is located approximately 1.0 mi (1.6 km) east of the proposed plant site. From there, the CO₂ would be comingled in the pipeline with CO₂ from other sources and then transported through the existing and extensive CO₂ pipeline system in the Permian Basin where it would be sold and used for EOR.

The TCEP interconnection to the Kinder Morgan pipeline would be buried approximately **3.0 ft (0.9 m)** below the ground surface. The interconnection would deliver the CO₂ at a pressure of approximately 2,000 lbs (907 kg) per in². The CO₂ delivered to the Kinder Morgan pipeline would meet the following specifications:

- Contain at least 95 mole percent of CO₂
- Contain no free water and no more than 30 lbs (14 kg) of water per 1 million ft³ in the vapor phase
- Contain no more than 20 ppmv of H₂S
- Contain no more than 35 ppmv of total sulfur
- Not exceed a temperature of 120 degrees Fahrenheit (49 degrees Celsius)
- Contain no more than 4 mole percent of N₂
- Contain no more than 5 mole percent of hydrocarbons and the dew point would not exceed -20 degrees Fahrenheit (-29 degrees Celsius)
- Contain no more than 10 parts per million (ppm) by weight of O₂
- Contain no more than 0.3 gal (1.1 L) of glycol per 1 million ft³ (2.8 million m³) and at no time would such glycol be present in a liquid state at the pressure and temperature conditions of the pipeline

All of the potential CO₂ purchasers under consideration at this time are or can be connected to the Kinder Morgan CO₂ pipeline system, and there is no requirement for any other CO₂ pipelines to be constructed other than the proposed connecting pipeline to the Kinder Morgan system. However, there may be commercial reasons to prefer a direct pipeline connection from the TCEP to a CO₂ offtaker in some circumstances, although no such direct pipelines are currently anticipated. Should a direct pipeline be proposed in the future, the possible pipeline route (or routes) could require new ROW(s) and additional environmental analysis. A direct pipeline would not be expected to exceed 10 mi (16 km) in length. Because no direct pipelines are proposed at this time, no further analysis of that option is included in this document.

2.4.4.2 CARBON DIOXIDE MARKETS

Summit plans to sell most of the CO₂ captured by the TCEP for EOR in the Permian Basin of West Texas, with the remainder used to produce urea as discussed in Section 2.4.2.12. This commercially proven and long-established use of CO₂ is for tertiary production of oil (i.e., the third stage of production) at existing oil-producing fields. Primary production follows initial drilling and results

from natural pressure in the oil reservoir or pumping of wells and gravity-induced flow in the reservoir toward producing wells. Secondary production comes from injection of water, which sweeps residual oil toward producing wells and helps bring additional oil to the surface. Injection of CO₂ is typically used to enhance production when production by water injection declines below economical levels. The use of CO₂ as a tertiary method of recovery usually produces an incremental 10 to 20 percent of the original oil in place, depending on the rock qualities.

The most likely potential buyers would be producers who already use CO₂ for EOR. Such producers may want more CO₂ than they are currently able to obtain (e.g., to expand their current CO₂/EOR), or they may want to buy Texas-generated CO₂ to obtain state tax benefits. It is likely that the TCEP's captured CO₂ would be sold to buyers that already use CO₂ for EOR, although other buyers could be oil producers that wish to commence using CO₂ to continue production at existing fields.

2.4.4.3 MONITORING, VERIFICATION, AND ACCOUNTING

Monitoring, verification, and accounting (MVA) measures provide an accurate accounting of stored CO₂ and a high level of confidence that the CO₂ is not being released or leaked to the surface. Such measures include EOR system material balance accounting, modeling, plume tracking, and leak detection.

Material balance accounting compares total injected CO₂ and CO₂ being recovered from oil production. Modeling involves putting field data into a representation of the CO₂ storage system. Usually computer models are used, and these provide helpful mathematical-numerical analysis and visualization of the system. The computer models provide a representation of the underground conditions that influence the behavior of CO₂ that has been injected into geologic formations and characterize the resulting pressure changes and fluid flow throughout the system. They may also provide a representation of certain types of geomechanical changes to the reservoir. Underground plume tracking provides the ability to map the injected CO₂ and track its movement and fate through a reservoir. Usually this is done by mapping pressure data from various wells in the field, although it may also be accomplished with repeat seismic surveys. CO₂ leak-detection systems provide critical measures of whether CO₂ is escaping from the storage reservoir at points or areas of monitoring.

A monitoring program for CO₂ injected in a reservoir for EOR serves the following purposes:

- Supports management of the injection process
- Identifies leakage risk or actual leakage and offers another layer of protection for drinking water aquifers located above the zones of injection. It provides early warnings if the CO₂ is migrating out of the intended reservoir zone
- Provides regulatory assurance that the injected CO₂ ultimately remains confined in the reservoir
- Meets monitoring requirements that may be required by carbon registries to verify carbon credits
- Verifies and provides input into reservoir models

The TCEP monitoring program would be specifically designed for each oilfield using CO₂ from the TCEP and would include one or more of the following approaches:

- Measuring to determine the mass of CO₂ injected, principally derived from the fluid pressure, temperature, flow rate, and gas composition at the wellhead
- Monitoring of the storage reservoir's pressure during the injection process using well gauges
- Using well data and seismic survey results, monitoring of the migration and distribution of CO₂ in the subsurface formation, focusing on the intended storage reservoir but including any unintended migration out of the storage reservoir
- Monitoring of the shallow subsurface through shallow wells to detect and quantify any CO₂ migrating out of the storage reservoir toward the ground surface
- Monitoring of the ground surface and atmosphere to detect and quantify CO₂ leaking into the biosphere
- Measuring and monitoring of the CO₂ that is produced with the oil, separated in the surface facilities, and reinjected into the storage reservoir

An operator implementing an EOR project with CO₂ is highly motivated to track and contain all the CO₂ purchased because it is expensive. If the CO₂ is lost out of the producing zone or vented into the atmosphere, the operator must purchase additional CO₂. This means that the operator is motivated to design the EOR project to minimize the loss of CO₂, either in the oil reservoir or in the surface facilities.

As part of the TCEP, Summit would work with EOR operators in the target field (or fields) to develop appropriate MVA measures, even though the CO₂ captured from the TCEP would be commingled with CO₂ from other sources. This effort would include coordination with the EOR field operators and the Texas Bureau of Economic Geology, which also functions as the State Geological Survey. Furthermore, all CO₂ injected for EOR in Texas is regulated by the RRC, which has been delegated Clean Water Act enforcement authority by EPA.

Summit has prepared a generic monitoring plan for the EOR sequestration of CO₂ that would be captured from the TCEP, and presented this plan for review to the Texas Bureau of Economic Geology (*Summit 2011a*). In the plan, Summit provided a suite of proposed monitoring technologies and noted that the final choice of specific monitoring technologies would be based on site-specific conditions taking into account the EOR site's geologic characterization and risk assessment. Table 2.1 describes these proposed MVA requirements.

Table 2.1. Summit’s Proposed Monitoring, Verification, and Accounting for Carbon Dioxide Enhanced Oil Recovery Sequestration

Technology	Potential for Use
Baseline Monitoring	
Geochemical sampling*	Sampling of nearest aquifers and underground sources of drinking water zones would be conducted at least monthly for a year prior to CO ₂ injection and more frequently if required by future regulations. Sensitivity analysis will determine which constituents will be sampled, sampling method, and frequency.
Mechanical integrity testing [†]	Mechanical integrity testing would be conducted by the operator in compliance with RRC regulations prior to initial injection of CO ₂ .
Pressure monitoring*	Pressure histories above the confining system will be monitored for one year prior to injection to determine trends from production and water disposal pre-injection.
Pressure testing [†]	Testing as required per RRC regulations prior to initial injection.
Operational Monitoring	
Geochemical sampling*	Sampling of nearest aquifers and underground sources of drinking water zones would be conducted semiannually and more frequently if required by future regulations.
Mechanical integrity testing [†]	Mechanical integrity testing would be conducted by the operator prior to the initial injection of CO ₂ , and once every five years as required by the RRC. This frequency of testing may be increased if required by future regulations (EPA has proposed annual testing).
Pressure monitoring [†]	Pressure inside the injection tubing string and inside the annulus of the well would be measured continuously. Monitoring would also be performed periodically in the nearest underground sources of drinking water zones.
Injection rate [†]	Injection rates would be measured continuously and reported monthly.
Pressure testing [†]	Testing is required prior to initial injection and once every five years thereafter. The frequency would conform to any change in regulations.
Material balance ^{†,*}	Material balances would be performed on a monthly basis on each injection pattern, comparing total injected CO ₂ and CO ₂ being recovered from oil production. The results would be compared to reservoir models for the injection pattern under review.

* Additional monitoring that EPA may require.

[†] Monitoring considered “business as usual” by industry.

2.4.5 Resource Requirements

Resource requirements for the TCEP include coal, land area, water treatment chemicals, natural gas, potable water, process water, transmission facilities, and transportation. These requirements are summarized in Table 2.2 and are described more fully below. **Note that final linear facility routes and locations of off-site facilities could vary slightly from those proposed in order to avoid sensitive environmental features, address engineering requirements, or meet landowner preferences.**

Table 2.2. TCEP Resource Requirements

Resource	Description
Coal	TCEP would use 5,800 tn (5.262 t) per day or 2.1 million tn (1.9 million t) per year of sub-bituminous coal from the Powder River Basin in Wyoming. The coal pile would be sized for about 45 days of total storage capacity, with approximately nine days of active storage and 36 days of inactive storage.
Natural Gas	2 trillion Btu (average annual use for startup, pilot burners, heating drying gases and other uses)).
Process Water	Annual peak water usage: up to 4.5 million gal (17.0 million L) per day. Annual average water usage: 4.2 million gal (15.9 million L) per day.
Potable Water	Peak construction (1,500 workers): 45,000 gal (170,000 million L) per day. Operation (150 workers): 4,500 gal (17,000 L) per day.
Electric Power	Construction power would be provided by connecting to a distribution line owned by Oncor Energy near the site.
Transportation	
Rail	The TCEP would require rail delivery of coal and some construction materials and equipment. The project may require rail transport off-site of construction and operational wastes and commercial products including argon, H ₂ SO ₄ , urea, and slag. Coal: maximum of up to two 150 -car unit trains per day; average of two to three 150 -car unit trains per week. Argon: Argon gas would be transported in rail tank cars. H ₂ SO ₄ : Up to one-half railcar per day would be filled and sold. Slag: up to five railcars per day. Urea: up to 21 railcars per day or an average of twenty 25-tn (23-t) trucks per day.
Truck (other materials [in and out])	The TCEP would require truck delivery for potable water, operations chemicals, and some construction materials and equipment. The project may also require truck transport off-site of construction and operational wastes and commercial products including argon, H ₂ SO ₄ , urea, and slag. Potable water (construction): forty-two 25-tn (23-t) trucks per week. Potable water (operations): five 25-tn (23-t) trucks per week. Slag: average of twenty 25-tn (23-t) trucks per day.

Table 2.2. TCEP Resource Requirements

Resource	Description
Land Area	
Polygen Plant	The polygen plant site would be constructed on 600 ac (243 ha). It is assumed that up to a maximum of 600 ac (243 ha) of the site would be permanently developed.
Linear Facilities	<p>The linear facility options for the process waterlines, natural gas pipeline, access roads, railroad, and CO₂ pipeline are estimated to have a 150-ft (46-m) construction ROW and 50-ft (15-m) operational ROW. The transmission line options would have an estimated 200-ft (60-m) construction ROW and a 150-ft (46-m) operational ROW.</p> <p>Temporary impacts during construction could range from 378 to 1,982 ac (153–802 ha), whereas permanent impacts from operations could range from 132 to 1,033 ac (53–418 ha), based on the smallest combination (NG3, WL2, WL4, TL4, AR1, AR4, RR1, CO₂) and largest combination (NG2, WL5, WL6, TL5, AR1, AR3, RR1, CO₂) of the linear facility options. Linear facility alignments could vary slightly depending on land acquisition issues, environmental conditions, and engineering considerations. Impact area details can be found in each linear facility description below.</p>
Natural Gas Pipelines	
NG1	A 2.8-mi (4.6-km), 12-in-diameter (30-cm-diameter) interconnection pipeline would be constructed approximately 100 ft (34 m) to the east of FM 1601 from an existing 20-in-diameter (51-cm-diameter) mainline operated by ONEOK located south of the polygen plant site. A maximum of 51.7 ac (20.9 ha) of temporary impacts and 17.2 ac (7.0 ha) permanent impacts could occur.
NG2	A 3.5-mi (5.6-km), 12-in-diameter (30-cm-diameter) interconnection pipeline would be constructed approximately 1.0 mi (1.6 km) east of FM 1601 from an existing 20-in-diameter (51-cm-diameter) ONEOK natural gas pipeline located southeast of the polygen plant site. A maximum of 63.6 ac (25.7 ha) of temporary impacts and 21.2 ac (8.6 ha) of permanent impacts could occur.
NG3	A 2.8-mi (4.5-km), 12-in-diameter (30-cm-diameter) interconnection pipeline would be constructed approximately 0.5 mi (0.8 km) west of FM 1601 from an existing 20-in-diameter (51-cm-diameter) ONEOK natural gas pipeline located south of the polygen plant site. A maximum of 49.9 ac (20.2 ha) of temporary impacts and 16.6 ac (6.7 ha) of permanent impacts could occur.
Process Waterlines	
WL1	A 41.3-mi (66.6-km), 20- to 30-in-diameter (51- to 76-cm-diameter) pipeline would be constructed south of I-20 from the city of Midland Wastewater Treatment Plant (WWTP) to the GCA Odessa South Facility and from there to the polygen plant site. A maximum of 539.1 ac (218.2 ha) of temporary impacts and 179.6 ac (72.7 ha) of permanent impacts could occur.
WL2	A 9.3-mi (15.0-km), up to 24-in-diameter (61-cm-diameter) pipeline would be constructed to connect to an existing Oxy Permian pipeline northwest of the polygen plant site. A maximum of 169.1 ac (68.4 ha) of temporary impacts and 56.3 ac (22.8 ha) of permanent impacts could occur.
WL3	A 14.2-mi (22.8-km), 16-in-diameter (41-cm-diameter) pipeline would be constructed to connect to the proposed FSH main waterline project southeast of the polygen plant site. A maximum of 257.7 ac (104.3 ha) of temporary impacts and 85.9 ac (34.8 ha) of permanent impacts could occur.
WL4	A 2.6-mi (4.2-km), 16-in-diameter (41-cm-diameter) pipeline would be constructed from the proposed FSH main waterline to the GCA Odessa South Facility. A maximum of 48.4 ac (48.4 ha) of temporary impacts and 16.0 ac (6.5 ha) of permanent impacts could occur.

Table 2.2. TCEP Resource Requirements

Resource	Description
WL5	<i>A 44.5-mi (71.6-km), 30-in-diameter (76-cm-diameter) pipeline would be constructed either south of I-20 from the city of Midland WWTP or originating from a pump station north of the Midland WWTP to the GCA Odessa South Facility and from there to the polygen plant site. A maximum of 834.1 ac (338.0 ha) of temporary impacts and 278 ac (112.5 ha) of permanent impacts could occur.</i>
WL6	<i>A 3.0-mi (4.8-km), 16-in-diameter (41-cm-diameter) pipeline would be constructed between the existing Odessa-Ector Power Partners (OEPP) facility and the GCA Odessa South Facility. A maximum of 54.8 ac (22.2 ha) of temporary impacts and 18.2 ac (7.4 ha) of permanent impacts could occur.</i>
<i>Transmission Lines</i>	
TL1	A 9.3-mi (15.0-km) transmission line would be constructed to connect to the ERCOT grid. 75 percent of the line would parallel a section line and existing 138-kilovolt (kV) line. A maximum of 224.6 ac (90.9 ha) of temporary impacts and 168.5 ac (68.2 ha) of permanent impacts could occur.
TL2	An 8.7-mi (13.9-km) transmission line would be constructed to connect to the ERCOT grid. 90 percent of the line would parallel a section line, FM 866, and existing 138-kV line. A maximum of 209.9 ac (84.9 ha) of temporary impact and 157.5 ac (63.7 ha) of permanent impacts could occur.
TL3	A 2.2-mi (3.6-km) transmission line would be constructed to connect to the ERCOT grid. The line would require a new ROW. A maximum of 54.3 ac (22.0 ha) of temporary impacts and 40.7 ac (16.5 ha) of permanent impacts could occur.
TL4	A 0.6-mi (1.0-km) transmission line would be constructed to connect to the ERCOT grid. The line would require new ROW. A maximum of 15.2 ac (6.2 ha) of temporary impacts and 11.4 ac (4.6 ha) of permanent impacts could occur.
TL5	A 36.8-mi (59.2-km) transmission line would be constructed to connect to the Southwest Power Pool (SPP) grid. The line would parallel a section line, existing transmission lines, roads, and would partially require new ROW. A maximum of 893.1 ac (361.4 ha) of temporary impacts and 669.8 ac (271.1 ha) of permanent impacts could occur.
TL6	A 32.8-mi (52.8-km) transmission line would be constructed to connect to the SPP grid. The line would parallel a section line, existing transmission lines, roads, and would partially require new ROW. A maximum of 796.3 ac (322.3 ha) of temporary impacts and 597.3 ac (241.7 ha) of permanent impacts could occur.
<i>Access Roads</i>	
AR1	<i>A 0.3-mi (0.5-km) access road would be newly constructed from the intersection of FM 1601 and County Road (CR) 1216 north into the polygen plant site. FM1601 would be improved and perhaps re-routed from this intersection to I-20. A maximum of 6.4 ac (2.6 ha) of temporary impacts and 1.8 ac (0.7 ha) of permanent impacts could occur.</i>
AR2	A 3.8-mi (6.1-km) access road would be constructed from FM 866 along an existing 138-kV transmission line to the northeast corner of the polygen plant site. A maximum of 69.3 ac (28.0 ha) of temporary impacts and 23.1 ac (9.3 ha) of permanent impacts could occur.
AR3	<i>A 5.0-mi (8.0-km) access road would be constructed from FM 866 along existing roads and rangeland to the northeast corner of the polygen plant site. A maximum of 91.2 ac (146.8 ha) of temporary impacts and 30.4 ac (48.9 ha) of permanent impacts could occur.</i>
AR4	<i>A 2.8-mi (4.5-km) access road would be constructed from the frontage road of I-20 along existing roads to the northeast corner of the polygen plant site. A maximum of 50.1 ac (80.6 ha) of temporary impacts and 16.7 ac (6.8 ha) of permanent impacts could occur.</i>

Table 2.2. TCEP Resource Requirements

Resource	Description
<i>Railroad Line</i>	
RR1	A 1.1-mi (1.8-km) rail spur would be constructed to connect the existing UPRR line to the on-site rail loop. A maximum of 20.5 ac (8.3 ha) of temporary impacts and 6.8 ac (2.8 ha) of permanent impacts could occur. Attendant features <i>in the polygen plant site</i> would include a maintenance shop, refueling station, on-site engine yard.
<i>CO₂ Pipeline</i>	
CO ₂	A 1.0-mi (1.6-km), 12-in (30-cm) CO ₂ pipeline would be constructed to connect plant facilities to the existing Kinder Morgan Central Basin pipeline east of the polygen plant site; a maximum of 18.7 ac (7.6 ha) of temporary impacts and 6.2 ac (2.5 ha) of permanent impacts could occur.

2.4.5.1 COAL

The TCEP would use low-sulfur, sub-bituminous Powder River Basin coal. The plant would use approximately 2.1 million tn (1.9 million t) of coal annually, assuming operation at 100 percent capacity.

Coal would be received by rail in dedicated unit trains from a coal mine. Unit trains would contain up to **150** railcars. Each railcar would carry up to 120 tn (109 t) of coal. ***Coal is generally transported in small, gravel-sized pieces. As a standard practice, a coal dust suppressant would be applied to loaded coal train cars prior to transport and applied to the coal pile storage at the polygen plant site.***

A maximum of **two** unit trains per day could be received and unloaded at the plant site; ***however, an average of two to three 150-car unit trains per week would be used.*** Coal would be stored on-site in coal piles, which would be sized for about 45 days of total storage capacity, with approximately nine days of active storage and 36 days of inactive storage.

The UPRR, which has a rail line at the southern border of the plant site, has agreed to provide coal transportation services to the TCEP. Rio Tinto, a coal producer, has provided a letter of support for the TCEP and is willing to provide sufficient quantities of coal from its Cordero Rojo Mine complex in Wyoming at standard market terms. Although Cordero Rojo coal is being used for purposes of preliminary design engineering, the TCEP would not be dependent on access to Cordero Rojo coal.

2.4.5.2 NATURAL GAS

Although the primary fuel source for electric power production would be coal-derived syngas, the TCEP would require up to 2 trillion Btu of natural gas annually for polygen plant startup and as a backup fuel for the power island. Natural gas would also be used during operations for heating drying gases, fueling an auxiliary boiler, and providing burner pilot flames (see Section 2.4.3.2 for pilot usage). Using the access to natural gas, Summit could decide to install the combined-cycle power island early in the construction process (that is, before the gasification island), which would allow for electricity production from natural gas until the gasification island could be installed and the TCEP began full operation. This would also result in permanent job creation earlier than expected. Use of natural gas for full electricity dispatch would require 17.5 trillion Btu annually.

The plant would tap an existing natural gas pipeline for access to natural gas. Natural gas would be obtained through **one of three proposed natural gas line options**. **NG1 is a proposed 2.8-mi (4.6-km), 12-in-diameter (30-cm-diameter) pipeline that would connect with the ONEOK 20-in-diameter (50-cm-diameter) mainline south of the proposed plant site. NG2 is a proposed 3.5-mi (5.6-km), 12-in-diameter (30-cm-diameter) pipeline that would be constructed approximately 1.0 mi (1.6 km) east of FM 1601 from an existing 20-in-diameter (51-cm-diameter) ONEOK natural gas pipeline located southeast of the polygen plant site. NG3 is a proposed 2.8-mi (4.5-km), 12-in-diameter (30-cm-diameter) pipeline that would be constructed approximately 0.5 mi (0.8 km) west of FM 1601 from an existing 20-in-diameter (51-cm-diameter) ONEOK natural gas pipeline located south of the polygen plant site.** The locations of the **natural gas line options** are identified in Figure 2.7.

2.4.5.3 PROCESS WATER

The TCEP would require **an average of 4.2 million gal (15.9 million L)** per day and a maximum of **4.5 million gal (17.0 million L)** per day of **source** water for all polygen plant **processes**. Water used for steam production in the HRSG must be of very high quality and, for economic reasons, would be condensed and reused rather than vented to the atmosphere as steam. Water for the plant would be supplied by a pipeline from one or more of the three **primary** sources as described below. WL5 is the preferred **primary** process water option. **A number of backup process water supply sources have been identified and would be used only in the event that the selected primary process water source is not available due to a disruption of service. Backup process water supply sources are also described below.** The locations of the waterline options for **the TCEP** are shown in Figure 2.8.

Primary Water Supply Options

Gulf Coast Waste Disposal Authority

The GCA owns and operates the Odessa South Facility, an existing facility in Odessa that treats municipal sewage from the city of Odessa and industrial waste water from nearby industries. GCA's current discharge permit **daily maximum** is 7.0 million gal (26.5 million L) per day and on average, the plant treats **and discharges 2.8 million gal (10.6 million L)** per day (**Summit 2011b**). GCA has a minimum required discharge rate of approximately 2.0 million gal (7.5 million L) per day into Monahans Draw. **In anticipation of receiving waste water from the city of Midland to support TCEP's needs, GCA recently requested approval from TCEQ to increase their discharge limits to a daily average of 10.6 million gal (40.1 million L) with a daily maximum of 12.0 million gal (45.4 million L). The limit for total dissolved solids (e.g., salinity) would not be changed as part of GCA's requested permit modification.** GCA currently has no water reuse customers.

As one of the water sources under consideration, GCA would provide water to the TCEP from treated water from the Odessa South Facility. The Odessa South Facility would continue to receive waste water from the existing sources and would also receive waste water from the city of Midland WWTP, which currently treats its waste water (primary treatment only) and disposes of it through land application for agricultural irrigation. Under the GCA source option (WL1 or WL5), waste water from the city of Midland WWTP would be piped to the GCA Odessa South Facility where it would receive additional, secondary treatment and filtration. GCA would need to construct additional handling and treatment capacity at its existing facility, and existing but currently unused systems would be refurbished and put into service. GCA would then pipe the treated water to the TCEP, as needed, for use as process water.




Figure 2.7. Proposed natural gas pipeline interconnection *options* (NG1–NG3).




Figure 2.8. Proposed routes for the process water pipeline options (WL1-WL6).

There are two GCA waterline options that could transport the secondary-treated water to the polygen plant. WL1 would require the construction of a 20- to 30-in-diameter (51- to 76-cm-diameter) pipeline from the city of Midland WWTP to the GCA Odessa South Facility and from the GCA Odessa South Facility to the polygen plant site. The pipeline would be approximately 41.3 mi (66.6 km) long, of which approximately 20 mi (32 km) would require a new ROW. WL5 would require the construction of a 20- to 30-in-diameter (51- to 76-cm-diameter) pipeline connecting the city of Midland WWTP, the GCA Odessa South Facility, and the polygen plant site. The pipeline would be approximately 44.5 mi (71.6 km) long, of which approximately 30 mi (48 km) would require new ROW. Both WL1 and WL5 would require pump stations at or near the Midland WWTP as well as at the GCA Odessa South Facility. The pump stations would be needed to provide the necessary pumping capacity and would consist of three electric pumps enclosed in an approximately 30 × 30-ft (9 × 9-m) building. The pump stations could either be 1) constructed within the city of Midland WWTP or b) constructed approximately 620 ft (189 m) upstream of the incoming pipeline to avoid 90 percent of the industrial customer drains, which have the potential to discharge waste outside the limits of the GCA discharge permit. The pump station at the GCA Odessa South Facility would be located within the facility boundary. WL5 is Summit's preferred GCA option.

The specific quantity of waste water to be transferred from the city of Midland to the GCA Odessa South Facility is currently being negotiated by those two entities. ***The objective of these negotiations is to secure the needed water for the TCEP while not decreasing GCA's current discharge into Monahans Draw. Under this primary water source option (WL1 or WL5), the quality of the treated waste water discharged into Monahans Draw from the GCA Odessa South Facility would be similar to the existing quality of discharged water. At a minimum, the city of Midland WWTP would provide a flow volume of approximately 6.0 million gal (22.7 million L) per day to GCA. The daily average discharge into Monahans Draw from the GCA Odessa South Facility would increase by approximately 0.4 to 1.4 million gal (1.5 to 5.3 million L) per day (annual average would be 0.75 million gal [2.8 million L] per day), with the greater amounts discharged during the winter months when the polygen plant would need less water for cooling. The sanitary sewer system for the city of Midland WWTP is separate from its storm water sewer system; therefore, no storm water from the city of Midland would be transferred to the GCA Odessa South Facility.***

Nontransferred waste water would continue to be sent from the city of Midland WWTP to irrigate croplands, although at a reduced level (approximately 6.0 million gal [22.7 million L] per day less) compared to current levels. DOE's understanding, based on communication between Summit representatives and representatives of the city of Midland and the GCA, is that the city of Midland would continue sending nearly half of its waste water to Midland's spray irrigation fields for disposal. Midland's current rate of spray disposal exceeds the optimal land irrigation rates for crops, and that diversion of excess waste water to the TCEP would be beneficial to the spray disposal system currently in use by Midland without reducing the production of crops. In addition, the city of Midland would continue to provide waste water, fertilizer, and seed base to the selected bidders and collect a small percentage of the profit.

The city of Midland also has plans to treat a small percentage of its waste water (to a higher quality) through a small supplemental WWTP (to be installed at or near the point of use). This treated waste water would be for reuse purposes, including landscaping and lawn maintenance at Midland College. Accounting for these applications, there would be sufficient waste water remaining to meet the needs of the TCEP and to continue Midland's spray irrigation.

Oxy Permian

Oxy Permian operates a network of pipelines that provide brackish (highly saline and nonpotable) ground water from the Capitan Reef Complex Aquifer. The Oxy Permian Waterline option (WL2) would provide **source** water to the TCEP from the existing pipeline system through a new 9.3-mi (15.0-km), **up to 24-in-diameter (61-cm-diameter)** pipeline. Of the 9.3-mi (15.0-km) length, approximately 8.7 mi (14.0 km) of new ROW would be required. **Source** water from Oxy Permian would require treatment to meet gasifier manufacturer specifications.

Fort Stockton Holdings

Currently in the developmental stages, the FSH waterline project has been proposed to provide drinking water to the cities of Midland and Odessa. Under this option, FSH would provide water to the TCEP from one of two potential waterlines (WL3 and WL4). The viability of the main FSH waterline project would be independent of the TCEP. If it were built, the TCEP could use approximately 10 percent of the total water that would be available through the FSH waterline. The FSH water source would be ground water from the Edwards-Trinity (**Plateau**) Aquifer located near the city of Fort Stockton, which is approximately 66 mi (106 km) southwest of the proposed TCEP. **Source** water from the FSH option would require treatment to meet the gasifier manufacturer's specifications. WL3 would require construction of a **14.2-mi (22.8-km)** connector pipeline from the **polygen plant site** to the FSH pipeline using 9.2 mi (14.8 km) of new ROW.

Backup Water Supply Options

Summit is also considering a number of backup water supply options. These options would supply water to the TCEP in the event of a disruption in the primary water source. Because of the designed reliability of the primary water source options, it is anticipated that the backup water supply sources would be used infrequently and for periods of short duration. Backup water supply options under consideration are described below.

Texland Great Plains Water Company

Under this option, the Texland Great Plains Water Company (Texland) would provide the backup water supply using their existing firm service capacity reserved for the OEPP. OEPP operates as an intermediate power provider in the ERCOT system. Currently, the OEPP facility is dispatched in the range of 12–15 percent per year. When the OEPP facility is online, water could not be made available for backup service to the TCEP. The Texland water would only be paid for by TCEP when used. Texland was not considered as a primary water supplier for the TCEP because all of its available capacity is under contract to other users.

Texland pumps water from the Ogallala Aquifer and is currently serving electric power plants, oil and gas field waterfloods and gas plants, a municipal water system, and agricultural users. Texland has agreed to develop commercial terms with TCEP to provide the needed water quantity when 1) TCEP calls upon the service and 2) it is not being used by OEPP.

If GCA is chosen as the primary water source option (WL1 or WL5), a new 16-in-diameter (41-cm-diameter) pipeline (WL6) between the existing OEPP facility and the GCA Odessa South Facility (a distance of approximately 3 mi (2.8 km) with 0.9 mi (1.4 km) of new ROW) would be required for the backup water supply. From the GCA Odessa South Facility, backup water from the Texland system would then be transported to the polygen plant site in either the WL1 or WL5 pipeline options.

Alternatively, a new 16-in-diameter (41-cm-diameter) pipeline would also be required if WL2 is chosen as the primary water source option. This pipeline would be constructed between the OEPP facility and TCEP, a distance of 17 mi (27 km), following one of the alignments proposed for WL1 or WL5 between the GCA Odessa South Facility and the polygen plant site.

Fort Stockton Holdings

If the FSH pipeline is constructed, this water source could be used as a backup water source for the polygen plant. As a backup to WL1 or WL5 (from the GCA Odessa South Facility), a 2.7-mi (4.3-km), 16-in-diameter (41-cm-diameter) pipeline (WL4) could be constructed from the main FSH waterline to the existing GCA Odessa South Facility. Water would be filtered and piped from the GCA Odessa South Facility to the polygen plant site using WL1 or WL5. Approximately 1.3 mi (2.1 km) of WL4 would require a new ROW. As a backup water source for WL2, backup water from the FSH waterline could be piped to the polygen plant using WL3.

Other Backup Sources

Backup water supply sources could also come from treated waste water from the city of Odessa Derrington Water Reclamation Plant or from the GCA Odessa South Facility. If the city of Odessa Derrington Water Reclamation Plant is chosen as a backup water source, additional waste water from this plant could be routed to the GCA Odessa South Facility, or Summit could tap into the existing Odessa reuse line that runs adjacent to the GCA Odessa South Facility. Although the city of Odessa has over-committed their reuse water, they do have excess water that discharges into Monahans Draw in the winter months that could potentially be used as a backup water source on a short-term basis. Summit could purchase secondary or tertiary water rights during these months as a backup water supply.

The GCA Odessa South Facility base flow of approximately 2.8 million gal (10.6 million L) per day could also be used as a potential backup water source in the event effluent from the city of Midland WWTP was interrupted. Under this scenario, part or all of the GCA Odessa South Facility base flow could be diverted to the polygen plant on a temporary basis. These backup water source plans would be refined, and a final backup water source plan developed for the TCEP prior to plant operation.

2.4.5.4 POTABLE WATER

Potable water demand would be generated by construction and operations personnel. Approximately 30 gal (113 L) per day per person would be required. During construction peak employment, water demand would be approximately 45,000 gal (170,343 L) per day based on a peak construction workforce of approximately 1,500 workers. Once operational, water demand would decrease to 4,500 gal (17,034 L) per day based on approximately 150 workers on-site.

During construction, potable water would be delivered to the plant site by truck **by a commercial provider**, requiring approximately six 25-ton (23-t) trucks per day (**fourty-two** 25-ton [23-t] trucks per week). **Several options are being evaluated for potable water sources during polygen plant operation. The options consist of transporting water by truck, installing an on-site water well with additional treatment, or providing additional treatment to the process water source to bring it up to potable water standards. If delivered by truck**, Summit estimates that **plant operations** would require approximately five trucks per week.

2.4.5.5 ELECTRIC TRANSMISSION

The TCEP would tie into the existing transmission grid at one of the six options described below. *A new 138-kV switchyard would be constructed at the polygen plant site to facilitate this connection. Two large generator step-up transformers would be located next to the plant's electric generators and would connect to a smaller transformer in the on-site switchyard. The new transmission line that connects the plant-site switchyard to the existing transmission infrastructure would consist of a series of 86-ft-tall (26-m-tall) monopoles in 600-ft (183-m) spans. Transmission lines themselves would range from 20 to 80 ft (6-24 m) in height, depending on the temperature (e.g., heat expansion) and mounting position on the monopoles.*

The proposed routes for the transmission line interconnection options are identified in Figure 2.9. Maximizing the use of existing infrastructure facilities, Summit identified the following potential transmission line routes that would connect to the ERCOT market:

- TL1 would connect the TCEP with the existing Moss Substation. It would have a total length of 9.3 mi (15.0 km), with segments running parallel to a section line and an existing 138-kV transmission line. This route would require new ROW, although approximately 75 percent of the proposed transmission line would parallel existing linear facilities.
- TL2 would connect the TCEP with the existing Moss Substation. It would have a total length of **8.7 mi (13.9 km)**, with segments running parallel to a section line, FM 866, and an existing 138-kV transmission line. This route would require new ROW, although more than 90 percent of the proposed transmission line would parallel existing linear facilities.
- TL3 would have a total length of **2.2 mi (3.6 km)** and would follow a section line north to a point where it would interconnect with the existing Oncor 138-kV transmission line. This route would require new ROW. This alternative may require the reconductoring of the existing 138-kV transmission line between the point of interconnection with the TCEP and the Moss Substation. The need for reconductoring would be determined by the ongoing interconnection studies currently being conducted by Oncor. Construction of **two 3-ac (1-ha) switchyards** would be required at the intersection point of **1) the existing 138-kV transmission line approximately 0.6 mi (1.0 km) north of the polygen plant site** and, **2) the existing 138-kV transmission line approximately 2.2-mi (3.6-km) north of the polygen plant site.** Both switchyards would be used for the physical interconnection between the polygen plant site and the existing transmission system and would include a ring bus, circuit breakers, lightning arrestors and a small single story building. The switchyards would be graded level and would be surrounded by a chain link fence, while the ground area around the equipment would be covered with gravel.
- TL4 would have a total length of 0.6 mi (1.0 km) and would follow a section line north to a point where it would interconnect with **the nearest** existing Oncor 138-kV transmission line. **An Oncor interconnection study is being conducted for TL4, which is the preferred interconnection option; it has preliminarily identified the following upgrades (Oncor 2011):**
 - **A new 3-ac (1.2-ha) Penwell Switching Station would be constructed at the point of interconnection approximately 0.6 mi (1.0 km) north of the polygen plant site (TL4). The switching station would include a ring bus, circuit breakers, lightning arrestors, and a small single story building. The switchyard would be graded level and would be surrounded by a chain-link fence; the ground area around the equipment would be covered with gravel.**

- *Approximately 6.8 mi (10.9 km) of the existing 138-kV transmission line beginning at the proposed Penwell Switching Station to the existing Moss Switching Station would be rebuilt with single-circuit structures using 959 aluminum conductor, steel-supported cables on a series of 86-ft-tall (26-m-tall) monopoles in 600-ft (183-m) spans and would terminate on a new 86-ft-tall (26-m-tall) structure in the Penwell Switching Station.*
- *Transfer-trip carrier equipment would be added at the existing Moss Switching Station.*
- *Various other minor improvements within the existing Moss and Permian Basin Switching Stations would be required.*

Summit may determine that, from a power marketing standpoint, it **would be** beneficial to connect to the SPP market instead of or in addition to the ERCOT market. ***If Summit determines that the SPP market is preferable to ERCOT, interconnection studies may require upgrades to other existing infrastructure. Similar to the upgrades needed to connect with the ERCOT system, potential infrastructure upgrades to connect to the SPP system may include new and/or upgraded switch stations, an upgraded substation at the point of interconnection, upgrading conductors and/or structures on existing transmission lines, and other system infrastructure.***

The following two options would support the connection to the SPP:

- TL5 **would** connect the TCEP with the existing Midland County Substation. It would have a total length of 36.8 mi (59.2 km), with segments running parallel to a section line, existing transmission lines, and existing roads. This route would require a new ROW.
- TL6 would connect the TCEP with the existing Midland County Substation. It would have a total length of 32.8 mi (52.8 km), with segments running parallel to a section line, existing transmission lines, and existing roads. This route would require a new ROW.




Figure 2.9. Proposed routes for the transmission line interconnection options (TL1-TL6).

2.4.5.6 CARBON DIOXIDE PIPELINE

As discussed in Section 2.4.4.1, captured CO₂ would be transported from the TCEP by pipeline to connect with an existing Kinder Morgan CO₂ pipeline located approximately 1.0 mi (1.6 km) east of the plant site. Figure 2.10 shows the proposed route for the CO₂ pipeline. All of the potential CO₂ purchasers under consideration at this time are or can be connected to the existing Kinder Morgan CO₂ pipeline system. However, there may be commercial reasons in the future to prefer a direct pipeline connection from TCEP to a local CO₂ offtaker. No such direct pipelines are currently under consideration.

2.4.5.7 TRANSPORTATION

The polygen plant site would have two access points: one located along the northern boundary of the site near the northeast corner and one located along the southern boundary at the intersection of FM 1601. There would also be rail access to the plant site. Figure 2.11 identifies the *four* access road *options that lead to the two access points and the rail spur alignment under consideration for the TCEP.*

Access to the polygen plant *during construction* would be primarily *from FM 866 (AR2-AR3) or by the I-20 frontage road (AR4); all would enter the site through the access point near the northeast corner of the polygen plant site.* Approximately 95 percent of the construction and operations vehicle traffic would use *options AR2, AR3, or AR4.*

Access from FM 1601 (AR1) would be used primarily for emergency vehicle access, plant administrative workforce, and visitors (anticipated 5 percent use). AR1 would require the construction of an approximately 0.04-mi (0.06-km) underpass beneath the UPRR line, which would connect the southern portion of the polygen plant site to FM 1601. Although details have not been finalized, for purposes of this analysis, DOE assumed that improvement of approximately 0.26 mi (0.42 km) may be required along FM 1601 to I-20. Therefore, AR1 totals approximately 0.3 mi (0.5 km) for both construction and potential improvements.

Option AR2 would require the construction of approximately 3.7 mi (6.0 km) of a new county road between FM 866 and the plant site. Ector County has proposed to build the selected northern access road. The new county road for AR2 would interconnect with existing FM 866 and would parallel an existing 138-kV transmission line for approximately 3.1 mi (5.0 km), then turn south for approximately 0.6 mi (1.0 km), where it would terminate at the northern access point to the plant site.

Option AR3 would require the construction of approximately 5.0 mi (8.0 km) of a new county road. This road would intersect with the existing FM 866 and would parallel an existing private oil field road for approximately 1.9 mi (3.1 km), continue on for approximately 1.1 mi (1.8 km), then turn south for approximately 2.0 mi (3.2 km) where it would terminate at the northern access point to the plant site.

Option AR4 would require construction of approximately 2.8 mi (4.5 km) of new county road. This road would run from I-20 frontage road and continue northwest along a private access road to a limestone quarry for approximately 0.9 mi (1.4 km) where it would turn west for approximately 1.9 mi (3.1 km) along existing private oil field roads, entering the plant site at the northern access point.

A railroad line or *rail spur* (RR1) would be constructed from the UPRR line to the polygen plant site. This rail spur would connect to a rail loop within the site boundary that would facilitate the unloading of coal, the loading of H₂SO₄, urea, and slag, as well as the loading and unloading of construction and operations materials. Track layout design has not yet been finalized but would include the 1.1-mi (1.8-km) rail spur at the southeast corner of the plant site, on-site tracks (***rail loop***) to accommodate two coal train sets and two urea unit trains, a locomotive refueling location and road access for a ***fuel*** tank truck. ***An*** area for railcar maintenance (including a maintenance building) with access for a railcar repair contractor ***would also be constructed***. Features associated with rail maintenance and refueling would include the plant's own small railcar pusher engine, aboveground fuel storage tanks and/or tanker trucks, lubricants, engine oils, hydraulic fluids, and other equipment necessary to ensure equipment remains in safe operating conditions. To minimize environmental risks, all attendant features will comply with applicable rules and regulations for their storage and handling, as well as implement spill and pollution controls.




Figure 2.10. Proposed carbon dioxide pipeline route (CO₂).




Figure 2.11. Proposed routes for TCEP access roads (AR1-AR4) and the rail spur (RR1).

2.4.5.8 LAND AREA

The proposed plant site is approximately 600 ac (243 ha) in size, **all of which could** be permanently affected by construction and operation of the proposed TCEP. Construction of the various off-site **waterlines, natural gas pipelines, transmission line, access roads, rail spur, and CO₂ pipeline** would also require commitments of land resources (see Table 2.2). **The linear facility options for the process waterline, natural gas pipeline, access roads, rail spur, and CO₂ pipeline** would have an estimated **150-ft (46-m)** construction ROW and a 50-ft (15-m) operational ROW. **The transmission line options would have an estimated 200-ft (60-m) construction ROW and a 150-ft (46-m) operational ROW.** Temporary impacts during construction could range from **377 to 1,982 ac (153–802 ha)**. Permanent impacts from operations could range from **132 to 1,032 ac (53–418 ha)**, based on the smallest combination (**NG3, WL2, WL4, TL4, AR1, AR4, RR1, CO₂**) and largest combination (**NG2, WL5, WL6, TL5, AR1, AR3, RR1, CO₂**) of the linear facility options. **Linear facility alignments could vary slightly depending on land acquisition issues, environmental conditions, and engineering considerations.**

2.4.5.9 TOXIC AND HAZARDOUS MATERIALS

Hazardous materials that would be used or stored for TCEP operations include relatively small quantities of petroleum products, liquid O₂ and N₂, sulfur, catalysts, flammable and compressed gases, methanol, water treatment chemicals, and minor amounts of solvents and paints (see Table 2.2).

Natural gas and H₂-rich fuel gas (i.e., clean syngas), which are flammable fuels, would be used in the TCEP, specifically for the power block. Natural gas would be used as a startup and backup fuel and would also provide support during operations; it would be utilized directly from the on-site pipeline (connecting to the off-site main pipeline) and would not be stored on-site. H₂-rich fuel gas would be the primary fuel for the **gas** turbine. It would be generated on site and not stored.

Bulk quantities of liquid O₂ and N₂ would be stored in tanks in the air separation unit to provide capacity for startups and continued plant operation during short-duration air separation unit system outages. Other gases stored and used at the polygen plant would include those typically used for maintenance activities such as shop welding, emissions monitoring, and laboratory instrument calibration. These gases would be stored in approved standard-sized portable cylinders kept at appropriate locations.

Water treatment chemicals would be required and stored on site. Bulk chemicals such as acids and bases for pH control would require storage in appropriately designed tanks, with secondary containment and monitoring. Hypochlorite bleach is expected to be used for biological control of the various circulating and cooling tower water streams. Other water treatment chemicals would be required as biocides and for pH control, dissolved O₂ removal, and corrosion control for boiler feed water, cooling tower treatment, and cooling water treatment.

For **process** water treatment, coagulants and polymers could also be used. Chemicals used for these purposes are generally specified by the water treatment provider and are available under a number of trade names. Stored quantities of these materials would be small, ranging from 55-gal (208-L) drums to 500-gal (1,892-L) tanks.

Diesel fuel would be used for the emergency generator and for the fire-water pump. The expected stored quantity (2,000 gal [7,570 L]) was based on approximately eight hours of operation of the

diesel generators at full output (approximately 3 MW). This limited storage would require the plant to have contracts with fuel providers specifying that deliveries of diesel fuel could be provided in fewer than eight hours in an emergency. Appropriate containment and monitoring for spillage control would be provided.

Other petroleum-containing hazardous materials **would** include the **gas** and steam turbine lube oils, steam turbine hydraulic fluid, transformer oils, and miscellaneous plant equipment lube oils. These materials would be delivered and stored in approved containers in areas with appropriate secondary containment and would be used in curbed areas that only drain to internal drains connected to an oil-water separator system. Oil reservoirs, containment areas, and the separators would be checked regularly to identify potential leaks and to initiate appropriate actions. The on-site switchyard, which would be the main connection between the polygen plant and the associated transmission line to the transmission grid, would include one small transformer that will require 250 gal (946 L) of mineral-based insulating oil. Two larger generator step-up transformers, which will also require about 18,000 to 20,000 gal (68,137–75,705 L) of mineral-based insulating oil, will be located next to the generators that they serve in the plant. Design of the switchyard and the area containing the larger transformers would include curbing to contain any potential spills, as well as a fire protection system.

Toxic and hazardous materials that would be used or stored for project operations include those used for general plant usage, gasification, **process** water treatment, waste water treatment, cooling tower, urea synthesis, sour shift, power block, and fuel, as shown in Table 2.3.

Table 2.3. Toxic and Hazardous Materials and Estimated Storage at the Polygen Plant Site

Chemical	Estimated Storage on Polygen Plant Site	
	Volume (gal [L])	Mass (lbs [kg])
General Plant Usage		
Anhydrous NH ₃	1,365,988 (5,170,827)	7,249,454 (3,288,297)
Aqueous NH ₃	31,231 (188,222)	232,529 (105,473)
Caustic	29,802 (112,813)	301,153 (136,601)
H ₂ SO ₄ (process water treatment use)	54,062 (204,647)	815,176 (369,759)
H₂SO₄ Plant		
Hydrogen peroxide	9,725 (36,813)	89,700 (40,687)
H ₂ SO ₄	36,408 (137,819)	558,817 (253,475)
Gasification		
Hydrochloric acid	13,981 (52,924)	131,637 (59,710)
Process Water Treatment		
Anti-scalant	157 (594)	1,342 (609)
Calcium hydroxide (dry)	n/a	225,927 (102,479)
Ferric chloride	898 (3,399)	10,491 (4,759)
Hydrochloric acid	16,779 (63,515)	159,003 (72,123)
Nalco 7341 (sodium hypochlorite [bleach])	516 (1,953)	5,109 (2,317)

Table 2.3. Toxic and Hazardous Materials and Estimated Storage at the Polygen Plant Site

Chemical	Estimated Storage on Polygen Plant Site	
	Volume (gal [L])	Mass (lbs [kg])
Sodium bisulfite	142 (538)	1,560 (708)
Sodium carbonate (dry)	n/a	409,968 (185,958)
Waste Water Treatment		
Acetic acid	11,011 (41,681)	97,500 (44,225)
Ferric chloride	22 (83)	273 (124)
Hydrochloric acid	875 (3,312)	8,323 (3,775)
Nalco 7341 (sodium hypochlorite)	52 (197)	507 (230)
Organo sulfide	52 (197)	429 (195)
Phosphoric acid	90 (341)	1,248 (566)
Cooling Tower		
Nalco 3DT120	3,463 (13,109)	29,452 (13,359)
Nalco 3DT177	1,070 (4,050)	11,781 (5,344)
Nalco 7341 (sodium hypochlorite)	4,960 (18,776)	49,177 (22,306)
Nalco 90005	254 (961)	2,003 (909)
Nalco 71D5	524 (1,984)	3,640 (1,651)
Urea Synthesis		
UF85 (formaldehyde/urea/water)	23,863 (90,331)	260,000 (117,934)
Sour Shift		
Dimethyl Disulfide	591 (2,237)	5,200 (2,359)
Power Block*		
Hydrazine	875 (3,312)	7,377 (3,346)
Ammonium-Ethylenediaminetetraacetic acid disodium salt (dry)	n/a	18,200 (8,255)
Antifreeze (propylene glycol or ethylene glycol)	5,057 (19,143)	43,409 (19,690)
Ethylenediaminetetraacetic acid	778 (2,945)	6,500 (2,948)
Sodium borate (dry)	n/a	30 (14)
Trisodium phosphate	524 (1,984)	4,335 (1,966)
Fuel		
Coal dust suppression polymer	TBD	TBD
Diesel	1,997 (7,559)	16,000 (7,257)

Note: n/a = not available and TBD = to be determined.

*The power block consists of the electric generation unit, *gas* turbines, HRSG, and associated equipment.

2.4.6 Emissions, Discharges, and Wastes

2.4.6.1 AIR EMISSIONS FROM PLANT OPERATIONS

The TCEP is being designed with state-of-the-art emissions-control systems that would allow for the conversion of coal to a H₂-rich syngas, which would burn with substantially less air pollution as compared to other fuels. H₂ would combust to produce water vapor. Because H₂ constitutes most of the fuel, much of the exhaust from the *gas* turbine would be water vapor.

Summit's design team estimated the maximum and average emission quantities from each emission point using

- equipment supplier data;
- test results for similar equipment at other IGCC facilities;
- engineering calculations, experience, and professional judgment; and
- published and accepted average emission factors such as the EPA Compilation of Air Pollutant Emission Factors (AP-42).

House Bill 469, passed by the Texas Legislature in 2009, requires the use of best available control technology by requiring that IGCC projects meet or improve upon the most stringent emissions limits that have been set for a U.S. coal-based plant. The emissions must be comparable to or better than those of a natural gas-fueled combined-cycle plant. The TCEP's air permit includes even lower emissions limits than those required by House Bill 469.

The maximum air pollutant emissions from the polygen plant are shown in Table 2.4.

Table 2.4. TCEP Permitted Air Pollutant Emissions

Type	Emissions (tn [t] per year)
Criteria Air Pollutants	
NO _x	225.00 (204.10)
Volatile organic compounds	39.60 (35.90)
SO ₂	251.10 (227.80)
CO	1,173.00 (1,064.10)
PM	416.10 (377.50)
PM ₁₀	385.00 (349.30)
PM _{2.5}	367.00 (332.90)
Lead	0.02 (0.018)
Hazardous Air Pollutants (HAP)	
COS	2.61 (2.37)
Hg	0.01 (0.01)
Hydrochloric acid	1.39 (1.26)
Hydrofluoric acid	0.83 (0.75)
Formaldehyde	2.96 (2.69)
Other Air Pollutants	

Table 2.4. TCEP Permitted Air Pollutant Emissions

Type	Emissions (tn [t] per year)
H ₂ S	3.20 (2.90)
Total reduced sulfur	5.80 (5.26)
H ₂ SO ₄	15.00 (13.60)
NH ₃	363.00 (329.3)

Source: Summit (2011b).

Note: PM₁₀ = PM with aerodynamic diameters equal to or less than 0.00039 in (10 micrometers);

PM_{2.5} = PM with aerodynamic diameters equal to or less than (0.000098 in (2.5 micrometer).

Table 2.5 compares the maximum emissions from TCEP to the emissions from conventional power plants in Texas ranging in size from 765 MW to 2,565 MW.

Table 2.5. Comparison of Power Plant Emissions Per Megawatt Hour

Power Plants	Air Emissions (lbs [kg]/MW-hours)				
	SO ₂	NO _x	PM ₁₀	Hg	CO ₂
1970s pulverized coal plant	11.97 (5.43)	4.49 (2.04)	1.00 (0.45)	0.000214 (0.000097)	2,203 (999)
Recently permitted pulverized coal plant	2.01 (0.91)	0.84 (0.38)	0.42 (0.19)	0.000096 (0.000044)	2,203 (999)
Recently permitted coal plant using circulating fluidized bed technology	0.86 (0.39)	0.70 (0.32)	0.26 (0.12)	0.000008 (0.000004)	2,041 (926)
Recently permitted pulverized coal plant with carbon capture	0.65 (0.29)	0.55 (0.25)	0.29 (0.13)	0.000019 (0.000009)	331 (150)
TCEP	0.14 (0.064)	0.13 (0.596)	0.22 (0.10)	0.000007 (0.000003)	228 (103)

Source: Summit (2011a).

2.4.6.2 WASTE WATER EFFLUENTS

Industrial and Process Water Treatment Effluents

As described in Section 2.4.3.5, the TCEP would ***include separate waste disposal systems designed to treat and dispose of both the reverse reject water from the source water treatment system and the residual industrial waste water from the process water treatment system.*** Cooling tower blowdown (water removed from the wet cooling system), ***contaminated*** water generated from gasification and slag processing operations, ***and other waste streams generated at the polygen plant*** would be routed to ***a treatment system that would allow a large portion of the water to be cleaned and reused in the plant.*** ***The options under consideration for the reverse osmosis reject water is the combination of solar evaporation ponds and deep well***

injection. The residual industrial waste water would then be sent to a disposal system designated for this stream. The options under consideration for the disposal of the residual industrial waste water include a mechanical crystallizer and filter press system or solar evaporation ponds, with an option to deep well inject the industrial waste water, depending on its quality. If deep injection were chosen for residual industrial waste water, the well would be permitted separately from the wells that would inject deep underground the reject water from the source water treatment system.

The **mechanical crystallizer and filter press system** would **produce** a solid filter cake material, which would be transported off-site to appropriate facilities for disposal. Based on preliminary design information, Summit estimates that up to 23,360 tn (21,191 t) of clarifier sludge and solids (filter cake) would be generated **annually** by the **mechanical crystallizer and filter press** system. The filter cake is expected to be nonhazardous, but **it** would be tested to confirm its characteristics.

Storm Water Management

Noncontact storm water runoff would be directed to an on-site retention pond designed to hold all runoff from the polygen site. Storm water would not be discharged from the retention pond. Any storm water runoff that had the potential to come in contact with oil (such as water runoff from parking lots) would be directed to a separate storm water pond that would direct collected storm water to an oil/water separator before entering the **residual industrial waste water disposal** system.

Sanitary Waste Water

Approximately 150 portable toilets would be required during construction, which would be collected and removed by a licensed sanitary waste disposal **company**. Sanitary wastes would be collected and discharged directly to an on-site underground septic disposal field. The septic field would be sized based on the number of workers, site-specific soil conditions and the specific areal requirements of the equipment to be used. It is estimated that sanitary waste would be approximately 55 gal (208 L) per person per day.

2.4.6.3 SOLID WASTES

During TCEP operation, the primary solid waste generated on-site would be slag from the coal gasification process. Wetted slag would be stored on an approximately 0.5-ac (0.2-ha) concrete slab, prior to being loaded into rail cars for transportation off-site for commercial use. If the slag cannot be sold for commercial use, it would be properly disposed of off-site in a licensed landfill.

In addition to the **filter cake**, other **process** solid wastes such as spent catalyst materials, spent activated carbon beds associated with Hg removal processes, and spent activated carbon beds and char sludge associated with the sour water treatment system would also be generated, along with municipal-type wastes. Summit would manage operational wastes in accordance with applicable regulations, good industry practice, and internal company procedures. Hazardous and nonhazardous wastes would be properly collected, segregated, and recycled or disposed of at approved wastes management facilities. Volumes of these waste streams and their disposal methods are shown in Table 2.6.

Table 2.6. Solid Wastes from the Polygen Plant

Waste	Annual Quantity	Disposal Method
Black water system filter cake	86,870 tn (78,973 t) if filter cake recycle is not feasible 9,259 tn (8,400 t) if filter cake recycle is feasible	Industrial landfill
Clarifier sludge and solids (filter cake)	23,360 tn (21,191 t)	Industrial landfill
Sanitary waste	3,011,250 gal (11,398,820 L)	On-site leach field
Slag from gasifier	178,485 tn (162,060 t)	To be sold (landfill)
Solid waste (office and break room waste)*	252 tn (229 t)	Municipal/industrial landfill

*Quantity estimated for 200 workers using an industrial waste generation rate of 9.2 lbs (4.2 kg) per day per worker (California Integrated Waste Management Board 2006).

Removal of sulfur and downstream production of H₂SO₄ for commercial sale would eliminate sulfur as a significant solid waste. Slag production would be approximately 489 tn (444 t) per day. Slag is considered a potential revenue-producing stream that would be actively marketed by Summit; however, if no market is available slag would be disposed of in an off-site landfill.

2.4.6.4 TOXIC AND HAZARDOUS MATERIALS

Management of toxic and hazardous wastes would begin by limiting the amounts of toxic and hazardous materials used and by reducing the generation of waste through reuse and recycling. Wherever possible, nontoxic and nonhazardous materials would be used instead of hazardous chemicals. Hazardous material use and hazardous waste generation programs would be supported by appropriate training. Hazardous wastes would be managed in accordance with applicable state and federal regulations. The largest quantities of hazardous wastes generated during construction of the power plant would be associated with equipment maintenance. Waste oil, spent solvents, and coolants would be drummed and periodically removed and disposed of at regulated facilities, depending on waste type. During plant operation, spent equipment fluids, such as waste oil, waste coolant, and used hydraulic oil would be properly managed on-site prior to removal off-site to a recycler for processing. Spent batteries, would also be temporarily stored on-site before being removed off-site for recycling or disposal at a properly licensed facility. Periodic maintenance activities would result in the temporary accumulation of a larger amount of wastes. Arrangements would be made with outside contractors to dispose of spent materials in an appropriate manner.

Adequate capacity exists in Texas for off-site disposal of all hazardous and nonhazardous wastes in fully authorized, commercial waste disposal facilities. The nearest hazardous waste disposal facility is Waste Control Specialists, LLC, located in Andrews, Texas, approximately 60 mi (97 km) from the proposed power plant site (Lott 2006a). Waste Control Specialists is also the only facility in the area to accept Class I nonhazardous industrial waste (Lott 2006b). The existing capacity of the facility is more than 5.0 million cubic yards (3.8 million m³). The only other hazardous waste disposal facility in Texas is US Ecology Texas, Inc., located just south of Robstown, Texas, near Corpus Christi (Lott 2006a).

2.4.6.5 Pollution Prevention, Recycling, and Reuse

The TCEP would be designed to minimize process-related discharges into the environment. A plan for pollution prevention and recycling would be developed during the detailed design and permitting steps, and the plan would be put into practice after the plant became operational. Table 2.7 lists some measures that may be employed as part of that plan.

Table 2.7. Possible Pollution Prevention, Recycling, and Reuse Features of the TCEP

Feature	Description
Spill prevention, control, and countermeasure (SPCC) plan	The SPCC plan would develop measures to take in the event of a spill, thereby insulating environmental media from the effects of accidental releases. The surfaces under and around aboveground chemical storage tanks would be lined or paved and curbed/diked, and would have sufficient volume to hold the contents of the tank. A site drainage plan would also be developed to prevent routine, process-related operations from affecting the surrounding environment.
Feedstock material handling	The coal storage area would be paved or lined so that runoff could be collected, tested, and treated as necessary. The coal storage area would be managed to control fugitive dust emissions. The coal conveyors would be covered.
Coal drying and grinding	The coal grinding equipment would be enclosed; a portion of the spent drying gas would be purged through a dust collector and vented into the atmosphere.
Gasification	The char produced in gasification would be removed in the black water treatment system as a dewatered filter cake and recycled for blending with the pulverized coal for feed to the gasifiers. This would improve the carbon conversion in the gasifier and reduce the amount of carbon contained in the gasifier slag.
Slag handling	The slag dewatering system would generate some flash gas that contains H ₂ S. This flash gas would be sent to the H ₂ SO ₄ plant. Water that is entrained with the slag would be collected and sent to the black water treatment system.
Sour water system	Sour water would be collected from the low-temperature syngas cooling system, and the NH ₃ and H ₂ S would be stripped out and sent to the H ₂ SO ₄ plant. The stripped condensate would be recycled to low-temperature syngas cooling.
Mechanical crystallizer and filter press system	The mechanical crystallizer and filter press system would concentrate and evaporate the residual industrial waste water that could no longer be cleaned in the process water treatment system . The mechanical crystallizer and filter press system would produce high-purity water for reuse and a solid filter cake for disposal off-site. The mechanical crystallizer and filter press system would concentrate and dispose of heavy metals and other constituents in the process condensate. The mechanical crystallizer and filter press system would also be a recycle unit because the recovered water would be reused, reducing the total plant water consumption.
Hg removal features	The Hg removal unit would use specially formulated activated carbon to capture trace quantities of Hg in the syngas.
Acid gas removal	The acid gas removal system would remove H ₂ S and CO ₂ from the raw syngas and produce a H ₂ -rich fuel gas for use in the combined-cycle power block and for urea production. The acid gas removal would produce concentrated H ₂ S feed for the H ₂ SO ₄ plant and concentrated CO ₂ for drying, compression, and transport for EOR.
H ₂ SO ₄ plant	The H ₂ SO ₄ plant would convert the H ₂ S to concentrated H ₂ SO ₄ , a commercial product.
Training and leadership	All corporate and plant personnel would be trained on continuous improvement in environmental performance, especially as such training and programs apply to setting, measuring, evaluating, and achieving waste reduction goals.

2.4.7 Marketable Products

2.4.7.1 ELECTRICITY

Up to 400 MW (gross) of electric power would be generated by the TCEP, with approximately 130–213 MW (net) going to the power grid, based on minimum and maximum power output conditions. Fluctuations in the urea and electricity markets could encourage Summit to increase its production of urea by up to 40 percent, which could result in a corresponding decrease in net electrical output due to the use of additional syngas for the production of NH₃, a precursor for the production of urea. The balance of the gross power generated would be used to operate the plant and produce urea fertilizer.

2.4.7.2 CARBON DIOXIDE

The TCEP *would* capture approximately *3 million tn (2.7 million t)* of CO₂ per year, *with 2.5–3 million tn (2.3–2.7 million t) sold to EOR, depending on electricity and urea demand.* After compression, drying, and purification, part of the CO₂ would be sent to the urea synthesis plant, and the remainder would be put into the CO₂ pipeline for sale and transport to EOR. For the *maximum* urea production *case*, approximately *1,512 tn (1,372 t)* per day of CO₂ (would be sent to the urea synthesis plant, with approximately *8,633 tn (7,832 t)* per day of CO₂ being compressed and sent to the CO₂ pipeline for use in EOR. *For the maximum power case, approximately 600 tn (544 t)* per day of CO₂ would be sent to the urea synthesis plant, with approximately 9,100 tn (8,255 t) per day of CO₂ being compressed and sent to the CO₂ pipeline for use in EOR. There would be no storage of CO₂ on site.

2.4.7.3 UREA

To optimize the operational flexibility of the polygen plant, Summit is considering increasing urea production by up to 40 percent, with a resulting decrease in the production of electricity and CO₂ available for EOR. With this flexibility, Summit would expect to produce between 1,485 and 2,079 tn (1,347–1,886 t) per day of granulated urea (542,025–758,835 tn [491,716–688,404 t] annually) at minimum and maximum capacities. This product would be transported off-site by rail, using an average of 15–21 railcars per day. The plant would include storage facilities for seven days of urea production.

2.4.7.4 ARGON

Argon, an inert gas, would be produced as a by-product of the coal gasification process. Up to seven days of argon production may be stored on-site; it would be transported off-site for sale in rail tank cars. Summit's market analysis confirms that there would be a viable market for the sale of the argon produced. *Up to seven days of argon production may be stored on-site; it would be sold and transported off-site in rail tank cars. The quantities of argon to be produced would be determined as part of the air separation unit system design.*

2.4.7.5 SULFURIC ACID

H₂SO₄, a hazardous material, would also be produced as a by-product of the coal gasification process. The TCEP would produce up to 56 tn (51 t) per day of H₂SO₄, which would be transported off-site by rail (up to four railcars per week) or truck. Prior to transport, H₂SO₄ would be stored in a small storage tank with a 36,400-gal (137,789-L) capacity and then pumped to the railcars on site.

Summit's market analysis confirms that there would be a viable market for the sale of the H₂SO₄ produced.

2.4.7.6 SLAG

Slag production would be approximately 489 tn (444 t) per day. Slag is a potential revenue-producing stream that would be actively marketed by Summit. The slag would be temporarily stored on site prior to being loaded into railcars for sale and transportation off-site. If no market was available, it would be trucked to an off-site permitted solid waste landfill. Using 25-tn (23-t) trucks, off-site transportation of slag would require approximately 20 trucks per day.

2.4.8 Construction Plans

2.4.8.1 CONSTRUCTION STAGING AND SCHEDULE

The TCEP would be constructed over the course of up to 38 months, including the installation of linear facilities (process waterlines, CO₂ pipeline, high voltage transmission line, and road and rail access). Before construction, environmentally sensitive areas at the plant site and along the linear facility corridors would be identified so that impacts could be avoided or minimized. A storm water pollution prevention plan (SWPPP) would be developed for erosion prevention and sediment control during construction. The plan would include a description of construction activities, and address the following:

- The potential for discharge of sediment or pollutants from the site.
- The location and type of temporary and permanent erosion prevention and sediment control methods, along with procedures to be used to establish additional temporary controls as necessary for the site conditions during construction.
- The site map with existing and final grades, including dividing lines and direction of flow for all pre-construction and post-construction storm water runoff drainage areas located within the project limits. The site map would also include impervious surfaces and soil types.
- The location of areas not to be disturbed.
- The location of areas where construction would be phased to minimize duration of exposed soil.
- The identification of surface waters and wetlands, either on site or within 0.5 mi (0.8 km) of the site boundaries, which could be affected by storm water runoff from the construction site during or after construction.
- Methods to be used for final stabilization of all exposed soil areas.

Initial site preparation activities would include building access roads, clearing brush and trees, leveling and grading the site, removing unnecessary existing pipelines and other oil field infrastructure and connecting to utilities. Construction would involve the use of large earthmoving machines to clear and prepare the site. Trucks would bring fill material for roadways and the plant site, remove plant-site material and debris, and temporarily stockpile materials. Construction crews would spread gravel and road base for the temporary roads, material storage areas, and parking areas.

Worker vehicles, heavy construction vehicles, diesel generators, and other machinery and tools would generate emissions. Fugitive dust would result from excavation, soil storage, and earthwork. Construction-related emissions and noise could be minimized by running electricity to the site from the local utility provider to reduce reliance on diesel generators, and by wetting soil to reduce dust during earthwork.

Summit's TCEP schedule provides the following key dates for the plant construction:

- **January–March 2012:** Site mobilization and preparation
- **June 2012–July 2013:** Construction of main foundations
- **March 2013–October 2013:** Construction of steel
- **November 2012–March 2013:** Construction of transmission interconnection
- **March 2013–April 2014:** Construction of power island
- **April 2013–September 2014:** Construction of gasification island

Summit expects the TCEP to be operational in ***the fourth quarter of 2014***.

2.4.8.2 CONSTRUCTION MATERIALS

Construction materials would be delivered to the site by truck and rail. An access road to the plant site would be developed for construction traffic, and completion of the rail spur at the start of construction activities would allow some plant equipment to be delivered by rail. Approximately 20 trucks per day and approximately two trains per week would deliver material to the site.

During construction, temporary utilities would be extended to construction offices, worker trailers, laydown areas, and construction areas. The local electricity utility service would provide temporary construction power. Temporary generators could also be used until the temporary power system was completed. Construction crews would position temporary lighting for safety and security. Local telecommunication lines would be installed for telephone and electronic communications.

Water would be required during construction for various purposes, including personal consumption and sanitation, concrete formulation, preparation of other mixtures needed to construct the facilities, equipment washdown, general cleaning, dust suppression, and fire protection.

2.4.8.3 CONSTRUCTION WASTES

Construction of the TCEP would generate wastes that would be typical of the construction of any large industrial facility. Potential wastes would include soil and land clearing debris, metal scraps, electrical wiring and cable scraps, packaging materials, and office wastes.

Prior to conducting any land clearing or demolition, surveys for regulated substances (e.g., oil drums, asbestos-containing materials, and other regulated wastes) would be conducted. Any such materials found would be managed in accordance with applicable regulations.

Any potentially reusable materials would be retained for future use, and the recyclable materials would periodically be collected and transferred to local recycling facilities. If feasible, removed site vegetation would be salvaged or recycled for mulch. Other recyclable materials would include packaging material (e.g., wooden pallets and crates), support cradles used for shipping of large

vessels and heavy components (gasifiers, *gas turbine*, and steam turbine parts), and cardboard and plastic packaging. Metal scraps unsuitable for reuse would be sold to scrap dealers. Materials that could not be reused or recycled would be collected in dumpsters and periodically trucked off-site by a waste management contractor for disposal in a licensed landfill.

Construction water use would be greatest during the natural gas and CO₂ pipeline testing phase. Hydrotest water would be reused for subsequent pressure tests if practical. Spent hydrotest water would be tested to determine the presence of hazardous characteristics (e.g., traces of pipe oil or grease). If hazardous, the hydrotest water would be sent off-site for treatment; if nonhazardous, it would be routed to the *residual industrial waste water disposal* system, disposed of through a licensed contractor, or discharged (with consideration for erosion protection). Scrap and surplus materials and used lubricant oils would be recycled or reused to the maximum extent practical.

Summit would ultimately be responsible for the proper handling and disposal of construction wastes. However, construction management, contractors, and their workers would be responsible for minimizing the wastes produced by construction activities. They would also be expected to adhere to all project procedures and regulatory requirements for waste minimization and proper handling, storage, and disposal of hazardous and nonhazardous wastes. Each construction contractor would be required to include wastes management in their overall project health, safety, and environmental site plans. Typical construction waste management activities may include the following:

- Creation of dedicated areas and a system for waste management and segregation of incompatible wastes. Wastes segregation would occur at time of generation.
- A waste control plan detailing wastes collection and removal from the site. The plan would identify where wastes of different categories would be collected in separate stockpiles, bins, etc., and clear, appropriate signage would be required to identify the category of each collection stockpile, bin, etc.
- Storage of hazardous wastes, as defined by the applicable regulations, separately from nonhazardous wastes (and other, noncompatible hazardous wastes) in accordance with applicable regulations, project-specific requirements, and good waste management practices.
- Periodic inspections to verify that wastes are properly stored and covered to prevent accidental spills and to prevent wastes from being blown away.
- Use of appropriately labeled wastes disposal containers.
- Implementation of good housekeeping procedures. Work areas would be left in a clean and orderly condition at the end of each workday, with surplus materials and wastes transferred to the wastes management area.

2.4.8.4 CONSTRUCTION LABOR

Based on other coal-fueled power plant construction projects, Summit estimates that an average of approximately 650 construction workers would be employed throughout the project. However, during peak construction, the projected number of on-site workers could be as many as 1,500. Summit expects that most labor would be supplied through the local building trades. It is estimated that construction workers would work a 50-hour workweek, and that construction activity would normally occur during daylight hours, but would not always be restricted to these hours.

2.4.8.5 CONSTRUCTION SAFETY POLICIES AND PROGRAMS

Construction of the entire TCEP would involve the operation of heavy equipment and other job site hazards typical of heavy construction projects. The TCEP would be subject to U.S. Occupational Safety and Health Administration (OSHA) standards during construction (e.g., OSHA General Industry Standards [29 C.F.R. Part 1910] and the OSHA Construction Industry Standards [29 C.F.R. Part 1926]). During construction, risks would be minimized by the TCEP's adherence to procedures and policies required by OSHA. These standards establish practices, chemical and physical exposure limits, and equipment specifications to preserve worker health and safety. Construction permits and safety inspections would be employed to minimize the frequency of accidents and further ensure worker safety. Construction equipment would be required to meet all applicable safety design and inspection requirements, and personal protective equipment would be used when needed to meet regulatory and consensus standards.

These laws and regulations would form the basis of TCEP construction safety policies and programs. In addition, Summit would develop overall site- and project-specific environmental health and safety policies and programs for the TCEP. These would be included in all construction contracts, and construction contractors would be required to adhere to them.

TCEP construction management would develop a manual to include detailed procedures for use in its Occupational Safety and Health Program; to assure compliance with OSHA and EPA regulations; and to serve as a guide for providing a safe and healthy environment for workers, contractors, visitors, and the community. These procedures would include job procedures describing proper and safe manners of working in the TCEP (e.g., handling and storage of NH₃ would comply with 29 C.F.R. § 1910.111), appropriate personal protective equipment (in compliance with 29 C.F.R. § 1910.132), and appropriate hearing-protection devices.

The manual would be used as a reference and training source and would include accident reporting and investigation procedures, emergency-response procedures, toxic gas rescue-plan procedures, hazard communication program provisions, material safety data sheet accessibility, medical program requirements, and initial and refresher training requirements. In addition, supplemental provisions would be added to the TCEP's emergency action, risk management, and process safety management plans.

Emergency services during construction would be coordinated with the local fire departments, police departments, paramedics, and hospitals. A first-aid office would be located on site for minor first-aid incidents. Trained and certified health, safety, and environmental personnel would be on site to coordinate emergency response. All temporary facilities would have fire extinguishers, and fire protection would be provided in work areas where welding would be performed.

The natural gas and CO₂ pipeline facilities would be designed, constructed, tested, and operated in accordance with applicable requirements included in the Department of Transportation regulations in 49 C.F.R. Part 192, Transportation of Natural and Other Gas by Pipeline: Minimum Federal Safety Standards, and other applicable federal and state regulations, including OSHA requirements. These regulations provide for adequate protection of the public and workers and prevention of natural gas and other gas pipeline accidents and failures. Among other design standards, 49 C.F.R. Part 192 specifies minimum pipeline materials and qualifications, minimum design requirements, and requirements for protection from internal, external, and atmospheric corrosion.

2.4.9 Operation Plans

2.4.9.1 PLANT OPERATIONS

Following construction, Summit would begin initial startup, followed by demonstration testing and then operational testing. TCEP demonstration testing would include the following:

- Verification of coal feedstock amounts (per heat and material balances for specific cases)
- Verification of overall polygen plant 90 percent carbon capture
- Verification of CO₂ compression and meeting pipeline CO₂-quality specifications
- Plant performance and emissions testing (for compliance with permit limits and conditions)

Operational testing would occur in parallel with portions of the demonstration testing. Operational testing would focus on achieving reliable plant operation along with high thermal efficiency, low emissions, equipment performance improvement, and optimization of power generation and urea production. Operational testing would include the following:

- Plant reliability testing (to meet reliability goals and guarantees for individual gasification, urea production, and power generation systems as well as for the overall TCEP)
- Startup/shutdown testing (number and duration)
- Shakedown period (the shakedown period is expected to continue for three years, through late 2017)

The TCEP would operate for at least 30 years and possibly up to 50 years.

2.4.9.2 OPERATIONAL LABOR

The TCEP operational workforce would include a mix of plant operators, craft workers, managers, supervisors, engineers, and clerical workers. The TCEP would require skilled operations and maintenance personnel, with temporary construction or maintenance workers on site for periodic outages and additional work.

Workforce size would vary between the demonstration period and the period of commercial operation. Operations workforce would be assembled during the last 18 months of construction for training and to assist with startup of the facilities. The TCEP workforce would consist of approximately 150 full-time workers.

2.4.9.3 HEALTH AND SAFETY POLICIES AND PROGRAMS

TCEP design features and management programs would be established to address hazardous materials storage locations, emergency response procedures, worker training requirements, hazard recognition, fire control procedures, hazard communications training, personal protective equipment training, and reporting requirements. For accidental releases, significance criteria would be determined based on federal, state, and local guidelines, and on performance standards and thresholds adopted by responsible agencies.

Basic approaches to prevent spills to the environment would include comprehensive containment and worker safety programs. The comprehensive containment program would ensure the use of appropriate tanks and containers, as well as proper secondary containment using walls, dikes,

berms, curbs, etc. Worker safety programs would ensure that workers are aware of, and trained in, spill containment procedures and related health, safety, and environmental protection policies.

2.4.9.4 CLOSURE AND DECOMMISSIONING

As noted above, the planned life of the TCEP would be 30 years. However, if the TCEP is still economically viable, it could be operated up to 50 years. A closure plan would be developed at the time that the plant was to be permanently closed. A closure plan would also be developed should unforeseen circumstances require the polygen plant to be closed earlier than the planned 30-year period. The removal of the TCEP from service, or decommissioning, may range from “mothballing” to the removal of all equipment and facilities, depending on conditions at the time. The closure plan would be provided to state and local authorities as required.

2.5 Avoidance and Mitigation Measures

For all environmental resources, the mitigation of potential adverse impacts from project activities would be achieved through the implementation of controls generally required by permitting processes and other federal, state, or municipal regulations and ordinances. Table 2.8 outlines specific mitigation measures, including those required under federal, state, or local regulations, and permitting requirements that Summit would implement to reduce adverse environmental impacts in specific resource areas.

Table 2.8. TCEP Incorporated Mitigation Measures

Resource	Mitigation Measure
Air Quality and GHG Emissions	<p data-bbox="493 359 618 380"><u>Construction</u></p> <p data-bbox="529 394 1219 415">During construction, Summit would implement the following practices:</p> <ul data-bbox="578 432 1357 856" style="list-style-type: none"> • Using dust-abatement techniques such as wetting soils • Surfacing unpaved access roads with stone whenever reasonable • Covering construction materials and stockpiled soils to reduce fugitive dust • Minimizing disturbed areas • Watering land prior to disturbance (excavation, grading, backfilling, or compacting) • Revegetating disturbed areas as soon as possible after disturbance • Moistening soil before loading into dump trucks • Covering material in dump trucks before traveling on public roads • Minimizing the use of diesel or gasoline generators for operating construction equipment • Using modern, well-maintained diesel powered construction equipment <p data-bbox="493 873 594 894"><u>Operation</u></p> <p data-bbox="529 909 1411 961">The following process enhancements and improved work practices would be implemented to mitigate emissions:</p> <ul data-bbox="578 978 1419 1614" style="list-style-type: none"> • To reduce NO_x: Using diluent injection in the gas turbine in addition to selective catalytic reduction; incorporating good flare design in accordance with 40 C.F.R. § 60.18; limiting the hours of operation of the fire pump and emergency generators • To reduce CO and volatile organic compounds: Implementing good combustion practices in the gas turbine; incorporating good flare design; limiting the hours of operation of the fire pump and emergency generators • To reduce SO₂: Using clean syngas in the gas turbine; incorporating good flare design; limiting the hours of operation of the fire pump and emergency generators; using low-sulfur diesel in the fire pump and emergency generators • To reduce H₂SO₄ mist: Using clean syngas in the gas turbine • To reduce PM: Implementing good combustion practices in the gas turbine; incorporating high-efficiency drift eliminators in the wet cooling tower; incorporating good flare design; limiting the hours of operation of the fire pump and emergency generators; using low-sulfur diesel in the fire pump and emergency generators • To reduce CO₂: Capturing as CO₂ 90 percent of the carbon entering the plant with compression and pipeline transportation of the CO₂ for use in EOR; limiting use of the CO₂ bypass vent to 5 percent of the year • To reduce Hg: Using clean syngas in the gas turbine

Table 2.8. TCEP Incorporated Mitigation Measures

Resource	Mitigation Measure
Geology and Soils	<p data-bbox="493 354 618 375"><u>Construction</u></p> <p data-bbox="529 394 1370 499">Summit would develop and implement an approved SWPPP to reduce erosion, control sediment runoff, reduce storm water runoff, and promote ground water recharge. The SWPPP would be submitted to the TCEQ for approval prior to the initiation of any construction activities.</p> <p data-bbox="529 518 1349 569">Summit would stockpile and cover excavated topsoil until reuse, install wind and silt fences, and reseed disturbed areas.</p> <p data-bbox="493 585 591 606"><u>Operation</u></p> <p data-bbox="529 625 1273 646">Summit would continue to implement relevant parts of its approved SWPPP.</p> <p data-bbox="529 665 1403 709">Summit would develop and implement a SPCC plan covering TCEP operations, as required by TCEQ under the Clean Water Act (Public Law 92-500).</p>
Ground and Surface Water Resources	<p data-bbox="493 737 618 758"><u>Construction</u></p> <p data-bbox="529 774 1414 850">Summit would develop and implement an approved SWPPP for construction activities. The SWPPP would address the polygen plant site, laydown areas, and construction along linear facilities.</p> <p data-bbox="529 869 1321 890">Summit would implement dust suppression and sedimentation control measures.</p> <p data-bbox="529 909 1370 959">For construction of linear facilities, Summit would apply for appropriate permits for all stream and water crossings and would implement required mitigation measures.</p> <p data-bbox="493 976 591 997"><u>Operation</u></p> <p data-bbox="529 1016 1273 1037">Summit would continue to implement relevant parts of its approved SWPPP.</p> <p data-bbox="529 1056 1414 1106">Summit would develop and implement effective measures, in accordance with a SPCC plan, to mitigate potential impacts caused by the release of petroleum products.</p> <p data-bbox="529 1125 1382 1161">As needed, Summit would develop a water management plan to minimize potential impacts on water resources as a result of the TCEP's withdrawals of water for the plant.</p>
Floodplains	<p data-bbox="493 1188 618 1209"><u>Construction</u></p> <p data-bbox="529 1226 1414 1276">Summit would develop and implement an approved SWPPP to minimize sedimentation and the filling of any downstream floodplains.</p> <p data-bbox="493 1293 591 1314"><u>Operation</u></p> <p data-bbox="529 1333 1414 1381">Summit would develop and implement an approved SWPPP to minimize sedimentation and the filling of any downstream floodplains.</p>

Table 2.8. TCEP Incorporated Mitigation Measures

Resource	Mitigation Measure
Wetlands	<p><u>Construction</u></p> <p>Summit would develop and implement an approved SWPPP to minimize potential impacts on wetlands.</p> <p>Mitigation of wetland impacts would take place in the form of direct replacement or through the purchase of credits via an approved wetland bank under U.S. Army Corps of Engineers and TCEQ requirements and guidance. A Combined Wetland Permit Application, as applicable, would be submitted to applicable federal, state, and local regulatory entities and would include design details on any wetland replacement sites, wetland banks, and sources of wetland credits for the project. Mitigation requirements would be determined during the wetland-permitting phase of the project following the NEPA process and before construction activities begin.</p> <p><u>Operation</u></p> <p>Summit would continue to implement relevant parts of its approved SWPPP to minimize potential impacts on wetlands.</p> <p>Summit would develop and implement effective measures, in accordance with a SPCC plan, to reduce the risk of contamination of wetlands.</p> <p>Summit would use a mechanical crystallizer and filter press system, solar evaporation ponds, or deep well injection for disposal of waste water, which would eliminate any discharges of process water and cooling tower blowdown into any water bodies and would, therefore, eliminate water-quality impacts to wetlands.</p>
Biological Resources	<p><u>Construction</u></p> <p>Summit would develop and implement an approved SWPPP that would minimize potential impacts on wildlife using downstream water resources, wetlands, and floodplains.</p> <p>Summit would use dust suppression and sedimentation control measures.</p> <p>Summit would comply with the provisions of the federal Migratory Bird Treaty Act, which could include limiting land-clearing activities to periods outside of the nesting season.</p> <p>Summit would coordinate with the TPWD with regard to state-listed species and sensitive habitats listed in the TPWD Natural Diversity Database. Mitigation of impacts to state-listed species could incorporate a variety of options ranging from passive measures (e.g., construction timing outside critical breeding periods and permanent protection of known habitats elsewhere that contain the resource to be affected) or more aggressive measures (e.g., complete avoidance of impact).</p> <p><u>Operation</u></p> <p>Summit would continue to implement relevant parts of its approved SWPPP to help minimize impacts to certain biological resources.</p> <p>Summit would develop and implement effective measures, in accordance with an SPCC plan, to mitigate potential impacts caused by the release of petroleum products.</p> <p>Summit would ensure evaporative ponds are covered with netting to prevent wildlife access, if required by the State of Texas.</p>
Aesthetics	<p><u>Construction</u></p> <p>Summit would develop and implement a SWPPP to reduce erosion and minimize landscape scarring.</p> <p>Summit would employ dust-suppression techniques.</p> <p><u>Operation</u></p> <p>Summit would plan and install an outdoor lighting system that would minimize TCEP's nighttime, off-site illumination and glare.</p>

Table 2.8. TCEP Incorporated Mitigation Measures

Resource	Mitigation Measure
Cultural Resources	<p><u>Construction</u></p> <p>In accordance with Section 106 of the National Historic Preservation Act (Public Law 89-665), Summit has provided surveys and cultural resource assessments for the proposed polygen plant site and preliminary assessment recommendations for linear facilities to the Texas Historical Commission and other appropriate agencies for review and comment.</p> <p>With regard to the roads, rail lines, high-voltage transmission lines, and other linear facilities, archaeological surveys would only be conducted for corridors identified by state agencies as needing such surveys. Surveys would be completed if DOE issues a favorable Record of Decision.</p>
Traffic and Transportation	<p><u>Construction</u></p> <p>To prevent unnecessary traffic congestion and road hazards, Summit would coordinate with local authorities and employ safety measures, especially during the movement of oversized loads, construction equipment, and materials.</p> <p>Where traffic disruptions would be necessary, Summit would coordinate with local authorities and implement detour plans, warning signs, and traffic-diversion equipment to improve traffic flow and road safety.</p> <p><u>Operation</u></p> <p>Summit would make road improvements, where necessary, to minimize traffic congestion and road hazards. Improvements may include adding lanes for turning and acceleration.</p>
Safety and Health	<p><u>Construction and Operation</u></p> <p>Summit would comply with OSHA requirements as they apply to the project during construction and operation activities.</p>
Noise	<p><u>Construction</u></p> <p>Summit would equip steam piping with silencers to reduce noise levels during steam blows by up to 20–30 A-weighted decibels (dBa) at each receptor location.</p> <p><u>Operation</u></p> <p>Summit would equip silencers on the relief valves.</p> <p>Summit would perform a noise survey to ensure that operations are in compliance with applicable noise standards.</p> <p>Summit would locate and orient plant equipment to minimize sound emissions; provide buffer zones; enclose noise sources within buildings; install inlet air silencers for the gas turbine; and include silencers on plant vents and relief valves.</p>

2.6 DOE's No Action Alternative

Under the No Action Alternative, DOE would not share in the cost of the TCEP beyond the project definition phase; in other words, DOE would not share in the costs of detailed design, construction, or the three-year demonstration-phase testing and operations. In this case, some amount of the money withheld from partial funding for the TCEP may be applied to other current or future eligible projects that would meet the objectives of the CCPI program. In the absence of partial funding from DOE, Summit could still elect to construct and operate the TCEP if it could obtain private financing as well as the required permits from state and federal agencies; therefore, the DOE No Action Alternative could result in one of three potential scenarios:

- The TCEP would not be built.
- The TCEP would be built by Summit without benefit of partial DOE financial assistance.
- The TCEP would not be built by Summit and the 600-ac (243-ha) site could be sold for industrial, commercial, or residential development, the impacts of which would be dependent on the type of development pursued.

DOE assumes that if Summit were to proceed with development in the absence of partial funding, the project would include all the features, attributes, and impacts as described for the Proposed Action; however, without DOE participation, it is likely that the proposed project would be canceled. For the purposes of analysis in this EIS, the DOE No Action Alternative is assumed to be equivalent to a “no build” alternative, meaning that environmental conditions would remain in the status quo (no new construction, resource utilization, emissions, discharges, or wastes generated).

If the project were canceled, the proposed technologies of the TCEP (demonstration of commercial-scale IGCC integrated with carbon capture and geologic storage of CO₂ using EOR, and manufacture of urea from gasified coal) may not be implemented in the near term. Consequently, commercialization of the integrated technologies may be delayed or not occur because utilities and industries tend to use known and demonstrated technologies rather than new technologies. This “no build” scenario would not contribute to the CCPI program goals of accelerating the commercial readiness of advanced multi-pollutant emissions control; **combustion**, gasification, and efficiency-improvement technologies; and demonstrating advanced coal-based technologies that capture and sequester, or put to beneficial use, CO₂ emissions.

This page intentionally blank