

# Field Demonstration Study for Heat and Water Recovery at a Coal-Fired Power Plant

---

Russell Noble (PI)  
Southern Company Services



Max Bernau, David Morett  
Katherine Dombrowski  
AECOM



Scott Hume  
Andrew Maxson  
EPRI



2016 Crosscutting Research & Rare Earth Elements Portfolios Review  
Pittsburgh, April 20, 2016

DE-FE0024066

# Overview

---

- Project Objectives
- Tasks
- Coal industry interviews
- Identification of technologies
- Selection process and scoring
- Discussion of selected technologies
- Going forward



# Objectives

---


Advance the path toward a field demonstration of waste (low-grade) heat recovery/use technology (HRUT) for a coal-fired power by:

- Establishing relationships between coal power industry, technology providers, technology experts, and engineering firm
- Comparing cost and benefits of emerging technologies and of commercially available technologies
- Recommending technology(ies) for further analysis
- Developing costs for pilot test at a Southern Company facility
- Developing costs for a conceptual commercial unit

# Project Task Structure



# Heat Recovery Opportunities



# Coal Power Industry Interviews

---

## Interview topics

- Appetite for low-temp HRUTs
- Previous experience with HRUTs
- HRUT integration flexibility/requirements

## Interview group

- Eight U.S. coal power utilities
- Over 500 GW collectively
- Mostly base load or daily cycling operation

# Interview Results

---

- Little new build or retrofit planned for coal power in the U.S.
- Only one site uses HRUT (coal drying); all had implemented steam turbine upgrades
- New Source Review (NSR) is a major obstacle for any efficiency/output changes: “NSR is not insurmountable but is a legal and political risk”
- If the efficiency improvement is large or the payback is short, it will be considered
- Most sites do not have space to accommodate new processes
- Reducing the final flue gas temperature may impact plume dispersion
- No district heating opportunities identified; limited industrial possibilities
- Respondents generally not water constrained; reducing FGD or cooling water makeup could be of interest
- Regulations (e.g., 111d) could increase interest in HRUTs

# Candidate HRUTs

---

## Identified through:

- Conference proceedings
- Industry experts
- Internet searches & literature review
- Similar DOE awards

## Resulted in 40 technologies for consideration

- Ranged from commercial to conceptual

## Can be categorized into

- Bottoming cycles
- Heat exchangers (incl. condensing)
- Thermoelectric
- Water treatment technologies
- Other (e.g., fuel drying)



# Screening Process

---

## 40 technologies

- High level questionnaire
- Interviews with technology providers
- Eliminated those not feasible, leaving 24
  - Public sharing; uses flue gas;  $\leq 300\text{F}$ ; pilot in 2 yrs

## Remaining 24

- Detailed questionnaire
  - Organization, design, technology, environmental, costs
- 550MW reference plant for consistency
- Limited response

## Final 17 candidate technologies

- Scoring matrix applied

# Technology Vendors for Scoring

---

## Bottoming cycles

- Global Geothermal
- Ormat
- Turboden

## Heat exchangers

- ARVOS
- ConDex
- E-Tech
- Flucorrex
- Gas Technology Institute (GTI)
- Mitsubishi Heavy Industries (MHI)
- Wallstein

## Water treatment

- PAX Pure
- Porifera
- Sylvan Source International (SSI)
- Vacom

## Other

- Great River Energy (GRE)
  - DryFining process; coal drying
- Novus
- SSI
  - Heat feedwater

# Scoring Criteria and Weight

## Emphasis:

- Costs
- Technology
- Operation
- Design

Criteria	Weight %	Total %
<b>I. Organization Experience</b>	<b>10.0%</b>	<b>---</b>
A. Tech Experience	50.0%	5.0%
B. Organizational Experience	20.0%	2.0%
C. Size	30.0%	3.0%
<b>II. Design and Operation</b>	<b>25.0%</b>	<b>---</b>
A. Design	30.0%	---
1. Soundness of Design	50.0%	3.8%
2. Integration Complexity	50.0%	3.8%
B. Operation	70.0%	---
1. Response to Load Changes	35.0%	6.1%
2. Impact on Startup Times	35.0%	6.1%
3. Acceptable Flue Gas Composition	15.0%	2.6%
4. Pressure Drop	15.0%	2.6%
<b>III. Technology</b>	<b>30.0%</b>	<b>---</b>
A. Benefits	70.0%	---
1. Efficiency	40.0%	8.4%
2. Water Treatment	15.0%	3.2%
3. Water Use/Generation	15.0%	3.2%
4. Environmental	30.0%	6.3%
B. Operations, Maintenance, Availability, and Safety	30.0%	---
1. Operations	25.0%	2.3%
2. Maintenance	25.0%	2.3%
3. Availability	25.0%	2.3%
4. Safety	25.0%	2.3%
<b>IV. Potential for Future Improvements</b>	<b>2.5%</b>	<b>---</b>
A. Future Technology Improvements	50.0%	1.3%
B. Future Integration Improvements	50.0%	1.3%
<b>V. Costs</b>	<b>32.5%</b>	<b>---</b>
A. Commercial-Scale Plant Capital Cost	40.0%	13.0%
B. Cost-Benefit Analysis	40.0%	13.0%
C. Pilot Plant Capital Cost	20.0%	6.5%
<b>Total Score (Out of 100)</b>	<b>100.0%</b>	<b>100%</b>

# Detailed Evaluation

Component	Item	Value	Rating	Notes
A. General	1.1.1	...	...	...
	1.1.2	...	...	...
	1.1.3	...	...	...
	1.1.4	...	...	...
B. Specific	2.1.1	...	...	...
	2.1.2	...	...	...
	2.1.3	...	...	...
	2.1.4	...	...	...

Table 1: Component Evaluation Summary

Component	Item	Value	Rating	Notes
A. General	1.1.1	...	...	...
	1.1.2	...	...	...
	1.1.3	...	...	...
	1.1.4	...	...	...
B. Specific	2.1.1	...	...	...
	2.1.2	...	...	...
	2.1.3	...	...	...
	2.1.4	...	...	...

Table 2: Component Evaluation Summary

Component	Item	Value	Rating	Notes
A. General	1.1.1	...	...	...
	1.1.2	...	...	...
	1.1.3	...	...	...
	1.1.4	...	...	...
B. Specific	2.1.1	...	...	...
	2.1.2	...	...	...
	2.1.3	...	...	...
	2.1.4	...	...	...

Table 3: Component Evaluation Summary

Component	Item	Value	Rating	Notes
A. General	1.1.1	...	...	...
	1.1.2	...	...	...
	1.1.3	...	...	...
	1.1.4	...	...	...
B. Specific	2.1.1	...	...	...
	2.1.2	...	...	...
	2.1.3	...	...	...
	2.1.4	...	...	...

Table 4: Component Evaluation Summary

Component	Item	Value	Rating	Notes
A. General	1.1.1	...	...	...
	1.1.2	...	...	...
	1.1.3	...	...	...
	1.1.4	...	...	...
B. Specific	2.1.1	...	...	...
	2.1.2	...	...	...
	2.1.3	...	...	...
	2.1.4	...	...	...

Table 5: Component Evaluation Summary

Component	Item	Value	Rating	Notes
A. General	1.1.1	...	...	...
	1.1.2	...	...	...
	1.1.3	...	...	...
	1.1.4	...	...	...
B. Specific	2.1.1	...	...	...
	2.1.2	...	...	...
	2.1.3	...	...	...
	2.1.4	...	...	...

Table 6: Component Evaluation Summary

Component	Item	Value	Rating	Notes
A. General	1.1.1	...	...	...
	1.1.2	...	...	...
	1.1.3	...	...	...
	1.1.4	...	...	...
B. Specific	2.1.1	...	...	...
	2.1.2	...	...	...
	2.1.3	...	...	...
	2.1.4	...	...	...

Table 7: Component Evaluation Summary

Component	Item	Value	Rating	Notes
A. General	1.1.1	...	...	...
	1.1.2	...	...	...
	1.1.3	...	...	...
	1.1.4	...	...	...
B. Specific	2.1.1	...	...	...
	2.1.2	...	...	...
	2.1.3	...	...	...
	2.1.4	...	...	...

Table 8: Component Evaluation Summary

Component	Item	Value	Rating	Notes
A. General	1.1.1	...	...	...
	1.1.2	...	...	...
	1.1.3	...	...	...
	1.1.4	...	...	...
B. Specific	2.1.1	...	...	...
	2.1.2	...	...	...
	2.1.3	...	...	...
	2.1.4	...	...	...

Table 9: Component Evaluation Summary

Component	Item	Value	Rating	Notes
A. General	1.1.1	...	...	...
	1.1.2	...	...	...
	1.1.3	...	...	...
	1.1.4	...	...	...
B. Specific	2.1.1	...	...	...
	2.1.2	...	...	...
	2.1.3	...	...	...
	2.1.4	...	...	...

Table 10: Component Evaluation Summary

Component	Item	Value	Rating	Notes
A. General	1.1.1	...	...	...
	1.1.2	...	...	...
	1.1.3	...	...	...
	1.1.4	...	...	...
B. Specific	2.1.1	...	...	...
	2.1.2	...	...	...
	2.1.3	...	...	...
	2.1.4	...	...	...

Table 11: Component Evaluation Summary



# Rankings


Organization	Type	TRL
→ GTI	Heat Exchanger (Condensing Heat Recovery)	6
→ ARVOS	Heat Exchanger	9
ConDex	Heat Exchanger (Condensing Heat Recovery)	9
Sylvan Source International (SSI)	Heat Pipe	4
SSI	Water Treatment	5
Wallstein	Heat Exchanger	9
PAX Pure	Water Treatment	5
Flucorrex	Heat Exchanger	9
Mitsubishi Heavy Industries (MHI)	Heat Exchanger	9
Global Geothermal	Bottoming Cycle	8
Porifera	Water Treatment	4
Novus	Thermoelectric	5
Great River Energy (GRE)	Coal Drying	8
Turboden	Bottoming Cycle	8
Ormat	Bottoming Cycle	8
e-Tech	Heat Exchanger (Condensing Heat Recovery)	7
Vacom	Water Treatment	8

# Selected Technology: GTI

---

## Transport Membrane Condenser

- Uses a nano-porous ceramic membrane to capture waste heat and water vapor downstream of the wet FGD
- Previously demonstrated at a coal plant at ~500 scfm (0.2 MWe) scale
- Recovered heat and water can be used as boiler feedwater
- Some increase in net plant efficiency depending on coal moisture content and ambient temperatures




# Selected Technology: GTI

Water is captured via capillary condensation

- Capillary condensation can occur at 50-80% of the saturation vapor pressure
- Significant portion of the thermal energy as latent heat
- Captured water is pure enough to use as boiler feed water

Modules also act as heat exchangers capturing sensible heat




Sulfur resistance of tubes up to 300 ppm



# Commercial & Pilot Conceptual Designs: GTI

## Commercial (550MW):

- Early stages of development
- Cost (high) reflects uncertainty
- Integration into FGD vessel – lower \$\$
- Thermal heat recovery ~ 16 MW<sub>th</sub>
- Minimal plant output increase ~ 1 MW
- Water recovery of ~100 gpm






# Commercial & Pilot Conceptual Designs: GTI

## Pilot


- 2 MW slipstream basis
- Potentially located at SoCo Water Research Center
- Skid cost: approximately \$1M
- Tie-ins, foundations and operation not included



# Selected Technology: ARVOS

## ARVOS: Air Heater Improvements

- Extends and modifies heat transfer surface further decreasing flue gas outlet T
- Sulfuric acid condensation mitigated via SBS™ (sodium-based solution) injection upstream of the air heater
- Increased combustion air temperature improves boiler efficiency by 1-3%
- Decreased flue gas outlet temperature reduces water consumption in wet FGD
- Can be implemented easily as air heater is already present



# Commercial & Pilot Conceptual Designs: ARVOS

## Commercial only; no need for pilot

- 550 MW reference - retrofit
- Full air pre heater rotor replacement
- New SBS system
- Total: ~\$19M
- At least one system in service



# What's Next

---

- Final report in preparation
  - Details of evaluation
  - Pilot recommendation & cost
- Funding for pilot?
- Some general takeaways
  - Low grade heat is difficult to recover/use
  - Steam cycle integration is not optimal
  - Space requirements are a barrier
  - Little funding for coal plant upgrades
  - NSR threat

# QUESTIONS?

---

