


# Update on the Techno-Economic Viability of AUSC Systems

Travis Shultz


Energy Process and Analysis Team

Systems Engineering & Analysis Directorate



# Outline

- Objectives
- PC (steam Rankine cycle) Plants
  - Evaluation Basis
  - Case Matrix
  - Process Flow Diagram
  - Results
  - Summary
- sCO<sub>2</sub> (recompression Brayton cycle) Plants
  - Overview
  - Evaluation Basis
  - Case Matrix
  - Process Flow Diagram
  - Results
  - Summary
- Cost and Efficiency Summary



Conventional Boiler



Downdraft Inverted Tower Boiler\*

# Objectives



- **Conduct assessments of advanced material-enabled coal-fueled power plants**
  - Advanced ultrasupercritical (AUSC) Rankine-cycle-based pulverized coal (PC) plants
  - Supercritical carbon dioxide (sCO<sub>2</sub>) oxy-circulating fluidized bed (CFB) plants
- **Thermodynamic and economic analyses**
  - Analyses follow NETL Quality Guidelines for Energy Systems Studies (QGESS)
  - Cost estimates developed at same detail level as NETL's Cost and Performance Baseline for Fossil Energy Plants report series; in particular, Volume 1, Bituminous Coal and Natural Gas to Electricity (the “Bituminous Baseline”)
  - Bituminous Coal (Illinois #6), generic Midwestern location, ISO ambient conditions
  - Estimated emissions of Hg, PM, NO<sub>x</sub>, and SO<sub>2</sub> are all at or below the applicable regulatory limits at the time of preparation for all cases
  - 2011 \$
  - 85% capacity factor
  - CCS cases include transport and storage (T&S) in a saline formation
  - Incorporated results from the literature and in consultation with developers for advanced technologies

# Evaluation Basis – PC Plants

## Thermodynamic Performance



- **ASPEN Plus models**
  - Based on NETL Bituminous Baseline supercritical PC (SC PC) cases B12A (no CCS) and B12B (with CCS)
  - NETL supercritical steam conditions - 3500 psig/1100°F/1100°F
- **550MW net scale**
- **Reliant upon a notional downdraft inverted tower boiler (B&W)**
- **AUSC conditions for temperature/pressure**
  - T - HP: 1350°F, RH: 1400°F
  - P - HP: 3500, 4250, 5000 psig

# Evaluation Basis – PC Plants



## Economics

- **Scaling from Bituminous Baseline SC PC cases B12A and B12B for commercial and post-combustion capture technology sections**
- **Components requiring advanced materials and/or novel designs**
  - Notional downdraft inverted tower boiler
    - Information/discussions with B&W
    - Previous NETL study
  - Main and reheat steam leads
    - Use of aforementioned boiler reduces lead lengths from ~450 ft found in conventional boiler designs to ~160 ft
    - Assumed \$40/lb for Inconel 740H pipe
  - Steam turbine generator (STG) and accessories
    - AUSC Consortium data (EPRI/GE)

# Case Matrix – PC Plants




Case	Unit Cycle	Steam Cycle, psig/°F/°F	Boiler Technology	Oxidant	Sulfur Removal/ Recovery	PM Control	NOx Control	CO <sub>2</sub> Separation <sup>A</sup>
Case 1	PC	3500/1350/1400	Conceptual Inverted Tower	Air	Wet FGD/ Gypsum	Baghouse	LNB w/OFA and SCR	N/A
Case 2	PC	3500/1350/1400	Conceptual Inverted Tower	Air	Wet FGD/ Gypsum	Baghouse	LNB w/OFA and SCR	Cansolv
Case 3	PC	4250/1350/1400	Conceptual Inverted Tower	Air	Wet FGD/ Gypsum	Baghouse	LNB w/OFA and SCR	N/A
Case 4	PC	4250/1350/1400	Conceptual Inverted Tower	Air	Wet FGD/ Gypsum	Baghouse	LNB w/OFA and SCR	Cansolv
Case 5	PC	5000/1350/1400	Conceptual Inverted Tower	Air	Wet FGD/ Gypsum	Baghouse	LNB and SCR	N/A
Case 6	PC	5000/1350/1400	Conceptual Inverted Tower	Air	Wet FGD/ Gypsum	Baghouse	LNB w/OFA and SCR	Cansolv

<sup>A</sup>All capture cases have a nominal 90 percent (90%) removal rate based on the total feedstock minus unburned carbon in ash. The rate of CO<sub>2</sub> capture from the flue gas in the Shell Cansolv systems varies. An explanation for the difference is provided in Report Section 2.3.2. All cases sequester the CO<sub>2</sub> offsite.

# Block Flow Diagram – PC Plants

## Study Cases 2, 4, and 6 (w/ CCS)



Note: Block Flow Diagram is not intended to represent a complete material balance. Only major process streams and equipment are shown.

Source: NETL

# Results – PC Plants

## Thermodynamic Performance and Emissions




Case Name	Pulverized Coal Boiler							
	PC Supercritical		PC A-USC					
	B12A	B12B	Case 1	Case 2	Case 3	Case 4	Case 5	Case 6
<b>PERFORMANCE</b>								
Gross Power Output (MWe)	580	642	578	635	578	634	578	633
Auxiliary Power Requirement (MWe)	30	91	27	85	27	84	27	84
Net Power Output (MWe)	550	550	550	550	550	550	550	550
Coal Flow rate (lb/hr)	395,053	495,578	368,475	463,058	366,459	458,873	364,825	456,109
HHV Thermal Input (kW <sub>t</sub> )	1,350,672	1,694,366	1,259,804	1,583,179	1,252,911	1,568,872	1,247,323	1,559,420
<b>Net Plant HHV Efficiency (%)</b>	<b>40.7%</b>	<b>32.5%</b>	<b>43.7%</b>	<b>34.7%</b>	<b>43.9%</b>	<b>35.0%</b>	<b>44.1%</b>	<b>35.2%</b>
Net Plant HHV Heat Rate (Btu/kWh)	8,379	10,508	7,814	9,826	7,769	9,741	7,732	9,683
Raw Water Withdrawal, gpm	5,105	7,882	4,508	7,124	4,461	7,025	4,422	6,960
Process Water Discharge, gpm	1,059	1,813	930	1,638	919	1,615	911	1,600
Raw Water Consumption, gpm	4,045	6,069	3,578	5,486	3,541	5,410	3,511	5,360
CO <sub>2</sub> Capture Rate (%)	0%	90%	0%	90%	0%	90%	0%	90%
CO <sub>2</sub> Emissions (lb/MMBtu)	204	20	204	20	204	20	204	20
<b>CO<sub>2</sub> Emissions (lb/MWh-gross)</b>	<b>1,618</b>	<b>183</b>	<b>1,515</b>	<b>173</b>	<b>1,506</b>	<b>172</b>	<b>1,500</b>	<b>171</b>
CO <sub>2</sub> Emissions (lb/MWh-net)	1,705	214	1,590	200	1,581	198	1,574	197

Note: The average annual CO<sub>2</sub> emissions limit for new coal plants under Section 111(b) of the Clean Air Act is 1,400 lb CO<sub>2</sub>/MWh-gross. To accommodate start-ups, shut-downs, and part-load operation, the design emissions level will have to be some amount less than this limit.



# Results – PC Plants


## Efficiency



Source: NETL

# Results – PC Plants


## CO<sub>2</sub> Emissions



Source: NETL

# Results – PC Plants

## Raw Water Withdrawal and Consumption



Source: NETL

# Results – PC Plants




## Economics

Case Name	PC Supercritical		PC A-USC					
	B12A	B12B	Case 1	Case 2	Case 3	Case 4	Case 5	Case 6
<b>COST</b>								
<b>Total Plant Cost (2011\$/kW)</b>	2,026	3,524	1,986	3,447	1,977	3,429	1,972	3,417
Bare Erected Cost	1,646	2,716	1,614	2,660	1,607	2,646	1,603	2,636
Home Office Expenses	165	263	161	258	161	256	160	256
Project Contingency	216	430	210	419	209	417	209	416
Process Contingency	0	115	0	111	0	110	0	110
Total Overnight Cost (2011\$MM)	1,379	2,384	1,350	2,329	1,345	2,316	1,341	2,308
<b>Total Overnight Cost (2011\$/kW)</b>	<b>2,507</b>	<b>4,333</b>	<b>2,455</b>	<b>4,236</b>	<b>2,444</b>	<b>4,214</b>	<b>2,437</b>	<b>4,199</b>
Owner's Costs	480	809	469	789	467	785	465	782
Total As-Spent Cost (2011\$/kW)	2,842	4,940	2,784	4,829	2,772	4,804	2,764	4,787
<b>COE (\$/MWh) (excluding T&amp;S)</b>	<b>82.3</b>	<b>133.2</b>	<b>79.2</b>	<b>124.1</b>	<b>78.9</b>	<b>123.3</b>	<b>78.6</b>	<b>122.8</b>
Capital Costs	39.0	72.2	38.2	66.0	38.1	65.6	38.0	65.4
Fixed Costs	9.6	15.4	9.5	15.2	9.5	15.2	9.4	15.1
Variable Costs	9.1	14.7	8.6	14.0	8.5	13.9	8.5	13.9
Fuel Costs	24.6	30.9	23.0	28.9	22.8	28.6	22.7	28.4
<b>COE (\$/MWh) (including T&amp;S)</b>	<b>82.3</b>	<b>142.8</b>	<b>79.2</b>	<b>133.1</b>	<b>78.9</b>	<b>132.2</b>	<b>78.6</b>	<b>131.7</b>
CO <sub>2</sub> T&S Costs	0.0	9.6	0.0	9.0	0.0	8.9	0.0	8.9
CO <sub>2</sub> Captured Cost (excluding T&S), \$/tonne	N/A	58.2	N/A	51.1	N/A	50.7	N/A	50.4
CO <sub>2</sub> Avoided Cost (including T&S), \$/tonne	N/A	89.4	N/A	74.3	N/A	73.0	N/A	72.2

# Results – PC Plants


## Cost of Electricity (COE)



Source: NETL

# Results – PC Plants

## Sensitivity – Capacity Factor




CO<sub>2</sub> capture cases include T&S

Source: NETL

# Results – PC Plants

## Sensitivity – Coal Price




CO<sub>2</sub> capture cases include T&S

Source: NETL

# Results – PC Plants

## Sensitivity – Boiler Cost (w/o CCS)




Source: NETL



# Results – PC Plants

## Sensitivity – Boiler Cost (w/ CCS)



Source: NETL

# Results – PC Plants





## Summary

- **PC plants without CCS gain 3.0% points; with CCS, 2.2% points**
  - SC (3500 psig/1100°F/1100°F) to AUSC (3500 psig/1350°F/1400°F)
  - Small gains with incremental increases in main steam pressure
- **PC plants without CCS show a 3.8% decrease in COE; with CCS, 6.8%**
  - SC (3500 psig/1100°F/1100°F) to AUSC (3500 psig/1350°F/1400°F)
  - Small decreases with incremental increases in main steam pressure
- **Primary uncertainty is downdraft inverted tower boiler**
  - Cost estimation, particularly as configured for AUSC steam conditions
- **Multiple approaches taken to estimate cost of steam leads**
  - Very small COE effect

# Overview – Indirect sCO<sub>2</sub> Power Cycles

- **Potential higher efficiency relative to traditional fossil energy cycles**
  - Recuperation of high-quality heat from the turbine exhaust
  - sCO<sub>2</sub> has beneficial thermodynamic properties (high density and specific heat) near the critical point
- **Reduced turbomachinery equipment sizes due to higher working fluid density results in reduced capital costs**
- **sCO<sub>2</sub> is generally stable, abundant, inexpensive, non-flammable, and less corrosive than H<sub>2</sub>O**



Source: Dostal, 2004<sup>1</sup>

# Evaluation Basis – sCO<sub>2</sub> Plants

## Thermodynamic Performance



- **ASPEN Plus models**
  - Based on NETL atmospheric pressure oxy-CFB with a supercritical Rankine cycle (B22F)
  - Evaluated an atmospheric pressure oxy-CFB with an AUSC Rankine cycle (B24F)
  - Series of cases with Rankine cycle replaced with an indirect sCO<sub>2</sub> cycle (closed recompression Brayton cycle)
- **AUSC conditions for Rankine cycle temperature/pressure**
  - T - HP: 1400 °F, RH: 1400 °F
  - P - HP: 3500 psig
- **AUSC conditions for sCO<sub>2</sub> temperature/pressure**
  - T - HP: 1400 °F, RH: 1400 °F
  - P - HP: 5000 psig
- **sCO<sub>2</sub> analyses included base, reheat, intercooling, and reheat + intercooling cases**

# Evaluation Basis – sCO<sub>2</sub> Plants




## Economics

- **Scaling from atmospheric oxy-CFB with a SC Rankine cycle for commercial technology sections, and previously-presented AUSC PC study**
- **SCO<sub>2</sub> components requiring advanced materials and/or novel designs**
  - CFB
    - Modification and scaling of previous NETL study
  - Main and reheat sCO<sub>2</sub> leads
    - ~150 ft in length, Assumed \$40/lb for Inconel 740H pipe
  - sCO<sub>2</sub> turbine
    - Le Moullec paper, with adjustments
  - High- and low-temperature sCO<sub>2</sub> recuperators
    - Aerojet Rocketdyne, with adjustments
  - Main and bypass sCO<sub>2</sub> compressors
    - MAN Turbo

# Block Flow Diagram – sCO<sub>2</sub> Plants

## With Reheat and Intercooling



Note: Block Flow Diagram is not intended to represent a complete process. Only major process streams and equipment are shown.

Source: NETL

# Case Matrix – sCO<sub>2</sub> Plants

Case (°F)	Reheat	Inter-cooling	Boiler Technology	Cycle Conditions (psig/°F/°F)	Sulfur Capture / Removal*	PM control	CO <sub>2</sub> Separation / Gas Cleanup
Base (1150)	No	No	Oxy-CFB	5000/1150	Limestone injection / ash	Baghouse	Auto Refrigerated CPU
Reheat (1150)	Yes	No	Oxy-CFB	5000/1150/1150	Limestone injection / ash	Baghouse	Auto Refrigerated CPU
InterCooling (1150)	No	Yes	Oxy-CFB	5000/1150	Limestone injection / ash	Baghouse	Auto Refrigerated CPU
Reheat/InterCooling (1150)	Yes	Yes	Oxy-CFB	5000/1150/1150	Limestone injection / ash	Baghouse	Auto Refrigerated CPU
Base (1400)	No	No	Oxy-CFB	5000/1400	Limestone injection / ash	Baghouse	Auto Refrigerated CPU
Reheat (1400)	Yes	No	Oxy-CFB	5000/1400/1400	Limestone injection / ash	Baghouse	Auto Refrigerated CPU
InterCooling (1400)	No	Yes	Oxy-CFB	5000/1400	Limestone injection / ash	Baghouse	Auto Refrigerated CPU
Reheat/InterCooling) (1400)	Yes	Yes	Oxy-CFB	5000/1400/1400	Limestone injection / ash	Baghouse	Auto Refrigerated CPU

\* Sulfur removal is primarily in the cyclone bottom ash and baghouse fly ash, Emissions (lb/MWhgross) were set at SO<sub>x</sub> =1.0, NO<sub>x</sub> =0.7, PM=0.09, and Hg = 0.000003



# Results – sCO<sub>2</sub> Plants




## Thermodynamic Performance and Emissions

Parameter	Reference SC Rankine (B22F)	Reference AUSC Rankine (B24F)	sCO <sub>2</sub> Rht/IC (T=1150 °F)	sCO <sub>2</sub> Rht/IC (T=1400 °F)
CFB Coal Flow Rate (lb/hr)	483,994	441,293	456,032	408,616
Limestone Flow Rate (lb/hr)	116,535	106,123	109,898	98,472
Oxygen Flow Rate (lb/hr)	1,034,064	942,849	975,627	874,198
sCO <sub>2</sub> Flow Rate (lb/hr)	---	---	37,234,900	29,863,300
Steam to HP Turbine (lb/hr)	4,403,776	3,375,905	---	---
Net Plant Efficiency (HHV %)	33.23	36.45	35.27	39.37
HHV Heat Rate (Btu/kWh)	10,267	9,876	9,673	8,668
sCO <sub>2</sub> Power Cycle Efficiency (%)	---	---	49.49	53.89
sCO <sub>2</sub> Cycle Heat Rate (Btu/kWh)	---	---	6,894	6,332
Steam Power Cycle Efficiency (%)	48.27	51.8	---	---
Steam Cycle Heat Rate (Btu/kWh)	7069	6,582	---	---
Coal Thermal Input (MMBtu/hr)	5,646	5,148	5,320	4,767
Power Cycle Thermal Input (MMBtu/hr)	5,109	4,653	4,932	4,417
Fractional Thermal Input to Power Cycle	0.905	0.904	0.927	0.927
Raw Water Withdrawal (gpm)	8,466	7,355	6,816	5,676
Raw Water Discharge (gpm)	1,994	1,738	1,826	1,529
Raw Water Consumption (gpm)	6,472	5,617	4,990	4,147
<b>Power Summary</b>				
Steam Turbine Power Output	722,836	707,328	0	0
sCO <sub>2</sub> Cycle Power Output	0	0	715,305	697,587
Gross Power Output	722,836	707,328	715,305	697,587
Total Auxiliary Power Load	172,851	157,308	165,308	147,597
Net Power Output	549,985	550,020	549,997	549,990
CO <sub>2</sub> Emissions (lb/MWh-gross)	119	111	53	47
CO <sub>2</sub> Emissions (lb/MWh-net)	156	142	69	60




# Results – sCO<sub>2</sub> Plants - Efficiency



# Results – sCO<sub>2</sub> Plants



## Raw Water: Withdrawal, Discharge and Consumption



Cycle	Reference SC Rankine	Reference AUSC Rankine	sCO <sub>2</sub> Rht/IC (T=1150 °F)	sCO <sub>2</sub> Rht/IC (T=1400 °F)
gpm				
Raw Water Withdrawal	8,466	7,355	6,816	5,676
Raw Water Discharge	1,994	1,738	1,826	1,529
Raw Water Consumption	6,472	5,617	4,990	4,147
Net Power (MW)	550	550	550	550
gpm/MWnet				
Raw Water Withdrawal	15.4	13.4	12.4	10.3
Raw Water Discharge	3.6	3.2	3.3	2.8
Raw Water Consumption	11.8	10.2	9.1	7.5

# Results – sCO<sub>2</sub> Plants

## Economics




Cycle	OXY-CFB Rankine		OXY-CFB sCO <sub>2</sub> (Brayton)	
Case Name	B22F	B24F	sCO <sub>2</sub> Reheat/IC (T=1150 °F)	sCO <sub>2</sub> Reheat/IC (T=1400 °F)
<b>COST</b>				
Total Plant Cost (2011\$/kW)	3,337	3,363	3800	3601
Bare Erected Cost	2,666	2,695	3017	2864
Home Office Expenses	245	247	282	268
Project Contingency	371	369	443	417
Process Contingency	55	51	58	52
Total Overnight Cost (2011\$MM)	2,255	2,270	2561.35	2561
Total Overnight Cost (2011\$/kW)	4,101	4,127	4657	4418
Owner's Costs	501	505		
Total As-Spent Cost (2011\$/kW)	4,675	4,705	5309	5036
COE (\$/MWh) (excluding T&S)	127.2	124.2	139.3	129.2
Capital Costs	68.3	68.7	77.6	73.6
Fixed Costs	14.8	14.9	16.6	15.8
Variable Costs	13.8	12.9	14.8	13.2
Fuel Costs	30.2	27.5	30.5	26.7
COE (\$/MWh) (including T&S)	135.8	132.1	148.5	137.3
CO <sub>2</sub> T&S Costs	8.7	7.9	9.1	8.0

Source: NETL


# Results – sCO<sub>2</sub> Plants

## Cost of Electricity (with T&S)



# Results – sCO<sub>2</sub> Plants

## Sensitivity – TPC for RhtIC760 Case



Case B24F - Atm. Oxy-CFB  
w/ AUSC Rankine Cycle

- Considerable uncertainty with capital cost estimation for certain sCO<sub>2</sub> plant components.
- Blue bars represent the estimated TPC for major plant components.
- A TPC reduction of ~\$40MM achieves COE parity with a comparable atm. Oxy-CFB AUSC Rankine plant.

COE excludes T&S

Source: NETL

# Results – sCO<sub>2</sub> Plants




## Summary

- **The AUSC sCO<sub>2</sub> cycle atm. Oxy-CFB plant with reheat and intercooling provides a 2.9% point improvement over the comparable AUSC Rankine cycle atm. Oxy-CFB plant**
  - 39.4% HHV vs. 36.5% HHV
- **However, COE is equivalent between these cases**
  - \$124/MWh (Rankine) vs. \$126/MWh (sCO<sub>2</sub>)
  - Higher sCO<sub>2</sub> COE primarily due to 8-12x sCO<sub>2</sub> mass flow relative to steam (primary and reheat leads)
  - High- and low-temperature recuperators, and multi-stage sCO<sub>2</sub> compressors (vs. feedwater pumps in a Rankine cycle) also contribute
- **Alternative sCO<sub>2</sub> cycle configurations are under development**
- **Large uncertainty in commercial-scale sCO<sub>2</sub> component costs warrant further study**

# Cost and Efficiency Summary

Steam Rankine and Indirect sCO<sub>2</sub> cycles with CCS

- **Reference: Supercritical Oxy-combustion CFB with Auto-refrigerated CPU (Case B22F)**
  - \$0/tonne CO<sub>2</sub> Revenue
  - 550 MWe
- COE reductions are relative to an air-fired, supercritical PC coal plant with CCS (Case B12B)
- Ongoing work assessing condensing CO<sub>2</sub> cycles





Questions?

[Travis.Shultz@NETL.DOE.GOV](mailto:Travis.Shultz@NETL.DOE.GOV)

304.285.1370



# Authors

NETL: Walther Shelton, Nathan Weiland, Travis Shultz,  
Deloitte Consulting: Eric Lewis , Dale Keairns  
Key Logic: Mark Woods, Richard Newby, Charles White  
David Gray, John Plunkett