

JOC-NETL PROJECT UPDATE

(to be supplemented as the project proceeds)

Reporting Period Start Date: 6/1/10

Reporting Period End Date: 7/31/10

Principal Authors:

Mark Schoenfield (Jupiter Oxygen Corporation) and Tom Ochs (NETL)

Date Report Issued: August 2, 2010

DOE AWARD Number: DE-FC26-06NT42811

Name and Address of Submitting Organizations:

Jupiter Oxygen Corporation

Suite 200

4825 N. Scott Street, Chicago, Illinois

National Energy Technology Laboratory

1450 Queen Avenue SW, Albany, Oregon

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

JOC-NETL PROJECT UPDATE

The Jupiter Oxygen and NETL ORD project teams find that the testing to date indicates as follows for the combined Jupiter Oxygen high flame temperature oxy-combustion technology and NETL IPR pollution control and carbon capture system for coal fired power plants:

1. These technologies provide a means to retrofit existing power plants and build new ones.
2. Boiler system fuel savings can be expected from high flame temperature oxy-combustion technology, resulting in cost savings for fuel as well as CO₂ transport and sequestration since less CO₂ is produced.
3. 95-100% carbon capture is feasible, with the range depending on whether the IPR has an alternative source of power when a power plant is being started up or shutdown, except for any loss to reach high purity levels.
4. Pending CO₂ transport and sequestration infrastructure development, these combined technologies allow fully carbon capture ready power plants to exist today which can be completely compliant with clean air NO_x, SO_x, mercury and particulate regulatory requirements.
5. Water recovery will exceed boiler feedwater requirements.
6. Heat integration from cryogenic oxygen plant and IPR compressors can lower fuel costs as well.

7. While high flame temperature oxy-combustion burner and IPR scale-up and optimization will continue during the current project year, these technologies are ready for commencement of a demonstration pilot project. The 15MWth [5 MWe equivalent] boiler retrofit completed for this JOC-NETL project has demonstrated that high flame temperature oxy-combustion can make steam in a conventional, older boiler without changing boiler interior materials, and with an IPR slipstream system operating to control pollution and capture carbon as described above. The IPR system uses commercialized equipment, and scale-up also will use commercialized equipment.
8. With these technologies, total parasitic power requirements for both oxygen production and carbon capture currently are in the range of 20%, far below earlier DOE projections because of system improvements using commercialized equipment.
9. Preliminary economic projections indicate that these technologies can generally allow new and retrofitted coal fired power plants to achieve 95-100% carbon capture with zero amortized net incremental economic cost if there is net CO₂ revenue of approximately \$20 per ton and a COE increase of not more than 35%. The minimum net CO₂ revenue and COE increase which will be necessary to achieve zero amortized net incremental economic cost are unclear.