

Expanding the Inventory of Emissions in the NETL Power Plant Flexible Model

Matt Jamieson – KeyLogic Systems, Inc.

Greg Cooney - KeyLogic Systems, Inc.

Timothy Skone – National Energy Technology
Laboratory

ISSST 2018 – Buffalo, NY

June 27, 2018



Disclaimer and Attribution



DISCLAIMER

"This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof."

Attribution

KeyLogic Systems, Inc.'s contributions to this work were funded by the National Energy Technology Laboratory under the Mission Execution and Strategic Analysis contract (DE-FE0025912) for support services.

About the Power Plant Flexible Model

(PPFM)



- Spreadsheet model for
 - pulverized coal
 - circulating fluidized bed power plants
 - natural gas combined cycle
 - solid oxide fuel cell power plants
- Reduced-order model allowing changing of coal characteristics and pollution control equipment configuration
- Emissions limited to those available in NETL techno-economic assessments
 - CO₂, SO₂, Hg, NO_x, Particulate


<https://netl.doe.gov/research/energy-analysis/search-publications/vuedetails?id=785>

A	B	C	D	E	F	G
Feedstock (Coal/Biomass only)				Air separation unit (oxy-firing) (Coal/Biomass only)		
Bituminous Coal	100%	Total: 100%		Status	0	0 - Off, 1 - On
Sub-bituminous Coal	0%			Plant		
Lignite Coal	0%			Plant Type	2	1 - Subcritical Pulverized Coal (PC) 2 - Supercritical Pulverized Coal (SCPC) 3 - Ultra-supercritical Pulverized Coal (USPC) 4 - Circulating Fluidized Bed (CFB) 5 - Natural Gas Combined Cycle (NGCC) 6 - Solid Oxide Fuel Cell (SOFC)
Hybrid Poplar	0%			SOFC Scenario	1-6	Conventional gasifier w/ natural gas injection
Switchgrass	0%			Thermal input (HHV)	1351	MWt
Corn Stover	0%				4,609	MMbtu/hr, 1,350,672 kWt
Forest Residue	0%			SOx controls (Coal only)	1	
Custom Coal	0%			Wet FGD	1	0 - Off, 1 - On
Torrefied biomass	0	0 - Off, 1 - On	SOx removal efficiency	98%	molar percent, Default 98%	
Biomass target moisture level	0%	Range: 0 to 00%		0		
NOx controls				Dry FGD	0	0 - Off, 1 - On
Selective Catalytic Reduction	1	0 - Off, 1 - On		SOx removal efficiency	0%	molar percent, Default 93%
SCR efficiency	83%	Default: 86%			0	
Fly ash and particulate matter controls (Coal/Biomass only)				In-bed limestone injection	0	0 - Off, 1 - On (to be used only with CFB)
Fabric Filter	1	0 - Off, 1 - On		SOx removal efficiency	0%	molar percent, Default: 94%
Ash removal efficiency	99.8%	Default: 99.8%		Plant cooling		
Electrostatic Precipitator	0	0 - Off, 1 - On		Wet cooling tower/Hybrid Condenser	1	0 - Off, 1 - On
Ash removal efficiency	0.0%	Default: 99%			0%	Percentage Air-Cooled Condenser (Default)
Carbon dioxide capture				Once-through cooling	0	0 - Off, 1 - On
Status	0	0 - Off, 1 - On		Allowable temperature increase	20	°F, default 60°F
If ASU is off, CO2 capture is amine-based.				Combined Heat and Power (coal and biomass only)	0	0 - Off, 1 - On, 0 MW sent to CHP
Capture bypass	0%	Default: 0%			0.0%	Percent of steam, N/A
Mercury control (Coal/Biomass only)				Power Plant Capacity Factor	0.85	Capacity factor used for yearly operating
Filter/ESP co-benefit cap. Rate	90.2%	Default: 70.2%		Municipal Water Usage	50%	% water withdrawn from municipal source
Wet FGD co-benefit cap. Rate	70.2%	Default: 70.2%		Ground Water Percent	100%	% of remaining water withdrawn from ground
Activated Carbon Injection	1	Default: 0				

Power Plant Flexible Model Uses


Co-fire biomass vs. CO₂ emissions and net plant power

- PPFM intended as a tool to quickly assess changes in equipment or feedstock
- Example: Can relatively quickly assess impacts of co-firing varying amounts of biomass while maintaining sulfur emissions
 - 98.0% to 97.6% removal rate for SO₂ (Wet FGD) at 0.327 kg SO₂/MWh net




Moving Beyond GHGs, CAPs, and Water Use

- Past focus of LCAs have been on greenhouse gases (GHGs), criteria air pollutants (CAPs), and water use
- Expanding inventory across all NETL models to support broader analyses
 - Impact analysis via EPA TRACI 2.1
- As an input to other models (i.e., CO₂-enhanced oil recovery (CO₂-EOR), PPFM emissions inventory needed to be expanded




Goals for PPFM Inventory Expansion

- Emissions that respond to changing plant configuration
 - Boiler type (for coal): sub-critical vs. supercritical
 - Air pollution control: equipment type and operation
 - Coal type: bituminous vs. sub-bituminous vs. lignite
- Use publicly available data
 - National Emissions Inventory (NEI), Energy Information Administration (EIA) power plant data, etc.



Method Overview



Source Data

- 2011 NEI: Annual emission rate for each plant
 - Combined with data below using crosswalk provided by Eastern Research Group (EPA Plant ID to NEI EIS Facility ID)

Coal Plants

Power Plant and Fuel Parameters	Data Source
Power Plant Unit Capacity (MW)	EIA 860
Power Plant Unit Generation (MWh)	EIA 923
Control Equipment (Boolean)	ABB Velocity
Supercritical (Boolean)	ABB Velocity
Fraction of Each Coal Type (BIT/SUB/LIG)	EIA 923
Coal Quality (heat/sulfur/ash content)	EIA 923
Heat Rate (BTU/kWh)	EIA 923 (calculated)

Natural Gas Plants

Power Plant Parameters	Data Source
Power Plant Capacity (MW)	EIA 923
Power Plant Generation (MWh)	EIA 923
Control Equipment (Boolean by type)*	ABB Velocity
Heat Rate (BTU/kWh)	EIA 923 (calculated)
*Water/Steam, Catalytic, Ammonia, Overfire, and Low NOx	

Parameters for Regression Analysis

- The parameters were chosen based on configuration data available
- Some consideration given for options available within PPFM

Coal – 14 available parameters


Nameplate Capacity	Bituminous Coal
Capacity Factor	Sub-bituminous Coal
Heat Rate	Lignite Coal
Heat Content of Coal	SO ₂ Control (Boolean)
Sulfur Content of Coal	NO _x Control (Boolean)
Ash Content of Coal	PM Control (Boolean)
Supercritical Plant (Boolean)	Mercury Control (Boolean)

NGCC – 11 available parameters

Nameplate Capacity	NO _x Control Types:
Capacity Factor	Water
Heat Rate	Catalytic
Percent Gas	Ammonia
Percent NGCC	Overfire
NO _x Control (Boolean)	Low NO _x Burners

Data Cleanup


- **Plants removed based on heat rate – any plants outside of these heat rates were removed**
 - Coal: 7,500-12,000 BTU/kWh (28-45% efficiency)
 - Natural gas: 6,000-15,000 BTU/kWh (23-57% efficiency)
- **All negative values were removed**
- **Species filtering**
 - NEI has 151 emissions species for coal plants and 124 for NGCC plants
 - Species with less than 10 facilities reporting emissions were omitted
 - Remaining species count – coal: 90, NGCC: 38



https://commons.wikimedia.org/wiki/File:Broom_.svg



Outlier Filtering

- Examined different ways to filter outliers – noticed trend to the right among most species
 - The goal was to use as much of the data as possible to train and test the regression model
 - Graph shows the average as the highest values are incrementally removed
 - Only a handful of values need to be removed before the change in average stabilizes – in this case 4 values
- This process was implemented in Python and used to filter outliers prior to creating testing and training datasets
- The remaining data was then split into training and test sets



The Regression Method


Machine-learning algorithm LassoCV



In minimizing, coefficients can be set to 0 (parameter selection)

Testing the Regression Model

Getting to a final model




Repeated 1,000 times with randomly chosen Training and Test Sets

Regression Results


Sample results for methyl methacrylate emissions

- The number of successful models generated for each species ranged from 0 to 932 (of 1,000 possible)
- The final count of species with accepted emissions models (Adjusted $R^2 \geq 0.5$):
 - Coal: 13 (of 32 species that had regression models generated)
 - NGCC: 0 (of 17 species that had regression models generated)



Contribution Analysis of Results

What are the most important parameters?



Back to the Drawing Board

New Dataset!

- **Update the data to use 2014 NEI and power plant data**
 - Previous analysis used 2011 NEI and power plant data
- **NEI emissions are reported at the boiler level (Tennessee Valley Authority Kingston Plant has 9 boilers)**
- **EPA 860 data is available at the boiler level and includes**
 - Information on all pollution control equipment
 - 10 codes for FGD
 - 24 codes for NO_x control
 - 16 codes for PM control
 - 21 codes for Hg control
 - Boiler-level fuel consumption with sulfur and ash specs
 - Also includes combustion of DFO and natural gas for auxiliary operations

A Deeper Look at the NEI Data

What do the reported emissions actually represent?


- **Working directly with the NEI database has revealed some more detail in the metadata:**
 - Of the 53,598 non-zero data points, over half use an EPA, no control emission factor – 119 of 119 species have an EPA emission factor
 - Most emission factors are based on coal throughput (skimming through comments for the calculations)
 - The majority of continuous emission monitoring system (CEMS) data is for NO_x, SO₂, VOCs, and PM

Continuous Emission Monitoring System	1,237	2.3%
Engineering Judgment	4,281	8.0%
Manufacturer Specification	66	0.1%
Material Balance	319	0.6%
Other Emission Factor (no Control Efficiency used)	833	1.6%
Other Emission Factor (pre-control) plus Control Efficiency	463	0.9%
S/L/T Emission Factor (no Control Efficiency used)	3,409	6.4%
S/L/T Emission Factor (pre-control) plus Control Efficiency	8	0.0%
S/L/T Speciation Profile	31	0.1%
Site-Specific Emission Factor (no Control Efficiency used)	906	1.7%
Site-Specific Emission Factor (pre-control) plus Control Efficiency	30	0.1%
Stack Test (no Control Efficiency used)	2,736	5.1%
Stack Test (pre-control) plus Control Efficiency	105	0.2%
Trade Group Emission Factor (no Control Efficiency used)	1,474	2.8%
Trade Group Emission Factor (pre-control) plus Control Efficiency	8	0.0%
USEPA Emission Factor (no Control Efficiency used)	29,135	54.4%
USEPA Emission Factor (pre-control) plus Control Efficiency	2,827	5.3%
USEPA Speciation Profile	5,719	10.7%
Vendor Emission Factor (no Control Efficiency used)	11	0.0%

Adjustment to Method

Changing LassoCV Parameter

- 5-fold cross-validation used for species with > 20 samples, 2-fold otherwise
- Example path for anthracene



Good News, Bad News


Example phenol results – species with the lowest passing final R^2 test

Good News

- **Species count for successful models and score of those models went up considerably**
 - 63 species now have “good” models from 13 previously
 - Notable omissions from the “good” model list due to bad final R^2 test (as opposed to too few emissions or no successful regressions):
 - SO_2 , NO_x , ammonia, PM 10, PM 2.5
 - Suspect these score low because emissions are driven by regulation rather than any of the variables

Bad News

- **We’re mostly regressing against emissions that are generated using emission factors rather than measured emissions**
 - There’s still value in providing a weighted average without examining all of the metadata



- **A large number of NEI emissions are the result of emissions factors applied to coal throughput**
 - Depending on how you get NEI data this isn't readily apparent
 - Despite this, using this method to provide a weighted factor used by the fleet is still useful
- **The emissions that should be most responsive to plant configuration are not (SO₂, NO_x, CO, etc.)**
 - Suspect this is because permits drive these emissions more than the existence of particular control equipment
 - Would like to re-do the analysis for these emissions using locale as a parameter
- **More work to do**
 - Revisit the analysis for natural gas plants to see if boiler- or turbine-level data results in successful models
 - Include facility-level emissions: species count from original analysis was 158 vs. 119 in the new approach, presumably omitting facility-level emissions from TRI

Acknowledgements



- Dave Morgan – National Energy Technology Laboratory
- Greg Schivley – Carnegie Mellon University

Contact Information

Timothy J. Skone, P.E.

Senior Environmental Engineer • U.S. DOE, NETL
(412) 386-4495 • timothy.skone@netl.doe.gov

Matt Jamieson

Staff Engineer • KeyLogic
matthew.jamieson@netl.doe.gov

Greg Cooney

Senior Engineer • KeyLogic
gregory.cooney@netl.doe.gov

