

HIGH CO₂ CAPTURE RATE COST AND PERFORMANCE FOR F- and H-CLASS NATURAL GAS COMBINED CYCLES (NGCC)



*Tim Fout¹, Travis Shultz¹, **Robert James¹**, Tommy Schmitt², Sarah Leptinsky², Marc Turner², Sydney Hughes², Alex Zoelle², Charles White², and Mark Woods²*

¹NETL, ²NETL support contractors



Pittsburgh Coal Conference, September 19-22, 2022



DISCLAIMER

"This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof."


Attribution

KeyLogic Systems, Inc.'s contributions to this work were funded by the National Energy Technology Laboratory under the Mission Execution and Strategic Analysis contract (DE-FE0025912) for support services.

Agenda

- Overview
- Design Basis
- NGCC Performance Results
- NGCC Cost Results
- 97% Capture Rate Analysis
- Sensitivity Analysis
- Future Work

- This work is an in-progress update to the 2019 report [Cost and Performance Baseline for Fossil Energy Plants Volume 1: Bituminous Coal and Natural Gas to Electricity](#)
- The F-class NGCC base plant performance and cost from the 2019 report remains unchanged.
- This update includes:
 - Addition of H-Frame NGCC cases
 - Updated Shell Cansolv performance and cost data
 - Extended capture rates above 90% to include 95% and 97% capture
 - The 97% cases are included in an appendix, requiring further evaluation

The image features a series of high-voltage electrical transmission towers, also known as pylons, silhouetted against a dramatic sky at sunset or sunrise. The towers are constructed from a complex lattice of steel beams and are connected by high-tension power lines. The sky is a mix of deep blues, oranges, and yellows, with scattered clouds catching the low light. The overall composition is symmetrical, with the towers receding into the distance, creating a sense of depth and scale. The text "Design Basis" is centered over the middle of the image in a clean, white, sans-serif font.

Design Basis

Site and Fuel Characteristics¹

Parameter	Value
Location	Greenfield, Midwestern U.S.
Topography	Level
Size (IGCC and PC), acres	300
Size (NGCC), acres	100
Transportation	Rail or Highway
Slag (IGCC) and Ash (PC) Disposal	Off-Site
Water	50% Municipal and 50% Ground Water

Component		Volume Percentage
Methane	CH ₄	93.1
Ethane	C ₂ H ₆	3.2
Propane	C ₃ H ₈	0.7
<i>n</i> -Butane	C ₄ H ₁₀	0.4
Carbon Dioxide	CO ₂	1.0
Nitrogen	N ₂	1.6
Methanethiol ^A	CH ₄ S	5.75x10 ⁻⁶
	Total	100.0
	LHV	HHV
kJ/kg (Btu/lb)	47,201 (20,293)	52,295 (22,483)
MJ/scm (Btu/scf)	34.52 (927)	38.25 (1,027)

Parameter	Value
Elevation, m (ft)	0 (0)
Barometric Pressure, MPa (psia)	0.101 (14.696)
Average Ambient Dry Bulb Temperature, °C (°F)	15 (59)
Average Ambient Wet Bulb Temperature, °C (°F)	10.8 (51.5)
Design Ambient Relative Humidity, %	60
Cooling Water Temperature, °C (°F) ^A	15.6 (60)
Air composition based on published psychrometric data, mass %	
N ₂	75.055
O ₂	22.998
Ar	1.280
H ₂ O	0.616
CO ₂	0.050
Total	100.00

^AThe cooling water temperature is the cooling tower cooling water exit temperature. This is set to 4.8°C (8.5°F) above ambient wet bulb conditions in ISO cases.

^AThe sulfur content of natural gas is primarily composed of added Mercaptan (methanethiol [CH₄S]) with trace levels of hydrogen sulfide (H₂S) [14]


Note: Fuel composition is normalized, and heating values are calculated using Aspen

1 - National Energy Technology Laboratory, "Quality Guidelines for Energy System Studies: Specification for Selected Feedstocks," U.S. Department of Energy, Pittsburgh, PA, 2019.

Case Configuration Summary

- While the study includes IGCC and PC plant cases, only NGCC presented here
- Both with and without CO₂ capture


Case	Plant Type	Steam Cycle, psig/°F/°F	Combustion Turbine	Gasifier/Boiler Technology	Sulfur Removal	Particulate Matter Control	CO2 Separation	Capture Rate	Process Water Treatment
B31A	NGCC	2400/1085/1085	2 x State-of-the-art 2017 F-Class	HRSG	N/A	N/A	N/A	N/A	N/A
B31B.90							Shell Cansolv	90%	
B31B.95								95%	
B32A		2700/1085/1045	2 x State-of-the-art 2017 H-Class				N/A	N/A	
B32B.90							Shell Cansolv	90%	
B32B.95								95%	




The image features a series of high-voltage power transmission towers, also known as pylons, silhouetted against a dramatic sky at sunset or sunrise. The towers are arranged in a perspective that leads the eye from the foreground into the distance. The sky is a mix of deep blues, oranges, and yellows, with some wispy clouds. The overall mood is industrial yet serene.

NGCC Performance Results

NGCC Net Plant Efficiency




NGCC Raw Water Withdrawal and Consumption



NGCC CO₂ Emissions

NGCC
Emission limit:
1000 lb/MWh-
gross



¹Office of the Federal Register, "Proposed Rules Vol. 83 No. 244," 20 December 2018. [Online]. Available: <https://www.govinfo.gov/content/pkg/FR-2018-12-20/pdf/2018-27052.pdf>. [Accessed 6 June 2019].

The image features a series of high-voltage power transmission towers, also known as pylons, silhouetted against a dramatic sky at sunset or sunrise. The towers are arranged in a receding line, creating a sense of depth. The sky is filled with soft, colorful clouds in shades of orange, yellow, and blue. The overall mood is industrial yet serene.


NGCC Cost Results

Special Considerations On Reported Costs

- Capital Cost Estimates
 - NGCC -15/+25, Class 4 AACE Classification
- Costs for Mature Technologies and Designs
 - NGCC plant
- Costs for Emerging Technologies and Designs
 - CO₂ Capture Systems
- Other Factors
 - Site/project Specific
- Future Cost Trends
 - Effect of R&D


Capital Cost Comparison

Total Overnight Cost (TOC) and Total As-spent Cost (TASC)





LCOE Breakdown

85% Capacity Factor, \$4.42/MMBtu NG Price, 2018\$



Cost of CO₂ Captured/Avoided Penalty



The background of the slide features a series of high-voltage power transmission towers, also known as pylons, silhouetted against a dramatic sky at sunset or sunrise. The sky transitions from a deep blue at the top to a bright orange and yellow near the horizon, with scattered clouds catching the low light. The towers are arranged in a receding line, creating a sense of depth. The text "97% Capture Rate Analysis" is centered over the middle of the image in a white, sans-serif font.


97% Capture Rate Analysis

Distinction Between 95% Capture and Higher Rates


- Commercial-scale demonstration of solvent-based post-combustion CO₂ capture systems at power generation facilities (specifically PC plants) has shown the ability to capture 90% of the CO₂ in the flue gas stream.
- Field-testing of post-combustion CO₂ capture technology as well as vendor and industry feedback on projects currently in the planning stages (including FEED projects sponsored by DOE) indicate that capture rates as high as 95% are feasible for both coal- and natural gas-fueled electricity generating units.
- Technology suppliers (as reflected in vendor-supplied information provided to DOE for this study that included cost and performance estimates for both NGCC (97%) and PC (99%) study cases) as well as subject matter experts acknowledge and support that solvent-based post-combustion CO₂ capture technologies are capable of achieving CO₂ removal rates beyond 95% on low-purity streams representative of fossil-fueled combustion.
- Although technoeconomic analyses of deep decarbonization ($\geq 99\%$) of combustion flue gas have been published by others, the relatively limited experience with design and operation of capture systems that can routinely, reliably, and economically achieve very high removal rates requires further study. Technoeconomic analysis of the higher capture rates (97% NGCC and 99% PC) will be included in the appendices of the subject report.


NGCC with 97% CCS

HHV Efficiency




LCOE




The background of the slide is a photograph showing the silhouettes of several high-voltage electrical transmission towers. The towers are arranged in a perspective that leads the eye from the foreground towards the horizon. They are set against a dramatic sky at sunset or sunrise, with colors ranging from deep orange near the horizon to a dark blue at the top. The text "Sensitivity Analysis" is centered over the middle of the image.

Sensitivity Analysis

Sensitivity to Capacity Factor



Sensitivity to Fuel Cost



The image features a series of high-voltage electrical transmission towers, also known as pylons, silhouetted against a dramatic sky at sunset or sunrise. The towers are constructed from a complex lattice of steel beams and are connected by high-tension power lines. The sky is a mix of deep blues, oranges, and yellows, with scattered clouds catching the low light. The overall mood is industrial yet serene, suggesting a connection between modern infrastructure and the natural world.

Future Work

- Cost and Performance Baseline for Fossil Energy Plants Volume 1: Bituminous Coal and Natural Gas to Electricity – Revision 4A
 - To be published late September 2022
- Other related/derivative studies underway:
 - Cost and Performance of Retrofitting NGCC Units for Carbon Capture and associated Carbon Capture Retrofit Database (CCRD) - late 2022
 - Eliminating the Derate of Carbon Capture Retrofits and associated CCRD - late 2022/early 2023
 - Detailed cost sensitivity for NGCC with CCS - 2023
 - Technoeconomic and Life Cycle Analysis of Bio-Energy with Carbon Capture and Storage (BECCS) Baseline – late 2022
 - Update to include capture system performance and cost, and a 100% biomass case
 - Cost of Capturing CO₂ from Industrial Sources - Revision 1 and associated CCRD - September 2022

Questions/ Comments

VISIT US AT: www.NETL.DOE.gov



@NETL_DOE



@NETL_DOE



@NationalEnergyTechnologyLaboratory

CONTACT:

Robert James

Robert.James@netl.doe.gov

