




Performing a Techno-economic Analysis for Power Generation Plants

Rank	Bituminous	
Seam	Illinois No. 6 (Herrin)	
Source	Old Ben Mine	
Proximate Analysis (weight %) (Note A)		
	As Received	Dry
Moisture	11.12	0.00
Ash	9.70	10.91
Volatile Matter	34.99	39.37
Fixed Carbon	44.19	49.72
Total	100.00	100.00
Sulfur	2.51	2.82
HHV, kJ/kg	27,113	30,506
HHV, Btu/lb	11,666	13,126
		29,544
		12,712
		6)
		Dry
		,00
		72
		6



July 2015

DOE/NETL-2015/1726

Disclaimer

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed or represents that its use would not infringe privately owned rights. Reference therein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed therein do not necessarily state or reflect those of the United States Government or any agency thereof.

Quality Guidelines for Energy System Studies Performing a Techno-economic Analysis for Power Generation Plants

DOE/NETL-341/020915

Final Report

June 30, 2015

NETL Contact:

James Fisher

General Engineer

Office of Program Performance & Benefits, Performance Division

**National Energy Technology Laboratory
www.netl.doe.gov**

Prepared by:

Energy Sector Planning and Analysis

Alex Zoelle

Booz Allen Hamilton, Inc.

Marc J. Turner

Booz Allen Hamilton, Inc.

Vince Chou

Booz Allen Hamilton, Inc.

DOE Contract Number DE-FE0004001

Acknowledgments

This report was prepared by Energy Sector Planning and Analysis (ESPA) for the United States Department of Energy (DOE), National Energy Technology Laboratory (NETL). This work was completed under DOE NETL Contract Number DE-FE0004001. This work was performed under ESPA Task 341.03.01.

The authors wish to acknowledge the excellent guidance, contributions, and cooperation of the NETL staff, particularly—

James C. Fisher II, General Engineer

Travis Shultz, Director, Performance Division

Kristin Gerdes, Director, Office of Program Performance and Benefits

James Black, General Engineer, Office of Research and Development

Michael Matuszewski, formerly NETL

This page intentionally left blank.

Table of Contents

1 Introduction.....	11
2 Technology Analysis Plan	14
2.1 Goals and Desired Outcomes.....	14
2.2 Cases to be Evaluated	15
2.3 Novel Technology Basis.....	16
2.3.1 Novel Equipment Size and Performance Basis	16
2.3.2 Novel Equipment Costing.....	16
2.3.3 Sensitivities	17
3 Technical Analysis.....	18
3.1 Overview of TEA Requirements	18
3.2 Technical Evaluation of Advanced Technology Plant Impacts	18
3.2.1 Design Basis Decision’s Effect on Base Plant.....	19
3.2.2 Advanced Technology Operating Parameter’s Effect on Base Plant	19
3.3 Advanced Technology Details.....	20
4 Economic Analysis	21
4.1 Overview	21
4.2 Capital Cost Estimating	21
4.3 Operating and Maintenance	23
4.4 Cost Metrics	24
5 Reporting Requirements/Required Deliverables	25
5.1 Executive Summary	25
5.2 Performance	25
5.3 Cost	26
5.4 Advanced Technology Details.....	26
5.5 Sensitivity Analysis	26
5.6 Additional Deliverables	27
6 Common Missteps and Omissions.....	28
Appendix A – Additional Metrics.....	30
Appendix B – Reference Plant Design Basis Parameters	31
System Boundaries.....	31

Process Design Assumptions	31
Product Specifications	33
CO ₂ Removal	33
Availability and Capacity Factor	33
Plant Size	34
CO ₂ Transportation and Storage	34
Finance Structure	34
Appendix C – Example High-Level Performance Summary and Cost Tables.....	35

Exhibits

Exhibit 1-1 NETL Baseline Studies including TEAs	11
Exhibit 1-2 Available QGESS Documents	13
Exhibit 2-1 Example TEA Goals and Outcomes	14
Exhibit 2-2 Sample Illustration of Novel Technology Cases Examined	15
Exhibit B-1 Balance of Plant Assumptions	32
Exhibit C-1 Example of High-Level Performance Summary.....	35
Exhibit C-2 Example of High-Level Cost Results.....	36

Acronyms and Abbreviations

AACE	Association for the Advancement of Cost Engineering	lb	Pounds
ASU	Air separation unit	mi	Mile
BEC	Bare erected cost	MW	Megawatt
BFD	Block-flow diagram	MWh	Megawatt hour
Btu	British thermal units	NETL	National Energy Technology Laboratory
CO ₂	Carbon dioxide	NGCC	Natural gas combined cycle
COE	Cost of electricity	O&M	Operating and maintenance
CCF	Capital charge factor	O ₂	Oxygen
CF	Capacity factor	PC	Pulverized coal
DOE	Department of Energy	PRB	Powder River Basin
EOR	Enhanced oil recovery	psia	Pounds per square inch absolute
ESPA	Energy Sector Planning and Analysis	QGESS	Quality Guidelines for Energy System Studies
FGD	Flue gas desulfurization	R&D	Research and development
ft	Feet	ST	Steam turbine
hp	Horsepower	T&S	Transport and storage
HRSG	Heat recovery steam generator	TAP	Technology Analysis Plan
IGCC	Integrated gasification combined cycle	TEA	Techno-economic analyses
ISO	International Organization for Standardization	TOC	Total overnight capital
km	Kilometer	TPC	Total plant cost
kV	Kilovolt	WGS	Water-gas shift

This page intentionally left blank.

1 Introduction

This document will serve as a guideline for performing power generation studies on a consistent, comparable basis. Each year, the National Energy Technology Laboratory (NETL), technology developers supported by NETL, and other organizations conduct techno-economic analyses (TEA) to assess the viability of state-of-the-art and advanced technologies. These analyses help provide context for identifying potential benefits and risks of new technologies and configurations by connecting bench-, lab-, and pilot-scale test results to representative performance ranges in full-scale utility power plant applications. These performance estimates are combined with cost estimates to evaluate economic viability and identify technology development challenges and risks. The assumptions outlined here and in the referenced documents are intended to provide a common basis to facilitate comparison between technology choices—different assumptions can drastically change the final results of a TEA. Hence, these assumptions are not intended to be used as a complete assessment for a specific power plant, which would require far greater detail and site-specific information.

Examples of TEA's performed by NETL include those found in the baseline studies listed in Exhibit 1-1 lists the volumes in the Cost and Performance Baseline for Fossil Energy Plants reference documents. These studies include several configurations for integrated gasification combined cycle (IGCC), pulverized coal (PC), and natural gas combined cycle (NGCC) plants, both with and without carbon dioxide (CO₂) capture.

Exhibit 1-1 NETL Baseline Studies including TEAs

Volume	Title	Description	Notes
1	<i>Bituminous Coal and Natural Gas to Electricity, aka Bituminous Baseline</i>	Establishes performance and cost data for fossil energy power systems for IGCC, PC, and NGCC plants	All plants are modeled with and without carbon capture and storage All plants are conducted at International Organization for Standardization (ISO) conditions PC and IGCC plants fire Illinois No. 6 bituminous coal
3	<i>Low-Rank Coal and Natural Gas to Electricity, aka Low-Rank Baseline</i>	Establishes performance and cost data for fossil energy power systems for IGCC, PC, and NGCC plants at different elevations with different coal types	All plants are modeled with and without carbon capture and storage All plants are conducted at Montana elevation (3,400 ft.) and North Dakota elevation (1,900 ft.) PC and IGCC plants fire either Powder River Basin (PRB) sub-bituminous coal or North Dakota lignite coal

Conducting fair and rational comparisons to isolate the effects of specific phenomena can be enabled by using consistent design bases, modeling assumptions, and approaches. Adhering to the following guidelines will allow for better and more transparent analyses for comparing the effects of energy conversion systems.

A TEA report is required to include—

- General block flow diagrams identifying all major process equipment and/or steps (for example, CO₂ capture and compression systems, separation process equipment, heat exchangers, pumps, and compressors).
- Material and energy balances around the complete plant and all major pieces of equipment or process areas, including all heating and cooling duties and electric power requirements. A level of reporting similar to that found in the baseline studies referenced above is expected.
- Complete stream tables showing operating pressures, temperatures, compositions, and enthalpies for all streams entering or leaving major process equipment.
- Economic analysis providing a detailed code of accounts for the capital cost estimate. Operating and maintenance (O&M) costs should be itemized to a similar level of detail as shown in the baseline studies referenced above. Greater costing detail is expected for equipment related to the research topic.
- Estimates prepared by the technology developer for equipment and consumables unique to the process being developed.
 - If possible, capital cost estimates for unique equipment should be made based on similar equipment that may exist for other type processes.
 - If equipment analogs do not exist for unique equipment, the developer should do a bottom-up estimate of the unique equipment.

This Quality Guideline for Energy System Studies (QGESS) document defines the suggested minimum analysis requirements and describes NETL's process for performing TEAs, including typical suggestions and optional analyses that help demonstrate understanding and guide R&D efforts. The TEA QGESS is one in a series of QGESS documents that outlines the assumptions utilized in the baseline studies and can provide guidance for developing the reference plant. These documents are organized and available on NETL's Quality Guideline website¹. A listing of the available QGESS documents is provided in Exhibit 1-2 with a brief description of each.

The balance of this document details information that should be considered while—

- Developing the analysis plan
- Performing the technical analysis
- Performing the economic analysis
- Reporting the results

¹ NETL's Quality Guideline website can be found at <http://www.netl.doe.gov/research/energy-analysis/quality-guidelines-qgess>

Exhibit 1-2 Available QGESS Documents

No.	Title	Description
1	<u>Cost Estimation Methodology for NETL Assessments of Power Plant Performance</u>	Summarizes the cost estimation methodology employed by NETL in its assessment of power plant performance.
2	<u>Estimating Carbon Dioxide Transport and Storage Costs</u>	Estimates the cost of CO ₂ transport and storage (T&S) in a deep saline aquifer for plant locations used in the energy system studies sponsored by NETL. To account for these variances in the geologic formations that make up saline aquifers across the United States, region-specific results from NETL's CO ₂ Saline Storage Cost Model are utilized to represent costs for plant locations used in NETL studies.
3	<u>Specifications for Selected Feedstocks</u>	Provides recommended specifications for various feedstocks that are commonly found in NETL-sponsored energy system studies. NETL recommends that these guidelines be followed in the absence of any compelling market, project, or site-specific requirements to facilitate the comparison of studies evaluating coal-based technologies.
4	<u>Process Modeling Design Parameters</u>	Documents the process modeling assumptions most commonly used in systems analysis studies and the basis for those assumptions. The large number of assumptions required for a systems analysis makes it impractical to document the entire set in each report. This document should serve as a comprehensive reference for these assumptions as well as their justification.
5	<u>CO₂ Impurity Design Parameters</u>	Provides recommended impurity limits for CO ₂ stream components for use in conceptual studies of CO ₂ carbon capture, utilization, and storage systems. Impurity levels are provided for limitations of carbon steel pipelines, enhanced oil recovery (EOR), saline formation storage, and co-storage of CO ₂ and hydrogen sulfide in saline formations.
6	<u>Fuel Prices for Selected Feedstocks in NETL Studies</u>	Provides an estimate of the market price delivered to specific end-use areas of four coals that are commonly used as feedstocks in the energy system studies sponsored by NETL; also includes the estimated market price for natural gas delivered to three different regions.
7	<u>Capital Cost Scaling Methodology</u>	Provides a standard basis for scaling capital costs, with specific emphasis on scaling exponents; also contains a listing of frequently-used pieces of equipment and their corresponding scaling exponents for various plant types, along with their ranges of applicability.
8	<u>Detailed Coal Specifications</u>	Provides data on the coal industry and detailed specifications for seven coals commonly used in energy system studies for NETL.

2 Technology Analysis Plan

The Technology Analysis Plan (TAP) is a roadmap for executing a TEA. It is prepared prior to conducting the TEA and includes the overall process design basis as outlined in Appendix B, a concise description of the cost and performance basis for the novel technology, and the interfaces with the base plant. The path from technology concept to commercial embodiment involves many R&D stages, and the design data that are available can vary significantly at each stage. The TAP includes clearly defined process design and operating parameters and presents the available experimental data and theoretical analyses used to support design choices. A key feature of conducting a TEA is identification of data gaps, which can guide R&D efforts; if data gaps are known or identified while conducting the preliminary TAP, discussion of these data gaps with the stakeholders and how they will be addressed with regards to completing the TEA should be done prior to proceeding with the full TEA analysis.

Typically, a TEA is conducted first by modeling a reference plant, and then by inserting a novel technology into the reference plant. The TAP must clearly define the reference plant, which should replicate one of the plants found in NETL's baseline studies, as shown in Exhibit 1-1. The design basis elements in Appendix B represent the key technology and process parameter choices that are needed to maintain consistency with the chosen baseline plant reference. Deviations from the reference plant design basis must be described and justified.

In instances where the novel technology enables and/or requires application of other advanced technologies, the TAP defines the cases to be evaluated in the TEA step by step.

The elements of the TAP are discussed in more detail in the following sections.

2.1 Goals and Desired Outcomes

The execution of a TEA depends on the overall objective and the desired outcome. Typical examples illustrating possible goals and outcomes are shown in Exhibit 2-1. Detailing the goals and outcomes in the TAP prior to performing the TEA and involving all stakeholders is an important step to maximize the quality and benefit of the analysis.

Exhibit 2-1 Example TEA Goals and Outcomes

Goal	TEA Implementation	Desired Outcome
Evaluate current state of the technology	Design parameters are based on current data	Cost and performance of the intended application of the technology based on currently demonstrated results
Evaluate aspirational (or R&D target) goals	Design parameters are based on goals that meet overall cost and performance targets	Cost and performance of the intended application that meets target goals

2.2 Cases to be Evaluated

A complete TEA includes a non-capture reference case selected from either the Bituminous Baseline or Low-Rank Baseline (Exhibit 1-1) and a second case implementing the novel technology. The primary intent of specifying the reference plant is to provide a common starting point for evaluating different technologies. However, if the advanced technology is not applicable to any of the baseline reference cases, a new reference case can be created. The new reference case, at a minimum, is reported at the same level of detail shown in the baseline studies.

The primary TEA case focuses on the direct impacts of the novel technology, while excluding secondary technologies or alternative process configurations that may be enabled by the novel technology. The secondary affects can be assessed in subsequent cases. In no instance should benefits be included that are not specifically provided or enabled by the technology of interest, such as advanced steam conditions, reduced turbine condenser temperature, or advanced CO₂ compression technology (unless it's the technology being demonstrated). A diagram illustrating the multiple case approach (specific to pre-combustion capture) is shown in Exhibit 2-2, where the capture technology of interest is implemented as Case 1. In this example, the capture technology enables a second technology (or eliminates an existing technology), providing an additional economic benefit outlined in Case 2. Case 2A adds a purification step to provide EOR-quality CO₂. A table similar to Exhibit 2-2 should be provided if more than a reference case and single novel technology case are to be evaluated. It is important to minimize the number of advanced technologies utilized to demonstrate each individual component's impact. If multiple advanced technologies are being developed in unison, a cumulative case should also be developed to show the interactions and overall impacts. Examples of cumulative additions can be found in NETL's pathway studies (e.g. "Current and Future Technologies for Gasification-Based Power Generation"). **If plant-wide changes are required to implement a new technology, the design basis presented in the TAP should be reviewed with all stakeholders prior to executing the TEA to gain consensus that the technology is accurately represented.**

Exhibit 2-2 Sample Illustration of Novel Technology Cases Examined

Case	Baseline (Reference)	Case Study		
		Case 1	Case 2	Case 2A
Technology Combinations				
CO ₂ Removal	Selexol	Novel Capture Tech.		
Enabling Tech.	Std. Tech.		Enabled Tech.	
CO ₂ Purification	No			Yes

The TAP includes high-level block-flow diagrams (BFDs) of the reference plant and all cases to be evaluated. The BFDs highlight the interface points between the novel technology and the reference plant. The text includes a description of the interface points, as well as the technology impact on upstream and downstream processes.

2.3 Novel Technology Basis

Innovative technologies frequently require novel equipment items, advanced materials of construction, unique chemicals, and/or new process configurations. Accurate cost and performance of these items are frequently unknown at the outset of the development program. Execution of a TEA requires that some assumptions be made to predict cost and performance parameters. The TAP documents key assumptions and the approach for novel equipment size, performance basis, and costing as detailed in the following sections.

2.3.1 Novel Equipment Size and Performance Basis

As a technology is developed and tested, the quantity, quality, and scale of components change. The TAP provides the basis for relevant process phenomena, which includes items such as reaction chemistry, equipment sizing and costing, materials selection, mitigation of trace element impacts, particle attrition, or material degradation. In cases where data are not yet available, the assumptions used to model the equipment design and performance are to be clearly stated and justified. Typical assumptions when data are lacking may include—

- Size and/or performance is based on a similar piece of equipment in a different commercial application
- Size and/or performance is based on aspirational R&D goals not yet achieved
- Size and/or performance is based on engineering calculations not yet verified experimentally

In the instance where data do not yet exist, the TAP documents data gaps for future R&D.

2.3.2 Novel Equipment Costing

Once sized, a cost for the novel equipment must be estimated to complete the TEA. Several possible cost methods are listed here—

- Obtain a vendor quote.
- Scale from an analogous equipment item that is similar in size and function.
- Scale from a vendor quote for similar equipment scaled to the appropriate size.
- Estimate the amount and cost of required raw materials, and apply a manufacturing cost multiplier.
- Calculate an allowable cost based on meeting a cost of electricity (COE) target.

If a vendor quote can be obtained, it is the most direct and accurate means of cost estimating. Frequently, vendor quotes are not practical at an early stage of technology development. In that case, the preferred method for costing is to use an analogous piece of equipment from the reference plant and scale it using an appropriate process parameter and scaling exponent. Scaling a vendor quote for a similar equipment item used in a commercial-scale process or performing a bottom-up cost estimate where the amount of raw material is estimated and a manufacturing fee is applied are also acceptable methods. While less desirable, a bottom-up cost estimate is acceptable for novel equipment that does not have an analogous equivalent. The final, though

least favored, method is a cost based on research goals. In this method, the COE is assumed (and justified) and the allowable cost for the novel equipment is calculated. If this method is applied, a detailed justification as to why the other methods are not applicable should be provided.

The balance of plant equipment that is changed in size only should be scaled according to QGESS #7 “Capital Cost Scaling Methodology.”

2.3.3 Sensitivities

Sensitivity analyses are important to identify salient design and operating parameters and to gain understanding that is important for guiding the technology development. Sensitivity analyses change a single variable while holding the balance of the plant constant. The efficiency and COE can be calculated for select values of the sensitivity variables to quantify the importance of that variable. The TAP identifies planned sensitivity analyses, taking into account the key assumptions and any data limitations regarding the novel technology performance and cost. Frequently used variables include capital cost, reaction rates, and general performance characteristics. In early development stages, sensitivity studies should be broad and bound by fundamental understanding of the technology. As the technology matures, the sensitivities should become more focused on the expected performance verified through experimental data.

3 Technical Analysis

3.1 Overview of TEA Requirements

This section details the required elements for the technical analysis. The TEA must include results in such a form and level of detail sufficient to facilitate a meaningful technical analysis of the advanced technology. The TEA should include—

- Block flow diagram and accompanying stream tables
- Performance summary
- Air emissions tables
- Carbon, sulfur, and water balances
- Itemized equipment list

The block flow diagram identifies all major process areas for the power plant, including, but not limited to, CO₂ capture and compression systems, separation equipment, heat exchangers, pumps, and compressors. Examples of these can be found in the baseline studies and can be referenced to simplify the development of the TEA. Once the reference plant has been selected, the block flow diagram for the TEA should start with the reference case and substitute the advanced technology for the reference technology with additional streams routed as appropriate. It should be discussed if the advanced technology requires, or may benefit from, integration that is different from the original reference technology's integration in the base case, giving justification for the change and identifying performance implications for other sub-systems.

Material and energy balances around the complete power plant and all major pieces of equipment are required to be shown (proprietary data can be marked or removed in a supplementary redacted version, in accordance with the provisions of the cooperative agreement, if applicable). These should include all heating and cooling duties, as well as electric power requirements. Material and energy balance calculations must be accurate; equilibria and physical and thermodynamic properties must be calculated using rigorous models. A convenient way to perform the material and energy balance calculations is by using a process simulator, such as Aspen Plus[®] or other process model simulation software. For simple systems, a spreadsheet analysis may be possible. The methods and models used must be documented in the final TEA report. For cases where the advanced technology employs novel approaches to mass and heat transfer, sufficient detail surrounding the process and calculations should be given.

Complete stream tables should also be included and should contain operating pressures, temperatures, compositions, and enthalpies for all streams entering or leaving major process equipment. The property methods used for determining thermo-physical properties should follow those given in the QGESS #4 document "Process Modeling Design Parameters." The property methods to be used are determined by the location of the process in the overall model.

3.2 Technical Evaluation of Advanced Technology Plant Impacts

The performance of the advanced technology integrated into the power plant and how it compares to the reference case technology is a key result of the TEA. The elements discussed in

Section 3.1 allow for this comparison of performance, emissions, and equipment requirements. In addition, it is important to identify how design choices affect the base plant and how these effects carry through to the advanced technology. The reverse is also important because operating parameters of the advanced technology may impact other sub-systems in the power plant. A comparison table for the performance summaries, with line item auxiliary loads, can show the intended benefit of the advanced technology, especially if the pertinent scaling parameters are displayed. This section presents several specific examples of these types of design choices and impacts, but the technical evaluation is not limited to these scenarios.

3.2.1 Design Basis Decision's Effect on Base Plant

Ambient Condition's Effect on Condenser Performance—The choice of plant location and ambient conditions combined with cooling system type (wet, dry, or parallel cooling) and temperature approaches determine the cooling water temperature and steam turbine condenser pressure, which can drastically affect the performance of the plant. Any major deviations should be noted and justified based on the requirements of the advanced technologies, and the standard analysis should use similar assumptions to eliminate any unnecessary bias.

Cooling Water Temperature—The selection of cooling water temperature can have large impacts on performance estimates, especially for compressor intercooling and the steam turbine condenser pressure. If the cooling water temperature selected deviates from NETL baseline case assumptions selected, models should be developed to predict the performance impacts. If the cooling water temperature selected matches the baseline case, simple scaling based on mass flow may be used.

Temperature Approach and Pressure Drop—The QGESS #4 document “Process Modeling Design Parameters” gives recommended temperature approaches and pressure drops to be used in TEAs. These parameters are suggested, and advanced technology may come with the benefit of decreased pressure drop or the ability to reduce temperature approach. These parameters, such as the ones used for advanced heat recovery from a rich/lean solvent cross exchanger, should be highlighted in the TEA.

3.2.2 Advanced Technology Operating Parameter's Effect on Base Plant

CO₂ Capture System Operating Pressure—The operating pressure of a CO₂ capture system impacts both the auxiliary power requirement of the plant and the capital cost of the CO₂ compressors. Consequently, this downstream impact should be clearly identified and included in the evaluation of the capture technology on the overall plant performance.

For example, advanced solvents may have the ability to operate at increased pressure with equivalent or improved performance compared to their conventional counterparts. One of the downstream effects is the elevated pressure of the regenerated CO₂ stream that is compressed to the pipeline specification. CO₂ compression auxiliaries can account for as much as 40 percent of a PC power plants' auxiliary load; a reduction in compression ratio stemming from increased regeneration pressure should have a beneficial impact in reducing this large parasitic load, as well as the capital cost component of the compression train.

Adjustments to Systems that Perform Secondary Functions—Several sub-systems serve multiple areas or perform multiple functions for the plant. In instances where the advanced

technology attempts to improve the performance of a primary function of a sub-system, any impact on secondary functions should be discussed and quantified, if possible.

For example, the primary function of the wet flue gas desulfurization (FGD) is to remove sulfur from the flue gas. However, a secondary effect of the wet FGD is to capture water-soluble oxidized mercury. The mercury mitigation systems of PC plants can use co-benefit capture via selective catalytic reduction, fabric filters, and wet FGD, aided with chemical injection. All of these systems have other primary functions but cumulatively support a secondary function of mercury capture. These types of considerations require a complete understanding of the overall power plant and should be acknowledged when the advanced technology targets these systems.

Sub-system Integration—Common utilities that are shared throughout the plant, such as cooling water, process water, and steam, need to be considered to fully characterize the effect of an advanced technology. In addition, heat integration is essential to maximizing plant efficiency, particularly in IGCC and NGCC plants. The quality and amount of heat available at any one point in the system are important when determining how and where to integrate that heat with other sub-systems. Any assumptions on the availability of heat sinks or sources should be discussed to help justify the associated costs and benefits.

For example, in IGCC cases, heat is recovered from the exothermic reaction taking place in the water-gas shift (WGS) reactors. This heat and other waste heat are used to generate steam that is sent back to the inlet of the WGS reactors. If the advanced technology targets a WGS catalyst that operates at significantly lower temperature, the quantity of waste heat to be recovered may be reduced, and the plant's heat integration may need to be adjusted.

This type of analysis requires a strong understanding of the selected reference base case configuration and operating principles. However, development and analysis of an emerging technology is incomplete if the overall effects of the system on the base plant are not well characterized.

3.3 Advanced Technology Details

Each advanced technology will have performance parameters that are essential to understanding the system and the TEA results. An example of this type of parameter is the steam required to regenerate a CO₂ capture solvent, normally reported in Btu/lb CO₂. For an advanced solvent CO₂ capture technology, comparison of this steam requirement between the advanced technology and reference technology shows the benefit of the new solvent. For TEAs, these performance parameter values used for the critical components should be highlighted. Additionally, the experimental data from where the performance parameters derive and the projections of performance parameters due to scale-up or other factors should also be discussed. Itemized equipment lists for equipment unique to the advanced technology and other equipment required for integration to the power plant should also be reported.

4 Economic Analysis

4.1 Overview

The following economic analysis requirements help demonstrate the viability of a given technology, within the established ranges of research and development, based on a set of market conditions for the utility power generation market. The economic analysis should follow the QGESS #1 document “Cost Estimation Methodology for NETL Assessments of Power Plant Performance,” which is the same methodology used in the NETL baseline studies. The detailed code of accounts for the capital cost estimate used in the baseline studies should be implemented for the TEA. These accounts are given in the QGESS #7 document “Capital Cost Scaling Methodology.” Within the given code of accounts are sub-accounts that give more detailed categorization of sub-systems, and they should be used and adjusted to fit the advanced technology, as appropriate. For example, account 5B “CO₂ Removal and Compression” contains sub-accounts 5B.1 “CO₂ Removal System” and 5B.2 “CO₂ Compression and Drying System.” For a capture technology being evaluated, the system may be comprised of elements of both sub-accounts 5B.1 and 5B.2. Alternatively, the level of detail may be sufficient to separate sub-account 5B.1 further to provide increased transparency for the TEA reviewer. The greater detail in the cost accounts demonstrates greater depth of understanding and thought provided to a given area; therefore, providing detailed cost accounts is important. O&M costs should be itemized as shown in the baseline studies.

The developer should prepare estimates for equipment and consumables unique to the process being developed. If possible, capital cost estimates for unique equipment should be made based on similar equipment that may exist for other types of processes. For equipment estimates that must be based on analogs, breaking sub-accounts down, as suggested above, to show the results of these estimates allows for better understanding of how estimates were completed. It is recommended that the pertinent scaling parameters are presented next to the costs to provide context and easy validation of the cost estimates. If equipment analogs do not exist for unique equipment, the developer should explain how the costs are represented, ranging from a full bottom-up estimate of the unique equipment to an R&D goal based on reasonable assumptions.

4.2 Capital Cost Estimating

The code of accounts for the capital cost estimate should follow those used in the NETL baseline studies (referenced in Exhibit 1-1). Engineering fees, contingencies (discussed further below), and owner’s costs should follow the QGESS #1 document “Cost Estimation Methodology for NETL Assessments of Power Plant Performance.”

For equipment and sub-system items that can be identified in an NETL baseline study, use the baseline study cost and scale from the QGESS #7 document “Capital Cost Scaling Methodology” to estimate the bare erected cost (BEC).

For equipment that is not included in an NETL baseline study, attempt to identify an analog from an NETL study or from a literature source and scale it using the QGESS #7 document “Capital Cost Scaling Methodology.” Discuss the rationale for this decision in the TEA costing section.

If no other sources are available, prepare a list of the major pieces of equipment in the sub-system, including process parameters, physical size, and materials of construction, and perform a bottom-up estimate of the sub-system.

The best cost presentations show the cause and effect of changing design parameters and the resulting cost adjustments. Sensitivity of Cost Metrics (Section 4.4) to the capital cost of technologies being developed is a very useful analysis tool (Section 5.5).

Contingencies

Process and project contingencies are included in estimates to account for unknown costs that are omitted or unforeseen due to a lack of complete project definition and engineering.

Contingencies are added because experience has shown that such costs are likely and expected to be incurred even though they cannot be explicitly determined at the time the estimate is prepared.

Capital cost contingencies do not cover uncertainties or risks associated with—

- Changes in scope
- Changes in labor availability or productivity
- Delays in equipment deliveries
- Changes in regulatory requirements
- Unexpected cost escalation
- Unexpected performance impacts after startup (e.g., availability, efficiency)

Process contingency is intended to compensate for uncertainty in cost estimates caused by performance uncertainties associated with the development status of a technology. Process contingencies are applied to each plant section based on its current technology status. AACE International Recommended Practice No. 116R-90, Conducting Technical and Economic Evaluations as applied for the Process and Utility Industries (AACE 16R-90) states that process contingency can range from zero to 70 percent of BEC based on the technology status level at the time of the estimate. QGESS #7 provides guidance on implementing a process contingency, which does require some interpretation and judgment. Depending on the status of the technology being developed, different process contingencies should be applied. Discussing the current status (i.e. laboratory scale, bench scale, demonstration scale) of the technology helps justify the contingencies utilized. As an example, the amine capture system employed for PC plant cases has a process contingency of 20 percent; this is considered appropriate based on the current deployment of the technology in other fields and the application of the technology, as guided by the QGESS. It is suggested that when selecting a process contingency to apply to the technology being evaluated, the percentage be identified and the reason for selection be discussed in the TEA. An overall capital cost sensitivity analysis can also help provide insight into the uncertainty of the process and equipment or R&D goals, as viewed by the developer.

Project contingencies are applied to each plant section. AACE 16R-90 states that project contingency for a “budget-type” estimate (AACE Class 4 or 5) should be 15 to 30 percent of the sum of BEC; engineering, procurement, and construction fees; and process contingency.

4.3 Operating and Maintenance

O&M cost should be itemized and use the same dollar basis found in an appropriate reference case. In most cases, the advanced technology will not have the ability to reduce the operating labor category by reducing the reference base case number of operators. However, changes to the number of operators due to known operational complexity of the advanced technology is encouraged and allows for a more transparent understanding of the advanced technology's operational challenges or advantages by TEA reviewers.

Maintenance material costs should be adjusted as appropriate, depending on the nature of the advanced technology. For example, maintenance material costs for a membrane-based CO₂ capture system will be higher than that for a solvent-based system. These differences should be discussed and quantified. If the plant size changes as a result of the advanced technology, the balance of the maintenance material costs not attributed to the advanced technology should be based on the ratio of the selected reference case maintenance material costs to total plant cost (TPC).

If the advanced technology uses consumables already present in the O&M sheets, the additional consumption should be added. If the advanced technology requires new or unique consumables (such as sorbent or solvent replacement), then they should be added to the appropriate section of the O&M sheet. If saleable byproducts or disposable wastes are to be added to the O&M costs, the reasoning should be given for the selected unit cost.

Coal and natural gas costs should follow the costs in the QGESS #6 document "Fuel Prices for Selected Feedstocks in NETL Studies." Coal costs include a fixed amount of transportation costs, and sensitivities to this cost can be included if well-reasoned.

4.4 Cost Metrics

The most relevant cost metric that should be reported is the COE. The COE allows for comparison of not only the technology performance, but also the overall cost impact. The QGESS #1 document “Cost Estimation Methodology for NETL Assessments of Power Plant Performance,” provides a procedure for calculating the COE. The following simplified equation can be used to estimate COE as a function of TOC¹, fixed O&M, variable O&M (including fuel), capacity factor, and net output. Depending on the type of plant, PC or IGCC, factors such as economic analysis period, distribution of capital, repayment term on debt, and capital charge factor have been pre-determined and only require application. These factors are given in QGESS #1.

$$COE = \frac{\text{first year capital charge} + \text{first year fixed operating costs} + \text{first year variable operating costs}}{\text{annual net megawatt hours of power generated}}$$

$$COE = \frac{(CCF)(TOC) + OC_{FIX} + (CF)(OC_{VAR})}{(CF)(MWH)}$$

where:

- COE = revenue received by the generator (\$/MWh, equivalent to mills/kWh) during the power plant’s first year of operation (but expressed in base-year dollars), assuming the COE escalates at a nominal annual rate equal to the general inflation rate, i.e., it remains constant in real terms over the operational period of the power plant.
- CCF = capital charge factor taken from Exhibit 2-22 of “Cost and Performance Baseline for Fossil Energy Plants Volume 1: Bituminous Coal and Natural Gas to Electricity” matching the applicable finance structure and capital expenditure period
- TOC = total overnight capital, expressed in base-year dollars
- OC_{FIX} = sum of all fixed annual operating costs, expressed in base-year dollars
- OC_{VAR} = sum of all variable annual operating costs, including fuel at 100 percent capacity factor, expressed in base-year dollars
- CF = plant capacity factor, assumed to be constant over the operational period
- MWh = annual net megawatt-hours of power generated at 100 percent capacity factor

¹ Although TOC is used in the simplified COE equation, the CCF that multiplies it accounts for escalation during construction and interest during construction (along with other factors related to the recovery of capital costs).

5 Reporting Requirements/Required Deliverables

Generally, at a minimum, reporting should be consistent with the level of detail found in the chosen baseline study reference plant. Novel technologies should be reported, in both performance and cost, at a level sufficient to replicate the calculated values, which may be in greater detail than found in the baseline study. Required deliverable items listed below are discussed in more detail in the previous technical analysis (Section 3) and economic analysis (Section 4) sections of this document.

5.1 Executive Summary

An executive summary should be a clear, concise, brief, and well thought out narrative of the effort and the results of that effort, generally 2–3 pages long not including any tables or images. The summary should expedite communication with the stakeholders who may not have the availability to read the entire document. As such, the executive summary should be a standalone piece of the report addressing the following criteria—

- The goals and objectives of the effort—a clear, concise, and brief paragraph about the effort’s objectives outlined in the technical direction.
- Salient results—the results in terms of process efficiency, COE, and only metrics contributing substantially to the change in performance or COE. Each technology should have a separate paragraph outlining the key factors that influenced the results for that technology. The paragraph should also address the results, which should include sensitivity studies. If multiple technologies or pathways are assessed, a paragraph summarizing the results may also be included.
- The limitations of the results—often this will be the result of the performance and cost basis for the technology.
- Impacts and consequences of the investigated technology regarding the balance of the plant.
- Tabular results and graphics—The data should be presented and further described in the body of the report, but it can be truncated and combined with other tables/graphics for brevity. An example from the executive summary from the Bituminous Baseline is located in Appendix C (although the rows and columns may be added and/or subtracted to highlight the particular effort).

5.2 Performance

Appendix C provides an example table of high-level reporting generally utilized to encourage communication with stakeholders. These tables are typically used to allow side-by-side comparisons; however, greater detail about the technology must be provided in a full TEA report, although that can be located in an appendix of the TEA. Truncated versions of these tables are often used in an executive summary to quickly convey the results. Using the NETL baseline studies as a template, the final report should include the following—

- Plant and component descriptions—including design specifications and assumptions
- Block flow diagrams and associated stream tables—including operating pressures, temperatures, compositions, and enthalpies for all streams entering or leaving major process equipment (separation vessels, heat exchangers, pumps, compressors, etc.)

- Performance summary—including breakdown of gross power generation, auxiliary power requirements, and net plant efficiency at the same level of detail as the NETL studies
- Itemized equipment list—including detailed sizing parameters for all critical equipment that is added or changed
- Air emissions tables for the plant
- Carbon, sulfur, and water balances for the plant
- Material and energy balances around major equipment/plant systems—including all heating and cooling duties and electric power requirements
- Performance sensitivities with discussion on why these performance parameters have been identified as key parameters

Performance sensitivities should target important process parameters over a relevant range of values, and performance impacts should be discussed.

5.3 Cost

Appendix C provides a table that should be used for high-level reporting of the economics; however, greater detail should be reported throughout the document. Cost results should follow the format given in the baseline studies.

- Capital costs should use the code of accounts used in the NETL studies. For each account, costs should be broken down into bare erected costs, engineering fees, process contingency, and project contingency, adding up to an account-level total plant cost. The total plant cost, owner's cost, and total overnight cost for the entire plant should also be reported.
- O&M costs (variable and fixed) should be itemized according to those used in the baseline studies, including all consumables unique to the process being developed.
- Cost metrics that should be reported include COE as defined in the QGESS #1 document "Cost Estimation Methodology for NETL Assessments of Power Plant Performance."

5.4 Advanced Technology Details

Additional details are required to be reported regarding the advanced technology, including—

- Performance parameters with a range of experimental data and reasonable projections, as well as actual values used for the TEA
- Itemized equipment list for equipment unique to the advanced technology and other equipment required for the integration of the advanced technology into the power plant
- Estimates for equipment and consumables unique to the process, based on analogous technology if possible or using a bottom-up approach

5.5 Sensitivity Analysis

Sensitivity of COE to the following parameters can help demonstrate an understanding of the potential markets, uncertainty of test data, or state of technology development—

- Critical advanced technology performance parameters
- Capital cost of advanced technology
- Consumable prices that are specific to the investigated technology

5.6 Additional Deliverables

Process models with brief documentation and economic spreadsheet tools or models can be submitted as accompanying materials. All methods and models used should be documented in the TEA.

6 Common Missteps and Omissions

Below is a list of common mistakes and/or omissions seen in TEAs that have been submitted to NETL. Many of these issues are discussed in the previous sections and highlighted here. Care should be taken to address these issues in all TEAs.

1. Underestimating or neglecting to include pressure drops across process components or equipment
Estimating appropriate pressure drops for equipment can reduce errors in accidentally overestimating performance or omitting additional auxiliary equipment needs (blowers, pumps, etc.).
2. Modifying design specifications for equipment and processes unrelated to actual technology-based requirements
Using design specifications identical to the reference cases can reduce errors in accidentally overestimating the performance impact of technologies. Examples of such modifications include reducing cooling water temperatures, modifying steam turbine exhaust pressures, modifying steam extraction rates or conditions for processes uninvolved in the technology under analysis, modifying required combustion turbine air feed and inlet conditions, and reducing heat exchanger temperature approaches.
3. Ignoring design limitations of downstream equipment
Exploring the impact of technologies on downstream equipment designs, such as increasing the chloride scrubber efficiency requirements or increasing the need for drying in a CO₂ compression train, can present a more accurate view of the technologies' impact on the total plant.
4. Overestimating heat recovery possibilities
Assuming uses are available for all low-quality heat (less than 150 °F) can overstate heat recovery possibilities. Not all low-quality heat can be utilized efficiently in every process design. Some may have to be rejected to the cooling water system or other non-recoverable sinks.
5. Omitting the initial fill quantities or costs and/or minimizing makeup rates or costs
Estimating appropriate initial fill quantities and makeup rates for consumables reduces errors in accidentally underestimating operating and startup costs.
6. Ignoring the potential impact of novel technologies on plant availability or capacity factor
Using capacity factors identical to the reference cases enables more direct comparisons between cases. However, if a technology could impact the availability of the plant, the analysis should include an estimate of the impact and a discussion of the reasoning behind it.
7. Using overly simplified scaling methods or assumptions for equipment costs
Estimating appropriate capital costs for all equipment or sub-system items is crucial to any TEA. Utilizing information provided in the QGESS #7 document "Capital

Cost Scaling Methodology” and other design engineering standard practices can reduce accidentally underestimating capital costs.

8. Omitting the basis of design, performance, and/or costs for process components

Projecting designs and operating parameters is expected, but relevant test data (kinetic data, reaction rates, selectivity, degradation, attrition) or future test plans should be explained to enable tracking of progress toward proposed designs.

A discussion of the risks associated with planned research can help guide future work and demonstrate an understanding of the necessary development steps toward a commercially viable technology offering.

9. Neglecting or minimizing details of novel materials and consumables

Technologies that use novel or proprietary materials or consumables should include a discussion of the current production methods and costs. Expected scale-up or manufacturing improvements can be proposed, and a sensitivity to the range of expected costs will show the economic attractiveness of these advancements.

10. Omitting discussions of system integration, including expected complexity, startup and turndown concerns, etc.

Integration of novel technologies into reference plant designs should describe expected complexity and plant interfaces ranging from adding a simple bolt-on attachment before the stack to requiring recycle to the boiler, enriching feed streams, steam extractions, cooling water requirements, or additional electrical auxiliaries. Major startup or turndown concerns should be identified to demonstrate understanding of the novel phenomena and the expected market. These concerns can be mitigated by comparing them to existing technologies or by performing more detailed engineering and costing to help bound the effects.

11. Omitting sensitivities to key assumptions for performance or costs

Idealized performance can help clarify the potential of a novel technology; sensitivities to the important operating parameters help demonstrate the benefits of continuing research and development.

Each examined sensitivity represents an opportunity to improve the attractiveness of a new technology. The resulting effect on the relevant metrics shows the possible benefit; the range of the varied parameters shows the possibility of continued research, which needs to be connected to expected tests of relevant phenomena.

Appendix A – Additional Metrics

The cost of CO₂ capture and the cost of CO₂ avoided are two additional metrics frequently included in requests for TEAs. The equations for these metrics based on the methodology used as of January 2015 are given below.

The cost of captured CO₂ represents the minimum CO₂ plant gate sales price that will incentivize carbon capture in lieu of a defined reference non-capture plant. The cost of captured CO₂ is calculated using the following formula—

$$\text{Cost of CO}_2 \text{ Captured} = \frac{(COE_{CCS} - COE_{Non\ CCS})}{CO_2 \text{ Captured}}$$

The cost of CO₂ avoided is calculated using the following formula—

$$\text{Cost of CO}_2 \text{ Avoided} = \frac{(COE_{CCS\ with\ T\ \&\ S} - COE_{Non\ CCS})}{CO_2 \text{ Emissions}_{Non\ CCS} - CO_2 \text{ Emissions}_{CCS}}$$

where:

- CCS—the capture plant for which the cost of CO₂ captured/avoided is being calculated
- Non-CCS—the reference non-capture plant, as described below
- COE—the cost of electricity, reported in mills/kWh
 - o The CCS plant includes compression to 2,215 psia
 - o For CO₂ Captured, the COE excludes transportation and storage (T&S) costs
 - o For CO₂ Avoided, the COE includes T&S costs
- CO₂ Captured—the rate of CO₂ captured, reported in tonne/MWh
- CO₂ Emissions—the rate of CO₂ emitted out the stack, reported in tonne/MWh

For today's greenfield coal with CCS plants, the reference non-capture plant used to calculate the cost of captured CO₂ is a supercritical pulverized coal (SCPC) plant without capture. For a greenfield natural gas-based power system, the reference plant used to calculate the cost of captured CO₂ is a non-capture natural gas-based plant. Values for these reference cases are presented in NETL's baseline studies "Cost and Performance Baseline for Fossil Energy Plants" listed in Exhibit 1-1 of this document.

Appendix B – Reference Plant Design Basis Parameters

Below is a brief description of design basis items found in the NETL baseline studies.

System Boundaries

The plant boundary limit is typically defined as the total plant facility within the “fence line” and may include—

- Delivered feedstock (e.g., coal, biofuel, and natural gas) [QGESS #3, 6, and 8]
- Miscellaneous delivered materials (e.g., limestone, CO₂ absorbent, and catalyst) [QGESS #3]
- Raw water makeup [QGESS #4]
- Intake air [QGESS #4]
- Stack gas or vent gases
- Waste streams (e.g., process water, ash, slag, and spent carbon)
- Products (e.g., high-pressure CO₂ [QGESS #5] and high-voltage electricity)

While the CO₂ transportation occurs beyond the plant fence line, the COE is frequently reported both with and without the T&S costs. The choice of including or excluding T&S costs in COE should be clearly indicated.

The treatment of the waste streams generated by the power plant is typically considered within the fence line and included in the capital and O&M costs of the plant. The treatment of the waste streams must be adequate for preparation of disposal either in a landfill or other commercial disposal option.

The treatment of stack and vent gases, as well as wastewater, must be sufficient to satisfy applicable environmental regulations.

Process Design Assumptions

Examples of process design assumptions are provided in this section. It is important to maintain consistent conditions across all designs that are intended to be compared. This is to ensure that the comparisons accurately highlight the performance and cost impacts of the intended systems. Well justified sensitivities are the best way to capture deviations from NETL baseline case assumptions for technologies with specific niches or advantages.

Feedstock Analysis—If the purpose of the TEA is to compare the advantages and benefits of an advanced technology, the feedstocks, including the fuel, should be the same for both the reference (refer to Section 2.1) and advanced cases. If multiple fuels are used (e.g., co-feeding of coal and biomass or coal and natural gas), the fractions of each fuel should be the same for the reference and advanced cases.

The QGESS documents #3 “Specification for Selected Feedstocks” and #8 “Detailed Coal Specifications” provide the specifications for natural gas, multiple coal types, and a number of other feedstocks (e.g., limestone).

Site Characteristics and Ambient Conditions—The site characteristics and ambient conditions can vary significantly based on location and should be taken into consideration when designing the power generation facility. The ambient conditions can have a significant impact on the performance of many systems in a power generation facility; the site characteristics can limit the layout design options, as well as fuel choices that are available. For instance, PRB coal can be delivered to a Midwest location at ISO conditions; however, lignite would not be economical to deliver and must be used at or near “mine mouth” locations (e.g., Texas or North Dakota). If choosing a location that differs from the site of the fuel source and those outlined in the baseline reference plant, the cost of the fuel must be adjusted for delivery. Additionally, the reason for location selection must be justified and documented in the design basis section of the TEA.

The QGESS #4 “Process Modeling Design Parameters” and #6 “Fuel Prices for Selected Feedstocks in NETL Studies” provide information on the cost of transportation of fuel, as well as the methodology for selecting ambient conditions based on location.

Steam and Gas Turbine Cycle Conditions—The conditions assumed for both the steam and gas turbine cycle have a significant impact on the overall performance of the plant. The ambient conditions, cooling water assumptions, and site characteristics will impact the final pressure ratios of these power cycles. In the event any of these change significantly, the changes should be documented in the TEA design basis section.

Environmental Controls and Performance—As mentioned in the previous section, the water and gas emissions from the facility must comply with any applicable regulations. Descriptions of the technologies utilized to control each environmental concern should be provided with as detailed performance and cost specifications as reasonable.

Balance of Plant—A summary of the remaining assumptions regarding the plant should be provided. An example of a balance of plant summary for an IGCC system is provided in Exhibit B-1.

Exhibit B-1 Balance of Plant Assumptions

Cooling System	Recirculating Wet Cooling Tower
Fuel and Other Storage	
Coal	30 days
Slag	30 days
Sulfur	30 days
Sorbent	30 days
Plant Distribution Voltage	
Motors below 1 hp	110/220 volt
Motors between 1 hp and 250 hp	480 volt
Motors between 250 hp and 5,000 hp	4,160 volt
Motors above 5,000 hp	13,800 volt

Steam and Gas Turbine Generators	24,000 volt
Grid Interconnection Voltage	345 kV
<u>Water and Wastewater</u>	
Makeup Water	The water supply is 50 percent from a local publically owned treatment works and 50 percent from groundwater and is assumed to be in sufficient quantities to meet plant makeup requirements. Makeup for potable, process, and de-ionized water is drawn from municipal sources.
Process Wastewater	Water associated with gasification activity and storm water that contacts equipment surfaces is collected and treated for discharge through a permitted discharge.
Sanitary Waste Disposal	Design includes a packaged domestic sewage treatment plant with effluent discharged to the industrial wastewater treatment system. Sludge is hauled offsite. Packaged plant was sized for 5.68 cubic meters per day (1,500 gallons per day).
Water Discharge	Most of the process wastewater is recycled to the cooling tower basin. Blowdown is treated for chloride and metals, and discharged.

Product Specifications

For power generation cases, the power produced should account for 100 percent of the product distribution. Any byproducts produced should not be considered in the financial analysis. If the topic of research does produce a salable product, a separate case considering the expected revenue can be provided in addition to the “no additional revenue” cases.

The CO₂ product should satisfy the “Conceptual Design Limits” for EOR as listed in the QGESS #5 document “CO₂ Impurity Design Parameters.”

CO₂ Removal

All cases that utilize CO₂ recovery should remove at least 90 percent of the CO₂ based on the raw syngas or flue gas carbon content. Final CO₂ product purity should satisfy “Conceptual Design Limits” for EOR as listed in the QGESS #5 document “CO₂ Impurity Design Parameters.” Product CO₂ delivery pressure should be 2,215 psia at the plant gate for delivery to the pipeline.

Availability and Capacity Factor

NETL typically assumes that the capacity factor will be equal to the availability. These values are commonly 80 percent for IGCC plants and 85 percent for PC and NGCC plants in both non-capture and carbon capture configurations. If possible, the capacity factor should be held to the suggested values. However, if the advanced technology will impact the availability of the entire plant, the basis for such a change should be clearly stated in the TEA design basis.

Plant Size

The PC cases should be sized to maintain 550 MW net power output with a single boiler and steam turbine, unless otherwise required and discussed for the advanced technology. This generally requires an adjustment to the reference plant coal feed rate to compensate for the auxiliary load and extraction steam (if any) required by the novel technology.

The size of a combined cycle plant, IGCC or NGCC, is typically determined by fully loading the combustion turbine (constant maximum power output) and then scaling the balance of plant accordingly. After adding the steam turbine power and subtracting the auxiliary loads, the net capacity is typically in the range of 500–700 MW for a 2-train combustion turbine and heat recovery steam generator (HRSG) tandem (2 x 50 percent) system that feeds into a single steam turbine (1 x 100 percent).

CO₂ Transportation and Storage

The cost of transportation and storage of CO₂ is location specific. Suggested values along with the methodology for their calculations are provided in QGESS #5 “Estimating Carbon Dioxide Transport and Storage Costs.” Available sites include Midwest, Texas, North Dakota, and Montana.

Finance Structure

The financial structure utilized for power generation facilities with advanced technologies should be a high-risk investor-owned utility, and the methodology should be the same methodology used in QGESS #1 “Cost Estimation Methodology for NETL Assessments of Power Plant Performance.”

An alternate discounted cash flow analysis approach and reporting of required selling price may be utilized in addition to the suggested approach but should not be substituted for the suggested approach.

The year dollar basis should be identical for the advanced and reference facilities, and should match the year suggested in the previously mentioned QGESS #1 document.

Appendix C – Example High-Level Performance Summary and Cost Tables

The following table formats are examples of high-level results that enable the comparison of the novel technology with a reference plant.

Exhibit C-2 Example of High-Level Performance Summary

Parameter	Reference Case from Baseline Studies	Novel Technology
Turbine Power (MWe)	464.0	680.0
Fuel Gas Expander (MWe)	6.7	5.0
Steam Turbine Power (MWe)	248.1	322.6
Gross Power Produced (MWe)	718.9	1,007.6
Coal Handling	0.5	0.5
Coal Milling	2.2	2.9
Coal Slurry Pumps	0.3	0.4
Slag Handling and Dewatering	1.2	1.5
Air Separation Unit Auxiliaries	1.0	1.5
ASU Main Air Compressor	64.7	84.9
Oxygen Compressor	10.1	13.3
Nitrogen Compressor	31.5	39.3
CO ₂ Compressor	35.4	41.9
Tail Gas Recycle Blower	2.2	2.9
Cooling Tower Fans	1.8	2.5
Boiler Feedwater Pumps	4.5	5.7
Flash Bottoms Pump	0.2	0.2
Circulating Water Pump	3.5	4.8
Quench Water Pump	0.6	0.8
Selexol Unit Auxiliaries	19.0	24.9
Gas Turbine Auxiliaries	1.0	1.5
Steam Turbine Auxiliaries	0.1	0.1
Claus Plant Auxiliaries	0.3	0.3
Miscellaneous Balance-of-Plant	3.0	3.0
Transformer Losses	2.7	3.7
Auxiliary Power Use (MWe)	-185.6	-236.7
Net Power (MWe)	533.2	770.9
As-Received Coal Feed (lb/hr)	481,787	632,523
Net Heat Rate (Btu/kW-hr)	10,540	9,571
Net Plant Efficiency (% HHV)	32.4	35.7
CO ₂ Capture Rate (%)	90.4	90.1
Net CO ₂ Emissions (lb/kW-hr _{net})	0.213	0.192
Simple Cycle Efficiency (%)	41.1	46.1
Steam Cycle Efficiency (%)	39.3	39.9
Shift Steam Requirement (lb/hr)	330,566	433,642

Exhibit C-3 Example of High-Level Cost Results

Costs	Reference Case from Baseline Studies			Novel Technology Case			Δ	
Capital Cost	BEC (\$1,000)	TPC (\$1,000)	TPC (\$/kW)	BEC (\$1,000)	TPC (\$1,000)	TPC (\$/kW)	Δ TPC (\$/kW)	Δ (%)
1 Coal and Sorbent Handling	33,394	44,080	83	39,227	51,780	67	-16	-19
2 Coal and Sorbent Prep & Feed	51,684	70,503	132	61,841	83,913	109	-23	-17
3 Feedwater & Balance of Plant	35,447	47,882	90	44,578	60,238	78	-12	-13
4a Gasifier	254,011	359,827	675	296,311	419,733	544	-131	-19
4b Air Separation Unit	224,008	271,050	508	290,220	351,166	456	-52	-10
5a Gas Cleanup & CO ₂ Separation	208,087	312,025	585	254,582	381,621	495	-90	-15
5b CO ₂ Purification & Compression	56,259	74,262	139	65,020	85,826	111	-28	-20
6 Hydrogen Turbine	129,157	170,319	319	166,450	219,662	285	-34	-11
7 HRSG	45,189	55,397	104	50,822	62,271	81	-23	-22
8 Steam Cycle and Turbines	68,916	87,335	164	82,911	105,093	136	-28	-17
9 Cooling Water System	29,760	39,663	74	36,875	49,133	64	-10	-14
10 Waste Solids Handling System	45,213	55,091	103	53,067	64,657	84	-19	-19
11 Accessory Electric Plant	81,200	106,392	200	91,369	119,748	155	-45	-22
12 Instrumentation & Control	24,763	33,396	63	28,242	38,087	49	-14	-22
13 Site Preparation	16,436	23,503	44	19,071	27,272	35	-9	-20
14 Buildings and Structures	17,067	21,850	41	18,960	24,251	31	-10	-23
Total Plant Cost	1,320,591	1,772,575	3,324	1,599,545	2,144,450	2,782	-542	-16
Other Capital Costs	(\$1,000,000)	\$/kW		(\$1,000,000)	\$/kW		Δ (\$/kW)	Δ (%)
Owner's Cost	421	790		513	666		-124	-16
Total Overnight Cost	2,194	4,114		2,658	3,448		-666	-16
Total As-Spent Capital	2,501	4,690		3,030	3,930		-760	-16
Fixed O&M Costs	(\$1,000/yr)	\$/kW		(\$1,000/yr)	\$/kW		Δ (\$/kW)	Δ (%)
Labor	32,324	61		36,168	47		-14	-23
Taxes and Insurance	35,452	66		42,889	56		-10	-16
Total Fixed Costs	67,775	127		79,057	103		-24	-19
Variable O&M Costs	(\$1,000/yr)	\$/MWh		(\$1,000/yr)	\$/MWh		Δ (\$/MWh)	Δ (%)
Maintenance Materials	35,256	9.43		42,432	7.85		-1.58	-17
Water	1,141	0.31		1,598	0.30		-0.01	-5
Chemicals	3,625	0.97		5,051	0.93		-0.04	-4
Waste Disposal	4,678	1.25		6,142	1.14		-0.11	-9
Total Variable O&M Costs	44,701	11.96		55,224	10.22		-1.74	-15
Fuel Cost	115,707	30.96		151,909	28.12		-2.84	-9
Cost of Electricity	(\$/MWh)			(\$/MWh)			Δ (\$/MWh)	Δ (%)
Capital Cost	72.79			61.00			-11.79	-16
Fixed O&M Cost	18.14			14.63			-3.51	-19
Variable O&M Cost	11.96			10.22			-1.74	-15
Fuel Cost	30.96			28.12			-2.84	-9
COE without CO ₂ T&S	133.85			113.97			-19.88	-15
CO ₂ T&S Cost	9.29			8.44			-0.85	-9
COE with CO ₂ T&S	143.14			122.41			-20.73	-14