PEFORMANCE RESULTS REPORT

Coal-Based Power Plants of the Future – Hybrid Coal and Gas Boiler and Turbine Concept with Post Combustion Carbon Capture (HGCC)

Rev. 1 – Final

Prepared by: Barr Engineering Co.

Updated April 2020

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

PEFORMANCE RESULTS REPORT

Coal-Based Power Plants of the Future – Hybrid Coal and Gas Boiler and Turbine Concept with Post Combustion Carbon Capture (HGCC)

Rev. 1 – Final

Prepared by: Barr Engineering Co.

Updated April 2020

PERFORMANCE RESULTS REPORT

Coal-Based Power Plants of the Future -Hybrid Coal and Gas Boiler and Turbine Concept with Post Combustion Carbon Capture (HGCC) $\overline{\text{Rev}}$, 1 – Final

Updated April 2020

Contents

List of Tables

List of Figures

List of Appendices

- Appendix [A Power Plant of the Future Process Flow Diagrams](#page-37-0)
- Appendix B Power Plant of the Future Overall and Feedwater Stream Mass & Energy [Balances](#page-41-0)
- Appendix [C Power Plant of the Future Site Layout](#page-49-0)
- Appendix [D Power Plant of the Future Performance Report List of Assumptions](#page-51-0)

Acronyms

1.0 Plant Performance Targets

1.1 General Plant Requirements

The proposed concept meets specific design criteria in the RFP as follows:

- Overall plant efficiency of 43% with ESS, 37% without ESS (RFP value 40% without carbon capture).
- Using a modular approach as much as possible.
- Near-zero emissions using a combination of advanced air quality control systems (electrostatic precipitator (ESP), wet flue gas desulfurization system (FGD), selective catalytic reduction (SCR) for NO_x control) that make the flue gas ready for traditional post-combustion carbon-capture technology.
- Capable of high ramp rates (expected 6% versus RFP 4%) and minimum loads (expected better than 5:1 target).
- Integrated energy storage system (ESS) with 50 MW Lithium Ion / Vanadium Redox Hybrid System.
- Minimized water consumption by the use of a cooling tower versus once-through cooling, and internal recycling of water where possible.
- Design and commissioning schedules shortened by using state-of-the-art design technology, such as digital twin, 3D modeling, and dynamic simulation.
- Enhanced maintenance features to improve monitoring and diagnostics such as coalquality impact modeling and monitoring, advanced sensors, and controls.
- Integration with coal upgrading or other plant value streams (co-production). Potential for rare earth element extraction in the raw coal feed stage.
- Natural gas co-firing is an integral part of the design with the gas turbine responsible for nearly a quarter of direct power output. The gas turbine exhaust is used to assist with heating the coal-fired steam boiler.

Table 1-1 General Plant Requirements

1.2 Water Requirements

Table 1-2 Water Requirements

1.3 System Size Basis

Table 1-3 System Size Requirements

1.4 Environmental Targets

Table 1-4 Environmental Targets

The output-based emissions limits shown above are specified in the Coal FIRST RFP. While these are reasonable emission limits, case-specific air-quality compliance requirements could drive limit adjustments. Ambient air-quality attainment designations vary across the country; therefore, the ultimate siting of the project will determine the increment of negative air quality impact that is available for new emissions. The carbon capture aspect of the project implies a process that exhausts a cooler residual gas stream to the atmosphere from a stack that is likely lower than a conventional coal plant stack. These stack parameters will be used as inputs to air dispersion modeling, which would be expected to show a dispersion profile different than experienced with a conventional coal-fired stack. Until siting and exhaust stream characteristics are established, it is possible that compliance with air quality standards could drive project design adjustments.

Table 1-5 Solid Waste Requirements

Table 1-6 Liquid Discharge Requirements

1.5 Plant Capacity Factor

Table 1-7 Plant Capacity Factor

2.0 Performance Results Summary

2.1 Plant Performance Summary

Table 2-1 Overall Plant Performance Summary

Table 2-2 Plant Power Summary

A Includes plant control systems, lighting, HVAC, and miscellaneous low voltage loads

3.0 Performance Results Details

3.1 Performance Model/Material and Energy Balance

The mass and energy balances around the power block of the system for the steam, flue gas emissions (including boiler and gas turbine), and feedwater systems were modeled in an integrated plant performance calculation tool—UniPlant from Doosan Heavy Industries. The results from the model are included in [Appendix](#page-37-0) A. The full-load carbon capture system mass and energy balance was modeled in Doosan Babcock process simulation software. Doosan Heavy Industries has modeled low-load operation of the power block and steam and flue gas emissions, and the University of North Dakota/Envergex has performed low-load operation modeling of the carbon capture system. Additional documents from Doosan Heavy Industries and Doosan Babcock and the modeling results performed by the University of North Dakota/Envergex are provided in [Appendix](#page-41-0) B.

Barr evaluated water, carbon, and other balance-of-plant systems by doing an overall mass balance in Excel, based on vendor-provided information. The environmental systems were specified based on the power block simulations, and vendor information was gathered and integrated into the overall mass balance.

The Hybrid Gas/Coal Concept (HGCC) power plant has a high predicted plant efficiency of 37.0% with PCC. This efficiency can be increased up to 43.2% during peak time by using ESS power charged with surplus power during low demand time and near area renewable power.

The HGCC power plant can use various kind of coals as well as natural gas. This feature can help energy security and flexibility during future fuel market fluctuation. Bituminous and subbituminous coal can be burned in a same boiler design with a well proven coal blending technology. In case of the High-Sodium lignite coal firing, a larger boiler is required for the same power output with bituminous. But, the same HGCC boiler can be used if the steam power output is reduced from 270MW to 227MW. The slagging and fouling can be controlled with the reduced heat release rate by this reduced power output and proper selection of boiler tube transverse pitch. The burner system can operate without significant issues using the High-Sodium Lignite coal moisture up to 40% moisture. Plant efficiency using the High-Sodium lignite coals is expected to be approximately 3.1% lower than a bituminous firing. The lignite coal power plant efficiency can be increased if the steam turbine is modified for 227MW power output. Additional coal drying system with waste heat can also increase efficiency.

The HGCC power plant can be applied and have optimum efficiency to all kinds of U.S. coals with small modification of steam turbine and an addition of coal drying system for the High-Sodium lignite coal. Standardization of power output with the same hardware design is a realization of the "Transformative" concept of Coal FIRST which is fundamentally redesigned to change how coal technologies are manufactured. For the power plant construction, it can be more focused on the performance optimization and selection of optimum power output combination selection of modular product. DHI has been putting a great effort on the hardware design for each power plant construction in the past. HGCC power plants with various power generation units of gas turbine and ESS are appropriate to cover the whole U.S. power plant owner needs. The HGCC power plant efficiency can be increased by increasing the main and reheat steam temperature more than 600°C. But, the steam temperature of 600°C would be very appropriate for the wide application of the HGCC in the U.S. because some coals may cause issues such as coal ash corrosion at higher steam temperatures.

3.2 Water Balance

A water balance was developed as part of the HGCC performance evaluation. Clean water is reused in the system as much as possible. Recycling considerations include:

- A portion of the cooling tower blowdown is used for the limestone slurry makeup that goes to the flue gas desulphurization scrubber and other FGD makeup water.
- The filtrate from dewatering is recirculated back into the scrubber as makeup.
- The carbon capture system produces a clean effluent at the cooler. This effluent is used as makeup to the PCC system, but about 50 gpm can be recirculated back into the overall plant makeup.
- About 24 gpm of condensate from the $CO₂$ compressors is recirculated back into the overall plant makeup.
- The distillate from the wastewater and ZLD system is recirculated back to the overall plant makeup.

The cooling tower makeup is considered greater than 95% of the overall plant makeup. The cooling tower evaporative losses are the most significant losses of water. The blowdown, which considers eight (8) cycles when using pretreatment addition for cooling tower make-up, is the largest stream that goes to wastewater. Because of the back-pressure requirements of the HGCC system, air-cooled condensers have not been considered as a viable cooling option.

Because the scrubber outlet temperature is expected to range from 50-55°C, the evaporative losses at the FGD system are not significant, and the makeup water requirement is enough for the reclaim recycle and limestone slurry feed. If the outlet temperature of the scrubber unit is higher, more cooling tower blowdown can be fed into the scrubber system as makeup water, while the remaining cooling tower blowdown is sent to the wastewater and ZLD system.

Separate systems for potable water (1 gpm), oil-water separator (3 gpm), and sanitary treatment were considered. These systems were not included in the system water balance and would operate independently of the plant. The stormwater system (estimated at 110 gpm rate) is also considered, but not included in the system water balance.

Table 3-1 Water Balance

3.3 Steady State Emissions Data

The environmental targets for emissions of Hg, NO_x , $SO₂$, and PM were presented in Section [1.4.](#page-8-0) A summary of plant air emissions is presented in [Table](#page-17-0) 3-2.

Pollutant	Bituminous TMCR at 85% Capacity Factor Kg/GJ (lb/MMBTU) (gross output)	Bituminous TMCR at 85% Capacity Factor Tonne/year (ton/year at 85% capacity factor)	Bituminous TMCR at 85% Capacity Factor Kg/MWh (lb/MWh) (gross output- unless specified other)	Subbituminous TMCR at 85% Capacity Factor Kg/MWh (lb/MWh) (gross) output-unless specified other)	Lignite TMCR at 85% Capacity Factor Kg/MWh (lb/MWh) (gross output- unless specified other)	Bituminous TMCR at 85% Capacity Factor PPMDV $(6\% O_2)$
SO ₂	0.000(0.000)	0.000(0.000)	0.000(0.000)	Ω	Ω	θ
NO _x	0.007(0.015)	148.6 (163.8)	0.056(0.123)	0.059(0.129)	0.062(0.137)	10
SO ₃	0.000(0.000)	0.000(0.000)	0.000(0.000)	Ω	Ω	$\overline{0}$
HCl	0.000(0.000)	0.000(0.000)	0.000(0.000)	Ω	Ω	Ω
Particulate	0.0003(0.0007)	6(6.6)	0.002(0.005)	θ	θ	Ω
Hg		0.0034(0.0037)	$9.2x10^{-7}$ $(2.0x10^{-6})$	$\mathbf{0}$	$\mathbf{0}$	$\mathbf{0}$
$CO2$ (gross output)	7(16)	167,616 (184, 765)	63 (139)	67 (149)	69 (153)	13,970
$CO2$ (net output)			75 (166)			13,970
Pollutant	mg/Nm ³					
Particulate Concentration	\langle 2 (after FGD at 32°F and 14.696 psia)					

Table 3-2 Air Emissions (Bituminous TMCR at 85% Capacity Factor)

 NO_x emissions from the boiler are anticipated to be below 150 ppm for bituminous coal firing using low NO_x burners and overfire air (OFA). It is further reduced to less than 10 ppm with the SCR system.

The temperature of the flue gas leading up to the gas-gas cooler (GGC) will be maintained higher than the acid dew point (\sim 130-140 \degree C), maintaining SO₃ in the gas phase. We, therefore, do not expect corrosion or fouling issues in the air-preheater or the feed-water heater HX.

Within the GGC, the flue gas is cooled to $\sim 95^{\circ}$ C, condensing a significant portion of the SO₃. Considering the bituminous coal composition, there is sufficient fly ash loading in the flue gas, where most of condensed SO_3 will be deposited. The SO_3 will adhere to the ash particles predominantly, and not on the tube surface, because of the much higher surface area of the fly ash. Some of the ash (with the condensed SO3) will find its way to the heat exchange surfaces of the GGC. The GGC is also equipped with aggressive soot-blowing functionality and complete soot-blowing coverage, to periodically clean the heat exchange surfaces in an effective fashion, allowing the HX to perform per design.

The GGC is installed ahead of the low temperature dry ESP, which is also designed with ash collection and discharge that can handle the SO_3 -coated ash. While earlier design guidelines may have been conservative with respect to acid dew points and heat exchanger operation, recent experiences in both Korea and China, provide sufficient data and details for the GGC design in the context of a low-temperature ESP $(< 100$ _oC₎,^{[i](#page-3-0)} [ii](#page-3-1)</sup>and provide the confidence that the GGC component can be operated reliably and meet performance targets (i.e., achieve low exit flue gas temperatures of ~90-100°C). Such operation is necessary to achieve the ultra-low emissions of particulate (<5 mg/Nm3) and acid gases. Additionally, materials of construction of the GGC (NL GGH Cooler) include sulfuric acid resistant material and a phenolic coating to combat any corrosion issues.

SO2 and Hg will be reduced to near zero by the wet FGD and new two-stage electrostatic mist eliminator (EME) technology. At the exit of the FGD, $SO₂$ concentration will be less than 15 ppm. The EME technology targets high-efficiency removal of pollutants via two steps: first, via the application of a micro spraying system that provides a very large number of reactive droplets and, consequently, a high surface area (10x versus the standard) to counteract the challenge of low SO2 concentrations at the exit of the FGD; and second, by incorporating a two-stage wet ESP (EME) for collection of the fine droplets with very high efficiency.

The EME is also very effective for particulate matter (PM), SO_3 , and Hg reduction. It has >99% removal efficiency for PM bigger than 0.7 μ m and >70% for 0.3 μ m or less. Therefore, EME has the same performance characteristics as a baghouse for PM10 removal.

In our AQCS system, a non-leakage gas-gas heat exchanger (GGH) is located before the dry ESP. Thus, this system includes a cold ESP, which has better removal efficiency of mercury. In addition, the majority of mercury in bituminous-fired boilers exists as Hg^{2+} , which is soluble. Most Hg^{2+} that is not removed in the ESP is captured by the wet FGD and additionally by the EME, which uses wet ESP technology to remove Hg^{2+} and Hg-PM. In the case of a subbituminous coal firing, Hg^0 exists in gaseous form. The SCR catalyst will oxidize a portion of the Hg^{0} to Hg^{2+} . This can be further supplemented with a trace bromide/iodide addition to the coalfired boiler, as necessary, to completely oxidize the mercury. The EME will also remove condensable PM such as SO_3 and HCl to a very high efficiency.

This AQCS system eliminates the need for activated carbon injection and additional sulfur oxide removal additives, which reduce CAPEX investment and OPEX cost.

Table 3-3 Carbon Balance

Table 3-4 Sulfur Balance

Table 3-5 Solid Waste

Table 3-6 Removal Performance

4.0 Equipment Summary

5.0 Technology Assessment

5.1 Technology Summary

The HGCC utilizes state-of-the-art power plant equipment and systems, including:

- USC pulverized coal boiler
- USC steam turbine
- AQCS consisting of SCR, ESP, Wet FGD, and EME
- PCC system and $CO₂$ compression
- Process controls
- ESS with storing capability from HGCC and nearby renewable source
- Advanced coal property monitoring and management system

The major engineering challenge will be integrating the following six systems into commercially-available hardware.

• *Indirect Coal Firing System.* This system effectively decouples coal mill operation from boiler operation. The advantage of this system is that the boiler turndown and ramp rate are dramatically improved when compared to a traditional pulverized coal boiler. This system mills the coal and stores it in bins, employing a $CO₂$ gas inerting system to prevent auto-ignition. Similar $CO₂$ gas inerting systems are deployed in the cement/lime industry and for lignite-fired boilers in Germany. From the bins, the coal is fed into the boiler as load changes. Kidde Fire Systems is currently developing the preliminary $CO₂$ gas inerting system design for the HGCC concept. DHI will supply the burners with design considerations identified during the FEED study.

In markets with increasing requirements for the flexible operation of the hard coal and lignite power plants, modifying an existing boiler and installing an indirect firing system in parallel with the conventional direct firing system will allow a reduction of the boiler's minimum load lower than 30%. In this way, a kind of "idle" operation can be achieved, where the plant stays on the grid at a very low load, providing primary and secondary control services with the ability to ramp up again whenever required by the system operator.

For fuels with high moisture contents, such as a lignite, the indirect firing concept requires heat energy for coal drying during pulverization and handling of the off-gas (vapors) from the dryer/pulverizer system. The process scheme of the steam-heated fluidized-bed drying and its integration in a hybrid firing system is shown in [Figure](#page-30-0) 5-1. The vapor resulting from coal water evaporation is cleaned and partially used for fluidization and heat recovery in the low-pressure preheaters of the power plant. A

system similar to that shown has operated for more than 10 years in the Niederaußem K power station (Germany), including a prototype fluidized-bed dryer.

Figure 5-1 External Pre-drying System based on Fluidized Bed Drying Technology for Lignite Firing

- • *Gas Turbine (GT) Integration*. The exhaust from the GT will be introduced into the boiler via the windbox and the overfire air system. The lower O_2 content and higher temperature of the flue gas requires that CFD modeling be performed to optimize the performance of the burner/OFA system for NO_x emission, combustion completion, and heat transfer rates for the various sections of the boiler (waterwalls, superheater, reheater, etc.).
- *Flue Gas/Air Heater Heat Recovery*. The high flowrate and temperature of the gas turbine flue gas (which, in part, is used to supply oxygen for combustion) minimizes boiler air preheating requirements. To accomplish the required heat recovery from the combustor flue gas, two additional heat exchangers are included to preheat the condensate and the feedwater system. The equipment used to achieve this integration is standard commercial systems; however, its integration with the boiler/feedwater cycle is novel.
- *ESS (batteries)*. The ESS (Lithium Ion / Vanadium Redox Hybrid System) is undergoing commercial deployment. Discussions are ongoing with ESS suppliers to integrate their systems with this concept.
- *Advanced coal property monitoring and management system.* This component is designed to minimize impact on performance and reliability. Variability of coal

properties is managed using on-line analyzers, fireside performance indices, and condition-based monitoring.

• *Cooling water circuit.* Due to the carbon capture system demands, we anticipate that the cooling tower cell footprint, power usage, and water usage will be significant compared to the rest of the plant. While we plan to further investigate how to optimize pretreatment to consider more cycles, reducing the amount of blowdown required for wastewater treatment, the evaporative losses and the makeup water necessary to recover those losses is great. In an effort to reduce the water consumption and wastewater, air-cooling was considered but disregarded due to backpressure requirements. We had also considered a modularized cooling system of cells, but due to their size, the modules would still require a significant amount of labor for installation. Further evaluation of how to reduce evaporative losses and water usage, the cooling tower footprint, and increased cooling efficiency could be beneficial.

5.2 Technical Challenges & Critical Components

5.2.1 Technical Gaps

The HGCC key technical gaps and risks as well as the proposed approaches to address them are discussed in the following subsections.

Boiler Combustion Gaps

Boiler Size: The USC technologies are well proven—up to 1,000 MW—and have demonstrated high reliability. However, a typical USC power plant is normally configured with a capacity of over 400 MW to take advantage of economies of scale. The 270 MW-class USC coal power plant, featuring rapid start and low-load operation, will require a thorough design study and analysis.

Coupled Indirect System Design and Optimization: Pulverized coal combustion systems are divided according to how they are connected to the boiler. In the preFEED phase, indirect coal firing system was applied to improve plant flexibility. To optimize the efficiency of the plant, it was upgraded to a system that combines boiler and pulverizer air. In the FEED study, coupled indirect system will be further developed through detailed design and system risk assessment.

Use of the turbine exhaust gas in the OFA ports is beneficial because the lower oxygen concentration and higher gas flow provides higher momentum for mixing with the main boiler flue gas (always a challenge for OFA injection). It also provides reduced O_2 levels throughout the furnace volume, reducing the formation of NO_x along with improved burnout.

Mixing the GT flue gas with the combustion air does not significantly affect flame stability. However, the draft loss of the burner air register increases when the oxygen partial pressure decreases, delaying combustion. This could result in increased unburned carbon content. This risk is mitigated by multiple strategies in our design.

Through the HGCC preFEED study, it is analyzed in terms of both the qualitative effects and the quantitative effects applying actual boiler design in both the GT exhaust gas and pure-air modes by combustion CFD. Investigated parameters include gas temperature, flow distribution, species concentration, and char burnout. CFD results show that NO_x concentration at the furnace outlet is 99 ppm (at 6% O2) in GT exhaust mode and 113 ppm in pure-air mode, which are less than the NO_x emission target of 150 ppm. Carbon in ash at the outlet of the furnace is 4.5% in the GT exhaust-gas mode and 2.7% in the pure air mode. These results indicate no serious problems in terms of combustion. These combustion performances will be verified in further by a pilot-scale test in the FEED study. However, the OFA system should be considered further to enhance flow penetration, such as by introducing two-stage OFA. In addition, it is assumed that GT exhaust gas and air are completely mixed, so suitable a mixer and duct should be designed to match this assumption.

Boiler Heat Transfer Surfaces: USC heat transfer surfaces operate at higher temperatures than subcritical boilers. The proposed concept has a lower adiabatic flame temperature than pure air combustion. The addition of the GT exhaust gas in the OFA could result in changing the furnace exit gas temperature, which would shift the heat absorption duty from the furnace body to the convective section. All of these could result in boiler heat absorption changes. Such changes require an optimization study of the configuration and design parameters of the boiler to maximize the benefits (heat extraction) and minimize the risks (fouling and slagging in convective section) for boiler design and the RFP requirements.

5.2.2 Risks

The key technical risk associated with the HGCC is the integration of the combustion turbine into the boiler. Introduction of turbine exhaust into the boiler requires that the following areas be redesigned compared to a traditional pulverized coal boiler (refer to Section [5.1\)](#page-29-1):

- Coal preparations, handling, storage, and fire suppression systems
- Furnace windbox and burners
- Overfired air system
- Flue gas/air heater and external heat exchangers

The design issues are anticipated to cover:

- $CO₂$ inerting system
- Heat transfer for the various boiler sections
- Expected tube metal temperatures and their variation as load changes
- NO_x emissions reductions from the overfire air system
- Flue gas temperature entering the SCR system at all boiler loads
- Efficiency at risk during high ramp rates
- Minimum load considerations

5.3 Development Pathway

5.3.1 Research & Development

To address the gaps identified above, we recommend:

- Burner evaluation to identify the optimal operating parameters for hotter transport air
- Demonstration testing at the MW_{th} scale to verify and confirm the CFD model and burner evaluation
- Burner performance test
- Optimizing OFA design

Analysis of the boiler furnaces using GT exhaust gas as an oxidant showed no serious problems in terms of combustion. This analysis result is performed under the premise that the GT exhaust gas supplied to the burner is well mixed with pure air and the mixed oxygen concentration is constant. Therefore, there is room for change, depending on actual GT and boiler operation. It is considered necessary to review this in the future and further study is needed.

It is proposed to carry out a combustion performance test by applying a pilot scale model (3MW) of actual burner. The burner combustion test facility owned by Doosan Heavy Industries & Construction is designed to recycle exhaust gas and supply pure air to the burner. It also has an indirect type pulverizer, which can be used to check the burner's combustion performance against the actual combustion conditions, which can be operated in the boiler by controlling the concentration of oxygen supplied to the burner by load. It is possible to obtain flame characteristic data according to the burner outlet speed which is different between the pure air operation mode and the GT exhaust gas operation mode.

Optimizing OFA Design

As confirmed by the analysis results, the penetration depth was different because the flow rate difference between the GT exhaust gas and the pure-air operation mode is very large. In order to optimize the performance, it is necessary to review the design that satisfies both modes of operation, such as adopting a two-stage OFA.

Mixer and Mixing Duct Design and Optimization

In the preFEED phase, the GT exhaust gas and the air were assumed to be completely mixed in the GT exhaust gas operation mode. However, this kind of mixing requires a suitable mixer and duct design for it.

Coupled Indirect System Design and Optimization

Pulverized coal combustion systems are divided according to how they are connected to the boiler. In the preFEED stage, indirect coal firing system was applied to improve plant flexibility. To optimize the efficiency of the plant, it was upgraded to a system that combines boiler and pulverizer air and injects it. This will further be developed in the FEED study.

The proposed development is essential to identifying the optimal method of adding GT flue gas into the boiler system without adversely affecting boiler design. A two-year timeline is proposed for the evaluations with a completion date of 2022. A FEED study can be performed concurrently with the evaluations. Subsequently, a demonstration of the concept to reduce investment and risk can be implemented in the 2024-2027 timeframe and the FEED updated to include results from the demonstration.

[Table](#page-34-0) 5-1 illustrates items to be addressed during the FEED stages of the project

Table 5-1 Technical Pathway

A project schedule has been developed as part of the project execution plan provided in [Appendix](#page-49-0) C. Items in the technology gap review will be addressed during the FEED study.

5.4 Technology Original Equipment Manufacturers

5.4.1 Commercial Equipment

The equipment required to execute the HGCC project is available on the market. Examples of the major components are listed in [Table](#page-35-2) 5-2. To the greatest extent practicable, all equipment and products purchased will be made in The United States of America, shop assembled and shipped. This will be further defined in our FEED proposal.

Table 5-2 Commercially Available Equipment

Equipment Requiring Research & Development

The main R&D challenge for the HGCC is the new and emerging hardware in the ESS Battery storage system. The concept envisions a 50-MW storage system integrated into the basic USC pulverized coal steam cycle. Items of concern are the capital cost, O&M cost, efficiency, and longevity.

The remainder of the concerns involve integrating the indirect firing system and the combustion turbine into the USC boiler design.

The R&D items listed in [Table](#page-36-0) 5-3 will be developed during the preFEED stage and conducted and completed in the FEED stage.

Table 5-3 Equipment Not Commercially Available

Appendix A Power Plant of the Future Process Flow Diagrams

Appendix B Power Plant of the Future Overall and Feedwater Stream Mass & Energy Balances

^A Steam table reference conditions are 32.02°F and 0.089 psia

^A Steam table reference conditions are 32.02°F and 0.089 psia

 $^{\rm B}$ Aspen thermodynamic reference state is the component's constituent elements in an ideal gas state at 25°C and 1 atm

CO2 Spent

Notes:

[1] Stream table data from the "HBD_BLR" & "HBD_TBN" tab of Doosan's conceptual heat and mass balance spreadsheet: DOE_HGCC_Pre‐ FEED_Final_TMCR_Release_rev0.2.xlsx

[2] Stream data design based off Exhibit 3‐ 54 Case B12B stream table, supercritical unit with capture on page 139 of the NETL report: \\barr.com\projects\Mpls\48 WV\31\48311001 Coal FIRST_01 Coal and NG Concept\Deliverables\20190731 CoalFIRST CombustionConcept 17_FINAL.docx

[3] The following Streams are no flow streams for the full load base case and would only have flow during certain situations such as startup or shutdown: 3A, 21A

 $^{\rm B}$ Aspen thermodynamic reference state is the component's constituent elements in an ideal gas state at 25°C and 1 atm

^A Steam table reference conditions are 32.02°F and 0.089 psia

^A Steam table reference conditions are 32.02°F and 0.089 psia

Notes:

[1] Stream table data from the "HBD_BLR" & "HBD_TBN" tab of Doosan's conceptual heat and mass balance spreadsheet: DOE_HGCC_Pre‐ FEED_Final_TMCR_Release_rev0.2.xlsx

[2] Stream data design based off Exhibit 3‐54 Case B12B stream table, supercritical unit with capture on page 139 of the NETL report: \\barr.com\projects\Mpls\48 WV\31\48311001 Coal FIRST_01 Coal and NG Concept\Deliverables\20190731 CoalFIRST CombustionConcept

17_FINAL.docx

[3] The following Streams are no flow streams for the full load base case and would only have flow during certain situations such as startup or shutdown: 3A, 21A

^A Steam table reference conditions are 32.02°F and 0.089 psia

Appendix C Power Plant of the Future Site Layout

Appendix D Power Plant of the Future Performance Report List of Assumptions

Appendix D Assumption List

- I. Site Characteristics and Ambient Conditions (Based on Design Basis Report)
- II. Water Balance
	- 1. Condenser backpressure is 1.5" Hg
	- 2. The hot circulating water temperature is 80oF, and is cooled down to 60oF
	- 3. The cooling tower will be run at at least eight (8) cycles of concentration to meet the cooling tower circulating water quality limits
	- 4. Boiler feedwater is 33.4gpm
	- 5. 15.4gpm of the treatment water backwash is sent to the wastewater treatment to maintain water balance.
	- 6. Scrubber Evaporative Losses are based on 55oC.
	- 7. 12.3 m3/hr of chloride is purged from the FGD
	- 8. Gypsum moisture is 0.15%
	- 9. The Gypsum bonded water is 21% of the total Gypsum capacity.
	- 10. FGD Makeup water / Limestone Slurry Feed can be taken from the cooling tower blowdown
	- 11. Limestone slurry feed is based on an 80/20 Water/Limestone mixture.
	- 12. 10,000 kg/hr of Flue Gas PCC condensate can be used in the remainder of the plant.
	- 13. PCC Effluent is based on Doosan's PCC Performance Results Rev F03.
	- 14. Wastewater Distillate can be reused in the plant makeup water system.
	- 15. Wastewater sludge is based on Doosan's PCC Performance Results Rev F03.
	- 16. Wastewater Effluent losses are 20%
	- 17. Flows are representative of average daily flows for annual average conditions
	- 18. Equipment shall not be designed to handle peak flows.
	- 19. Sanitary wastewater will be discharged to the POTW
	- 20. Coal pile area is 5 acres
	- 21. Paved area is 20 acres
	- 22. Non-Contact Stormwater will be discharged from the facility as direct discharge without treatment
	- 23. Oily wastewater will be treated to remove oil/grease and the effluent routed to the local POTW. The effluent stream will contain less than 10 mg/L of oil/grease.
	- 24. Potable water demand is 20 gallons per day per person
	- 25. Average daily precipitation is assumed 0.5 inches
	- 26. Steam/Condensate/Feedwater cycle makeup is 1% of main steam flow
- III. Carbon-Sulfur Balance
	- 1. 90% of FGD Limestone Slurry is CaCO3.
	- 2. FGD Gypsum flowrate is based on 90% Gypsum.

IV. Civil Assumptions

V. Structural Assumptions

VI. Mechanical Assumptions

VII. EI&C Assumptions

 \overline{a}

ⁱ Zhang, Yang, et al. "Field test of SO3 removal in ultra-low emission coal-fired power plants." Environmental Science and Pollution Research 27.5 (2020): 4746-4755.

ii Chen, Heng, et al. "Fouling of the flue gas cooler in a large-scale coal-fired power plant." Applied Thermal Engineering 117 (2017): 698-707.