

100 MWe COAL-FIRED DIRECT INJECTION CARBON ENGINE (DICE)
COMPOUND REHEAT COMBINED CYCLE (CRCC) WITH 90 PERCENT
POST-COMBUSTION CO₂ CAPTURE

FINAL REPORT FOR PRE-FEED STUDY

U. S. Department of Energy (DOE)

Contract No. 89243319CFE000025, Coal-Based Power Plants of the Future

By



Nexant, Inc

and



Bechtel Power and Infrastructure

April 30, 2020

Contents

Volume I: Executive Summary & Business Case.....	1 - 52
Volume II: Design Basis Report.....	53 - 73
Volume III: Technology Gap Analysis Report.....	74 - 128
Volume IV: Performance Results Report.....	129 - 237
Volume V: Cost Results Report.....	238 - 268
Appendix A: Project Execution Plan Presentation.....	269 - 322
Appendix B: Sedgman Coal Beneficiation Study Report.....	323 - 417
Appendix C: CSIRO DICE Study Report.....	418 - 479

100 MWe COAL-FIRED DIRECT INJECTION CARBON ENGINE (DICE)
COMPOUND REHEAT COMBINED CYCLE (CRCC) WITH 90 PERCENT
POST-COMBUSTION CO₂ CAPTURE

Volume I: Executive Summary & Business Case

U. S. Department of Energy (DOE)

Contract No. 89243319CFE000025, Coal-Based Power Plants of the Future

By



Nexant, Inc

and



Bechtel Power and Infrastructure

Contents

Section 1 Executive Summary	5
1.1 Introduction.....	5
1.2 Business Case.....	5
1.3 Technology Description.....	7
1.4 Technology Gaps.....	8
1.4.1 DICE Technology Gaps and Risks	8
1.4.2 Fuel Production Technology Gaps and Risks	11
1.5 DICE CRCC Performance Results	14
1.5.1 Process Flow Diagram	14
1.5.2 DICE CRCC Plant Net Efficiency.....	16
1.5.3 Plant Emissions.....	17
1.5.4 Potential Variants.....	17
1.6 DICE CRCC Cost Results.....	19
1.6.1 Cost Estimation Methodology	19
1.6.2 Capital Cost Estimate.....	19
1.6.3 Operating Cost Estimate	20
1.6.4 Design Levelized Cost of Electricity (LCOE).....	21
1.6.5 LCOE Estimates of Variant Cases.....	22
1.6.6 Sensitivity Analysis	23
Section 2 Business Case	25
2.1 Objective	25
2.2 Introduction.....	25
2.2.1 Overview	25
2.3 Market Scenario	27
2.3.1 Key Influencing Drivers.....	27
2.3.2 Coal Pricing	28
2.3.3 Natural Gas Price	29
2.3.4 CO ₂ Constraint and Price	29
2.3.5 Renewables Penetration	30
2.4 Market Applicability & advantage of Concept	38
2.4.1 Domestic U.S.....	38
2.4.2 International.....	39

2.4.3	Advantage of Concept.....	40
2.5	Commercialization pathway.....	42
2.5.1	Overview	42
2.5.2	Two-Phased Approach.....	42
2.5.3	Transitioning between Two Phases	44
2.5.4	Structuring Financing for NoaK Plant	45
2.5.5	Capital Structure	47
2.5.6	Financing Stages.....	48
2.5.7	Categories of Risks	48
2.6	Conclusions	51

List of Tables

Table 1-1 Component R&D Program for DICE Commercialization	9
Table 1-2 Proposed Engine Scale-Up	10
Table 1-3 Power Summary and Net Efficiency	16
Table 1-4 Plant Emissions Summary	17
Table 1-5 Performance Comparison of Base Case DICE CRCC and Variants.....	18
Table 1-6 Capital Cost Summary for DICE CRCC Plant	20
Table 1-7 100 MWe Nominal DICE CRCC Annual Operating Cost Breakdown	21
Table 1-8 LCOE Parameters and Cost Breakdown	22
Table 1-9 Performance and LCOE Summary Comparison for DICE CRCC Variants	23
Table 2-1 Key Influencing Drivers	27
Table 2-2 Factors for Resurgence in U.S. of New Coal Power Projects.....	38
Table 2-3 Potential for International Coal Power Projects.....	39
Table 2-4 Example of Capital Structure for NoaK Plant	47

List of Figures

Figure 1-1 Simplified Schematic Diagram of Coal-Fired DICE GTCC with Hot Gas Expander and Duct-Fired HRSG	7
Figure 1-2 Key Coal Beneficiation Unit Operations.....	12
Figure 1-3 100 MWe Nominal DICE CRCC Process Flow Diagram	15
Figure 1-4 LCOE Tornado Chart.....	24
Figure 2-1 Main Commercial Factors	26
Figure 2-2 Electricity Share from 2019 to 2050	31
Figure 2-3 Projections of Expected Retirements and Additions from 2019 to 2050.....	32
Figure 2-4 Projections of High and Low Renewables Cost Sensitivity Cases from 2019 to 2050	32
Figure 2-5 Share of Solar PV and Wind Energy in Renewable Energy Growth from 2019 to 2050	33
Figure 2-6 Intermittent Renewable Energy Integrated with Energy Storage	34
Figure 2-7 Growth of BESS Follows Solar PV Growth from 2019 to 2050.....	35
Figure 2-8 Coal Capacity Retirement and Improved Capacity Factor from 2019 to 2050.....	37
Figure 2-9 Process, Activity, and Funding of Pilot Plant and NoaK Plant	42
Figure 2-10 Avoiding Technology Investing and Funding Gaps	44
Figure 2-11 Transitioning from Pilot Plant to NoaK Plant	45
Figure 2-12 Most Likely Scenario via Limited Recourse Financing.....	46
Figure 2-13 Limited Recourse Financing of Project Company	46
Figure 2-14 Three Main Stages of Financing	48
Figure 2-14 Three Key Categories of Risks	49

Section 1 Executive Summary

1.1 INTRODUCTION

The Department of Energy (DOE) Office of Fossil Energy (FE) and the National Energy Technology Laboratory (NETL), through its Coal FIRST (Flexible, Innovative, Resilient, Small, Transformative) initiative, seek to understand the configurations, equipment features, performance characteristics, and cost implications for a future commercial coal plant that incorporates attributes that include, among others, high overall plant efficiency, modular design, near-zero emissions, high ramp rates, minimized water consumption, integration with coal upgrading, and capable of natural gas co-firing.

Nexant and Bechtel performed a conceptual design of the **Direct Injection Carbon Engine-Gas Turbine (DICE) Compound Reheat Combined Cycle (CRCC)** that demonstrated the aforementioned attributes of such a power plant. An option to complete a pre-defined design package (Pre-FEED study) was exercised to prove the technical and economic feasibility of the plant configuration. These efforts are documented in this report, which involves partnering and gathering input from equipment manufacturers and technology developers in determining component options for the this technology.

1.2 BUSINESS CASE

The business case covers a market scenario leading up to the commercialization of the DICE CRCC power plant. The main focus was on a commercial market driven scenario that is projected to be a candidate for the commercial implementation of DICE CRCC power plants. The business case addresses four main commercial factors covering market scenario, market applicability and advantage of concept, estimated cost of electricity, and commercialization pathway or roadmap for the DICE CRCC technology and power plant starting from a pilot plant to a Noak commercial project.

Based on the current trends and outlook, the market scenario for coal based power generation varies widely on a regional basis both in the domestic U.S. and internationally. The commercial market dynamics are dependent upon key influencing drivers which may also serve as challenges and barriers which can potentially impact the commercial implementation of a DICE CRCC power project. These include energy supply, security, and independence, competing power sources, air emissions regulations, reducing carbon footprint, de-carbonization, and energy transition, and project financing. The market scenario leading up to the commercialization of the DICE CRCC power plant addresses the coal type, natural gas price along with a sensitivity analysis, CO₂ constraint of 90 percent and the current market price, and renewable energy penetration based on the EIA's Annual Energy Outlook 2020.

The market applicability in domestic U.S. is dependent upon key factors for the resurgence of new coal power projects which includes increase in price of LNG/natural gas, increasing value of CO₂ via regulation or carbon capture and utilization, and the impact of regulatory framework and policy. The market applicability internationally indicates countries with relatively lower cost coal

but higher domestic natural gas prices (e.g. China, India, and Australia) which may also find the DICE CRCC power plants and configuration appealing. In the various countries and regions (e.g. Japan, South Korea, and Europe), smaller, modular, and efficient DICE CRCC power plants utilizing coal will most likely be attractive. The utilization of CO₂ for either EOR and/or enhanced gas recovery are also growing potential opportunities.

The market advantage of concept demonstrate that the DICE CRCC power plant is well suited for certain specific markets with unique attributes and features, such as those with smaller capacity utility grid(s) unable to accommodate large capacity power plants, modular design enabling “building block” methodology for incremental capital investment and capacity additions to match utility grid demand loads, higher efficiency and ability to operate at range of capacity factors, high natural gas price, the ability to use diesel fuel, high ambient temperature and humidity, and high altitude installations.


Based on the overall performance, total as-spent cost (TASC), and annual operating cost of the 100 MWe DICE CRCC plant, its LCOE was estimated to be \$223.9/MWh. The LCOE of variant cases were also estimated with the DICE CRCC plant without PCC having an LCOE of \$148.6/MWh, and the “ideal” DICE CRCC with PCC and centralization beneficiation having an LCOE of 145.7/MWh.

From a commercial project development and project financing perspective, the commercialization pathway for the DICE-GT CRCC power plant requires a two-phased approach and manner – ***initially with a pilot plant and later followed by a NoaK commercial plant***. The key funding and financing assumptions and drivers include TRL, funding via equity and grants for the pilot plant, funding via equity and limited recourse financing via debt for the first 1 to 3 NoaK plants (later followed by non-recourse financing), fiscal and financial incentives, and “***bankable***” transactional contracts.

1.3 TECHNOLOGY DESCRIPTION

The thermodynamic driver behind the DICE CRCC plant concept is described in detail in the papers and articles by Gülen. A simplified system diagram of the DICE CRCC plant is shown in Figure 1-1.

Figure 1-1
Simplified Schematic Diagram of Coal-Fired DICE GTCC with Hot Gas Expander and Duct-Fired HRSG



As shown in Figure 1-1, air compressed in the turbocompressor is sent to the DICE engine intake after being cooled in an aftercooler to a suitable temperature (~120 °F). Multiple DICES, operating in parallel, burn MRC slurry to generate power. The DICE exhaust gas temperature is sent to the hot gas expander for power generation.

The bottoming cycle is a Rankine steam cycle comprising an HRSG and a steam turbine generator with the balance of plant (BOP) including a backpressure steam turbine, myriad pipes, valves, pumps and heat exchangers. The HRSG is a waste heat recovery boiler utilizing hot gas turbine exhaust gas to make steam. Duct firing of natural gas in the HRSG is required in order to generate enough steam to meet the demand of the PCC system.

The flue gas is desulfurized in a direct contact caustic scrubber to reduce the SO_x content in the flue gas to less than 10 ppm and reduce amine losses in the downstream post combustion CO₂ capture (PCC) unit, while also cooling and condensing water from the flue gas, before it is sent to the amine-based PCC unit to remove 90 percent of its CO₂.

1.4 TECHNOLOGY GAPS

The DICE CRCC delivers the promised capabilities by combining mostly standardized, off-the-shelf, and commercially mature equipment with proven technology in a thermodynamically optimum manner. The combination of reheat with constant volume heat addition delivers the most efficient heat engine cycle, which can be implemented in the field with multi-equipment configurations for maximum modularity and flexibility with high efficiency at small ratings.

The DICE CRCC with post-combustion carbon capture (PCC) is a low emissions, coal-fired power plant comprising three “blocks” or “islands”:

- Coal beneficiation and coal-water slurry (CWS) fuel processing and production
- Modular electric power generation
- PCC

The PCC Block utilizes amine-based chemical absorption technology, which is currently available and is not considered a technology risk. The power generation system also comprises of commercially mature and proven technology *except for the DICE*. Thus, the main focus of the technology gap analysis is on:

- DICE R&D and development pathway
- CWS processing and production

1.4.1 DICE Technology Gaps and Risks

All of the major pieces of equipment for the DICE CRCC power system are standardized, off-the-shelf, and commercially mature products (i.e., representing TRL 9). The least-proven part of the cycle is DICE, which is a reciprocating internal combustion engine (RICE) fired with a coal-water slurry fuel, and which requires the following modifications and development:

- New fuel injector
- Cylinder/piston coating (with carbide)

The project team worked with the Commonwealth Scientific and Industrial Research Organisation (CSIRO) of Australia to address the developmental needs of DICE in these areas. The team also plans to continue partnering with CSIRO to further develop these modifications for the next phase of work.

1.4.1.1 R&D Requirements for DICE Commercialization

Table 1-1 suggests the component R&D program to commercialize the MRC-fired DICE component.

**Table 1-1
Component R&D Program for DICE Commercialization**

Component	4-stroke	2-stroke
Cylinder liners	Hard coating, optional provision of oil scrapper grooves to allow increased bore lubrication and flushing of solids to reduce filtration load on crankcase lubrication	Hard coating, optional provision of oil scrapper grooves to allow increased bore lubrication and flushing of solids above the scavenge ports
Piston	No change in short term, optimization of bowl shape for MRC rather than low NOx as required for fuel oil	
Rings	Hard coating, improved design to improve down scrape of contaminated bore oil	
Stuffing box	No change	Seal oil protection to eliminate the ingress of contaminated cylinder oil
Scavenge box drainage	No change	No change if scrapper grooves are used in the cylinder walls otherwise improved drainage
Crankcase oil filtration	200 percent increased filtration capacity; dual systems to allow on-line maintenance, separate centrifuge for cylinder scrape.	No change, but with separate centrifuge for reconditioning cylinder scrape
Fuel supply system	Dual system is required: One for MRC and one for a diesel/fuel oil which would be used for starting, idling and optional pilot injection (1-5% of heat rate, as is currently used for some gas engines).	
Injection system	Seal oil protected sliding surfaces including the pump plunger and needle valve. The seal oil should be maintained at 120% of the fuel supply pressure at all times.	
Pilot injection	Pilot injection is essential for engine conditions where ignition is less reliable - starting, idle and shutdown. Pilot injection is recommended for engine speed above 400 rpm, and at low load.	
Exhaust manifold (low speed 2-strokes)	Large horizontal exhaust gas ducting should also be provided with a positive grit removal system (e.g. auger).	
Exhaust turbine	No change for ash with aerodynamic diameter <10um. Possible use of coated metal for inlet guide vanes.	
Waste heat recovery	Conventional solid fuel boiler type for heat recovery	
Exhaust gas cleanup	The same as used for large land mounted 2-stroke engines using heavy fuel oils – ESP or fabric filtration, SCR and FGD	
Lubrication	Adjustment of crankcase oil to match sulfur content of the MRC and with increased detergency to keep char and ash in suspension.	

1.4.1.2 Staged Development of DICE

Previous R&D on DICE, while having provided promising findings on technical issues, can only provide a technology readiness level (TRL) of 4 for most technical aspects. DICE still needs considerable development and demonstration to match the technical development of current power generation technologies. However, this can be cost-effectively fast-tracked. Compared to the incumbent technologies, DICE has strong technical merit because of the ability to carry out a near-commercial scale demonstration at a relatively small size (e.g. 5 MW).

The 5 MW capacity engine-generator can be obtained in skid form, in a straight 6 configuration, giving a cylinder of approximately 400 mm bore and operating at 500 rpm. The simple in-line configuration and fewer cylinders ensure easier and faster incorporation of new components for testing - *essential to shortening development time*. This includes the option of only needing to make changes to one cylinder – which can also be swapped out as a complete power unit in a few hours to facilitate testing.

The data, information, and experience gained from this engine would be directly applicable to a larger semi-commercial demonstration (e.g. a V18 configuration producing 15 MW at 500 rpm). It is envisaged that successful demonstration at this scale would lead to larger commercial installations comprising multiple 15-20 MW engines, as is practiced for gas engine installations, without entailing any scale-up of DICE.

The cylinder size, rating and power output from a single engine unit for the proposed development steps to a full-size commercial engine are shown in Table 1-2.

**Table 1-2
Proposed Engine Scale-Up**

Development stage	Bore (cm)	Cylinder rating (kWe/cyl)	Cylinders Units	Plant Output (MWe)	Scale up
Small scale demonstration	46	1000	6	5-6	1
Demonstration plant	46	1000	18	20	1
First commercial	46	1000	18 5 units	100	1
Large commercial 4-stroke	63	2000	18 5 units	200	2x
Large commercial 2-stroke	94	5000	12 6 units	360	5x

The scale-up factor (based on cylinder area) between the development stages is at most 2-3x, which are relatively small scale-up steps compared to other technologies. It is envisaged that a staged development program could be established with an engine manufacturer and OEMs (e.g. suppliers of injection and turbocharging components) to quickly undertake the demonstration program to enable commercial deployment by 2030.

Following the successful demonstration, rapid commercialization is possible, and likely to be driven by a strong need for incremental coal generation capacity for:

- Replacing old, inefficient and uneconomic PC power plants (say units smaller than 300 MW and/or older than 30 years in plant economic life)
- New load-following capacity to secure a higher penetration of renewables, and in direct competition with gas open cycle plants with gas prices over \$5/GJ
- Remote generation, especially for supplying large mines and surrounding regions
- New capacity with CO₂ capture and storage, as DICE has the potential for a 30 percent reduction in the cost of capture over PC coal plants. The cost reduction is due to a combination of higher thermal efficiency (fewer kg CO₂/MWh) and the ability to use 130°C coolant and exhaust heat for stripping
- Once an engine is adapted for DICE it will be capable of handling a wide range of other alternative fuels (i.e. difficult) fuels (for example coal-biochar or coal-ammonia blends, crude bio-oils) which would extend the facilities value past the proposed demonstration, and provide additional environmental incentives for the facility and commercialization of DICE.

MRC, including higher ash products, could be used to replace fuel oil for boiler light-up and low load operation.

1.4.2 Fuel Production Technology Gaps and Risks


The project team worked with the Sedgman Inc to develop a flowsheet for the coal beneficiation and slurring process and to address the developmental needs of the coal beneficiation plant. It is understood from Sedgman that for a typical commercial beneficiation process, there are currently no specific components, equipment, or systems which require undertaking traditional R&D nor having any technology gaps. However, as part of the overall beneficiation process, there are key commercially available plant unit operations whose end-use application is novel - when beneficiation is based on coal. As shown in Figure 1 2, these unit operations include fine grinding mill, ash removal (via rougher flotation and cleaner flotation), and tailings handling.

In this study's performance evaluation of the DICE CRCC, subbituminous PRB coal was used as the feedstock to the beneficiation plant. Due to the hydrophilic nature of the PRB coal, the overall product recovery yield was about 50 percent on both a mass and combustible value basis. A consequence of this low product yield is the large quantity of reject tailings that, while still containing significant heating value, is in slurry form, and has no commercial value. The unsaleable tailings thus has to be disposed of in ash ponds, which constitute an environmental risk.

While it is possible to process the reject slurry (via dewatering, briquetting, etc.) to a more functional form, this requires additional energy and cost input. It is therefore key to address the

likely technology gap associated with disposing the otherwise unsaleable reject slurry tailings from coal beneficiation.

Figure 1-2
Key Coal Beneficiation Unit Operations



It is of utmost importance to increase the product recovery yield to way beyond the current 50 percent. Doing so would not only decrease the coal feed required by the beneficiation plant, but also minimize the quantity of reject tailings. It is understood that the hydrophilic nature of the subbituminous coal as-is makes it difficult to achieve a high recovery via the conventional flotation process for ash separation. Tests on various coal samples should therefore be undertaken to identify coal types that can achieve maximum product recovery

1.4.2.1 Development of Coal Processing Plant

From this study, items in proposed order of testing as discussed below, should be included in an ongoing work plan to further progress the development pathway of MRC as fuel for the DICE CRCC.

Feed Coal Analysis: One of the main drivers for the success of DICE CRCC is the feed coal selection. The PRB coal is shown to be not suitable in current pre-FEED study. Bench-scale tests are therefore needed on various coals to establish and select feed with best available yield, while meeting the heating value, ash content, and rheology specifications required by DICE. The

selection of the preferred coal type is a critical component of any ongoing work as this will drive the downstream test work.

Coal Grain Analysis: Once a preferred coal source, or sources, are identified, detailed coal grain analysis on this coal is required to determine liberation requirements to reach the required product ash level.

Crushing and Grinding Test Work: Laboratory scale comminution tests (comminution is particle size reduction by breaking, crushing, or grinding of ore, rock, coal, or other materials) should be carried out on the selected coal to determine the energy inputs required for crushing and grinding.

Flotation Tests: Flotation tests should be performed on freshly ground coal samples to avoid oxidation of the particle surfaces which will adversely impact flotation performance. The results of the flotation test work may require an iteration of the grinding work to be done.

Thickening and Dewatering Tests: Both the product (concentrate) and tailings material from the flotation test work would need to be collected to perform thickening and dewatering testing. Thickener testing will help to determine thickener size, flocculant type and dosage rates. Dewatering test work will help to size the dewatering equipment and assist in selection of the final dewatering technology to use.

Rheology Characterization: To support the sizing and selection of agitators, pumps and piping a range of rheology characterization tests should be undertaken on the key intermediate and final product and tailings slurry streams.

Pilot Plant Operation: While the individual pieces of major equipment required for the coal beneficiation plant producing MRC slurry are commercially available, the overall process as applied to coal is novel. It is therefore recommended that following the completion of the above initial laboratory scale analysis, a pilot plant be constructed and operated to provide an indication of the expected continuous performance.

1.4.2.2 *Centralized Beneficiation Plant*

For a small, modular power plant such as the DICE CRCC (< 100 MW for this introductory variant), the performance and cost estimates presented in the report suggest that it makes no economic sense to install a coal beneficiation plant on-site at every DICE CRCC plant. This is analogous to building a crude oil refinery on-site at every gas station. For the modular DICE CRCC plant to be feasible, there must be multiples of such power plants, each receiving fuel from a centralized coal beneficiation plant, thereby taking advantage of the economies-of-scale benefits that the large central beneficiation plant possesses. Research and development efforts must therefore be geared towards a large centralized processing facility, and take into consideration the delivery aspects of the beneficiated coal (e.g. delivering the coal in dry, powdered form risks self-ignition, slurry form delivery incurs additional costs for shipping what is essentially just water)


1.5 DICE CRCC PERFORMANCE RESULTS

1.5.1 Process Flow Diagram

The overall DICE CRCC power plant PFD is shown in Figure 1-3 and comprises the following:

- Coal beneficiation plant
- 5 DICE (nominally 20 MWe each)
- 1 main air compressor (MAC)
- 1 hot gas expander
- Bottoming cycle consisting of HRSG with natural gas duct firing and back pressure steam turbine
- 30 wt% MEA-based PCC unit capturing 90 percent of CO₂ in the flue gas

Figure 1-3
100 MWe Nominal DICE CRCC Process Flow Diagram



1.5.2 DICE CRCC Plant Net Efficiency

Table 1-3 summarizes the overall performance based on the design of the nominal 100 MWe DICE CRCC power plant. Overall fuel mix to the plant consists of 71.5 percent coal, 3.5 percent diesel fuel and 25.0 percent natural gas, on an LHV basis. The net efficiency of the plant is 30.8 percent on an LHV basis (29.1 percent HHV). As the rejected PRB coal tailings from the beneficiation process do not participate in the combustion reactions, the heating value associated with these rejects is not included in the efficiency calculation.

**Table 1-3
Power Summary and Net Efficiency**

Power Summary	
POWER GENERATION, kWe	
5 x DICE	78,730
Turboexpander	31,787
Steam Turbine	14,676
Total Power Generation	125,192
AUXILIARY LOAD SUMMARY, kWe	
MRC Fuel Prep	5,472
Main Air Compressor	26,301
SCR	88
Fabric Filter	69
Boiler Feed Water Pump	261
Economizer Recirculation Pump	5
Steam Turbine Auxiliaries	31
DCC Circulating Pump	400
CO ₂ Capture	2,549
CO ₂ Compression	7,838
Circulating Water Pumps	2,407
Makeup Water Pumps	70
Cooling Tower Fans	977
Wastewater Pumps	14
Miscellaneous Auxiliaries	135
Transformer Losses	626
Total Auxiliaries, kWe	47,242
Net Power, kWe	77,950
As-Received PRB Coal Feed, lb/hr	148,818
Beneficiated Coal Slurry Fuel Feed, lb/hr	91,934
Diesel Fuel Feed, lb/hr	1,651
Natural Gas Feed Flow, lb/hr	10,640
Coal LHV Thermal Input, MMBtu/hr	619
Diesel LHV Thermal Input, MMBtu/hr	30
Gas LHV Thermal Input, MMBtu/hr	216
Total LHV Thermal Input, MMBtu/hr	865
LHV Efficiency, %	30.8%
Coal HHV Thermal Input, MMBtu/hr	643
Diesel HHV Thermal Input, MMBtu/hr	32
Gas HHV Thermal Input, MMBtu/hr	239
Total HHV Thermal Input, MMBtu/hr	914
HHV Efficiency, %	29.1%

1.5.3 Plant Emissions

Table 1-4 summarizes the various DICE CRCC plant emissions and control measures undertaken to achieve these emissions.

**Table 1-4
Plant Emissions Summary**

Pollutant	lb/MWh-gross	Control Technology
SO _x	Trace (0.000)	Direct Contact Cooler (DCC) with caustic scrubbing + MEA reaction with residual SO _x in flue gas to effectively reduce to zero
NO _x	1.2	Selective Catalytic Reduction + MEA reaction with NO ₂ to effectively scrub out all NO ₂ , reducing NO _x content by 10% (assume 90:10 NO/NO ₂ ratio in flue gas) while all NO passes through
PM	Trace (0.000)	DCC water wash in PCC plant further scrubs out residual PM in flue gas
Hg	3 x 10 ⁶ (estimated)	Third Stage Separator (TSS) + SCR + DCC. If mercury is still an issue, activated carbon injection (ACI) can be utilized at a location with appropriate temperature before the cyclone.
HCl	0.06 (unabated) 0.000 (SO _x surrogate)	Uses SO _x as surrogate, per DOE Bituminous Baseline Report
	lb/MWh-net	
CO ₂	221	30 wt% MEA
Volatile Organic Compounds (VOC)	1 ppm	Water wash at the top of the PCC absorber is expected to remove VOC in flue gas before venting to atmosphere

1.5.4 Potential Variants

Two variants of the DICE CRCC system were considered and their performances were evaluated as part of this study. One scenario considered eliminating PCC of the DICE CRCC system flue gas. In this case, exhaust steam from the main steam turbine that would have been diverted to the PCC is sent to a condensing turbine to produce more power, resulting in greater power generation from the steam cycle.

The second scenario evaluated was that for a modular DICE CRCC plant that, instead of having an on-site, similarly modular coal beneficiation plant, receives coal from a centralized beneficiation facility, thereby taking advantage of the economies-of-scale benefits that a large central beneficiation plant possesses.

Table 1-5 summarizes the plant performances of these variations, along with the base case.

**Table 1-5
Performance Comparison of Base Case DICE CRCC and Variants**

Description	DICE CRCC with PCC (On-site coal beneficiation)	DICE CRCC No PCC	DICE CRCC with PCC (Centralized coal beneficiation)
POWER GENERATION			
DICE	78,730	78,730	78,730
Turboexpander	31,787	31,900	31,787
Steam Turbine	14,676	31,299	14,676
Total Power Generation, kWe	125,192	141,929	125,192
AUXILIARY LOAD SUMMARY, kWe			
Coal Processing	5,472	5,472	500
Power Cycle Auxiliaries	27155	27476	27155
CO2 Capture and Compression	10387	0	10387
Balance of Plant	4,229	3,891	4,240
Total Auxiliaries, kWe	47,243	36,840	42,282
Net Power, kWe	77,949	105,089	82,910
Coal HHV Thermal Input, MMBtu/hr	643	649	643
Diesel HHV Thermal Input, MMBtu/hr	32	33	32
Gas HHV Thermal Input, MMBtu/hr	239	270	239
Total HHV Thermal Input, MMBtu/hr	914	952	914
HHV Efficiency, %	29.1%	37.7%	31.0%
LHV Efficiency, %	30.8%	39.9%	32.7%

1.6 DICE CRCC COST RESULTS

1.6.1 Cost Estimation Methodology

Capital costs for the 100 MWe DICE CRCC plant were derived based on the following methodology:

- Capital costs for the coal beneficiation system were estimated by Sedgman and presented as a turnkey subcontract cost in this report. The capital cost estimate is reflective of the facility fully designed, supplied, fabricated and delivered to site, constructed and commissioned in accordance with the coal beneficiation plant scope of work detailed in the pre-FEED performance results study. .
- The costs for certain specialized, commercial equipment associated with the DICE CRCC plant, such as the air compressor, hot gas combustor, hot gas expander and the various generator equipment, were estimated and verified with budgetary quotes from equipment vendors. These were then developed up to the total plant cost level, which includes bulk material, labor, and construction indirect costs based on historical factors for similar equipment type.
- Post combustion capture (PCC) plant cost was determined via a bottoms-up cost estimate based on major equipment sizing and using past quotes from equipment vendors or cost curves derived from commercial cost estimate software
- DICE CRCC balance of plant (BOP) systems were estimated via a bottoms-up cost estimate based on major equipment sizing and developed to total plant cost level using historical factors. The exception is the ash handling system, which was scaled via capacity factor, using appropriate scaling parameters and capacity factoring exponents stated in NETL's Quality Guidelines for Energy System Studies (QGESS) Cost Scaling Report

1.6.2 Capital Cost Estimate

Table 1-6 provides a summary of the DICE CRCC total plant cost (TPC), total overnight cost (TOC), and total as-spent cost (TASC), in 2018 dollars.

The estimated TPC for the small, modular (nominal 100 MW “block”) DICE CRCC plant is \$422.4 million (MM), or \$5,419/kW-net. Its TOC is \$524.7MM, or \$6,732/kW-net, and its TASC is \$575.5MM, or \$7,358/kW-net.

**Table 1-6
Capital Cost Summary for DICE CRCC Plant**

Plant	DICE CRCC
Size	78 MWe
Total Plant Cost (2018 \$/kW)	5,419
Total Plant Cost (2018 \$MM)	422.4
<i>Bare Erected Cost</i>	323.5
<i>Home Office Expenses</i>	38.6
<i>Project Contingency</i>	17.7
<i>Process Contingency</i>	49.9
Total Overnight Cost (2018 \$/kW)	6,732
Total Overnight Cost (2018 \$MM)	524.7
<i>Owner's Costs</i>	102.3
Total As-Spent Cost (2018 \$/kW)	7.358
Total As-Spent Cost (2018 \$MM)	573.5

1.6.3 Operating Cost Estimate

Table 1-7 presents a breakdown of the nominal 100 MWe DICE CRCC fixed and variable operating costs.

It is notable that the low recovery of beneficiated product from processing PRB coal, at less than 50 percent, results in a large consumption of the PRB coal feed. Additionally, it generates a significant quantity of coal tailings slurry that needs to be disposed of. A \$38/ton disposal cost was used in the cost estimate, as referenced from the DOE Bituminous Baseline Report, resulting in a very high annual waste disposal cost of \$24.4MM, by far the most significant contributor to the non-fuel O&M costs.

This disposal cost is considered conservative, since the tailings contain significant heating value, as much as the product itself, albeit with higher ash content and in the form of a slurry. Its quality can be comparable to that of lignite coals found in the Gulf Coast region, which have heating values as low as 4,000 Btu/lb, and moisture contents as high as 55 percent). It could therefore be potentially useful as a fuel for slurry-based gasification or for combustion after suitable processing (e.g. briquetting).

Table 1-7
100 MWe Nominal DICE CRCC Annual Operating Cost Breakdown

Plant	DICE CRCC
Size	78 MWe
Capacity Factor (CF)	85%
Fixed Operating Costs, 2018 \$MM/yr	20.8
<i>Annual Operating Labor Cost</i>	7.3
<i>Maintenance Labor Cost</i>	2.6
<i>Administration & Support Labor</i>	2.5
<i>Property Taxes and Insurance</i>	8.5
Variable Operating Costs, 2018 \$MM/yr	39.4
<i>DICE CRCC Plant Maintenance Material</i>	4.0
<i>Coal Beneficiation Plant Maintenance Material</i>	2.0
<i>Water</i>	0.5
<i>Chemicals</i>	8.4
<i>Waste Disposal</i>	24.4
Fuel, 2018 \$MM/yr	29.2
<i>PRB Coal</i>	21.2
<i>Diesel</i>	0.2
<i>Natural Gas</i>	7.9
Total Annual O&M Costs 2018 \$MM/yr	89.4

1.6.4 Design Levelized Cost of Electricity (LCOE)

Based on the overall performance, TOC, and annual operating cost of the 100 MWe DICE CRCC plant, its levelized cost of electricity (LCOE) was estimated to be \$223.9/MWh.

**Table 1-8
LCOE Parameters and Cost Breakdown**

Plant	DICE CRCC
Size	78 MWe
Capacity Factor (CF)	85%
Years of Construction	3
Total As-Spent Cost/Total Overnight Cost Ratio	1.093
Fixed Charge Rate (FCR)	0.0707
Total As-Spent Cost (TASC), \$MM	574
Fixed Operating Cost, \$MM/yr	20.8
Variable Operating Cost @ 100% CF, \$MM/yr	46.3
Fuel Cost @ 100% CF, \$MM/yr	34.4
Annual 1000 MWh (100% CF)	683
LCOE (excl. CO₂ T&S), \$/MWh	223.9
LCOE Breakdown, \$/MWh	
Fuel (incl. coal beneficiation)	50.4
Variable O&M	67.8
Fixed O&M	35.9
Capital Charges	69.9
Total LCOE, \$/MWh	223.9

Note: 3 year construction for DICE CRCC is consistent with NGCC construction period assumption as used by NETL in its reference reports. TASC/TOC ratio used for LCOE evaluation for such 3-year capital projects is 0.0707

1.6.5 LCOE Estimates of Variant Cases

Table 1-9 presents the summary comparison of the capital costs, operating costs, and LCOE breakdown of the DICE CRCC plant with and without PCC, and the envisioned “ideal” DICE plant that receives coal feed from a centralized coal beneficiation plant.

The DICE CRCC plant without PCC has an LCOE of \$148.6/MWh, or 66 percent of the same plant with PCC. Essentially, adding the PCC plant to capture 90 percent of the CO₂ in the DICE CRCC flue gas increases its cost of electricity by 50 percent.

The ideal DICE CRCC plant using coal received from a centralized beneficiation plant, assumed to be at \$4.3/MMBtu based on CSIRO’s research on the cost of coal beneficiation. Including 90 percent CO₂ capture, the LCOE of this plant is reasonable at \$145.7/MWh, or about 65 percent of the base case plant with on-site beneficiation.


**Table 1-9
Performance and LCOE Summary Comparison for DICE CRCC Variants**

Plant	DICE CRCC No PCC	DICE CRCC with PCC (on-site beneficiation)	Ideal DICE CRCC with PCC (centralized beneficiation)
Size	105 MWe	78 MWe	83 MWe
Plant Efficiency, LHV	39.9%	30.8%	32.7%
Plant Efficiency, HHV	37.7%	29.1%	31.0%
Capacity Factor (CF)	85%	85%	85%
Total As-Spent Cost (TASC), \$MM	474	573	492
Fixed Operating Cost, \$MM/yr	17.6	20.8	15.2
Variable Operating Cost @ 100% CF, \$MM/yr	40.8	46.3	13.4
Fuel Cost @ 100% CF, \$MM/yr	35.8	34.4	33.7
Annual 1000 MWh (100% CF)	921	683	726
LCOE (excl. CO₂ T&S), \$/MWh	148.6	223.9	145.7
LCOE Breakdown, \$/MWh			
Fuel (incl. coal beneficiation)	38.9	50.4	46.4
Variable O&M	44.4	67.8	18.4
Fixed O&M	22.5	35.9	24.6
Capital Charges	42.8	69.9	56.4
Total LCOE, \$/MWh	148.6	223.9	145.7

1.6.6 Sensitivity Analysis

Figure 1-4 depicts the tornado chart that provides both a ranking and measure of magnitude of the impact that the listed parameters have on the DICE CRCC plant LCOE. It is clear from this figure that the LCOE is most sensitive to the performance and cost of the coal beneficiation plant. It would therefore be most beneficial to the DICE CRCC technology if there was a centralized coal beneficiation plant with maximum economy-of-scale that also maximizes the yield of the beneficiation process (which simultaneously minimizes the tailings to be disposed of), thus reducing the beneficiated coal cost to be delivered to the modular DICE CRCC plant.

**Figure 1-4
LCOE Tornado Chart**



Section 2 Business Case

2.1 OBJECTIVE

The objective of this section is to evaluate a business case which demonstrates a market scenario leading up to the commercialization of Direct Injection Carbon Engine (DICE) Compound Reheat Combined Cycle (CRCC) technology and power plants. Accordingly, the main focus is on a commercial market driven scenario that is projected to be a candidate for the commercial implementation of DICE CRCC power plants.

2.2 INTRODUCTION

2.2.1 Overview

The power plant for this Pre-FEED study is configured as a 5x1x1x1 DICE CRCC facility generating a nominal 100 MWe of net power while capturing 90 percent of the CO₂ in the flue gas. The breakdown of the process system and power blocks is as follows:

1. Five (5) DICE (nominal 20 MWe each)
2. One (1) hot gas expander
3. One (1) Single pressure, no reheat heat recovery steam generator (HRSG)
4. One (1) Non-condensing (back-pressure) steam turbine
5. One (1) 30 wt percent MEA plant capturing 90 percent of the total CO₂ in the flue gas


Subject to the design basis set forth in the contract, the design for the DICE CRCC power plant is to be developed as a greenfield project with a U.S. Midwestern or Gulf Coast location.

This section describes the key commercial circumstances which establish the business case for the DICE CRCC power plant while addressing:

- Current coal power generation marketplace
- Competing conventional power generation sources
- Drive towards reducing carbon footprint, de-carbonization, and ongoing energy transition
- How the proposed technology will most likely respond to varying power market scenarios

Accordingly, the business case presented includes four main commercial factors as shown in Figure 2-1:

**Figure 2-1
Main Commercial Factors**



In accordance with the scope criteria set forth in the contract, the business case addresses the main tasks starting with market scenario, market applicability and advantage of concept, and estimated cost of electricity. In addition, a commercialization pathway or roadmap is provided for the DICE technology and power plant starting from a pilot plant to a next-of-a-kind (NoaK) commercial project.

2.3 MARKET SCENARIO

2.3.1 Key Influencing Drivers

Based on the current trends and outlook, the market scenario for coal based power generation varies widely on a regional basis both in the domestic U.S. and internationally. The commercial market dynamics are dependent upon key influencing drivers which may also serve as challenges and barriers which can potentially impact the commercial implementation of a DICE CRCC power project. Table 2-1 provides a listing of the key influencing drivers:

**Table 2-1
Key Influencing Drivers**

Key Drivers	Commentary
Energy Supply, Security, and Independence	In the domestic U.S. and internationally, various coal types are available as an abundant natural resource and on a regional basis. Coal provides highly reliable energy supply, independence, and security wherein the dependency on imported fuels and feedstocks is reduced – <i>key emphasis is on cleaner and efficient utilization of coal.</i>
Competing Power Sources	There is potential competition for coal based power generation versus other conventional energy sources such as natural gas. In some regions, coal based power plants remain the lower cost sources of electricity. In other regions, based on the availability of oil and gas resources, natural gas fueled power generation via gas turbine combined cycle (GTCC) is typically more viable due to the availability of lower cost natural gas.
Air Emissions Regulations	Air emissions from coal power plants includes CO, CO ₂ , NO _x , SO _x , mercury, particulate matter, and other hazardous air pollutants. Based on the prevailing stricter domestic U.S. and international emissions/environmental regulations, permitting of coal power plants is much more difficult than competing conventional energy sources such as natural gas.
Reducing Carbon Footprint and Energy Transition	There is a global drive towards reducing carbon footprint, de-carbonization, and energy transition through sustainable forms of energy. Accordingly, based on signatories to the Paris Accord, nearly 179 countries have stated their goal to reduce greenhouse gas (GHG) emissions. Countries pledged to reduce CO ₂ emissions in the range of 20 to 40 percent from their respective 2012 levels. Currently, the U.S. is not a signatory to the Paris Accord, however, there are multiple states which have enacted state-level energy policies and initiatives toward reducing carbon footprint, de-carbonization, and energy transition. In some states, there are commitments of up to 80 percent reductions by 2040. In these states, coal based power generation is a primary target with respect to reduction carbon footprint and de-carbonization (e.g. coal based power produces nearly double the CO ₂ per MWh as compared to natural gas power generation). . In addition, sustainable power sources such as intermittent utility-scale renewable energy (e.g. solar PV and wind) is integrated with large-scale energy storage and increasingly benefitting from state-level government mandates and policy support along with attracting major capital investment.
Project Financing	Initially, for the NoaK commercial DICE CRCC plants, financing will most likely be on a limited recourse basis versus project financing (on a non-recourse basis) - in order to meet lenders “bankability” requirements as well as mitigating technical and commercial risks. Currently, project financing of coal based power plants is more challenging due to the future power market

	<p>which has significant uncertainties (e.g. de-carbonization, stricter air emissions regulations, competing power sources, and power system wide penetration of renewable energy). In addition, larger output coal power plants are currently facing major challenges in securing financing from commercial lenders. Smaller and modular DICE CRCC plants may provide a lower risk profile since they require lower capital investment along with incremental capacity additions to meet baseload demand - <i>hence have a better opportunity for attracting financing.</i></p>
--	--

The market scenario leading up to the commercialization of the DICE CRCC power plant addresses the coal type, natural gas price, CO₂ constraint and price, and renewable energy penetration.

2.3.2 Coal Pricing

2.3.2.1 Design Fuel

The design fuel for the DICE CRCC power plant is a low-sulfur sub-bituminous Montana Rosebud Powder River Basin (PRB) coal, with an as-received heating value of 8,564 Btu/lb (HHV) or 8,252 Btu/lb (LHV). The coal has an ash content of 11.03 percent by weight (wt%) on a dry basis, and needs to be micronized and de-ashed to an appropriate level in order to protect the moving parts of the DICE unit that are exposed to either the micronized coal-water fuel (which is abrasive), or the solid particulate products of combustion which contain both ash and traces of unburned coal.

2.3.2.2 Physical Beneficiation

The DICE CRCC power plant design utilizes physical beneficiation to remove the minerals and sulfate/pyritic sulfur in the PRB coal. Physical beneficiation, depending on feedstock and process, is able to bring the ash content down to a few percent by weight. The resulting ash content of the coal is reduced to about 2 wt% on a dry basis, which is considered suitable for combustion in the DICE unit.

2.3.2.3 Cost of MRC Fuel

For this study, the design of a modular, on-site coal beneficiation plant for each 100 MW DICE CRCC plant was investigated. However, for such a small, modular power plant such as the DICE CRCC, it makes no economic sense to install a coal beneficiation plant on-site. This is analogous to building a crude oil refinery on-site at every gas station. For the modular DICE CRCC plant to be feasible, there must be multiples of such power plants, each receiving fuel from a centralized coal beneficiation plant, thereby taking advantage of the economies-of-scale benefits that the large central beneficiation plant possesses.

For this study, the equivalent beneficiated coal cost for PRB coal, calculated on a “net-back” basis, was \$14.2 per MMBtu, representing a more than 6-fold increase in coal cost due to the modular, economically disadvantaged coal beneficiation plant. However, based on CSIRO’s research involving Australian coals, it has been suggested that the cost of beneficiated coal is about AUD 6/GJ (USD 4.3/MMBtu). Additionally, coal beneficiation process and component developers have stated aspirational targets at less than \$1.50/MMBtu, based on using waste Eastern coal fines as feedstock, available at virtually no cost.

For the successful commercialization of DICE CRCC, it is of utmost importance that the beneficiated coal price be as low as possible. A market scenario which meets or exceeds CSIRO's \$4.3/MMBtu target, and closer to the aspirational targets of \$1.50/MMBtu would be imperative for this.

2.3.3 Natural Gas Price

For this Pre-FEED study, a levelized natural gas price of \$4.19/GJ or \$4.42/MMBtu (HHV) for delivery to the Midwest (reported in 2018 U.S. dollars) was used in the operating cost analysis, which is consistent with that used in the most recent DOE Bituminous Baseline Report (Revision 4, 2019). However, it is noted that current Henry Hub natural gas prices are only about \$1.9/MMBtu. Since natural gas is a co-fired feedstock to the DICE CRCC plant, a market scenario leading to successful commercialization of DICE CRCC would be one with low natural gas pricing, along the lines of current Henry Hub prices.

2.3.4 CO₂ Constraint and Price

2.3.4.1 Post-Combustion CO₂ Capture

The DICE CRCC power plant is fully integrated with a post-combustion CO₂ capture (PCC) unit using 30 wt% MEA that **captures 90 percent** of the CO₂ in the flue gas. The captured CO₂ meets the purity specifications set forth by DOE for pipeline delivery to saline aquifer sequestration, at a pressure of 2,200 psig at the plant battery limit for delivery to the storage site at 1,200 psig.

When the PCC is in operation, the DICE CRCC power plant has a CO₂ emission rate of 221 lb/MWh-net, far lower than natural gas technologies (~800 lb/MWh-net) without capture. Additionally, it is designed for maximum power generation when the PCC is offline with the addition of a low-pressure (LP) condensing turbine generating an additional 17 MW from steam that is normally routed to the PCC when it is in operation, and the elimination of PCC-associated auxiliary loads of about 10 MW, resulting in a total of 27 MW more power available for export.

2.3.4.2 CO₂ Price and 45Q Tax Credit

Based on the current CO₂ pricing and trends, the U.S. energy-related CO₂ emissions should have decreased by an anticipated 2.0 percent in 2019 and forecast to decrease by 0.9 percent in 2020. Carbon taxes have been suggested to help achieve this reduction. No credit for CO₂ has been taken for the purposes of cost comparisons in this Pre-FEED Study. The Bipartisan Budget Act of 2018 included in the FUTURE Act (Furthering carbon capture, Utilization, Technology, Underground storage, and Reduced Emissions) was intended to extend and reform the 45Q tax credit. Key provisions included an increase in the CO₂ credit value incrementally over ten years from \$10 to \$35 per metric ton (MT) of CO₂ stored geologically through enhanced oil recovery (EOR), and from \$20 to \$50 per MT for saline and other forms of geologic storage. In addition, 45Q tax credit provides a \$35 per MT for CO₂ captured and put to beneficial uses beyond EOR that reduce lifecycle emissions. Accordingly, the DICE CRCC power plant produces a captured CO₂ product at a purity greater than 95 percent, which currently can be sold in the U.S. market for in the range of \$15 to \$40 per MT CO₂.

2.3.5 Renewables Penetration

2.3.5.1 Major Energy Transition

As highlighted, the domestic U.S. and international commercial power market is undergoing a major energy transition towards more sustainable forms of energy. With emphasis on reducing carbon footprint and de-carbonization, there is increased interest and capital investment in commercialized renewable power technologies (e.g. utility-scale grid interconnected solar photovoltaics (PV), solar thermal, and onshore/offshore wind energy) that are at the center stage. As part of the definitive pathways towards de-carbonization, investors, lenders, market players such as project developers and sponsors, and policymakers are increasingly becoming aware of the need for flexibility in the energy value and supply chain.

2.3.5.2 Market Projections

The Annual Energy Outlook (AEO) 2020 presents an assessment by the U.S. Energy Information Administration (EIA) of the outlook for energy markets through 2050. Based on a high-level overview, the main highlights specifically with respect to electric power generation based on the Reference Case include:

- Power generation mix continues to experience a rapid rate of change with ***penetration of renewables being the fastest-growing source*** of electricity generation
- U.S. electricity load demand grows modestly with primary drivers for new capacity being:
 - Retirements of older and less-efficient conventional energy plants
 - Near-term availability of federal renewable energy tax credits and higher state-level renewables targets
 - Continued decline in the Capex of renewable energy sources, especially solar PV
 - Low natural gas prices and favorable costs for renewables result in natural gas and renewables as the primary sources of new generation capacity through 2050
 - Future generation mix is sensitive to the price of natural gas and growth in electricity demand
- U.S. ***coal*** and commercial nuclear power generation with ***most of the decline occurring by the mid-2020s as a result of plant retirements***

As shown in Figure 2-2, the AEO 2020 projects renewable energy growth from 19 percent (in 2019) to 38 percent (in 2050) of the total installed power generation. Of the total renewable energy growth, solar PV and wind energy market share is 53 percent (in 2019) increasing to 79 percent (in 2050).


Specifically, the share of solar PV is 15 percent (in 2019) increasing to 46 percent (in 2050). Wind energy with 38 percent (in 2019) with slight decrease to 33 percent (in 2050) since new wind

capacity additions are at much lower levels after production tax credits (PTCs) expire in the early 2020s.

Installed power generation via coal with 24 percent (in 2019) declining to 13 percent (in 2050). Natural gas power generation is the marginal fuel source to fulfill incremental demand and increases in the later projection years, averaging 0.8 percent growth per year through 2050.

Figure 2-2
Electricity Share from 2019 to 2050


Source: EIA Annual Energy Outlook 2020



As projected in Figure 2-3, the expected requirements for new power generating capacity will be met by both renewable energy sources and natural gas. Coal and commercial nuclear power generation stabilizes over the longer term as the more economically viable plants remain in service.

Figure 2-3
Projections of Expected Retirements and Additions from 2019 to 2050


Source: EIA Annual Energy Outlook 2020



As highlighted, power generation from renewable energy and natural gas increases, respectively, as a result of the declining costs of solar PV and wind renewable capacity and lower natural gas prices and, making these power generation sources increasingly competitive. As illustrated in Figure 2-4, the high renewables cost and low renewables cost Sensitivity Cases assume different rates of cost reduction for renewable energy technologies compared with the Reference Case wherein the non-renewables assume the same rates. Changes in cost assumptions for new wind and solar PV projects result in significantly different projected fuel mixes for power generation.

Figure 2-4
Projections of High and Low Renewables Cost Sensitivity Cases from 2019 to 2050


Source: EIA Annual Energy Outlook 2020



As depicted in Figure 2-5, the AEO 2020 shows that in all Reference and Sensitivity Cases, solar PV and wind energy lead the market share and growth in renewable power generation in most regions.

Figure 2-5
Share of Solar PV and Wind Energy in Renewable Energy Growth from 2019 to 2050

Source: EIA Annual Energy Outlook 2020




As more renewable energy resources are added, there will **most likely** be an additional need for novel, efficient, higher utilization capacity, and viable combustion power generation resources such as the DICE CRCC. A key market driver for DICE CRCC power plants includes providing grid reliability, availability, and maintainability (RAM). In addition, another market driver is ensuring grid resilience when the output of power generation via renewable energy sources is drastically reduced, curtailed, or insufficient.

2.3.5.3 Impact of Intermittency

An important commercial market impact and consideration is the intermittency of the various renewable energy sources and its consequential impact on front-of-the-meter (FTM) applications such as the utility grid. Integration of large-scale energy storage may most likely become the key enabler to the entire renewable power generation value and supply chain – especially solar PV power generation.

As illustrated in Figure 2-6, major electrochemical or battery energy storage system (BESS) capacity additions are expected to be integrated grid system wide with intermittent renewable energy sources in order to increase the dispatchability of utility-scale renewable power sources - especially in FTM applications.

Figure 2-6
Intermittent Renewable Energy Integrated with Energy Storage




*illustrative example only and detailed internal front-of-the meter (FTM) and behind-the-meter (BTM) and load distribution panels, inverters, controllers, transformers, and related infrastructure not shown.

Based on technological innovation and increased commercial market share, large-scale BESS systems’ Capex, Opex, and levelized cost of storage (LCOS) continue to decline. Commercial installations have tripled in less than three years, mainly using lithium-ion (Li-Ion) batteries that are primarily aimed at providing short-term energy storage, which presently accounts for nearly 80 percent of all BESS capacity. Besides Li-Ion, current BESS technologies include lead acid, sodium sulfur, sodium nickel chloride, and flow batteries (e.g. vanadium redox, iron, and zinc bromide).

As depicted in Figure 2-7, the AEO 2020 shows that the growth in utility-scale BESS follows the growth in solar PV in most regions in high renewable penetration scenarios.

**Figure 2-7
Growth of BESS Follows Solar PV Growth from 2019 to 2050**

Source: EIA Annual Energy Outlook 2020



Another important market driver related to the intermittency of renewable energy sources is the mandatory requirement proper utility grid protection which is currently being provided by various dispatchable sources - *largely comes from conventional or traditional energy sources and corresponding value and supply chains*. In the U.S., some coal power plants, commercial nuclear power, and natural gas GTCC are providing such baseload grid support, requiring them to operate more flexibly in terms of modes of service and duty than they were originally designed for, which is potentially adverse to performance:

- Continuous duty
- Baseload
- Other modes (cycling, peaking, and standby)

Such an operating profile and characteristics may most likely also occur in other regions as the penetration of renewable energy sources grows, thereby impacting the need for baseload fossil power, while putting extra importance on their ability to provide RAM as well as ensuring grid resilience.

The direct impact of commercial renewable sources on the DICE CRCC power plant will most likely be felt in terms of potential fluctuations in power prices and resulting dispatch of the plant. This high-level review does not attempt to predict future power prices, the commercial power market structure, and regulatory framework and policy. However and instead, this review seeks to address the price competitiveness of the DICE CRCC power plant to other dispatchable power plants as discussed in the subsequent section related to estimated cost of electricity. If the DICE CRCC power plant is the lowest marginal cost option for dispatchable power, *it will be competitive*.

2.3.5.4 Impact of Power Offtake

Power offtake is another commercial market impact and consideration. Most utility-scale renewable power projects operate with offtake under a power purchase agreement (PPA) with the local utility. These PPA contracts, typically on a take-or-pay terms and conditions, are based on competitive market price for the electricity. The LCOE of a given project is the present *intrinsic* value of that project's costs, levelized on an annual basis. For most solar PV and wind energy facilities, a project's LCOE closely tracks with the competitive PPA price.

Most project developers have good understanding of the prevailing PPA price in a given commercial market and at the project development stage seek out incentives, concessions from various suppliers, lenders, and local authority to match their baseline LCOE to the prevailing PPA prices. The project's LCOE is the "first order approximation" for that specific project's competitive PPA price. In order to increase the profit margin of the renewable energy facility, project developers always seek alternative methods of increasing revenue streams from power sales by assessing:

- Possible revenue streams based on a straight competitive PPA, versus
- Selling part of the power offtake from the renewable energy project under an *avoided cost* basis during winter and summer seasons and during respective peak periods via a levelized avoided cost of electricity (LACE)
- Resulting impact on project financing and rate of return on the capital investment

One most likely avenue available for a renewable project is selling power as a qualifying facility (QF) to the local utility as stipulated under the Public Utility Regulatory Policies Act (PURPA) regulations which was enacted in 1978. Current guidelines from the U.S. Federal Energy Regulatory Commission (FERC) indicate that renewable energy projects can be classified as a QF and sell power to the local grid under an avoided cost of generation basis.


If the DICE CRCC power plant, via its lower marginal LCOE and executed PPA, can demonstrate its price competitiveness to other dispatchable power plants, it can potentially be classified as a viable QF status.

2.3.5.5 Impact of Capacity Retirement and Improved Capacity Factor

As highlighted in the EIA's AEO 2020, coal power generation capacity retires at a faster pace as capacity factors increase for the more efficient coal power plants that remain in service as projected in Figure 2-8. In addition to decreases in installed capacity as a result of competitively priced natural gas and increasing renewables generation, coal power generating capacity decreases by 109 GW (or 46 percent) between 2019 and 2025 to comply with the Affordable Clean Energy (ACE) rule before leveling off near 127 GW by 2050 in the Reference Case.

Figure 2-8
Coal Capacity Retirement and Improved Capacity Factor from 2019 to 2050

Source: EIA Annual Energy Outlook 2020



The average capacity factors for coal power plants improve over time as less-efficient power plants are retired, as heat rates in the remaining coal power generation fleet improve to comply with the ACE rule, and as natural gas prices increase. Between 2019 and 2025, coal power generation decreases by 26 percent in the Reference Case while natural gas prices increase. By 2030, the plant utilization rate of the remaining coal power generation capacity returns to 65 percent, which is slightly less than in the early 2000s. In the high oil and gas supply Sensitivity Case, coal power generation decreases by 42 percent between 2019 and 2025, and lower natural gas prices limit the plant utilization rate of the coal fleet to a capacity factor of about 60 percent in 2030.

In addition, higher natural gas prices in the low oil and gas supply Sensitivity Case slow the pace of coal power plant retirements by about 23 GW through 2025 compared with the Reference Case. The low oil and gas supply Sensitivity Case has 155 GW of coal power generation capacity still in service in 2050. Conversely, lower natural gas prices in the high oil and gas supply Sensitivity Case increase coal power plant retirements by 28 GW in 2025, and 96 GW of remaining coal power plant capacity remains by 2050.

In order to reasonably compare the design of the DICE CRCC power plant with the benchmark DOE reference coal plant, this unit cost of electricity (COE) evaluation assumes a similar baseload plant with an **overall capacity factor of 85 percent**. The part load operation with the penetration of renewable energy sources is addressed in detail in the Performance Results Report Volume of this report. As highlighted, the DICE CRCC power plant **will be competitive** if it is the lowest marginal cost option for dispatchable power.

2.4 MARKET APPLICABILITY & ADVANTAGE OF CONCEPT

2.4.1 Domestic U.S.

In recent years, new coal power generation capacity additions have been drastically stagnating in the U.S. where coal is often non-competitive with offshore and onshore conventional as well as unconventional (shale) natural gas. In addition, coal power generation presents significant emissions, health, and related environmental risks. There are very few known greenfield coal power projects which are advancing in the U.S. and some major energy utilities have definitively pledged to eliminate coal power plants from their entire portfolio of power generation assets under operations and management.

However, based on this Pre-FEED study, it is believed that the DICE CRCC power plants can have a higher degree of success in the domestic U.S. market due to the modularity of the DICE CRCC technology, lower capital investment capital required as compared to large coal plants, incremental capacity additions to meet power market demand, relative abundance of coal in some regions and coupled with lower natural gas prices, thus minimizing its feedstock costs. Table 2-2 provides a high-level overview of the main market factors required for a significant resurgence in new coal power projects.

**Table 2-2
Factors for Resurgence in U.S. of New Coal Power Projects**

Factors	Commentary
Increase in price of LNG/natural gas	While the increase in the price of natural gas as compared to coal has not been forecasted, there is a potential especially as the international demand for LNG/natural gas grows.
Increasing value of CO ₂ via regulation or carbon capture and utilization	Subject to the development of a major domestic U.S. market for CO ₂ , this scenario could potentially drive new coal power projects with carbon capture and storage (CCS). Also, EOR continues to be the primary form of utilization and targeting this market can most likely be a necessity for any new coal power projects along with CCS in the short-term. Major governmental sponsored programs such as 45Q tax credits can also provide a value for captured CO ₂ , which in turn benefits the overall project economics. As an incentive, the value of capturing CO ₂ must be greater than the commodity cost, which is not the case in most circumstances. Accordingly, the value of CO ₂ must increase (e.g. via regulation or utilization) and/or the cost must decrease for coal power projects with CCS to be economically viable.
Impact of Regulatory Framework and Policy	There is considerable uncertainty in future regulatory framework and policy which increases the risk profile of undertaking the project development and project financing of coal power plants - power generators, equity investors, lenders along with insurers are highly risk adverse to develop and execute such projects. Recent revisions to the Clean Air Act section 111(b) have been proposed to alter the definition of best system of emissions reduction for new coal power plants to the most efficient demonstrated steam cycle in combination with best operating practices, instead of requiring partial CCS as was the case in the previous version of the Clean Air Act. Enactment of effective regulatory framework, policy, and directives favoring coal power plants is key to providing both developer's, investors, lenders, and insurers comfort and adding certainty around the low-carbon future - <i>which is important for growth in coal power.</i>

2.4.2 International

There are countries with relatively lower cost coal but higher domestic natural gas prices (e.g. China, India, and Australia) which may also find the DICE CRCC power plants and configuration appealing as the bulk of the fuel consumed is the lower cost coal, while the higher efficiency of the system offsets the cost of co-firing more expensive natural gas. Given the fuel flexibility of the DICE unit and its ability to use diesel as a feedstock, it is also applicable in the international market where crude oil prices are lower, such as in the Middle East.

In the various countries and regions, smaller, modular, and efficient DICE CRCC power plants utilizing coal will most likely be attractive for undertaking project development, execution, and operations. The utilization of CO₂ for either EOR and/or enhanced gas recovery are also growing potential opportunities. The market demand for coal power plants internationally varies by both country and region. Table 2-3 provides a high-level overview of the potential for international coal power projects.

**Table 2-3
Potential for International Coal Power Projects**

Country or Region	Commentary
China	China continues to be the largest coal producer as well as the largest consumer in the world. Coal accounts for nearly 70 percent of its total energy consumption. China forecasts coal capacity growth of approximately 19 percent over the next five years, during this timeframe there is a potential for declining electricity demand. Thus, many coal power plants have been operating at reduced capacity factors. Based on declining demand and growing emissions, health, and environmental concerns, the Chinese government has announced it may likely postpone building some coal power plants that have received prior approval and curtail construction of other projects. There are large coal supply resources in China and there is continuing demand for greenfield power plant capacity primarily in western China.
India	India has very large domestic coal reserves. The ash content of Indian coal produced is in the range of 25 to 45 percent whereas average ash content of imported coal varies from 10 to 20 percent. Indian coal has comparatively higher ash content than imported coal due to drift theory of formation of coal deposits in India. In recent years, India had the largest growth in coal utilization of any country. India's draft National Electricity Plan forecasts that the 50 GW of coal power generation capacity in construction is sufficient to meet the domestic power demand for the next decade, but there is a potential for new coal power plant capacity additions. Most new coal power plants proposed are state-of-the-art pulverized coal (PC) or circulating fluidized-bed (CFB) supercritical units as India has imposed a carbon tax on coal, which is about \$6.25 per MT of CO ₂ which requires efficiency as a key parameter in the region. India continues to seek and locate viable reservoirs for CCS.
Japan	Japan had over 44 GW of coal power plants in operation in 2018, with more than 6 GW additional capacity either permitted or in construction. Japan's climate change pledge is to reduce GHG emissions by 26 percent from 2013 levels by 2030. Accordingly, improving efficiency and potentially performing CCS are important market drivers in Japan. In addition, Japan

	is keen on promoting novel coal power cycles which have a smaller physical footprint due to space limitation.
South Korea	Coal power generation market share is more than 40 percent of South Korea's power mix. South Korea continues to have plans for additional coal power generation, despite having a climate change pledge of nearly 30 percent reduction in GHG emissions by 2030. South Korea's 8th Basic Plan for Electricity Supply and Demand (8th BPE) has a target of 35 percent of coal power in the generation mix before 2030. Regardless, South Korea is planning to add a net 5GW of new coal power generation capacity by 2022. There is also strong interest in oxy-combustion, and the country is investing in several technologies, including pressurized oxy-combustion (South Korea has previously invested in the DOE's STEP program).
Europe	Based on the Paris Accord, in the region of western Europe, there are several countries which announced plans to end coal power generation within their borders or establish emissions reductions targets that would effectively require an end to coal power generation without CCS. Countries include France by 2023, United Kingdom and Austria by 2025, Netherlands by 2030, and Germany by 2050. This makes new coal power generation very difficult to operate in the region. In eastern Europe, there is a higher potential for new coal power generation as "brown" coal resources are abundant and lower cost. Efficiency and cleanliness will be key market drivers in this region. CCS may be a challenge, however, as underground storage is not popular, although Norway is developing a potential sink for CO ₂ in the North Sea.
Others	There is increased utilization of coal in some regions in Africa (e.g., Kenya and Zimbabwe) and Southeast Asia (e.g., Indonesia and Vietnam), which presents major growth opportunities, although low-cost coal power generation will be critical in these areas. Smaller-scale plants will be a definite market advantage.

2.4.3 Advantage of Concept

As discussed in the market scenario, traditional coal power plants were typically designed for baseload mode of service and duty, and always-on or "must-run" operation. However, in the past decade, the penetration of utility-scale renewable energy sources has increased due declining costs, federal tax credits, state-level mandates. In addition, natural gas power generation has displaced coal power plants while providing greater flexibility in different modes of service and duty ranging from baseload, peaking, cycling, and standby.

As the commercial market matures in domestic U.S. and/or internationally, intermittent renewable energy sources may be less reliable, available, and maintainable than combustion based DICE CRCC power plants. As renewables become more cost-effective and a larger part of the generation mix, as previously highlighted, additional cycling requirements are being imposed on historically baseload coal power units and natural gas power generation - ***this was not originally anticipated when the coal power plants were designed and built.*** Energy utilities currently meet the expected grid load demand by using a "day-ahead" projections of electrical load demand to develop a power generation resource stack. The resource stacks start with the lowest marginal cost option for dispatchable power and add brownfield and greenfield power generation resources until the demand is properly met. As more, non-dispatchable renewables are added to the total power

generation portfolio, energy utilities must respond by adjusting the commitments to combustion based power generating resources. This key requirement requires coal power plants such as DICE CRCC to effectively transition from baseload operation to frequent cycling at certain times of the year. The DICE CRCC power plant is well suited for certain specific markets with unique attributes and features, such as those with:

- Smaller capacity utility grid(s) unable to accommodate large capacity power plants
- Modular design enabling “building block” methodology for incremental capital investment and capacity additions to match utility grid demand loads – baseload, peaking, and cycling duty and service
- Utilization of standard “off-the-shelf” components, equipment, and systems – minimizing requirements for basic and advanced R&D as well as demonstration
- Requirement for fast ramp rates and ability to operate at capacity factors as low as 30 percent
- High natural gas price (more than \$10 to \$12 per million BTU)
- Ability to use diesel fuel (places where gas supply is subject to uncertainty)
- High ambient temperature and humidity
- High-altitude installations
- Various combinations of the above

2.5 COMMERCIALIZATION PATHWAY

2.5.1 Overview

Coal based power generation technologies, existing assets, and greenfield projects *face a challenging future* given the uncertainty in the regulatory framework and policy area as well as environmental constraints (emissions and carbon capture), low natural gas prices, and declining cost of renewable energy resources. Given these *commercial market realities*, the most applicable, relevant, cost effective, and commercially viable application for the DICE CRCC power plants will most likely be:


- Smaller, modular, and efficient design providing incremental capacity additions to meet displaced coal power capacity due to the retirement of existing coal power generation facilities
- Providing grid stability and resilience by operating at various capacity factors in baseload, peaking, and cycling service and duty

2.5.2 Two-Phased Approach

From the commercial project development and project financing perspective, it is most likely that an energy utility or a project developer would initiate the development, execution, and operations of the DICE CRCC power plant at a greenfield site in a two-phased approach and manner – *initially with a pilot plant and later followed by a NoaK commercial plant*

For the pilot phase for the DICE CRCC power plant, the key technology investing stages and funding gaps cover basic R&D, applied R&D, and demonstration activities. In addition, for the NoaK phase for the commercial operation plant, key stages include market development and commercial diffusion which are directed towards roll-out and project financing. The traditional funding and investment stages of progression of energy technology and investments includes the development processes, various activities, and funding resources as shown in Figure 2-9.

Figure 2-9
Process, Activity, and Funding of Pilot Plant and NoaK Plant




The key funding and financing assumptions and drivers for the DICE CRCC power plant (pilot plant and NoaK commercial plant) include TRL, funding via equity and grants, financing via debt, fiscal and financial incentives, and transactional contracts:

- TRL of 5 to 6 assumes the pilot project will be in a pre-demonstration phase and beyond bench-scale unit. TRL of 9 for NoaK plant assumes advanced commercialization of the technology and market ready for commercial deployment
- Pilot plant will attract grants and equity only. The grants (e.g. R&D grants and project grants) will be required for the pilot plant since the DICE CRCC technology is assumed to be in a pre-commercial stage (from the viewpoint of equity investors and commercial lenders)
- NoaK plant is funded by equity and financed by debt. Grants are not applicable for the NoaK plant which is an advanced commercialized stage
- With respect to fiscal and financial incentives, at the federal and/or state level as applicable, the pilot plant can attract subsidies via additional grants, income tax credits (ITCs), accelerated depreciation, and carbon credits for CO₂
- NoaK plant can attract at the federal and/or state level, as applicable, loan guarantees, income tax credits (ITCs), accelerated depreciation, and carbon credits for CO₂
- The requirement of transactional contracts for the pilot plant includes, but not limited to, technology license agreement (if required), and EPC and O&M contract. In addition, to provide comfort to equity investors and grantors, the EPC contract must consider a “wrap” to cover warranties and guarantees
- The requirement for transactional contracts for the NoaK plant are discussed in the subsequent subsection entitled “Structuring Financing for NoaK Plant”

As shown in Figure 2-10, as part of the effective implementation of the two-phased approach, any technology investing and funding gaps must be avoided for the pilot phase as well as the pre-commercialization stages in order for success of the DICE CRCC power plant.

Figure 2-10
Avoiding Technology Investing and Funding Gaps




It is important to overcome any potential funding gaps which may arise for the pilot phase during the applied R&D phase and post-demonstration phase (prior to advanced commercialization). Typically, the “debt-equity gap” for capital requirements for commercializing energy technologies is beyond the risk tolerance and timelines of most existing debt and equity markets.

2.5.3 Transitioning between Two Phases

Once the pilot plant has been developed, executed, and in operations, definitive O&M experience feedback from the pilot phase for the DICE CRCC power plant can identify, quantify, and mitigate risks for implementing the NoAK commercial plant. As depicted in Figure 2-11, with lessons learned from O&M experience, the required modifications, upgrades, retrofits, revamps, and repairs can be undertaken to ensure the definitive transitioning from the pilot plant to the NoAK commercial operation plant.

Figure 2-11
Transitioning from Pilot Plant to NoaK Plant




During the transitioning, the technical and commercial risk profile is identified, quantified, reduced, and mitigated. In addition, with the main emphasis on **“bankability”**, key inputs are provided by the project sponsors, lenders, and other stakeholders in the DICE CRCC power plant project.

2.5.4 Structuring Financing for NoaK Plant

Typically, there are three (3) types of commercial financing available, namely, full-recourse, limited recourse, and non-recourse as shown in Figure 2-12. The structuring of the NoaK commercial operation plant would most likely attract limited recourse financing initially for the first 1 to 3 plants. For fully syndicating the limited recourse debt, lenders will most likely require the NoaK project assets be mortgaged, hypothecated, or collateralized. Thereafter, based on lenders’ comfort, the next generation of DICE CRCC power plants can attract non-recourse financing wherein the project’s earnings before interest, taxes, depreciation, and amortization (EBITDA) along with cash flows provide the required debt service coverage (DSC) over entire duration of repayment of loans while supported by **“bankable”** offtake agreements.


The typical Debt-to-Equity Ratio (DER) for the NoaK plant can typically range from 60:40 (or 1.5:1) to 70:30 (or 2.33:1). The lower DER is for first 1 to 3 plants and may vary depending on lenders risk profile and appetite.

Figure 2-12
Most Likely Scenario via Limited Recourse Financing



As illustrated in Figure 2-13, the limited recourse financing structure for the NoaK commercial operation plant will consist of a special purpose project company (SPPC) with key stakeholders covering debt, equity, insurance companies, risk guarantors, EPC and O&M contractors along with execution of **“bankable”** transactional contracts.

Figure 2-13
Limited Recourse Financing of Project Company



The limited recourse financing structure requires that the equity investment is made, possibly via escrow accounts, into the SPPC specifically set-up for the project development, execution, and operations of the DICE CRCC power plant project. The equity funding sources will execute shareholder agreements with the SPPC. The lenders for senior debt, subordinated debt, and working capital will execute respective loan agreements with the SPPC and debt drawl will occur, possibly via escrow accounts, in to the SPPC.

For subscribing equity and syndicating debt, both equity investors and lenders, respectively, will require detailed economic modeling and financial proforma analysis which can include, but not limited to, determining Capex, Opex, Total Installed Cost, LCOE, power tariffs for executing PPA, electricity merit-order dispatch scenarios, LACE for a securing a QF status, lifecycle assessment (LCA), insurance costs, and working capital margin. In addition, all financial projections over the economic life along with financial profitability indicators such payback period, internal rate of return (IRR), rate of return on equity (RROE), net present value (NPV), and debt service coverage ratio (DSCR). Based on the lenders debt financing norms, a sensitivity and scenario analysis must be conducted with respect to potential schedule delays, cost overruns, and changes in interest rates – *results showing variants and impact on IRR, RROE, DSCR, and payback period.*

The requirements for transactional contracts include, but not limited to, the DICE CRCC technology license agreement (if required), EPC and O&M contracts, fuel supply agreement (FSA), PPA, and agreement for purchase of carbon credits for CO₂. For the first 1 to 3 plants, the EPC contract must consider a “wrap” to cover warranties and guarantees. The O&M contact must consider a long-term service agreement (LTSA). In addition, all transactional contracts and agreements must be “*bankable*” with provisions for back-to-back arrangements to mitigate counterparty risks and downside risks.

2.5.5 Capital Structure

To illustrate the most likely structuring of the required financing for the NoaK commercial operation plant, a high-level example of a capital structure is provided in Table 2-4.

**Table 2-4
Example of Capital Structure for NoaK Plant**

Key Metric	Data and Information
Basis of Key Assumptions	Cost Report dated February 15, 2020
Project Capacity	78 MW
Total Overnight Cost (TOC)	\$525 million
Debt to Equity Ratio	60:40 or 1.5:1
Debt	<ul style="list-style-type: none"> ▪ \$315 million ▪ Senior, subordinated debt, and working capital ▪ Sources include U.S. Government loan guarantee and lenders (financial institutions, investment banks, and commercial banks)
Equity	<ul style="list-style-type: none"> ▪ \$210 million ▪ Common, preferred stock, and possible convertible debt along with warrants and options

	<ul style="list-style-type: none"> Sources include project sponsors, developers, private equity (PE) firms, OEMs, EPC and O&M contractors
Grants	None assumed since NoaK is a commercial operation plant

2.5.6 Financing Stages

Based on the current financing norms, the three main stages for the NoaK plant covers pre-financing, financing, and post-financing including and up to financial closure. Figure 2-14 provides an overview.

Figure 2-14
Three Main Stages of Financing



2.5.7 Categories of Risks

As part of equity investors' and lenders' technical and commercial due diligence during the three stages of financing, a key emphasis is to identify, minimize, and mitigate project risks, external risks, and financing risks.

The potential risks associated with the financing of the DICE CRCC power plant can be divided into 3 key categories which must be evaluated during the aforementioned 3 main financing stages in order to satisfy and meet both equity investors' and lenders' comfort. Figure 2-14 provides a summary and highlights the 3 key categories of risks.

**Figure 2-15
Three Key Categories of Risks**



2.5.8 Other Pre-Financing and Regulatory Requirements

2.5.8.1 Overview

As highlighted in Section 2.3.5.3, 2.3.5.4, and 2.3.5.5, the modular and higher efficiency DICE CRCC, via a NoaK commercial operation power plant, has the potential to meet growing electricity market demand for continuous duty, baseload, cycling, and other modes of service due to:

- Retiring of existing (older and inefficient) coal power plant capacity
- Intermittency of renewable resources
- Meeting mandatory requirement of proper baseload utility grid protection and support
- Providing critically required RAM while ensuring grid resilience

Typically, as part of either limited recourse financing or non-recourse/project financing, lenders and underwriters will require an independent electricity market assessment from the project sponsors and owners which includes a “merit order” dispatch ranking and priority analysis. In principle, the purpose of a merit order dispatch ranking and priority is to enable the lowest net cost electricity power generator to be dispatched first thus minimizing overall electricity system costs to wholesale and retail end-customers.

2.5.8.2 Continuous Duty and Baseload

In general practice, for all continuous duty and baseload power plants in a particular utility grid region which have executed a PPA and/or received a QF status, the approach and methodology utilized includes:

- Determining total power tariff (on two-part basis) via variable/energy cost *plus* fixed/capacity cost *minus* fiscal incentives (e.g. CO₂ credits)

- Ranking of all power plants solely on the basis of variable/energy cost **minus** fiscal incentives
- Based on the prevailing regulatory criteria, guidelines and directives of the State Public Utility Commissions (PUCs) and subject to the utility system grid demand response (DR) scenario, the power plant with the lowest variable/energy cost (**minus** fiscal incentives) dispatches first, followed by the next highest, the next highest, and so on as part of the permitting and licensing process

Accordingly, the independent electricity market assessment verifies and validates the **dispatchability** of the NoaK DICE-GT CRCC commercial operation power plant (in continuous duty and baseload mode) while meeting the State PUCs regulations as well as lenders and underwriters financing requirements.

2.5.8.3 Peaking and Other Modes

For meeting peaking load demand and other grid duty and service, a similar merit order dispatch ranking and priority assessment is required to be carried out for power plants which have executed a PPA and/or received a QF status, and the approach and methodology utilized includes:

- Conventional power generation (e.g. DICE-GT CRCC, commercial nuclear, natural gas GTCC, etc.) on the basis of determining total power tariff (on two-part basis) via variable/energy cost **plus** fixed/capacity cost **minus** fiscal incentives (e.g. CO₂ credits)
- Intermittent renewable power generation (e.g. solar PV) on the basis of total power tariff (on two-part basis) **minus** fiscal incentives (e.g. CO₂ credits) **plus** Levelized Cost of Storage (LCOS) for integrated battery energy storage as applicable
- Based on each State's Clean Energy Plan, various PUCs have their own specific prevailing regulatory criteria, guidelines and directives which are subject to the utility system grid demand response (DR) scenario, energy efficiency, and demand side management (DSM)
- Depending on the specific State PUC, a merit order dispatch ranking and priority has to be determined and met as part of the permitting and licensing process

Accordingly, the independent electricity market assessment verifies and validates the **dispatchability** of the NoaK DICE CRCC commercial operation power plant (in peaking and other modes) while meeting the State PUCs regulations as well as lenders and underwriters financing requirements.

2.6 CONCLUSIONS

The business case covers a market scenario leading up to the commercialization of the DICE CRCC power plant. The main focus was on a commercial market driven scenario that is projected to be a candidate for the commercial implementation of DICE CRCC power plants. The business case addresses four main commercial factors covering market scenario, market applicability and advantage of concept, estimated cost of electricity, and commercialization pathway or roadmap for the DICE CRCC technology and power plant starting from a pilot plant to a NoaK commercial project.

Based on the current trends and outlook, the market scenario for coal based power generation varies widely on a regional basis both in the domestic U.S. and internationally. The commercial market dynamics are dependent upon key influencing drivers which may also serve as challenges and barriers which can potentially impact the commercial implementation of a DICE CRCC power project. These include energy supply, security, and independence, competing power sources, air emissions regulations, reducing carbon footprint, de-carbonization, and energy transition, and project financing. The market scenario leading up to the commercialization of the DICE CRCC power plant addresses the coal type, natural gas price along with a sensitivity analysis, CO₂ constraint of 90 percent and the current market price, and renewable energy penetration based on the EIA's Annual Energy Outlook 2020.

The market applicability in domestic U.S. is dependent upon key factors for the resurgence of new coal power projects which includes increase in price of LNG/natural gas, increasing value of CO₂ via regulation or carbon capture and utilization, and the impact of regulatory framework and policy. The market applicability internationally indicates countries with relatively lower cost coal but higher domestic natural gas prices (e.g. China, India, and Australia) which may also find the DICE CRCC power plants and configuration appealing. In the various countries and regions (e.g. Japan, South Korea, and Europe), smaller, modular, and efficient DICE CRCC power plants utilizing coal will most likely be attractive. The utilization of CO₂ for either EOR and/or enhanced gas recovery are also growing potential opportunities.

The market advantage of concept demonstrate that the DICE CRCC power plant is well suited for certain specific markets with unique attributes and features, such as those with smaller capacity utility grid(s) unable to accommodate large capacity power plants, modular design enabling “building block” methodology for incremental capital investment and capacity additions to match utility grid demand loads, higher efficiency and ability to operate at range of capacity factors, high natural gas price, the ability to use diesel fuel, high ambient temperature and humidity, and high altitude installations.

Based on the overall performance, total as-spent capital cost (TPC), and annual operating cost of the 100 MWe DICE CRCC plant, its LCOE was estimated to be \$223.9/MWh. The LCOE of variant cases were also estimated with the DICE CRCC plant without PCC having an LCOE of \$148.6/MWh, and the “ideal” DICE CRCC with PCC and centralization beneficiation having an LCOE of 145.7/MWh.

From a commercial project development and project financing perspective, the commercialization pathway for the DICE CRCC power plant requires a two-phased approach and manner – *initially*

with a pilot plant and later followed by a NoaK commercial plant. The key funding and financing assumptions and drivers include TRL, funding via equity and grants for the pilot plant, funding via equity and limited recourse financing via debt for the first 1 to 3 NoaK plants (later followed by non-recourse financing), fiscal and financial incentives, and “*bankable*” transactional contracts.

100 MWe COAL-FIRED DIRECT INJECTION CARBON ENGINE (DICE)
COMPOUND REHEAT COMBINED CYCLE (CRCC) WITH 90 PERCENT
POST-COMBUSTION CO₂ CAPTURE

VOLUME II: DESIGN BASIS REPORT

U. S. Department of Energy (DOE)

Contract No. 89243319CFE000025, Coal-Based Power Plants of the Future

By



Nexant, Inc

and



Bechtel Power and Infrastructure

Table of Contents

Section 1 Pre-FEED Study Design Basis	56
1.1 Power Plant Design Criteria.....	56
1.1.1 General	56
1.1.2 Site-Related Conditions	56
1.1.3 Meteorological Data.....	57
1.1.4 Coal Feed Characteristics.....	57
1.1.5 Coal Beneficiation Characteristics.....	58
1.1.6 Natural Gas Characteristics	59
1.1.7 Flexible Plant Performance Targets.....	60
1.1.8 Water Requirements.....	61
1.1.9 Waste Water Treatment.....	61
1.1.10 Plant and Instrument Air Supply	61
1.1.11 Environmental/Emissions Requirements	62
1.1.12 Major Equipment Performance Assumptions	62
1.2 PCC Design Criteria	63
1.2.1 General	63
1.2.2 Flue Gas Feed Specification.....	63
1.2.3 CO ₂ Product Specifications	63
1.2.4 Utility Commodity Specifications	64
1.3 Project Transportation Size Limitations	65
1.4 CAPEX Cost Estimation Methodology	66
1.4.1 Coal Beneficiation and DICE CRCC Power Island.....	66
1.4.2 PCC Plant	66
1.4.3 Balance of Plant.....	67
1.5 O&M Cost Estimation Methodology	68
1.5.1 Operating Labor.....	68
1.5.2 Consumables and Waste Disposal	68
1.6 Financial Modeling Basis	69
1.6.1 Economic Assumptions.....	69
1.6.2 LCOE Calculation.....	71

List of Figures

Figure 1-1 DICE CRCC Part Load Performance.....60

List of Tables

Table 1-1 Design Air Composition.....57
Table 1-2 As-Received PRB Coal Properties58
Table 1-3 PRB MRC Coal Properties59
Table 1-4 Natural Gas Properties.....60
Table 1-5 Recovered CO₂ Product Properties63
Table 1-6 Global Economic Assumptions.....69
Table 1-7 Inputs for LCOE Calculation.....71

Section 1 Pre-FEED Study Design Basis

1.1 POWER PLANT DESIGN CRITERIA

1.1.1 General

Similar to the plant in the recently completed conceptual design, the DICE CRCC plant in this pre-FEED study is designed to generate a nominal 100 MWe on a net basis. It is to be equipped with a CO₂ capture plant that captures 90 percent of the total CO₂ in the flue gas. Based on the requirements of the Pre-FEED study as stated in the executed contract, the design criteria and assumptions are consistent with the Quality Guidelines for Energy Systems Studies (QGESS), and the QGESS documents are used as references to the greatest extent possible.

1.1.2 Site-Related Conditions

The DICE CRCC plant in this Pre-FEED study is assumed to be located at a generic plant site in the Midwestern USA, with site-related conditions as shown below:

▪ Location	Midwestern USA
▪ Elevation, ft above sea level	0
▪ Topography	Level
▪ Size, acres	300
▪ Coal delivery	Rail
▪ Gas delivery	Pipeline
▪ Ash/slag disposal	Off Site
▪ Water	Municipal (50 percent)/Groundwater (50 percent)
▪ Access	Landlocked, having access by train and highway
▪ CO ₂ disposition	Compressed to 2,200 psig at battery limit before being transported 50 miles for sequestered in a saline formation at a depth of 4,055 ft (Study scope limited to delivery at the plant battery limit (B/L) only)

1.1.3 Meteorological Data

The design ambient conditions for the material balances, thermal efficiencies, system design, and equipment sizing are shown in the following and in Table 1-1.:

- Atmospheric pressure, psia 14.7
- Maximum ambient dry bulb temperature (DBT) 59 °F
- Maximum ambient wet bulb temperature (WBT) 51.5 °F
- Design ambient relative humidity, percent 60
- Cooling water temperature 60 °F

**Table 1-1
Design Air Composition**

Air composition based on published psychrometric data, mass percent	
N ₂	75.055
O ₂	22.998
Ar	1.280
H ₂ O	0.616
CO ₂	0.050
Total	100.00

1.1.4 Coal Feed Characteristics

The design coal is Montana Rosebud PRB coal. The coal properties stated in Table 1-2 are from the 2019 revision of the QGESS document “Detailed Coal Specifications”.

**Table 1-2
As-Received PRB Coal Properties**

Coal seam nomenclature	Montana Rosebud
Coal field	PRB, Area D
Mine	Western Energy Co.
ASTM D388 Rank	Subbituminous

Proximate Analysis²	As-Received	Dry
Moisture ³	25.77%	0.00%
Volatile Matter	30.34%	40.87%
Ash	8.19%	11.04%
<u>Fixed Carbon</u>	<u>35.70%</u>	<u>48.09%</u>
Total	100.00%	100.00%

Ultimate Analysis²	As-Received	Dry
Carbon	50.07%	67.45%
Hydrogen	3.38%	4.56%
Nitrogen	0.71%	0.96%
Sulfur	0.73%	0.98%
Chlorine	0.01%	0.01%
Ash	8.19%	11.03%
Moisture ³	25.77%	0.00%
<u>Oxygen</u>	<u>11.14%</u>	<u>15.01%</u>
Total	100.00%	100.00%

Heating Value^{1,2}	As-Received	Dry (Dulong calc.)
HHV (Btu/lb)	8,564	11,516
LHV (Btu/lb)	8,252	11,096
HHV (kJ/kg)	19,920	26,787
LHV (kJ/kg)	19,195	25,810

Hardgrove Grindability Index	57
-------------------------------------	-----------

1.1.5 Coal Beneficiation Characteristics

The DICE CRCC conceptual design utilizes the physical beneficiation to remove the minerals and sulfate/pyritic sulfur in the PRB coal. Physical beneficiation, depending on the feedstock and process, is able to bring the coal ash content down to a few percent by weight. The process is expected to reduce the ash content of the coal to about 2 wt% on a dry basis, which is considered suitable for combustion in DICE.

The physical beneficiation process produces MRC, which is essentially finely ground low ash carbons in a slurry, similar in consistency to an acrylic paint. For effective atomization when injected into the DICE cylinder, the MRC should have a maximum size of around 50 microns in a 55 percent coal and a 45 percent water mixture.

There are a number of steps required to produce MRC. In general, the process comprises of:

- Coal washing
- Micronizing (fine grinding/milling)
- Froth flotation (de-ashing)
- Partial dewatering to 55 wt% coal MRC

For the design coal, it is assumed that the cleaned coal ash content is reduced to 2 percent on a dry weight basis, while also assuming that 20 percent of the sulfur in the coal is inorganic and is thereby removed during physical beneficiation. The expected resulting coal properties are shown in Table 1-3. Actual beneficiated coal properties will be based on the inputs from the coal beneficiation technology developer/original equipment manufacturer (OEM). Disposition of the tailings from the beneficiation process will also be addressed based on the technology developer/OEM inputs.

**Table 1-3
PRB MRC Coal Properties**

Ultimate Analysis, wt%	As Is (% wt)	Washed	Dry	Dry (% wt)	Slurry	MRC (% wt)
Moisture	25.77	25.77	0.00	0.00	81.82	45.00
Carbon	50.07	50.07	50.07	74.31	74.31	40.87
Hydrogen	3.38	3.38	3.38	5.02	5.02	2.76
Nitrogen	0.71	0.71	0.71	1.05	1.05	0.58
Chlorine	0.01	0.01	0.01	0.01	0.01	0.01
Sulfur	0.73	0.58	0.58	0.87	0.87	0.48
Ash	8.19	1.49	1.49	2.21	2.21	1.21
Oxygen	11.14	11.14	11.14	16.53	16.53	9.09
Total	100.00	93.15	67.38	100.00	181.82	100

1.1.6 Natural Gas Characteristics

Natural gas is the co-fired fuel in the DICE CRCC plant, being burned in the hot gas combustor to generate hot gas for expansion in the hot gas expander, and for the supplemental duct firing in the HRSG. The natural gas properties are shown in Table 1-4.

The natural gas composition to be used was specified in Appendix B of the Pre-FEED study contract, while the natural gas delivery conditions (temperature and pressure) were specified in the NETL Bituminous Baseline Report.


**Table 1-4
Natural Gas Properties**

Natural Gas Composition		
Component		Volume Percentage
Methane	CH ₄	93.1
Ethane	C ₂ H ₆	3.2
Propane	C ₃ H ₈	0.7
n-Butane	C ₄ H ₁₀	0.4
Carbon Dioxide	CO ₂	1.0
Nitrogen	N ₂	1.6
Methanethiol	CH ₄ S	5.75x10 ⁻⁶
	Total	100.00
	LHV	HHV
Btu/lb	20,410	22,600
Btu/scf	932	1,032
Natural Gas Delivered Conditions		
Pressure, psia		430
Temperature, °F		80

1.1.7 Flexible Plant Performance Targets

The DICE CRCC power plant shall be designed with a flexible plant performance target of being capable of turning down to 20 percent of full capacity. This can be achieved by turning off up to four of the five engines. This was explored in the conceptual design, per Figure 1-1, that indicated the number of DICE running at full load (horizontal axis) and the corresponding gross power output, net power output, and plant efficiency on a normalized basis. A similar evaluation will be performed for the pre-FEED study based on information from the DICE OEM.

**Figure 1-1
DICE CRCC Part Load Performance**



Other flexible performance plant targets include those set out in the contract as follow:

- Greater than or equal to 4% ramp rate
- Cold/Warm start in less than 2 hours
- 5:1 turndown with full environmental compliance

1.1.8 Water Requirements

The water supply is 50 percent from a local publicly owned treatment works and 50 percent from groundwater and is assumed to be in sufficient quantities to meet plant makeup requirements.

The raw water undergoes filtering to remove sediments, after which it is suitable for to be used as makeup water for process water, cooling water, and WFGD makeup.

The filtered raw water go through demineralization unit to produce demineralized water suitable for use as boiler feed water makeup.

1.1.9 Waste Water Treatment

Wastewater recycle will be maximized to reduce waste water disposal requirement and to minimize overall net fresh water makeup requirement. Blowdowns from cooling tower, steam drum, and demineralization regeneration will be considered for use as part of the makeup to the coal beneficiation plant and the WFGD plant. Flue gas condensate from the PCC direct contact cooler will be considered for use as part of the overall plant makeup water supply.

Net water purges from WFGD, PCC, and raw water treatment will be used to transport coal and ash solid wastes. Net decanted water from transport will either be exported to the local publicly owned treatment plant, or onsite evaporation ponds, consistent with NETL baseline studies.

Sanitary waste water will be exported to the local publicly owned treatment plant for disposal.

1.1.10 Plant and Instrument Air Supply

Plant air will be compressed and cooled ambient, and will be supplied to the DICE CRCC plant at the following conditions:

Nominal Temperature, °F	100
Maximum Temperature, °F	120
Nominal Pressure, psig	125
Maximum/Minimum Pressure, psig	150 / 100

Part of the plant air will be dried to -40°F dew point for use as instrument air for the DICE CRCC plant. Instrument air will be supplied to it at the following conditions:

Nominal Temperature, °F	100
Maximum Temperature, °F	120

Nominal Pressure, psig	100
Maximum/Minimum Pressure, psig	150 / 80

1.1.11 Environmental/Emissions Requirements

Design emissions requirements and limits for the DICE CRCC power plant with PCC in this study are per Appendix B of the Pre-FEED study contract as follows:

- SO₂ 1.00 lb/MWh-gross
- NO_x 0.70 lb/MWh-gross
- Particulate Matter (Filterable) 0.09 lb/MWh-gross
- Hg 3 x 10⁻⁶ lb/MWh-gross
- HCl 0.010 lb/MWh-gross
- CO₂ 90 percent removal from flue gas

1.1.12 Major Equipment Performance Assumptions

The assumptions used in the design of the following major equipment of the DICE CRCC plant are as shown:

- Main air compressor
 - Intercooled/integrally-gearred
 - Deliver 5 bar/70C charge air to the engines (with an aftercooler)
 - Performance calibration based on Kobelco budgetary quote
- Hot Gas Expander
 - Maximum pressure ratio 4:1
 - Maximum inlet gas temperature: 1,400 °F
 - Performance calibration per GE (formerly Baker-Hughes) quote
- Steam Turbine
 - Two casing, condensing, no reheat
 - Performance per modified Spencer, Cotton and Cannon in Thermo flow THERMOFLEX
 - Air-cooled condenser
- HRSG
 - Duct-fired
 - Single-pressure
 - Steam conditions TBD
- Particulate removal
 - Equipment, exact location and performance TBD subject to system optimization

1.2 PCC DESIGN CRITERIA

Guidelines for the PCC plant design include the following:

1.2.1 General

The PCC plant is designed as an integral part of the DICE CRCC plant to recover up to 90 percent of the CO₂ in the flue gas.

The projected largest-single train size equipment will be used to maximize economy-of-scale. The vessels exceeding transportation size limits (as specified in the Project Transportation Size Limitation section of this document) will be field fabricated. The equipment is designed for a 30-year plant life.

The rotating equipment (including turbomachinery) critical to the continuous plant operation will be provided with the required spare (or redundant) capacity. Where sparing capacity is not feasible, alternate operation will be identified to maintain continuous power plant operation.

1.2.2 Flue Gas Feed Specification

The flue gas exiting the WFGD is the design feed for the PCC plant. The corresponding flue gas feed composition and flow rate to the PCC plant will be specified after the design of the DICE CRCC plant is completed.

1.2.3 CO₂ Product Specifications

The recovered CO₂ is delivered at the plant B/L that meets enhanced oil recovery (EOR) specifications as listed in Table 1-5, per the 2019 version of the DOE QGESS CO₂ Impurity Design Parameters (NETL-PUB-22529).

**Table 1-5
Recovered CO₂ Product Properties**

Compositions:		
CO ₂	Vol% (Min)	95
N ₂	Vol% (Max)	1
Ar	Vol % (Max)	1
O ₂	ppmv (Max)	10
H ₂ O	ppmv (Max)	500
SO ₂ ,	ppmv (Max)	100
NO _x	ppmv (Max)	100
CO	ppmv (Max)	35
B/L pressure, psig		2,200
B/L Temperature, °F		70

1.2.4 Utility Commodity Specifications

Low Pressure Steam

Low pressure (LP) steam for the PCC stripper reboiler is the DICE CRCC backpressure steam turbine exhaust desuperheated to meet the following PCC B/L conditions:

Min pressure, psia	60
Temperature, °F	Saturated + 10 (303 °F)

The LP steam is assumed to be desuperheated to 10°F above saturation temperature to allow positive control of desuperheater condensate injection. The degree of LP steam superheat can be varied to meet minimum desuperheater design requirement.

Medium Pressure Steam

The medium pressure (MP) steam for amine reclaiming is to be extracted intermittently from the power plant steam cycle at the following B/L conditions:

Minimum pressure, psia	100
Temperature, °F	Saturated + 10
Equivalent frequency, percent of time	~ 15percent

The MP steam is assumed to be desuperheated to 10°F above saturation temperature to allow positive control of desuperheater condensate injection. The degree of MP steam superheat can be varied to meet minimum desuperheater design requirement.

PCC Return Condensate

The reboiler steam condensate will be pumped back to the power plant hot at the following conditions:

Minimum pressure, psia	175
Temperature, °F	To be determined by PCC Design

Cooling Tower Water

It is assumed that cooling water is available from the plant cooling towers at the following conditions:

Maximum supply temperature, °F	60
Maximum return temperature, °F	100
Maximum supply pressure, psia	70
Maximum PCC pressure drop, psi	30

PCC Plant Water Supply

The plant water will be filtered water from the groundwater/municipal water supply. The water will be supplied to the PCC facility where it is filtered and pumped to the internal subsystem battery limits at the following conditions:

Supply Temperature, °F	60
Return Temperature, °F	100
Nominal Pressure, psia	As Required

1.3 PROJECT TRANSPORTATION SIZE LIMITATIONS

The maximum overland transportable dimension is 100 feet long by 15 feet wide by 15 feet height (including carriage height). The maximum equipment height is 13.5 feet assuming using 1.5 feet height low boy carriage. The maximum overland transportable weight is 120 tons.

1.4 CAPEX COST ESTIMATION METHODOLOGY

Based on the requirements stated in the executed contract, the Capex for the pre-FEED study shall be reported at a level of detail similar to that found in DOE/NETL Baseline studies.

The DOE/NETL Bituminous Baseline Report report provided a cost estimate for 14 major subsystems of a reference 650 MWe supercritical PC plant with CO₂ capture. It is expected that the cost of the 100 MW DICE CRCC plant be broken down into these same categories.

1.4.1 Coal Beneficiation and DICE CRCC Power Island

For the pre-FEED design, additional cost details will be provided for the pertinent systems associated with the DICE CRCC plant. In particular, the Capex for the coal beneficiation and DICE CRCC power island will be better defined, with costs based on inputs from the DICE and coal beneficiation OEMs.

The costs for commercialized equipment associated with the DICE CRCC plant, such as the air compressor, hot gas combustor, hot gas expander and the various generator equipment, will be estimated and verified with quotes from equipment vendors. These will then be developed up to the total plant cost level, which includes bulk material, labor, and construction indirect costs based on historical factors for similar equipment type.

1.4.2 PCC Plant

The Capex for the 30wt% MEA-based PCC for the DICE CRCC plant is a major equipment (ME) factored estimate with a target accuracy of ± 30 percent.

For an ME-factored estimate, the ME material and labor costs were developed from equipment sizes, quantities, and design parameters defined by the PCC design from CCS. The bulk material and labor costs were factored from the ME costs. The sum of the ME and bulk material costs, including shipping costs, forms the total direct cost (TDC).

The construction indirect cost, factored from total direct labor cost, is added to the TDC to come up with the total field cost (TFC). Using factors consistent with the DOE/NETL report for the Case 12 total plant cost (TPC), the Engineering and Construction Management Fees and Home office cost, and contingencies are added to the TFC to come up with the TPC.

Upon generating the size estimates for the individual equipment, the costs for the equipment were generated using commercial estimation software (ASPEN ICARUS) with adjustments based on past quotes for similar equipment where necessary. Installation labor for each ME was factored from historical data by equipment type.

The costs for bulk materials such as instrumentation, piping, structure steel, insulation, electrical, painting, concrete and site preparation associated with the major equipment were factored from ME costs based on historical data for similar services. The installation labor for each bulk commodity was factored from historical data by type.

The construction indirect cost was factored from total direct labor costs based on historical data. The construction indirect cost covers the cost for setup, maintenance and removal of temporary

facilities, warehousing, surveying and security services, maintenance of construction tools and equipment, consumables and utilities purchases, and field office payrolls.

1.4.3 Balance of Plant

Cost estimates for the DICE CRCC balance of plant (BOP) systems, will be based on major equipment factored costs, wherever possible. For potential DICE CRCC BOP systems that have virtually identical counterparts in the NETL Bituminous Baseline Report PC and NGCC cases, with only differences in capacity, cost estimates that follow the QGESS Capital Cost Estimation guidelines that is based on capacity-factoring may be used.

1.5 O&M COST ESTIMATION METHODOLOGY

The operations and maintenance (O&M) costs pertain to those charges associated with operating and maintaining the power plant over their expected life. These costs include:

- Operating labor
- Maintenance – material and labor
- Administrative and support labor
- Consumables
- Fuel
- Waste disposal

There are two components of O&M costs; fixed O&M, which is independent of power generation, and variable O&M, which is proportional to power generation. The base case variable O&M costs are estimated assuming that the DICE CRCC plant is operating as a baseload plant, with a plant capacity factor of 85 percent. A range of O&M costs will also be estimated across a range of flexibility conditions.

1.5.1 Operating Labor

Operating labor cost is determined based on the number of operators required to work in the plant. Other assumptions used in calculating the total labor cost include, per the 2019 revision of the NETL Bituminous Baseline Report:

- | | |
|---|---------|
| ▪ 2018 Base hourly labor rate, \$/hr | \$38.50 |
| ▪ Length of work-week, hrs | 50 |
| ▪ Labor burden, percent | 30 |
| ▪ Administrative/Support labor, percent O&M Labor | 25 |

1.5.2 Consumables and Waste Disposal

The cost of consumables, including fuel, is determined based on the individual rates of consumption, the unit cost of each specific consumable commodity, and the plant annual operating hours. The waste quantities and disposal costs are evaluated similarly to the consumables.

The unit costs for major consumables and waste disposal are based on the values reported in the DOE/NETL Bituminous Baseline report. These costs are reported in Dec 2018 cost basis.

1.6 FINANCIAL MODELING BASIS

1.6.1 Economic Assumptions

The pre-FEED study deliverable calls for an estimate of the COE based on the technology concept and design criteria. The global economic assumptions for the COE calculation are based on the criteria set forth in the September 2019 version of NETL’s QGESS Cost Estimation Methodology for NETL Assessments of Power Plant Performance (NETL-PUB-22580) summarized in Table 1-6.

**Table 1-6
Global Economic Assumptions**

Parameter	Value
Taxes	
Income Tax Rates	21 percent federal, 6 percent state (Effective tax rate of 25.74 percent)
Capital Depreciation	20 years, 150 percent declining balance method (DBM)
Investment Tax Credit	0 percent
Tax Holiday	0 years
Contracting and Financing Terms	
Contracting Strategy	Engineering, Procurement, Construction, and Management (owner assumes project risks for performance, schedule, and cost)
Type of Debt Financing	Project finance/non-recourse basis (collateral that secures debt is limited to the real assets of the project)
Repayment Term of Debt	Equal to operational period in formula method
Grace Period on Debt Repayment	0 years
Debt Reserve Fund	None
Analysis Time Period	
Capital Expenditure Period	3 years
Operational Period	30 years
Economic Analysis Period	33 years (capital expenditure plus operational period)

Treatment of Capital Costs	
Capital Cost Escalation during Capital Expenditure Period	0 percent
Distribution of Total Overnight Capital Cost over the Capital Expenditure	10 percent, 60 percent, 30 percent
Working Capital	Zero
Percentage of Total Overnight Capital that is Depreciated	100 percent
Escalation of Operating Cost and Revenues	
Escalation of COE and O&M costs	0 percent real (3 percent nominal)
Levelized Fuel Costs	\$38.21/ton for PRB coal and \$4.420/MMBtu for natural gas delivered to U.S. Midwest, per NETL QGESS Fuel Prices for Selected Feedstocks in NETL Studies (January 2019 update)
Finance Structures	
Debt Percentage of Total	55 percent
Equity Percentage of Total	45 percent
Real Current Dollar Cost	2.94 percent
Real Return on Equity	7.84 percent

The figure-of-merit used in the evaluation of coal and gas-fired power plants in the most recent version of the Bituminous Baseline Report (rev 4) is the ***real levelized cost of electricity (LCOE)***. Similarly, this pre-FEED study will determine the DICE CRCC plant's performance based on the real LCOE. From the QGESS Cost Estimation Methodology for NETL Assessments of Power Plant Performance document, the pertinent factors used in determining the real LCOE as calculated based on the global economic assumptions shown in Table 1-6 are shown in Table 1-7.

Table 1-7
Inputs for LCOE Calculation

Parameter	Value
Total As Spent Capital/Total Overnight Cost factor (TASC/TOC _{real})	1.093
Fixed charge rate (FCR)	0.0707
Capital recovery factor (CRF)	0.0630
Effective tax rate (ETR)	25.74 percent
Nominal after tax weighted average cost of capital (ATWACC _r)	4.73 percent

1.6.2 LCOE Calculation

Per the QGESS Cost Estimation Methodology for NETL Assessments of Power Plant Performance document, the following methodology is used to calculate the *real* LCOE, the figure-of-merit used in the Bituminous in this pre-FEED study, expressed in dollars per MWh.

- 1) Calculate the levelized capital cost (LCC) using the fixed charge rate and capital recovery factor (CRF) formulas as follows for a real (r) approach:

$$LCC_r = TASC_r * FCR_r$$

where: $FCR_r = \frac{CRF_r}{1-ETR} - \frac{ETR * D_q}{1-ETR}$

and $CRF_r = \frac{ATWACC_r * (1+ATWACC_r)^y}{(1+ATWACC_r)^y - 1}$

and $D_q = CRF_r * \sum_{n=1}^z \frac{d_n}{(1+ATWACC_r)^n}$

where:

TASC = total as spent costs

FCR = Fixed charge rate

CRF = Capital recovery factor

ETR = effective tax rate

ATWACC_r = real after tax weighted average cost of capital

D_q = Present value of tax depreciation expense

d_n = the tax depreciation fraction in year n

z = number of years of depreciation (21 for 20-year, 150 percent DBMpercent)

y = number of operating years

Based on the inputs given in Table 2-6, it is verified that $FCR_r = 0.0707$ per Table 2-7.

- 2) Calculate levelized (and annual) O&M expenses (AOM) per MWh using the following formula:

$$LOM = AOM * \frac{ATWACC * (1 + ATWACC)^y}{(1 + ATWACC)^y - 1} * \frac{1 - \left[\frac{(1+i)}{(1+ATWACC)} \right]^y}{ATWACC - i}$$

where:

y = number of operating years

i = assumed annual (real) escalation rate for O&M

ATWACC = after tax weighted average cost of capital

ETR = effective tax rate

Based on the inputs given in Table 2-6 where real escalation is specified as zero, the levelized value equals the annual value, $LOM_{real} = AOM$.

- 3) Calculate levelized annual fuel (LFP) expenses per MWh using the price forecast for fuel costs for a 2023 to 2053 (30 years) operating period.

$$LFP = PV_{fuel\ price} * \frac{ATWACC * (1 + ATWACC)^y}{(1 + ATWACC)^y - 1}$$

where: $PV_{fuel\ price} = \sum_{n=1}^y \frac{P_n}{(1 + ATWACC_r)^n}$

where:

n = the year of operation

y = number of operating years

P_n = real price of fuel in year n

ATWACC = after tax weighted average cost of capital

Per the QGESS Cost Estimation Methodology for NETL Assessments of Power Plant Performance document, the levelized fuel price for PRB coal delivered to the U.S. Midwest is \$38.21/ton and the levelized fuel price for natural gas is \$4.42/MMBtu on an HHV basis.

All factors in the COE equation are expressed in dollars for the on-line year, which is 2023 for the reference NETL Baseline Study. The equation used is:

$$COE = \frac{\begin{array}{c} \text{first year} \\ \text{capital charge} \end{array} + \begin{array}{c} \text{first year} \\ \text{fixed operating} \\ \text{costs} \end{array} + \begin{array}{c} \text{first year} \\ \text{variable operating} \\ \text{costs} \end{array}}{\begin{array}{c} \text{annual net megawatt hours} \\ \text{of power generated} \end{array}}$$

$$COE = \frac{(FCR)(TASC) + OC_{FIX} + (CF)(OC_{VAR})}{(CF)(MWH)}$$

where:

COE = revenue required to be received by the generator (\$/MWh, equivalent to mills/kWh) during the power plant's first year of operation in order to satisfy the finance structure assumptions

FCR = fixed charge rate taken based on CRF values from that matches the finance structure and capital expenditure period. The interest rate used in the formula must by necessity be the ATWACC

TASC = total as spent capital (see TOC discussion below), expressed in on-line year cost

OC_{FIX} = the sum of all first-year-of-operation fixed annual operating costs

OC_{VAR} = the sum of all first-year-of-operation variable annual operating costs at 100 percent capacity factor, including fuel and other feedstock costs and (offset by) any byproduct revenues

CF = plant capacity factor, assumed to be constant (or levelized) over the operational period; expressed as a fraction of the total electricity that would be generated if the plant operated at full load without interruption

MWH = annual net megawatt-hours of electricity generated at 100 percent capacity factor

100 MWe COAL-FIRED DIRECT INJECTION CARBON ENGINE (DICE)
COMPOUND REHEAT COMBINED CYCLE (CRCC) WITH 90% POST-
COMBUSTION CO₂ CAPTURE

VOLUME III: TECHNOLOGY GAP ANALYSIS REPORT

U. S. Department of Energy (DOE)

Contract No. 89243319CFE000025, Coal-Based Power Plants of the Future

By



Nexant, Inc

And



Bechtel Power and Infrastructure

Table of Contents

Section 1 Introduction	78
1.1 Current State-of-the-Art Power Plant	78
1.2 Proposed Concept.....	79
1.3 Technology Gap Analysis – The Philosophy.....	80
1.4 DICE CRCC (Power Block) Technology Gaps And Risks	83
Section 2 DICE Technology Gaps and Risks	84
2.1 Limitations and Adaptations of Current Engines for DICE.....	84
2.1.1 Size and Speed.....	84
2.1.2 Fuel Supply System	85
2.1.3 Injectors.....	85
2.2 DICE Technology Gaps.....	88
2.3 Technical Risks and Issues	91
2.3.1 Commitment	91
2.3.2 Tradeoffs	91
2.3.3 Development Philosophy	91
2.3.4 Supporting R&D.....	91
2.3.5 Engine-ready MRC	92
2.3.6 Engine Modification	92
2.4 Key R&D Requirements for Development.....	93
2.4.1 Engine Component R&D	93
2.4.2 Logistics R&D	93
Section 3 Fuel Production Technology Gaps And Risks	94
3.1 Fuel Development Needs.....	96
3.1.1 Fuel R&D	96
3.1.2 Further Research Studies.....	97
3.2 CWS Processing Plants.....	99
3.3 Technology Gaps, Risks, and Development Pathways	103
3.3.1 Potential R&D Needs.....	103
3.3.2 Development Pathway via Testing	105
3.3.3 Testing Regime - Future Work Plan	105

Section 4 Development Coordination	109
4.1 Objectives.....	109
4.2 DICE Development Pathway	110
4.2.1 Development Imperatives	110
4.2.2 De-risking with Staged Development.....	111
4.2.3 Scale-Up Risk	111
4.2.4 Staged Development Program.....	112
Section 5 Emissions Control Technology.....	119
5.1 SO _x and Hg Removal	119
5.2 Particulate Matter Removal	120
Section 6 References.....	124
Appendix A Turbocompounding.....	125
Appendix B Technology Readiness Levels (TRLs).....	126

List of Tables

Table 2-1 Perceived DICE Technology Gaps	89
Table 3-1 CWS Properties.....	94
Table 3-2 MRC Properties.....	95
Table 3-3 Nominal Additives Used to Produce MRC	97
Table 3-4 Design Basis Coal Analysis.....	100
Table 3-5 Mineral Content of Rosebud Coal Seam Samples (percent by weight).....	101
Table 3-6 Study MRC Composition	102
Table 3-7 Testing Required to Confirm Key Assumptions, Design/Concept Impact	106
Table 4-1 Scale-Up Factors from Demonstration through to Large Commercial Installation.....	112

List of Figures

Figure 1-1 Efficiency-CO ₂ Emission Comparison of Fossil Fuel-Fired Technologies	79
Figure 3-1 Coal Beneficiation Cost (in Australian Dollars).....	95
Figure 3-2 Beneficiated “Clean” Feedstock Properties.....	101
Figure 3-3 Key Coal Beneficiation Unit Operations.....	103
Figure 4-1 Proposed 3-Stage Development Program	114
Figure 4-2 MRC Spill 24 Hours Later (From Hydrothermally Treated Lignite)	116
Figure 5-1 FCC Power Recovery System (UOP Honeywell)	120
Figure 5-2 UOP Honeywell TSS	122

Section 1 Introduction

1.1 CURRENT STATE-OF-THE-ART POWER PLANT

The current state-of-the-art in coal-fired power generation comprises supercritical (SC) and ultra-supercritical (USC) pulverized coal (PC) boiler-steam turbine generator (i.e., Rankine steam cycle) technology. Due to the nature of the main prime mover plant equipment and auxiliaries used and the underlying thermodynamic cycle (and the working fluid), the technology is cost-effective only at very large, utility-scale (almost gigawatt) installations. Even then, the strict environmental regulations governing criteria pollutants and other harmful emissions resulting from coal combustion impose very expensive coal treatment/preparation and flue gas treatment equipment, which negatively impacts plant cost and performance. On top of those challenges faced by conventional coal-fired power generation technologies, such mega-facilities are not amenable to fast and flexible operation requirements imposed by the rapidly changing nature of power generation portfolio with increasing penetration by renewables. Especially vexing is the clash between advanced alloys which are requisite to facilitate USC steam conditions for high efficiency (i.e., austenitic steels), which are less resistant to thermal stresses imposed by rapid load ramps and plant starts and shutdowns. A further challenge is faced during construction because of the need for skilled welders to handle pipes and valves made from such exotic (and expensive) alloys.

Even when all the practical challenges associated with advanced USC steam technology are ignored, the proverbial “*pot of gold at the end of the rainbow*” is more like copper – i.e., net lower heating value (LHV) efficiency that can be hoped for is worse than that of an E-class gas turbine combined cycle (GTCC).


1.2 PROPOSED CONCEPT

The proposed concept, the **Direct Injection Carbon Engine Compound Reheat Combined Cycle (DICE CRCC)** delivers the predicted and achievable efficiency by the most advanced USC technology while being:

- Modular
- Flexible
- Small (120 MW base, about 80 MW with post-combustion capture, PCC)

This is clearly highlighted and illustrated by the chart in Figure 1-1, which shows the CO₂ emissions and plant efficiency of PC, GTCC and DICE CRCC (without PCC and including their best embodiments) technologies.

Figure 1-1
Efficiency-CO₂ Emission Comparison of Fossil Fuel-Fired Technologies



The DICE CRCC delivers the promised capabilities by combining mostly standardized, off-the-shelf, and commercially mature equipment with proven technology in a thermodynamically optimum manner. The combination of reheat with constant volume heat addition delivers the most efficient heat engine cycle, which can be implemented in the field with multi-equipment configurations for maximum modularity and flexibility with high efficiency at small ratings. The DICE CRCC with post-combustion carbon capture (PCC) is a low emissions, coal-fired power plant comprising three “blocks” or “islands”:

- Coal beneficiation and coal-water slurry (CWS) fuel processing and production
- Modular electric power generation
- PCC

The basic operating principles and overview of the DICE CRCC can be found in Section 1 of the **Performance Results Report**.

1.3 TECHNOLOGY GAP ANALYSIS – THE PHILOSOPHY

The PCC Block utilizes amine-based chemical absorption technology, which is currently available and is not considered for technology gap/risk analysis. Detailed description of the PCC Block is provided in Section 4.8 of the **Performance Results Report**.

The Power Block also comprises of commercially mature and proven technology *except for the DICE*. Thus, the main focus of the technology gap analysis presented herein is on:

- DICE R&D and development pathway
- CWS processing and production.

The approach and methodology for the technology gap analysis presented herein is guided by the USDOE definition of **Technology Readiness Level** (TRL) is outlined in Appendix B. There are **three** areas of focus in the analysis:

- Technology Gap
- Technology Risk
- Development Pathway

The “gap” is determined by the TRL of a particular technology. *If the technology in question is at TRL 9, there is no gap*. If the technology is at, say, TRL 5, the technology gap is defined by the difference between TRL 9 and TRL 5.

As far as the distinction between technology “gap” and technology “risk” is concerned, in a nutshell:

- The “gap” is associated with the question “can we do it?”
- The “risk” is associated with the question “can we do it safely and economically?”

The “development pathway” is the key driving **stratagem** to be followed to bring the technology in question from TRL $X < 9$ to TRL 9 in the shortest time possible while mitigating the risks identified along the way.

The term “technology” can refer to a single system or a subsystem of a system. For example, the **Power Block** of DICE CRCC comprises the following “technologies” (not a *comprehensive* list):

- Reciprocating Internal Combustion Engine (RICE)
- Gas Turbine
 - Gas Compression
 - Combustion
 - Gas Expansion
- Waste Heat Recovery
- Steam Turbine
- Alternating Current Synchronous Machine
 - Motor
 - Generator

It should be highlighted that there is interchangeability between the terms “technology” and the “equipment” representing a particular technology. All technologies enumerated above are at TRL 9 when used with a conventional liquid or gaseous fuel.

From a subsystem perspective, the technology gap is inherent in RICE when burning an *unconventional* fuel (i.e., coal-water slurry in this case). In this particular case, the technology is referred to as *Direct Injection Carbon Engine* (DICE). Even then, note that DICE comprises various “subsystems”, which are “technologies” in their own right, i.e.

- “Stock” engine comprising
 - Engine block/cylinders
 - Pistons
 - Crankshaft
 - Camshaft
 - Fuel injectors
- Turbocharger
- Synchronous alternating current (AC) generator
- Lubrication system
- Engine cooling system
- Charge air cooling system

The vast majority of all “subsystem technologies” in DICE are at TRL 9. The exception is the fuel (MRC) preparation and fuel injection system, which is discussed in detail below.

For N subsystems in a system with N – 1 subsystems at TRL 9 and one system at, say, TRL 4, can one take the average (it can even be a somehow “weighted” average) and state that the system is at, say, TRL 8.2? This may not always be the case because a system is like a chain, it is as strong as its weakest link.

The other key vexing question is this: If the subsystem in question is developed from TRL X < 9 to TRL 9, can it be introduced into *any existing system framework* (with all other subsystems at TRL 9) so that the new system will be at TRL 9? Specifically:

- If the fuel injection system is brought to TRL 9 by using a RICE platform from OEM¹ X, can one say that any RICE (from OEM Y or Z) can be transformed to DICE at TRL 9?
- If DICE is brought to TRL 9, can one say that DICE CRCC can be deemed to be at TRL 9?

The answer to the second question is **NO**, because, while individual subsystems are at TRL 9, their seamless integration into a fully functional system may **NOT work and may require system modifications**. Due to the modular nature of DICE CRCC, however, moving from TRL 6 (pilot plant) to TRL 9 should be relatively straightforward. The focus is primarily on the interaction between the DICE and the expander in turbocompound configuration. There is field experience

¹ Original Equipment Manufacturer (OEM)

in very similar applications (see Appendix A). The development path is more of a “risk elimination” exercise rather than closing a “technology gap”

The answer to the first question is **NO** as well due to the other “risks” (not “gaps” *per se*) involved in the DICE (enumerated and discussed in detail in section 1.3), i.e.:

- Combustion, specifically, ignition characteristics of the CWS fuel
- Wear and tear of components (cylinder walls, rings, pistons) due to ash particles
- Fouling of components

Finally, production of the CWS fuel itself is a technology, which is not at TRL 9 either. This is discussed in detail in Section 1.5. In this case, additional technology risks are present due to the variances in reliability among the different coal feedstock (i.e., bituminous, subbituminous or lignite with differences in quality and composition from mine to mine in each category).

1.4 DICE CRCC (POWER BLOCK) TECHNOLOGY GAPS AND RISKS

A partial list of the technology OEMs for major equipment including standard, off-the-shelf equipment, and commercially mature in the power generation block (DICE CRCC) are listed below.

- Major equipment needed:
 - Reciprocating internal combustion engines (RICE)
 - Medium-speed, large-bore
 - MAN, Wärtsila
 - Hot gas expander (HGE)
 - Baker Hughes
 - Main air compressor
 - Integrally-gearred, centrifugal process compressor with intercooling
 - Kobelco, Dresser-Rand
 - Heat recovery steam generator (HRSG)
 - Single-pressure, non-reheat with duct burner and SCR/CO catalyst
 - NEM, Nooter Eriksen, Vogt
 - Steam turbine generator
 - Back-pressure (non-condensing)
 - GE, Siemens (Dresser-Rand), Elliott
 - Particle removal equipment
 - Third Stage Separator (TSS) used in FCC applications
 - Honeywell UOP
 - Shell

All of the major pieces of equipment are off-the-shelf and commercially mature products (i.e., representing TRL 9) *except* the RICE, which requires the following modifications to DICE:

- New fuel injector
- Cylinder/piston coating (with carbide)

The project team is planning to cooperate with CSIRO to further the development of these modifications in the next phase of work (CoalFIRST Critical Components Development).

The definitive associated technology gaps and risks as well as the development pathways are discussed in depth in Section 2 and Section 3.

It is also highlighted that:

- Bechtel has worked with all of the major OEMs of major equipment used in power generation and process
- Bechtel has access to data and information on the equipment included in the proposed concept

Section 2 DICE Technology Gaps and Risks

Prima facie, technology gaps and risks associated with the DICE CRCC concept are not overwhelmingly large. The least-proven part of the cycle is DICE, which is a *reciprocating internal combustion engine* (RICE) fired with a coal-water slurry fuel (roughly 45 weight percent (wt %) water). Even DICE has ample R&D and field operation history behind it (e.g., please refer to Nicol [1] and the extensive bibliography therein). One prominent example is medium-speed, large-bore RICE by Wärtsilä, which has been successfully operated with Orimulsion in Finland [2].

2.1 LIMITATIONS AND ADAPTATIONS OF CURRENT ENGINES FOR DICE

While atomized MRC burns well in diesel engines, the engines require several essential modifications, and the engine also need to be low-medium speed (preferably <500 rpm) to allow for longer combustion time and to reduce the fineness of atomization required to achieve efficient combustion.

To some extent these modifications are already used for commercial engines using Orimulsion and MSAR (bitumen-water emulsions – a close proxy for coal-based slurry in terms of combustion), high pressure gas, liquefied gases and alcohols. However, additional essential modifications are required for DICE. While most of these modifications involve straightforward engineering, several critical components will require redesign. The limitations and adaption of current engines for DICE is discussed for the following aspects:

- Cylinder size and speed
- Wear coatings
- Piston
- Ring shape
- Dual injection
- Injector
- Exhaust ducting
- Cylinder drains
- Turbocharger

2.1.1 Size and Speed

For coal, the cylinder size should be as large as possible and the engine speed as low as possible – larger and slower, respectively, than economically optimal for comparable installations using fuel oils and gas. Although low-speed engines cost proportionally more per MW, the benefits for coal are a reduction in cylinder wear and an increase in wear tolerance due to larger component sizes. In addition to increased wear tolerance, large bore and low speed mean that fineness of MRC atomization is less critical, and this allows both larger orifices (resulting in longer fuel jets) in the atomizer nozzle and lower injection pressure. Both are essential to reducing nozzle wear. A larger

bore also increases the space available for the injector, which for MRC will likely be larger to accommodate ceramic components.

2.1.2 Fuel Supply System

Conventional fuel supply systems are unsuitable for MRC and will require redesign to avoid clogging and wear issues. The MRC supply system should provide a small, controlled circulation flow around the fuel rail and through the injectors to enable rapid flushing of the system and to eliminate clogging of the fuel system when the engine is not in operation. This circulating flow should be down through the injectors suction valve to the seat of the needle valve and be controlled either electronically or from the same oil that actuates the fuel pump plunger. The spring-loaded inertial valves often used with HFO are not recommended desirable due to the variable flow properties of MRC (shear thinning) and seat wear.

It is recommended that a twin pump low-pressure fuel system is used, with one pump controlling the pressure in the circulating flow, and the other used to control the return flow – as described in more detail in Section 3.1 of the Performance Results Report.

2.1.3 Injectors

Conventional injection equipment, including pump-line-nozzle, hydraulically actuated electronically controlled unit injectors (HEUI), mechanically actuated electronic controlled unit injectors (MEUI) and common rail injectors are completely unsuitable for MRC due to instantaneous jamming of sliding parts with coal particles, clogging of fuel galleries, and rapid wear due to erosion/cavitation. Required modifications are summarized as follow:

Jamming of any sliding surfaces wetted by the fuel -- This is especially the case for the fuel pump plunger and the cut-off needle valve spindle, which will jam solid within several injection cycles unless protected by a higher-pressure seal oil. This also precludes the use of a conventional jerk pump with spill ports to control injection rate.

Clogging of fuel ways if the fuel is allowed to remain stagnant – This will occur especially if the engine is hot and the fuel has been repeatedly pressurized to injection pressure (which can destabilize the fuel). This means that flushing of the fuel system is necessary either before or immediately after stopping of the engine.

Erosive wear of fuel system components – This occurs not just to the atomizer orifices, but also for the non-return valve seat and the needle valve seat. The size of fuel galleries must also be increased to reduce fuel velocities to below 10 m/s if possible. Velocities over 20 m/s will cause galleries to wear. Erosive wear is further accelerated by corrosion-erosion mechanism if materials subjected to high-velocity fuel are not sufficiently hard and corrosion-resistant.

Cavitation wear is increased with MRC due to the higher vapor pressure of the fuel's continuous phase (water), and also due to its higher viscosity. Other fuel properties may contribute to cavitation, including the high particulates loading and the strongly shear-thinning nature of MRC, which tends to channel flow.

2.1.3.1 Piston

The piston bowls of modern engines are shallow and wide for less intense fuel-air mixing to reduce peak combustion temperatures and NO_x formation: NO_x should not be an issue due to the cooling effect of the fuel water – but requires full scale demonstration. Although the optimum shape for MRC has not been identified, it is probable that the older-style, deeper bowl, higher squish piston will give better results by providing faster and more complete fuel air mixing, which effectively increases the combustion time and allows the use of lower excess combustion air. The latter will also result in a higher charge temperature at the start of injection, further improving both ignition and combustion. Fuel-air mixing for DICE is also likely to be enhanced by the need for additional nozzle orifices to pass the higher fuel volume of MRC. A deeper bowl piston is also expected to reduce fuel contamination of the upper cylinder bore.

2.1.3.2 Piston Rings

There has been little published R&D on ring design for MRC. Conventional ring designs with hard coatings have given reasonable performance with MRC – but tests appear to have been of short duration (a maximum of 200 hours continuous). It is speculated that an optimized ring design will be necessary to minimize wear via 1) additional cylinder lubrication to carry away char and ash contamination of the cylinder wear surface, 2) avoiding Brinnelling by hard ash particles means that pressure equalisation across the ring pack will be more important which also increases the minimum oil film thickness, 3) ring porting/draining needs to be increased to allow for a step increase in particulates (ash and char) in the lubricant film, 4) ring shape may need to be changed to increase down scrap of contaminated lubricant to collection points. Piston ring rotation would also assist in evacuating contaminated oil grunge from behind the rings.

2.1.3.3 Materials

In general, the materials used for the critical components in the fuel system, piston rings and cylinder liner in conventional diesel engines are unsuitable for MRC. High hardness is essential to avoid abrasive wear from coal ash. Although ceramic coatings are available for piston rings and liners, conventional hard coatings are generally too thin to prevent the Brinelling effect of large hard fly ash particles – i.e. indenting through the hard coating into the softer substrate. Thicker, more monolithic coatings will be necessary with binders that are resistant to corrosion and grain plucking. The injector nozzle is particularly challenging. Although conventional polycrystalline diamond compacts have been shown to be effective in managing nozzle abrasive and cavitation wear of nozzles, the newer nanoparticle compacts of polycrystalline diamond or cubic boron nitride are expected to give an even better performance – and are tougher. These materials should also be used for fuel system valve seats and needles/poppets. A redesign of the injector is required to utilize these ceramics, in particular, as the ceramic components require an increase in component cross-section to compensate for lower tensile strength.

MRC can be handled using conventional steels (as for coal water fuels); however, it is recommended that components downstream of the fuel strainer are constructed from stainless steel – especially the engine fuel delivery system and high-pressure injection system. This is to reduce scaling and erosion-corrosion. For pump and injector bodies, steels recently developed for biofuel should be considered (e.g. Duval TN15 or similar).

2.1.3.4 Exhaust Ducting

Conventional horizontal ducting between the turbocharger turbine outlet and emissions control equipment will likely result in ash deposits on the lower surfaces of ducting – especially from shed ash deposits. Minimizing horizontal runs, live bottom ducts (e.g. equipped with drag chains), dropout boxes, soot blowers, and other measures will need to be used to prevent deposition from becoming an issue.

2.1.3.5 Dual Injection

A dual injection system will be necessary to allow the engine to start and warm-up on diesel or lighter fuel oil, and to enable pilot injection to control ignition (depending on the MRC quality). For some engines, the fuel oil side of the existing dual-fuel system may be used - possibly downsized to match only starting and pilot rating.

2.1.3.6 Cylinder Lubricant Drains

To accommodate increased particulates contamination of the cylinder lubricant film, increased cylinder lubrication is required, with provision to collect contaminated down scrap of lubricant (e.g. using a spiral/circumferential oil collection groove(s) near the bottom of the stroke). This arrangement will enable dirty lubricant to be routed out of the engine for separate deep cleaning using a centrifuge, thereby reducing the filtration load on the crankcase lubricant system.

2.1.3.7 Turbocharger

Coarse particulate matter in the engine exhaust will cause inlet vane and turbine erosion, especially for particles larger than (say) 10 μ m. While the bulk of the flyash is likely to be finer than this value (larger cenospheres are unlikely to be an issue as they are spherical and being hollow have a small equivalent aerodynamic diameter), ash deposits shedding from inside the engine and exhaust ducting will be larger. For this reason, turbines and inlet vanes will require hard facing – as used for large low-speed 2-stroke marine engines using heavy and residual fuel oils.

2.2 DICE TECHNOLOGY GAPS

While it is believed that there are no technical limitations concerning adapting an engine for DICE (this is an engineering issue only), there are a number of technology gaps that continue to hamper development. As these involve both the fuel and the engine, these gaps are discussed under that of a new fuel cycle involving the production of new fuel, for adapted engines for new coal generation markets

- For the fuel, this includes producing a suitable slurry fuel from coal that is exclusively used in boilers, and for which no experience with DICE exists
- Measurement of parameters requisite to predict coal suitability
- For the engine these involve items critical to producing a commercial engine with acceptable longevity and RAM² requirements
- Overall, there is a lack of logistics/infrastructure for a DICE fuel cycle
- Emissions prediction, especially, particulate matter (PM) 2.5, NO_x and CO, requires significant field experience and system tuning

While all of the issues were considered to some extent in the comprehensive USDOE program from 1978-92 (which focused on bituminous coal replacing diesel fuel), this data is only partially relevant to the present initiative which is for a sub-bituminous coal particle size distribution, new abrasion-resistant materials, manufacturing techniques, and larger capacity stationary generation. Also, there has been a range of new technologies and business drivers over the last 25 years, for example, more efficient mills, new abrasion-resistant materials, manufacturing methods, electronic control, the rise of the reciprocating engine for both decentralized and baseload generation.

What is lacking is an understanding of the trade-offs between fuel quality and engine modifications, and this balance should be reassessed in the context of developments in ultra-hard materials and manufacturing techniques introduced over the last 25 years.

Table 2-1 summarizes the currently known technology gaps. .

² Reliability, Availability, and Maintainability (RAM)

**Table 2-1
Perceived DICE Technology Gaps**

Technology gap	Description	Importance
Processing and formulation of subbituminous coal	<ul style="list-style-type: none"> • De-ashing by flotation or selective agglomeration may result in a higher product ash • Lower rank coals can make excellent MRC if the surface properties are altered and any porosity reduced (e.g. by hydrothermal treatment or low temperature carbonization) • Cost effective additive packs to provide optimal solids content and rheology 	High (trade-off between fuel cost and engine cost)
Fuel logistics	<ul style="list-style-type: none"> • Fuel quality standards including suitable performance tests need to be established • Pulverized coal and fuel oil standards do not apply for DICE • CSIRO has a number of DICE fuel tests which could be used 	High
Fuel-engine interactions	<ul style="list-style-type: none"> • Very little data for subbituminous coals • The occurrence of mineral matter in the processed coal will have a big influence on the required engine adaptations (armoring) and repairs and maintenance (R&M) costs • However, expect only a small increase in engine capital cost due to special componentry (for the Nth engine) 	High
Engine design	<ul style="list-style-type: none"> • Current designs and materials of construction assume clean fuel. This limitation applies to the fuel supply system, the injection system, cylinder components, exhaust valve seats, exhaust system, turbocharger turbine, and heat recovery systems. 	High

Technology gap	Description	Importance
	<ul style="list-style-type: none"> • Engine maker philosophy – the fuel needs to match the engine 	<p>High – potential large new markets using lower cost fuel needs to be valued</p>
<p>Next generation DICE fuel systems</p>	<ul style="list-style-type: none"> • Atomization and atomizer longevity is the absolute essential requirement/obstacle to DICE • The existing practice of pressure atomization is a quick fix – it works, but not for very long • Air blast atomization can solve this problem but requires more adaptation to the engine systems • A change in engine philosophy is required: new air blast could be much better than that of the 1920's, the benefits of DICE warrant extra effort on the engine, MRC is a different fuel that requires a different engine 	<p>Medium in the short term, but could eliminate the atomizer problem and result in relaxed fuel quality requirements</p> <p>High</p> <p>Engine manufacturers currently adopt the view that the fuel must match the engine. The opposite could be optimal for DICE</p>
<p>New coal philosophy – life-cycle analysis (LCA) based</p>	<ul style="list-style-type: none"> • DICE is a higher value market for coal. A new philosophy around quality and optimizing the overall coal fuel cycle is required. For example higher ash MRC could be used as a boiler low load or light-up fuel, creating operations for MRC with higher ash fractions to PC boilers, mining of tailings dams, other higher value end-uses for MRC quality coals • The highly flexible nature of DICE could directly underpin a high penetration of intermittent renewables 	<p>High</p> <p>Potential to reinvigorate the industry</p> <p>High</p> <p>New system boundaries need to be established – with coal and DICE</p>

2.3 TECHNICAL RISKS AND ISSUES

The key technical risks and issues associated with developing DICE – based on recent CSIRO experiences, are as follows, in decreasing order of importance:

2.3.1 Commitment

Ensuring commitment of both the engine manufacture and fuel supplier/fuel chain as this involves producing and using a fuel that is new to the world – this requires industry backing and commitment to not only undertake the engineering RD&D, but also to establish new logistics (including tests for quality, OH&S, public perceptions). If a holistic development approach is not taken, development could stall due to a chicken-and-egg situation between fuel supply and availability of suitable engines.

2.3.2 Tradeoffs

Establishing at the outset nominal trade-offs between fuel quality and engine modifications. The engine manufacturer will likely insist that the fuel is produced to suit the engine and the fuel supplier that the engine is adapted to suit the fuel. Although a full-scale demonstration is required to quantify the optimum quality-engine adaptations, an early decision should be made on fuel quality targets to give an acceptable overall generation cost. Other changes are also required: For the coal supplier, MRC must be regarded as a premium fuel and prepared and handled accordingly; for the engine manufacturer it should be accepted that MRC is not a fuel oil, and that DICE will require substantial changes to engine manufacturers to incorporate new materials and changes to the base engine (e.g. a new fuel system, revised cylinder heads to accommodate a larger injector, increased crankcase lubricant cleaning, revised exhaust ducting and turbine materials etc)..

2.3.3 Development Philosophy

Ensuring that both the engine manufacturer and fuel supply parties agree with the engine development program. There are two diametrically opposite pathways to achieving a commercial engine: 1) develop and test what is considered to be key components prior to undertaking the engine tests/demonstration, or 2) undertake engine tests early with adapted components to identify and prioritize component development needs and learn by doing. This single issue was the cause for termination of the recent CSIRO project with an engine manufacturer and the Australian coal industry: The coal industry disagreed with OEM's approach (which was a 3-5 year program based on early engine trials prior to component development) to develop a commercial engine for DICE. It is emphasized that the program was not terminated on technical grounds – only conflicting philosophies on how development should proceed.

2.3.4 Supporting R&D

Including a parallel program to develop and establish fuel cycle logistics. This should include identifying/developing suitable tests for the fuel – which will likely involve a hybrid of fuel oil and coal type tests. It is recommended that a high degree of importance is placed on understanding how the inorganics in the as mined coal report to the MRC fuel, the exhaust gases, and the wear implications – especially for the injector nozzles and cylinder components. For example, depending on the coal and the cleaning methods used, around one-third of the ash content (in, say a 2% ash coal) could be derived from organically bound or finely disseminated mineral matter

which will have different wear implications that coarser extraneous quartz particles. Another key area is MRC rheology: If this is correct the relatively high viscosity fuel will inject as well as fuel oil and will be safe to store without agitation. If not, fuel system and injector nozzle blockages will result, and fuel tanks settle to form a compacted sludge.

2.3.5 Engine-ready MRC

Developing a cost effective, engine ready fuel. For bituminous coals fully commercial technologies are available to do this. For lower rank coals such as Powder River Basin coal, some development is required to ensure sufficiently low mineral content and to allow an MRC with over 50% coal to be produced with acceptable rheology.

2.3.6 Engine Modification

The minimum modifications to enable an engine trial, for example, to obtain combustion and heat release data, and to identify other issues, is a seal oil protected injector and fuel pump. Using a standard tool steel nozzle should enable 5-10 hours of consistent operation to gain early engine performance data and to refine the component development program.

2.4 KEY R&D REQUIREMENTS FOR DEVELOPMENT

The technical R&D requirements are discussed below in the context of developing an overall fuel cycle that is ready for commercialization by 2030:

- Fuel development (elaborated in detail in Section 3.1)
- Engine component development
- Logistics.

2.4.1 Engine Component R&D

Engine component R&D is mostly for fuel delivery and injection systems, including materials selection. Key areas include:

- Wear coatings for the piston rings and cylinder walls
- Piston bowl shape
- Ring shape
- An MRC injection system with seal oil protected sliding surfaces and ceramic valves and atomizer nozzle.
- Exhaust ducting - reengineered to manage ash dropout
- Cylinder lubricant drains to remove contaminated oil
- Turbocharger armoring
- Reengineered fuel delivery system

These are described in more detail under development imperatives and the development pathway below.

2.4.2 Logistics R&D

DICE is a potential new market for both coal and reciprocating engines that requires the establishment of new fuel cycle logistics, especially fuel quality standards, and fuel supply logistics. These are described in more detail under development imperatives and the development pathway below

Section 3 Fuel Production Technology Gaps And Risks

The fuel burned in DICE is in the form of a “slurry”, which is defined as a “semi-liquid mixture, typically of fine particles of solids [*in our case, coal*] suspended in water”. The *coal-water slurry* (CWS) fuel has to be prepared before being used in DICE. This process can take one of the two forms:

- A central fuel processing plant (analogous to a petroleum refinery producing gasoline and diesel fuel among other products) serving many CWS-fired power plants
- A dedicated fuel processing plant serving each CWS-fired power plant

The CWS fuel processing power plant has two major functions:

- Creating “coal powder” to be mixed with water
- “Cleaning” the coal powder (commonly referred to as “beneficiation”) to reduce sulfur and ash

In the literature, cleaned, pulverized (or “powderized”) coal is also referred to as *micronized refined coal* (MRC) because of the size of the fine coal particles (mean size of the order of 10 to 15 *microns*). Typical, CWS is a mixture of MRC and water in roughly equal amounts by weight and has a consistency similar to that of paint. As an example, CWS properties from the USDOE’s *Clean Coal Technology* program in 1994 are provided in Table 3-1 [3]. (Additives such as xanthan gum and surfactants are used to control slurry viscosity; dispersants are added to prevent agglomeration.)

**Table 3-1
CWS Properties**

Coal content (%)	49.24
Water content (%)	49.25
Additives (%)	1.51
Viscosity at 100-200 s ⁻¹	50-100 cp
Viscosity at 1000 s ⁻¹	100-300 cp
Mean particle size	12 microns
99.9% less than	44 microns
100.0% less than	88 microns
Coal Analysis:	
Ash content (%)	1.8
Sulphur (%)	0.6
Volatiles (%)	38.6
Heating value (Btu/lb)	15 300


Ideal MRC properties for *black* (“high rank” or bituminous) and *brown* (“low rank”, subbituminous or lignite) coals are provided in Table 3-2 [4].

**Table 3-2
MRC Properties**

Property	Black	Brown
HHV (MJ/L)	21-25	16-19
Mineral ash (wt% dry)	1-2	0.2-1
Total ash (wt% dry)	1-2	2-3
Viscosity (apparent, mPa.s)		
@100/s (pumping)	200-500	400-700
@100,000/s (injection)	100-300	200-400
Unstirred settling rates(stagnant) mm/month	1-5	1-5
Particle size		
d50 µm	10-15	10-15
d95 µm	50	70
Cost including coal (\$/GJ)	\$4-6	\$2-3

Neither coal pulverization nor coal cleaning/beneficiation requires “invention” of new technologies. Currently available physical and chemical cleaning technologies can readily eliminate ash (including mineral sulfur) but there is a cost-performance trade-off as illustrated in Figure 3-1 [1]. Reducing the MRC specification from 2 wt% to 1 wt% can easily triple the coal processing cost.

**Figure 3-1
Coal Beneficiation Cost (in Australian Dollars)**



3.1 FUEL DEVELOPMENT NEEDS

3.1.1 Fuel R&D

Cost-effective fuel processing to meet a specification that is suitable for DICE is essential. For most coals, this will require producing a finer and lower ash product than for existing markets – but without the usual moisture constraints. Three steps are involved, and all require R&D and testing to optimize the processing for the specified feed coal.

1. Demineralizing and densification
2. Micronizing and slurry production
3. Blending

The steps and nominal targets for both R&D and test work is described below, based on CSIRO's experience with 48 coals.

3.1.1.1 Demineralizing and Densification

The first step is to produce feed coal with sufficiently low ash, and without coarse, hard minerals such as quartz, pyrites or rutile. It is important to recognize that this requires low temperature plasma ashing (LTA), followed by quantitative X-ray diffraction (XRD), to determine the mineral species. This complements a standard coal ash analysis. From recent experience, this step will be challenging for the sub-bituminous PRB coal proposed, as deep cleaning by a highly selective process, such as flotation or selective agglomeration, is likely to be less effective than for bituminous coals –resulting in both higher product ash and lower recovery. Ideally, cleaning would be undertaken on densified material – e.g. after pretreatment by hydrothermal treatment. Hydrothermal treatment is also known to reduce hydrophilic surface groups and oxygen content (slightly), which further assist in both cleaning and by increasing calorific value of the fuel slurry.

3.1.1.2 Micronizing and Slurry Production

The second step is to micronize the cleaned feed coal. Ideally, this is by higher efficiency wet milling with the required slurry water plus additives. For a 500 rpm engine, a conservative top size (d_{97}) is 65 μ m. The aim is to produce a size distribution that will have a good packing efficiency, which maximizes the coal loading and therefore calorific value of the fuel.

Unless a cleaning step follows micronizing (as would be the case for bituminous coal), micronizing should be undertaken with steel mill media, as ceramic media can chip and cause unacceptable contamination. If steel media is used, the fuel will pickup some Fe, but as discussed below, this iron pickup can improve fuel rheology.

3.1.1.3 Blending and Trimming

It is unlikely that a fuel freshly micronized and slurried in Step 2 will have acceptable rheology. A significant improvement in fuel rheology requires a combination of further blending and aging. Blending is most efficiently undertaken using a combination of a high shear mixer (eg Eirich-type paddle mixer) followed by a longer period of low-intensity mixing (eg a Visco-jet or similar). Experience has shown that the energy required for the high-intensity mixing stage can be as high as 30-50% of that of micronizing. The low shear mixing could also be provided by storage tank

agitation. During the blending and trimming step, the rheology of the MRC should be measured for the shear rate range 0.1-3000/s (or higher) to ensure the shear thinning behavior of the MRC. Additional trim additions of a surfactant or thickening agent may be required to achieve these properties.

Examples of additions for Australian bituminous and lignite coals are shown in Table 3-3.

**Table 3-3
Nominal Additives Used to Produce MRC**

Purpose	Example	Range wt%¹	Comment
Dispersant	Polystyrene sulfonate	0.1-0.5	Needs to be optimized for the coal. Other dispersants may be more economical
Stabiliser	Carboxymethylcellulose	0.0-0.1	Often not required, can interfere with the dispersant
Auxillary	Soluble Fe or Ca	0.01–0.1	Bridging agent. Most effective for bituminous coals. Not required for alkaline ash coals
Biocide	From vendors	0.0-0.1	Usually not required

¹ active ingredient, dry coal basis

As a general comment, processed lignite and sub-bituminous coal usually produce excellent fuel slurries from a stability and shear thinning perspective; however, porosity and residual surface groups reduce the coal content and, therefore, the calorific value of the fuel for a given viscosity. The other factor that affects the coal content of the slurry is the particle size distribution, which determines the packing efficiency (can be calculated).

3.1.2 Further Research Studies

Suggestions for research studies that would assist in de-risking the fuel technology for bituminous and sub-bituminous coals are given below. It should be noted that not all of these studies may be required – as work progresses, the research will be amended to achieve the goal cost effectively

3.1.2.1 Mineral Matter

- Identify the mineral species in the coal (LTA plus XRD, and the size distribution of the various minerals by SEM - very useful in considering beneficiation issues and options.
- Optimize mineral removal from micronized coal (with and without hydrothermal treatment), using flotation or other physical separation procedures- how much of which mineral species is removed?. This study will include the effect of flotation aids/chemicals on slurry rheology.

Dewatering is required after flotation, which requires a dilute (~5%) slurry. Research is required to develop the most cost-effective dewatering technology and to optimize dewatering aids, prior to fuel slurry formulation.

3.1.2.2 Surface Groups

- For lower rank coals, the level of carboxylic acid/carboxylate surface groups should be measured (e.g. by a titration procedure).
- If insufficient surface groups are present to achieve stability and shear thinning studies will be undertaken to determine how can they be generated at minimal cost for bituminous and sub-bituminous coals (eg by increasing surface oxidation using chemicals or electrolysis).
- Additives such as calcium ions have a very beneficial effect on bituminous coal slurries, with small additions (<0.02%) changing slurries from shear thickening to shear thinning. Is this effective for the target coal, and what is the effect when combined with a dispersant?
- What is the effect of hydrothermal treatment (and perhaps other treatments such as compression, or low temperature pyrolysis) on the coal properties such as surface groups and porosity may need to be assessed, as coal characterization proceeds.

3.1.2.3 Milling/Micronization

- It may be possible to wet micronize the coal to achieve the final slurry coal. concentration. This would have the benefit of avoiding an additional trim dewatering step, especially if a dry beneficiation process was used

3.1.2.4 Slurry Generation

- Mixing conditions (time, intensity, dispersant, type of mixer) are known to affect the properties of the slurry, but this depends on the coal and additives used. Experimentation is required to optimize mixing for the particular coal

3.1.2.5 Fuel Stability

- Coal slurries can be adversely affected by bacteria and may need biocides to maintain stability. Work is required to determine if biocide, if required, and identify formulations that do not negatively affect slurry rheology. CSIRO has had a bacterial problem with only 2 coals to date (out of 48). However, other research groups have experienced significant bacterial issues.
- Stability tests - many of the tests in the literature are focussed on comparatively short term stability (days to weeks). There is a need for tests that are relevant to commercial operations associated with storage and transport (months)
- Stability tests – many of the tests in the literature are focused on comparatively short-term stability (days to weeks). There is a definitive need for tests that are relevant to commercial operations associated with storage and transport (months)

3.2 CWS PROCESSING PLANTS

CWS processing plants in pilot scale has been designed, built and operated in the past. Key examples are:

- University of North Dakota's Energy & Environmental Research Center (EERC) CWS production process with hot water drying (using Kentucky and Usibelli coals) [5,6]
- Jameson Flotation Cell (Glencore Technology) in Australia [7]

A comprehensive review can be found in Nicol [1]. However, so far, no commercial-scale CWS production facility which is commensurate with the stringent requirements of DICE application has been built. In order to have an idea about the "commercial scale", the DICE considered in this project (about 16 MWe generator output) consumes CWS at a rate of **18,750 lb/hr** (about **8.5 metric tons** per hour). The proposed power plant is based on five DICE units.

In order to design the appropriate CWS processing plant, properties of the coal feedstock should be analyzed in great depth. The first step is to obtain a small sample of the coal feedstock to determine if grinding to finer particle sizes liberates the ash. If grinding does not liberate the ash, some cleaning technologies may not be able to produce a low ash coal. Additional lab work would be required to determine the best approach to clean the coal. As discussed in detail, *this is not an easy task*:

The design basis coal for the present project is low-sulfur, subbituminous Power River Basin (PRB) coal (a low rank coal) with proximate and ultimate analysis summarized in Table 3-4. In his 1993 Master's Thesis, Kong identified a total of 25 mineral phases in the samples from the Big Sky and Absaloka mines in the Rosebud subbituminous coal seam [8]. (The Big Sky samples were taken from different layers of the seam.) Mineral concentrations ranged between 5 wt% and 15 wt% on a whole coal basis (see Table 3-5). Pyrite (FeS_2) was the only important sulfide mineral identified. In the B-I sample in Table 3-5, pyrite was 8.5 wt% on coal basis; in B-III sample, it accounted for 2.5 wt%. In the others, pyrite content changed between 0.15 wt% and 1.29 wt%. The data and information clearly illustrates the difficulty of predicting de-ashing effectiveness and MRC product quality from proximate or ultimate analysis.

**Table 3-4
Design Basis Coal Analysis**

Rank	Sub-Bituminous	
Seam	Montana Rosebud	
Source	Montana	
Proximate Analysis (weight %)^A		
	As Received	Dry
Moisture	25.77	0.00
Ash	8.19	11.04
Volatile Matter	30.34	40.87
Fixed Carbon	35.7	48.09
Total	100.00	100.00
Sulfur	0.73	0.98
HHV, kJ/kg (Btu/lb)	19,920 (8,564)	26,787 (11,516)
LHV, kJ/kg (Btu/lb)	19,195 (8,252)	25,810 (11,096)
Ultimate Analysis (weight %)		
	As Received	Dry
Moisture	25.77	0.00
Carbon	50.07	67.45
Hydrogen	3.38	4.56
Nitrogen	0.71	0.96
Chlorine	0.01	0.01
Sulfur	0.73	0.98
Ash	8.19	10.91
Oxygen ^B	11.14	15.01
Total	100.00	100.00

The average total mineral content of the five Big Sky mine samples (B-I through B-V) in Table 3-5 is 7.35 wt%. Ignoring the outlier B-I, the average is 5.84 wt%. Accounting for the sulfur in pyrite, non-sulfur mineral content average is 6.17 wt%; without the outlier B-I, the average is 5.33 wt%. At the risk of being somewhat optimistic, we have assumed that non-sulfur mineral content of the design basis coal is 6.7 wt% so that the cleaned coal ash content can be reduced to 1.5 wt%. As far as the sulfur is concerned, we decided to be less optimistic and have assumed that 20% of the sulfur in the “as-received” coal is inorganic and can be removed during beneficiation.

Beneficiated “clean” coal properties (dry basis) are shown in Figure 3-2. The improvement in heat content on a higher heating value (HHV) basis is $29,748 / 26,787 = 1.11$ or 11 percent.

Table 3-5
Mineral Content of Rosebud Coal Seam Samples (percent by weight)

Mine	B-I	B-II	B-III	B-IV	B-V	A06	Average
Total Mineral	14.91	4.98	8.88	4.76	5.33	5.23	7.35
Pyrite	8.45	0.46	2.5	0.34	0.15	1.29	2.20
S (Pyrite)	4.52	0.25	1.34	0.18	0.08	0.69	1.18
Total - S	10.39	4.73	7.54	4.58	5.25	4.54	6.17

Figure 3-2
Beneficiated “Clean” Feedstock Properties

The screenshot shows a 'Fuel Analysis' window with the following data:

- Fuel name: Montana Rosebud (DOE)
- Solid type: Coal
- Fuel supply temperature: 25 C
- Update Fuel by Total Moisture Content... (button)
- Ultimate Analysis (weight percent):

Total moisture	0	%
Ash	2.2	%
Carbon	74.31	%
Hydrogen	5.02	%
Nitrogen	1.06	%
Chlorine	0.01	%
Sulfur	0.86	%
Oxygen	16.54	%
Total	100.000	%
- Heating Values (Moisture and Ash included):

HHV @ 25C	29478	kJ/kg
LHV @ 25C	28382	kJ/kg
- HV Estimation Method: Dulong
- Coal Rank:
 - Automatic estimate (selected)
 - User-defined
 - Inherent (as-mined) moisture as % of total moisture: 100 %
 - Coal rank: High-volatile B bituminous

This study assumes that the MRC composition is 45 wt% water and 55 wt% beneficiated and micronized coal. The resulting MRC fuel composition is listed in Table 3-6. The LHV of this fuel is 14,513 kJ/kg (HHV is 16,214 kJ/kg). It should be emphasized that, for an accurate determination of MRC composition, more detailed information about the feedstock (i.e., petrography data) is requisite. Depending on the actual coal microstructure, final MRC ash content can be 2 wt% or higher.

**Table 3-6
Study MRC Composition**

	As Is (wt%)	Washed	Dry	Dry (wt%)	Slurry	MRC (wt%)
Moisture	25.77	25.77	0.00	0.00	81.82	45.00
Carbon	50.07	50.07	50.07	74.31	74.31	40.87
Hydrogen	3.38	3.38	3.38	5.02	5.02	2.76
Nitrogen	0.71	0.71	0.71	1.05	1.05	0.58
Chlorine	0.01	0.01	0.01	0.01	0.01	0.01
Sulfur	0.73	0.58	0.58	0.87	0.87	0.48
Ash	8.19	1.49	1.49	2.21	2.21	1.21
Oxygen	11.14	11.14	11.14	16.53	16.53	9.09
Total	100.00	93.15	67.38	100.00	181.82	100

It is noted that this MRC composition based on PRB coal as feedstock differs from that listed in the coal beneficiation study in Appendix B. The MRC composition for this pre-FEED study assumes 45 percent total moisture and 55 percent dry coal solids by weight. In the coal beneficiation study performed by Sedgman, the coal beneficiation process OEM, it is assumed that the MRC has a free moisture content of 45 percent by weight and that the 55 percent solids by weight in the product still contains the inherent moisture of the PRB coal.


Due to the lower total moisture content of the MRC assumed in this study's design, the performance may be optimistic. The actual total moisture content of the MRC needs to be studied further and verified via testing on actual coals. These tests should establish the moisture content of the micronized coal and the minimum moisture content required for the slurried MRC to meet DICE rheology requirements.

3.3 TECHNOLOGY GAPS, RISKS, AND DEVELOPMENT PATHWAYS

3.3.1 Potential R&D Needs

For the typical commercial beneficiation process, there are *currently no specific components, equipment, or systems which require undertaking traditional R&D nor having any technology gaps*. However, as part of the overall beneficiation process, there are key commercially available plant unit operations whose end-use application is novel - **when beneficiation is based on coal**. As shown in Figure 3-3, these unit operations include fine grinding mill, ash removal (via rougher flotation and cleaner flotation), and tailings handling.

Figure 3-3
Key Coal Beneficiation Unit Operations



Based on the findings from the Performance Results and Cost Results reports, while the various components for a conventional flotation-based coal beneficiation plant, as shown in Figure 3-3, are all commercially available, the low overall product yield and tailings handling are areas that need to be addressed in order for the process to be economically feasible.

In the DICE CRCC pre-FEED study that uses PRB coal as the feedstock to the beneficiation plant, the overall product recovery yield was about 50 percent on both a mass and combustible value basis. A consequence of this low product yield is the large quantity of reject tailings that, while still containing significant heating value, is in slurry form, and has no commercial value. The unsaleable tailings thus has to be disposed of in ash ponds, which constitute an environmental risk.

While it is possible to process the reject slurry (via dewatering, briquetting, etc.) to a more functional form, this requires additional energy and cost input. It is therefore key to address the likely technology gap associated with disposing the otherwise unsaleable reject slurry tailings from coal beneficiation.

It is of utmost importance to increase the product recovery yield to way beyond the current 50 percent. Doing so would not only decrease the coal feed required by the beneficiation plant, but also minimize the quantity of reject tailings. It is understood that the hydrophilic nature of the subbituminous coal as-is makes it difficult to achieve a high recovery via the conventional flotation process for ash separation. Tests on various coal samples should therefore be undertaken to identify coal types that can achieve maximum product recovery.

Virginia Tech has developed a process that can increase combustible recoveries of typically hydrophilic materials such as PRB coals, which involves using an additive to increase their hydrophobicity. Virginia Tech plans to investigate and develop this technology further under the USDOE CoalFIRST Critical Components development program. Besides performing tests on a variety of high- and low-rank coals, this technology can also be used to recover MRCs from waste coals that are currently being discarded in the eastern US coal fields. If it can be demonstrated that these waste coal fines can be successfully beneficiated to produce suitable CWF fuels for firing in DICE, this substantially reduce the coal cost and produce MRC-based CWFs at cost below \$1.50/MMBtu. Supply of low-cost CWF fuels should expedite the commercialization of DICE technology and ensure a success of the CoalFirst program.

Additionally, Virginia Tech's process is understood to be able to reduce the inherent moisture of the coal particles in the MRC via a mechanism known as dewatering by displacement (DbD), described in US Patent 9,518,241. In this process, a hydrophobic liquid is introduced to displace the water trapped within the coal's pore structure and reduce its moisture. The resulting hydrophobic liquid phase contains coal particles free of surface moisture and entrained droplets of water stabilized by the coal particles, while the aqueous phase contains the mineral matter. By separating the entrained water droplets from the coal particles mechanically, a clean coal product of substantially reduced mineral matter and moisture contents is obtained. The spent hydrophobic liquid is separated from the clean coal product and recycled.

Another advantage of Virginia Tech's technology is that it processes the coal at a relatively coarse size, which allows the rejects to be easily disposed of without the need for expensive dewatering or environmentally hazardous ponds. Furthermore, the coarse product coal is dry yet does not catch fire spontaneously during shipping, which allows for the beneficiated product to be shipped to the DICE CRCC plant dry, where it is micronized and slurried on-site. This ability to ship a relatively coarse, dry product that avoids spontaneous combustion is believed to be able to reduce the overall fuel costs substantially.

3.3.2 Development Pathway via Testing

Since there is no requirement for undertaking traditional R&D, there is however a need for a commercial development pathway to definitively verify, validate, and confirm the key assumptions, design/concept impact, and end-use application of the highlighted beneficiation unit operations based on coal. Testing (e.g. combinations and permutations of laboratory based, independent/third-party, or any performance testing) is highly recommended and required to be undertaken. Currently, the beneficiation testing opportunities based on coal are limited since such applications are primarily market-driven. For commercial end-use application, further testing and development is required on specific coal types for optimal yield and efficiency for each of the key unit operations covering:

- **Fine Grinding Mill:** Available proven technologies include impact and attrition mills. Selection of most suitable grinding technology depends on various factors which include product size, feed size, and energy consumption
- **Ash Removal (via rougher/cleaner flotation):** Different proven flotation technologies available with different energy and reagent input requirements. The low ash concentration in product coal (2 wt% db) is a potential challenge which need to be proven-out via testing
- **Tailings Disposal/Utilization:** There is no market value in slurry form. There is additional energy/cost to process (dewatering, briquetting). Disposal and utilization is a function of product yield (< 50% for PRB coal)

3.3.3 Testing Regime - Future Work Plan

From this study, items in proposed order of testing as discussed below, should be included in an ongoing work plan to further progress the development pathway of MRC as fuel for the DICE CRCC. As shown in Table 3-7, these tests will verify, validate, and confirm the key assumptions, design/concept impact, component and equipment selection and sizing.

The specific detailed testing regime will be dependent on the final coal type(s) selected, availability of sample, and the testing work budget and schedule.

Table 3-7
Testing Required to Confirm Key Assumptions, Design/Concept Impact

Key Assumptions	Design/Concept Impact	Testing Required to Confirm
Feed quality size independent – all feed processed	<ul style="list-style-type: none"> ▪ Pre-sizing requirements ▪ Screening requirements ▪ Feed handling system (conveyors) 	<ul style="list-style-type: none"> ▪ Size/ash analysis of feed ▪ Coal Grain Analysis
Liberation of carbon requires grinding to 100% passing 50 micron	<ul style="list-style-type: none"> ▪ Grinding technology and power requirement ▪ Downstream processing technology and size (flotation thickening, dewatering) 	<ul style="list-style-type: none"> ▪ Size/ash analysis ▪ Coal Grain Analysis ▪ Grinding characteristics testing
Deep froth and high wash water required for low ash product	<ul style="list-style-type: none"> ▪ Flotation technology 	<ul style="list-style-type: none"> ▪ Flotation testing (tree flotation)
2 stage flotation required to reach required product ash	<ul style="list-style-type: none"> ▪ Flotation plant layout and size ▪ Power and consumables requirement 	<ul style="list-style-type: none"> ▪ Flotation testing (tree flotation)
24 hour product storage	<ul style="list-style-type: none"> ▪ Product slurry storage tank size and number 	<ul style="list-style-type: none"> ▪ Based on DICE CRCC pilot plant

Feed Coal Analysis: One of the main drivers for the success of DICE CRCC is the feed coal selection. The PRB coal is shown to be not ideal based on the current pre-FEED study. The low product yield results in a large quantity of as-received feed requirement, while generating similarly large quantities of tailings for disposal. Thus, bench-scale tests needed on various coals to establish and select feed with the best available yield. As part of the testing regime, analysis on a selection of possible feed coals should be carried out. A shortlist of possible feed coals with suitable properties (ash, sulfur content, and energy levels) could be selected based on known existing coal quality from different mine sites. The selection of the preferred coal type is a critical component of any ongoing work as this will drive the downstream test work, the results of which will determine equipment sizing and final project costs (e.g. capital and operating).

Coal Grain Analysis: Once a preferred coal source, or sources, are identified, the development team shall carry-out detailed coal grain analysis on this coal to determine liberation requirements to reach the required product ash level. The results of this analysis is critical to both the grinding and flotation equipment selection.

Crushing and Grinding Test Work: Laboratory scale comminution tests (comminution is particle size reduction by breaking, crushing, or grinding of ore, rock, coal, or other materials) should be carried out on the selected coal to determine the energy inputs required for crushing and grinding. These tests can be performed by a metallurgical testing laboratory or by sending samples to equipment suppliers. The following tests are recommended:

- Drop shatter
- Hargrove grindability

- Abrasion index testing
- Bond crushing work index or JK drop weight test
- Bond rod mill index
- Bond ball mill work index
- Signature plot and/or jar test

Flotation Tests: Flotation tests should be performed on freshly ground coal samples to avoid oxidation of the particle surfaces which will adversely impact flotation performance. These can be performed as part of a metallurgical laboratory suite of testing or samples can be sent to different suppliers/technology providers. These tests will assist in determining:

- Flotation behavior of ultrafine feed material
- Suitable flotation technology
- Suitable flotation circuit configuration to achieve required performance (ash and yield) - e.g. rougher-cleaner, rougher-scavenger, and rougher-cleaner-scavenger
- Reagent dosage required
- Froth carrying capacity
- Wash water requirements
- Froth depth requirements

The results of the flotation test work may require an iteration of the grinding work to be done.

The coal grain analysis will provide a target value for liberation size, however, the variability of coal feed and inefficiencies of the flotation process may necessitate a finer grind to be performed to realize the target ash. If this is the case then iterative tests may need to be performed.

Thickening and Dewatering Tests: Both the product (concentrate) and tailings material from the flotation test work would need to be collected to perform thickening and dewatering testing.

Thickener testing will help to determine thickener size, flocculant type and dosage rates. Dewatering test work will help to size the dewatering equipment and assist in selection of the final dewatering technology to use.

Rheology Characterization: To support the sizing and selection of agitators, pumps and piping a range of rheology characterization should be undertaken on the key intermediate and final product and tailings slurry streams. This testing will provide information on the deformation and flow behavior of the slurry compositions expected in the plant.

Pilot Plant Operation: The proposed flowsheet utilizes commercially available equipment however for most major equipment, as highlighted the commercial application to coal is novel. It is therefore recommended that following the completion of the above initial laboratory scale analysis, a pilot plant be constructed and operated to provide an indication of the expected continuous performance. A nominal throughput of 1 ton per hour should be considered as basis however the throughput will likely be based upon the size of the equipment commercially available. Often equipment can be leased from one or more laboratory testing companies or equipment suppliers. Evaluation of a suitable location for undertaking the test work should

consider the proximity to the feed coal, the disposal method for the tailings/waste, and if the product will be tested/utilized in the same location, i.e. a DICE CRCC pilot plant included with the coal beneficiation pilot plant.

Section 4 Development Coordination

4.1 OBJECTIVES

There is a need to work in close coordination with the DICE and coal beneficiation process developers. For example, the ash content, sulfur content, rheology, among other beneficiated MRC properties, need to be established between the DICE and coal beneficiation developers.

There must be an objective to develop this coordination under DOE CoalFIRST Critical Components development program. Accordingly, there are two competing “chicken or egg” factors that make a coordinated DICE development approach very difficult:

1. As clearly indicated by the findings of the pre-FEED study, a dedicated “fuel block” with each DICE is clearly not an economically viable proposition
2. Without a readily available fuel supply, DICE technology is a dead end

While the obvious solution to widespread DICE deployment is a centralized “coal-water slurry fuel factory” similar to a refinery producing gasoline or diesel fuel (after all, DICE CRCC is best suited to distributed generation), the question that remains is also obvious:

Who would make the investment into such a fuel factory without a readily available market for its product?

The second obvious question is a corollary of the first:

Who would make the investment into DICE technology without a readily available fuel supply?

Evidently, the two questions can be formed into a single one:

What is the market for DICE (or another technology for that matter) firing coal?

The key problem to this is that unless there is a coordinated effort akin to a “Manhattan Project” to “impose” widespread deployment of a modular, flexible and efficient coal-burning technology such as DICE CRCC for distributed generation applications in a future generating portfolio with heavy contribution from solar and wind energy (and other non-fossil fuel technologies).

Addressing this problem is certainly out of the scope of the pre-FEED study. However, it is still necessary to come up with a coherent approach to develop the technology in a feasible manner to TRL 8 or 9. The key obstacle in this endeavor is still the same, i.e., cost, and ultimately a question of financing.

4.2 DICE DEVELOPMENT PATHWAY

A development pathway is proposed in the context of a revised positioning of the DICE fuel cycle, including:

- Energy security
- High thermal efficiency and lower CO₂/MWh at small unit size
- A new coal replacement for oil, coal and natural gas
- Nimble generation to support variable electricity demand
- Underpinning a high penetration of intermittent renewables (it is the CO₂ intensity of the overall system that is key – not that of the individual technologies)
- A first commercial DICE plant by 2030

Also, the program considers several development imperatives, de-risking by staged development and scale-up risk, discussed per the following:

4.2.1 Development Imperatives

Recent R&D has highlighted development imperatives, which have shaped the proposed development pathway:

1. Securing the commitment of an engine OEM and component manufacturer (e.g., fuel systems).
2. Development of a suitable large engine test facility (i.e. small-scale demonstration engine), which is capable of firing MRC at near commercial scale conditions; for example, an inline 6-cylinder variant of a larger V18 cylinder engine suitable for commercial generation.
3. Small demonstration-scale engine tests to obtain key performance data on combustion, using tonnage lots of consistent and high-quality MRC produced from larger fuel plants.
4. Detailed techno-economic assessment of DICE for different markets to assist with developing engine and fuel targets, and to increase the case for industry commitment.
5. Detailed risk and hazard review to further de-risk the new fuel cycle, identify key technology gaps/showstoppers, and to broaden stakeholder engagement.
6. Duration engine tests to investigate fouling. These tests could be performed using smaller engine tests and a range of adapted boiler test methods, to avoid the need for producing a larger tonnage amount of MRC and the costs of duration operation of the larger test engine.
7. R&D to obtain data for optimizing fuel handling logistics, and to enable engineered systems to be developed for a range of scenarios (local generation, distributed generation, export).
8. Developments in MRC standards, in particular, to account for the wide differences and trade-off in MRC properties between different coals.
9. Developing an outreach program to ensure correct positioning and avoid negativities from coal's past image.

4.2.2 De-risking with Staged Development

While the previous R&D has provided promising findings for a range of technical issues around coal-engine interactions, this work can only provide a *technology readiness level* (TRL) of 4 for most technical aspects. De-risking by increasing the TRL from 4 to 8 in order to justify (e.g. a 50 MWe) commercial demonstration project requires that appropriate small-scale demonstration tests are undertaken – taking full benefit of the many technical improvements over the last 25 years. DICE needs considerable development and demonstration to match the technical development of current power generation technologies. However, this can be cost-effectively fast-tracked. Compared to the incumbent technologies, DICE has strong technical merit because of the ability to carry out a near-commercial scale demonstration at a relatively small size (e.g. 5 MW).

The 5 MW capacity engine-generator can be obtained in skid form, in a straight 6 configuration, giving a cylinder of approximately 400 mm bore and operating at 500 rpm. The simple in-line configuration and fewer cylinders ensure easier and faster incorporation of new components for testing - *essential to shortening development time*. This includes the option of only needing to make changes to one cylinder – which can also be swapped out as a complete power unit in a few hours to facilitate testing.

The data, information, and experience gained from this engine would be directly applicable to a larger semi-commercial demonstration (e.g. a V18 configuration producing 15 MW at 500 rpm). It is envisaged that successful demonstration at this scale would lead to larger commercial installations comprising multiple 15-20 MW engines, as is practiced for gas engine installations. This would not entail any scale-up of DICE. Standard approach to reduce capital cost and to improve overall efficiency is a conventional combined cycle. For higher efficiency, DICE CRCC is the ideal solution.

4.2.3 Scale-Up Risk

The cylinder size, rating and power output from a single engine unit for the proposed development steps to a full-size commercial engine are shown in Table 4-1).

**Table 4-1
Scale-Up Factors from Demonstration through to Large Commercial Installation**

Development stage	Bore (cm)	Cylinder rating (kWe/cyl)	Cylinders Units	Plant output (MWe)	Scale up
Small scale demonstration	46	1000	6	5-6	1
Demonstration plant	46	1000	18	20	1
First commercial	46	1000	18 5 units	100	1
Large commercial 4-stroke	63	2000	18 5 units	200	2x
Large commercial 2-stroke	94	5000	12 6 units	360	5x

The scale-up factor (based on cylinder area) between the development stages is at most 2-5x, which are relatively small scale-up steps that have low technical risk:

- The scale-ups are considered very conservative by the engine manufacturers – especially if a National Test Facility is available to test the latest developments before deployment
- In contrast to many technologies, DICE has the advantage of being able to undertake near full-scale demonstration at small-scale.
- As cylinder size increases, many of the technical issues associated with firing MRC decrease (e.g., more time and space for combustion allows reduced atomization, and wear effects also decrease).

Overall, it is envisaged that a staged development program could be established with an engine manufacturer and OEMs (e.g. suppliers of injection and turbocharging components) to quickly undertake the demonstration program, to enable commercial deployment by 2030.

4.2.4 Staged Development Program

The recommended program involves 3 stages, which allows sequential de-risking and the development necessary to provide the experience and data required to develop the components to adapt an engine for a demonstration plant. In comparison to other new technologies, DICE has the advantage of being based entirely on relatively small adaptations of existing commercial technology, and at a small scale to drastically shorten the time required to progress from single-cylinder tests through to commercial deployment. The stages and timings are as follows:

Stage 1 (2020-22)	Single-cylinder engine tests - component development, single-cylinder engine tests, logistics and business cases
Stage 2 (2023-26)	DICE test facility and fuel plant (5 MW)
Stage 3 (2027-30)	Semi-commercial DICE plant (20 MW units)


The program timeline is also shown in Figure 4-1, with additional details on the individual activities given below.

4.2.4.1 Stage 1 - Single-cylinder engine tests

These tests will provide both a focus and a framework for the entire fuel cycle, including:

- Processes and experience in the production of (say) 20 mt of suitable fuel
- Negotiation of a trade-off between fuel quality and engine modifications – both for short-term tests and future commercial operations.
- Hands-on experience with producing, handling and storage of bulk MRC fuel
- Fuel quality testing
- On-engine fuel handling experience, including both the low-pressure fuel supply system and the high-pressure injection system
- DICE operating strategy, including startup, operation at various load settings, and shut down with or without system flushing
- Optimizing pilot fueling
- Exhaust emissions
- Duration testing of a new injector
- Preliminary data on ash fouling
- Preliminary techno-economics and risk assessment
- Business case for DICE facility – a shared national facility or consortia owned
- Broadening stakeholder engagement with real data

**Figure 4-1
Proposed 3-Stage Development Program**



4.2.4.2 Stage 2 – DICE demonstration plant (5 MW)

Development of a suitable engine test facility (i.e., demonstration engine), capable of firing MRC under near commercial scale conditions is essential to development – of both the engine and fuel production.

While all manufacturers are capable of undertaking engine tests in dedicated test cells, to avoid competition for test cell access, it is recommended that either a dedicated test cell is obtained, or a new host site is used close to supporting engineers. Also, while a brake dynamometer is normally used for engine testing, a standard alternator load (i.e., as a genset) can be used with sufficiently accurate information of combustion and engine performance being obtained from cylinder indicator readings. The use of a generator also allows power exports to offset test costs (important for the longer duration tests).

An engine-generator producing around 5-6 MWe is recommended to increase the validity of the test results by demonstrating the technology with a cylinder size suitable for commercial operation – for example, a 6-cylinder variant of the 18V 48/60 engine by MAN.

An engine of this size will require around 6000 liters of fuel per day, equivalent to about 2 t/h of processed coal - which would also ensure MRC production at a reasonable scale.

Engine tests could determine the effects of the following on combustion/heat release, performance, thermal efficiency, lubricant contamination, wear, etc.:

- Engine load
- Cylinder air inlet temperature (by changing coolant flow to the aftercooler)
- MRC coal loading and rheology
- Pilot fuel timing and rate
- Development of operating strategies for starting, warmup, load changing, and shut down (short and long)
- Component durability tests – which could include using different materials and component designs for individual cylinders to provide a quicker and more cost-effective comparison of component performance than using individual test campaigns.
- Emissions as a function of load and fuel properties
- Engine ash fouling
- Turbine abrasion

Additional fuel supply tanks should be available to enable fuel batching to ensure consistent fuel quality for each series of tests.

It is also recommended that a parallel R&D and logistics program be undertaken, including:

- Detailed risk and hazard assessment, to further de-risk the new fuel cycle, identify key technology gaps/showstoppers, and to broaden stakeholder engagement. MRC slurry fuels and new coal combustion equipment will be required to demonstrate no surprises. For example, MRC is finely divided coal, but it is not classified as flammable. Spills can be

readily cleaned up with a shovel once the fuel loses a few percent moisture. While MRC looks like oil, spills are less detrimental (see Figure 4-2), and different handling and storage procedures are required.

Figure 4-2
MRC Spill 24 Hours Later (From Hydrothermally Treated Lignite)



- Detailed techno-economic assessment of DICE for different markets to assist with developing engine and fuel targets, and to increase the case for industry commitment. This assessment should include using DICE as both incremental and old replacement capacity at existing coal-fired power plants, as well as for greenfield development.
- R&D to obtain data for optimizing fuel handling logistics, and to enable engineered systems to be developed for a range of scenarios (captive or mine-mouth generation, decentralized generation, centralized generation, export).
- Developing standards and certification to account for the very different properties of MRC compared to fuel oil.
- Developing a detailed business case for commercialization.
- Broadening engagement/outreach. DICE is a potential new (and large) market for both coal suppliers and engine manufacturers and their componentry. However, recent experience has shown that engine manufacturers are generally reluctant to consider DICE due to coal's high CO₂ intensity (at the burner tip) – on top of their business-as-usual competing commercial priorities. It is therefore essential at the outset to establish and clearly articulate both the economic and environmental benefits of DICE to all stakeholders, for example:
 - Nomination as clean coal is no longer enough.

- DICE allows the novel use of coal to provide the backbone for a nimble, secure, ultra-low emissions power system by underpinning a high penetration of renewables - including the direct use of biomass and renewable ammonia. **It is the performance of the overall system that is key, not the individual technologies, as neither would likely exist without the other.**
- Also, once DICE is installed it can utilize a wide range of alternative fuels including crude bio-oils, chars and other niche fuels etc – giving many other advantages (increased utilization, reduced processing costs and losses, and the use of bioenergy wastes). These should be quantified using life cycle analysis. Only a streamlined LCA will be required to show the overall benefits. The LCA should be supported by a corresponding techno-economic assessment of the integrated energy cycle.

4.2.4.3 Stage 3 First-of-a-Kind DICE plant – 20 MW

The smallest representative, first of a kind DICE power plant, is likely to be that of a single large 4-stroke engine (say) 20 MWe.

- An engine of this size can be broken down into manageable sections, to enable road transport to most locations.
- Although essentially a commercial operation, it is expected that only limited performance warranties would be provided by the engine manufacturer, but this would be offset via the initial pricing and by close supervision of operation and maintenance by the engine manufacturer (and other equipment suppliers).
- Suitable locations or host sites for the first of a kind DICE plant are envisaged as:
 - Alongside existing pf steam plants to enable sharing of coal supply, logistics, and transmission infrastructure – possibly with the long-term aim of progressively replacing older pf units. This could have an additional benefit of training future operators and maintenance personnel. The MRC plant could also be used to supply light up and low load fuel to the pf plant.
 - A mine-mouth power plant. This location would provide additional economic benefits for the coal miner and allow any lower quality MRC feed coals to be diverted to conventional markets.
 - Alongside a natural gas fired power plant with limited gas supply – with the possibility of switching out/retrofitting existing engines for MRC.

4.2.4.4 Commercialization Approach beyond Stage 3

Following the successful demonstration, rapid commercialization is possible, and likely to be driven by a strong need for incremental coal generation capacity for:

- Replacing old, inefficient and uneconomic PC power plants (say units smaller than 300 MW and/or older than 30 years in plant economic life)
- New load-following capacity to secure a higher penetration of renewables, and in direct competition with gas open cycle plants with gas prices over \$5/GJ

- Remote generation, especially for supplying large mines and surrounding regions
- New capacity with CO₂ capture and storage, as DICE has the potential for a 30 percent reduction in the cost of capture over PC coal plants. The cost reduction is due to a combination of higher thermal efficiency (fewer kg CO₂/MWh) and the ability to use 130°C coolant and exhaust heat for stripping
- Once an engine is adapted for DICE it will be capable of handling a wide range of other alternative fuels (i.e. difficult) fuels (for example coal-biochar or coal-ammonia blends, crude bio-oils) which would extend the facilities value past the proposed demonstration, and provide additional environmental incentives for the facility and commercialization of DICE.
- MRC, including higher ash products, could be used to replace fuel oil for boiler light-up and low load operation.

Section 5 Emissions Control Technology

DICE CRCC is a fossil-fuel power plant burning two different types of fossil fuels: coal (in the form of a slurry) and natural gas. Let us address the second fuel first.

In DICE CRCC, natural gas is burned in the reheat combustor upstream of the hot gas expander and/or in the HRSG duct burners. In the introductory variant considered in the pre-FEED study, the reheat combustor is eliminated. Natural gas is the cleanest fossil fuel and is not a significant source of PM, VOC and SO_x emissions. In the duct burners, flame temperatures are quite low so that no significant NO_x emissions are expected either. Nevertheless, during the field operation, CO production due to flow and combustion instabilities can be a source of CO. In any event, minute amounts NO_x and CO generated in the HRSG duct burner are going to be managed by the SCR (downstream in the HRSG). In conclusion, there is no technology gap associated with this fuel, from the perspective of equipment for NO_x and CO removal.

5.1 SOX AND HG REMOVAL

PRB is a low-sulfur coal and the elemental sulfur is removed during the beneficiation process. SO_x removal is accomplished in the direct contact cooler (DCC) with caustic injection (to cool the flue gas and remove the bulk of the SO_x in the flue gas).

PRB coal typically contains less than 1 percent (wt) sulfur and less than 50 ppm chlorine, and the mercury (Hg) is primarily in the elemental form. Due to this reason, it is expected that the coal beneficiation process will remove some or most of the Hg in the coal feedstock. A feedstock sample analysis is requisite in order to provide a concrete estimate. For Hg remaining in micronized refined coal, post-combustion removal from the flue the gas is necessary to meet MATS requirements.

Activated carbon injection (ACI) is the standard method used for removal of Hg from the flue gas in coal-fired power plants. Activated carbon sorbents and high surface area unburned (loss on ignition, or LOI) carbon should be very effective for mercury capture when sufficient halogens (e.g., fluorine (F), chlorine (Cl) or bromine (Br)) or halides such as HCl are present in the flue gas³.

Activated carbon catalyzes SO₂ to H₂SO₄ in flue gas. The overall mercury adsorption capacity is dependent on the formation of H₂SO₄ on the surface of the carbon. Thus, the capacity of activated carbon for mercury is higher in low SO₂ flue gas such as in DICE CRCC. However low content of chlorine or bromine in the flue gas can render ACI infeasible for application in DICE CRCC. Once again, sample analysis and combustion tests with flue gas chromatography are requisite to provide a concrete answer.


³ HCl increases the mercury removal effectiveness of activated carbon and fly ash for mercury, particularly as the flue gas HCl concentration increases from 1 ppm to nominally 10 ppm.

In any event, the vanadium-based SCR catalyst used for NO_x-control promotes the oxidation of elemental mercury Hg to Hg²⁺ in the flue gas. Hg²⁺ is water soluble and can effectively be captured in a wet scrubber or, in this case, in the DCC.

5.2 PARTICULATE MATTER REMOVAL

Coal burned in the DICE is “cleaned” during the fuel production process to contain low ash and sulfur, sources of PM and SO_x emissions, respectively. DICE exhaust gas is scrubbed in a cyclone-type device to reduce PM content for protection of the downstream equipment, in particular, the hot gas expander. Similar devices have been widely used in fluidized catalytic cracking (FCC) of heavy hydrocarbon feeds for separating fine solids from vapor streams exactly for the same purpose, i.e., protection of the hot gas expander downstream (used for power recovery). A typical system is shown in Figure 5-1.

Figure 5-1
FCC Power Recovery System (UOP Honeywell)



It is worth noting that the hot gas expander shown in Figure 5-1 is the same piece of equipment used in DICE CRCC. The equipment used to clean up the particulate matter in the gas coming from the FCC reactor is the “third stage separator” (TSS). In order to understand the use of TSS and its suitability to application in DICE CRCC, an overview of the FCC process is provided.


In the FCC process, catalyst particles circulate between a cracking reactor and a catalyst regenerator. The cracking reaction deposits coke on the catalyst, thereby deactivating the catalyst. The catalyst regenerator burns coke from the catalyst with oxygen containing gas, usually air. Flue

gas formed by burning coke in the regenerator is treated for removal of particulates (by the regenerator cyclones) and for conversion of carbon monoxide. Even so, the amount of solid particles in most FCC flue gas streams exiting the regenerator is enough to cause severe erosion of the power recovery turbine (i.e., the hot gas expander) blades. Unfortunately, the PM remaining at this point are exceedingly difficult to recover, having successfully avoided capture despite passing through (typically) two stages of highly efficient cyclones. These particles (“fines”) are very small, essentially all of them are below 20 microns, and including significant amounts of submicron to under 5-micron sized material. Thus, a third stage of separation, which can capture these fines is necessary, i.e., the “third stage separator”.

The TSS uses a large number of small diameter cyclones because they give much better fines collection than larger cyclones, for the same gas velocity and pressure drop⁴. A schematic diagram of UOP Honeywell TSS is shown in Figure 5-2. FCC regenerator flue gas enters the TSS at the top and passes through a number of small-diameter, high efficiency, cyclonic elements arranged in parallel and contained within the separator vessel. After the catalyst particulates are separated from the flue gas in the cyclones, the clean flue gas leaves the separator. A small stream of gas, called the underflow, exits the separator through the bottom of the separator vessel. In some applications with stringent emission limits, the underflow is directed to an additional separation (i.e., the “fourth stage separator”) and collection stage before combining with the clean flue gas.

⁴ For example, for a 5 to 20-micron dust mixture, dust collection improves significantly as cyclone diameter decreases, i.e., with collection efficiencies for 6, 9 and 24-inch cyclones being 90%, 83% and 70% respectively.

Figure 5-2
UOP Honeywell TSS



As highlighted earlier, the hot gas expander used in DICE CRCC (by Baker Hughes) is the same equipment used in FCC applications. Equipment specification by Baker Hughes regarding PM is shown below (the term “catalyst” refers to the catalyst fines discussed above):

“The warranty is valid subject to the following conditions, to be fulfilled by Purchaser during the four (4) years of continuous operation:

- The catalyst concentration in the flue gas to the expander shall be maintained at less than 100 ppm (by weight)
- The catalyst particle size distribution shall not exceed the values listed below:
 - 99.9 percent less than 12 microns
 - 98.5 percent less than 10 microns
 - 92.0 percent less than 5 microns
 - 75.0 percent less than 2 microns

Typical coal (MRC) water slurry used in DICE has the following ash characteristics:

- 0.2 to 1 percent (w) mineral
- 1.5 to 3 percent (w) total
- With P50 of 10-15 microns and P95 of 70 microns

DICE exhaust gas conditions are around 1,000 °F and 60 psia, which are well within the range typical of FCC applications. For the particular fuel used in pre-FEED performance calculations, particulate loading at the inlet of the TSS would be around 750 to 800 ppm (by weight). Consequently, in order to satisfy the expander requirements, the TSS should be capable of 90 percent reduction.

UOP Honeywell confirmed that the service is similar to the typical FCC application for protecting a hot gas expander. They also confirmed that the temperature and pressure is within our experience range. UOP Honeywell is confident that, even without doing any calculations, they typically can meet the expander PM requirements of 100 ppm and the removal of large particles (<10 micron). However, they also stated that they would need more detailed particle size distribution (PSD) and particle density in order to perform requisite calculations. UOP Honeywell also recommended a more detailed feasibility study to further optimize the TSS design, the turndown strategy, and to further refine the cost estimates. Depending on the scope and what other information is required, a high-level estimate for this study is estimated to be approximately \$150,000.

In conclusion, equipment necessary for removal of PM from the DICE exhaust stream does not present itself as a technology gap as such. While the application of the existing equipment in DICE CRCC would be a first, it is clear that what is needed is requisite FEED to pinpoint the final design for the selected feedstock. This may require some testing as is the case with the design of the coal beneficiation system. Remaining fines (100 pm and P90 5 micron or less) will be washed away in the direct contact cooler upstream of the carbon capture block.

Section 6 References

1. Nicol, K., 2014, The Direct Injection Carbon Engine. London, UK: IEA Clean Coal Centre. Retrieved from www.iea-coal.org
2. Hägglund, T., *Comparative advantages of Orimulsion®, LNG and Petcoke*, Private Power in Central America, Miami, June 13-14, 2002
3. Rao, A.K., *Coal-diesel technology looks good for Clean Coal 5*, 1994.
4. Wibberley, L.J., *DICE – the best option for coal?*, www.dice-net.org, 18 May 2014.
5. DOE/NETL-2007/1287, *Clean Coal Diesel Demonstration Project – A DOE Assessment*, July 2007, U.S. Department of Energy, Office of Fossil Energy, National Energy Technology Laboratory.
6. TIAX, *Clean Coal Diesel Demonstration Project – Final Report*, March 2007, Principal Author Dr. R.P. Wilson, TIAX LLC, Cambridge, MA, TIAX Ref. D0195.
7. Wibberley, L.J., 2013, *Development of the Direct Injection Carbon Engine (DICE)*, Presented at the 38th Clearwater Clean Coal Conference, 2-6 June 2013.
8. Kong, L., 1993, *Petrography and inorganic geochemistry of the Rosebud coal seam at the Absaloka, Big Sky and Rosebud mines, Powder River Basin, Montana*, MS Thesis (164), University of North Dakota.

Turbocompounding has a long history going back to 1930s and 1940s for locomotive and aircraft propulsion. MAN Diesel & Turbo installed several turbocompound electric power generation systems about 20 years ago. MAN Diesel & Turbo also developed a turbocompound system for ship propulsion(e.g., see Figure A-1 for the system flow diagram). As shown in the diagram, the hot gas expander (the power turbine) is driven by part of the exhaust gas flow which bypasses the turbochargers. The power turbine produces extra output power for electric power production, which depends on the bypassed exhaust gas flow amount.

Figure A-1
Schematic Diagram of MAN D&T Turbocompound Ship Propulsion System




Table B-1 contains the detailed descriptions of the USDOE’s TRLs.

**Table B-1
Detailed Descriptions of USDOE’s TRLs**

Relative Level of Technology Development	Technology Readiness Level	TRL Definition	Description
System Operations	TRL 9	Actual system operated over the full range of expected mission conditions.	The technology is in its final form and operated under the full range of operating mission conditions. Examples include using the actual system with the full range of wastes in hot operations.
System Commissioning	TRL 8	Actual system completed and qualified through test and demonstration.	The technology has been proven to work in its final form and under expected conditions. In almost all cases, this TRL represents the end of true system development. Examples include developmental testing and evaluation of the system with actual waste in hot commissioning. Supporting information includes operational procedures that are virtually complete. An Operational Readiness Review (ORR) has been successfully completed prior to the start of hot testing.
	TRL 7	Full-scale, similar (prototypical) system demonstrated in relevant environment	This represents a major step up from TRL 6, requiring demonstration of an actual system prototype in a relevant environment. Examples include testing full-scale prototype in the field with a range of simulants in cold commissioning (1). Supporting information includes results from the full-scale testing and analysis of the differences between the test environment, and analysis of what the experimental results mean for the eventual operating system/environment. Final design is virtually complete.

Technology Demonstration	TRL 6	Engineering/pilot-scale, similar (prototypical) system validation in relevant environment	Engineering-scale models or prototypes are tested in a relevant environment. This represents a major step up in a technology's demonstrated readiness. Examples include testing an engineering scale prototypical system with a range of simulants (1). Supporting information includes results from the engineering scale testing and analysis of the differences between the engineering scale, prototypical system/environment, and analysis of what the experimental results mean for the eventual operating system/environment. TRL 6 begins true engineering development of the technology as an operational system. The major difference between TRL 5 and 6 is the step up from laboratory scale to engineering scale and the determination of scaling factors that will enable design of the operating system. The prototype should be capable of performing all the functions that will be required of the operational system. The operating environment for the testing should closely represent the actual operating environment.
Technology Development	TRL 5	Laboratory scale, similar system validation in relevant environment	The basic technological components are integrated so that the system configuration is similar to (matches) the final application in almost all respects. Examples include testing a high-fidelity, laboratory scale system in a simulated environment with a range of simulants (1) and actual waste (2). Supporting information includes results from the laboratory scale testing, analysis of the differences between the laboratory and eventual operating system/environment, and analysis of what the experimental results mean for the eventual operating system/environment. The major difference between TRL 4 and 5 is the increase in the fidelity of the system and environment to the actual application. The system tested is almost prototypical.
Technology Development	TRL 4	Component and/or system validation in laboratory environment	The basic technological components are integrated to establish that the pieces will work together. This is relatively "low fidelity" compared with the eventual system. Examples include integration of ad hoc hardware in a laboratory and testing with a range of simulants and small scale tests on actual waste (2). Supporting information includes the results of the integrated experiments and estimates of how the experimental components and experimental test results differ from the expected system performance goals. TRL 4-6 represent the bridge from scientific research to engineering. TRL 4 is the first step in determining whether the individual components will work together as a system. The laboratory system will probably be a mix of on hand equipment and a few special purpose components that may require special handling, calibration, or alignment to get them to function.

Relative Level of Technology Development	Technology Readiness Level	TRL Definition	Description
Research to Prove Feasibility	TRL 3	Analytical and experimental critical function and/or characteristic proof of concept	Active research and development (R&D) is initiated. This includes analytical studies and laboratory-scale studies to physically validate the analytical predictions of separate elements of the technology. Examples include components that are not yet integrated or representative tested with simulants (1). Supporting information includes results of laboratory tests performed to measure parameters of interest and comparison to analytical predictions for critical subsystems. At TRL 3 the work has moved beyond the paper phase to experimental work that verifies that the concept works as expected on simulants. Components of the technology are validated, but there is no attempt to integrate the components into a complete system. Modeling and simulation may be used to complement physical experiments.
	TRL 2	Technology concept and/or application formulated	Once basic principles are observed, practical applications can be invented. Applications are speculative, and there may be no proof or detailed analysis to support the assumptions. Examples are still limited to analytic studies. Supporting information includes publications or other references that outline the application being considered and that provide analysis to support the concept. The step up from TRL 1 to TRL 2 moves the ideas from pure to applied research. Most of the work is analytical or paper studies with the emphasis on understanding the science better. Experimental work is designed to corroborate the basic scientific observations made during TRL 1 work.
Basic Technology Research	TRL 1	Basic principles observed and reported	This is the lowest level of technology readiness. Scientific research begins to be translated into applied R&D. Examples might include paper studies of a technology's basic properties or experimental work that consists mainly of observations of the physical world. Supporting Information includes published research or other references that identify the principles that underlie the technology.

¹ Simulants should match relevant chemical and physical properties.

² Testing with as wide a range of actual waste as practicable and consistent with waste availability, safety, ALARA, cost and project risk is highly desirable.

Source: U.S. Department of Energy, "Technology Readiness Assessment Guide". Office of Management. 2011.

100 MWe COAL-FIRED DIRECT INJECTION CARBON ENGINE (DICE)
COMPOUND REHEAT COMBINED CYCLE (CRCC) WITH 90 PERCENT
POST-COMBUSTION CO₂ CAPTURE

VOLUME IV: PERFORMANCE RESULTS REPORT

U. S. Department of Energy (DOE)

Contract No. 89243319CFE000025, Coal-Based Power Plants of the Future

By



Nexant, Inc

and



Bechtel Power and Infrastructure

Table of Contents

Section 1 Technology Overview	135
1.1 Basic Operating Principle	135
1.2 Overview of DICE CRCC System.....	136
1.2.1 Original Gas-Fired Turbocompound Reheat Embodiment.....	136
1.2.2 Current Coal-Fired Embodiment	136
Section 2 Coal Beneficiation	139
2.1 Introduction.....	139
2.2 Process Description.....	141
2.2.1 Feed Coal Receiving and Handling	143
2.2.2 First Stage Size Reduction	143
2.2.3 Secondary Size Reduction	144
2.2.4 Primary Grinding Classification	144
2.2.5 Fine Grinding.....	144
2.2.6 Fine Grinding Classification.....	146
2.2.7 Ash Removal.....	146
2.2.8 Dewatering.....	147
2.2.9 Slurry Preparation	149
2.3 Coal Beneficiation Process Performance.....	150
2.3.1 Beneficiated Product Yield.....	150
2.3.2 Beneficiation Plant Power Consumption	152
Section 3 DICE System Design	153
3.1 Conceptual DICE Plant Background	153
3.1.1 Base Engine Choice	153
3.1.2 Recent Developments on Coal-Slurry Fuels Adaptability.....	154
3.1.3 Manufacturers	155
3.1.4 Bitumen-Water Fuels as Analogs for MRC.....	155
3.1.5 Humidified Diesel Engines	156
3.1.6 Direct Water Injection (DWI).....	156

3.2	Engine modifications needed for MRC	157
3.2.1	Overall Modifications	157
3.2.2	Fuel Supply System	159
3.2.3	Fuel Injection System	160
3.3	DICE Fuel Specifications	162
3.3.1	Coal Loading.....	163
3.3.2	Coal Particle Size.....	163
3.3.3	Coal Volatiles.....	164
3.3.4	Ash content	164
3.3.5	Sulfur.....	167
3.3.6	Alkalis.....	167
3.3.7	Viscosity/Rheology.....	168
3.3.8	Stability.....	170
3.3.9	Control of Microbial Activity.....	171
3.4	DICE Performance.....	172
3.4.1	DICE Performance Modeling.....	172
3.4.2	Performance Validation	173
Section 4 DICE CRCC Other Major Plant Components.....		179
4.1	Main Air Compressor	179
4.2	Hot Gas Expander	180
4.3	Third-Stage Separator	181
4.4	HRSB.....	181
4.5	Back-Pressure Steam Turbine (BPST).....	182
4.6	LP Condensing Turbine and Surface Condenser.....	183
4.7	Direct Contact Caustic Scrubber/Cooler.....	183
4.8	Post-Combustion CO ₂ Capture (PCC) Plant.....	183
4.8.1	CO ₂ Capture Plant.....	183
4.8.2	CO ₂ Compression Plant	184
Section 5 DICE CRCC Plant Performance		185
5.1	Process Flow Diagram.....	185
5.2	Heat and Material Balance.....	186

5.3	DICE CRCC Plant Net Efficiency.....	192
5.4	Overall Utilities Balance.....	194
5.5	DICE CRCC Water Balance.....	194
5.6	Plant Emissions.....	197
5.7	Potential Variants.....	199
5.7.1	No Post-Combustion Capture.....	199
5.7.2	Centralized Coal Beneficiation Plant.....	201
5.8	Energy Storage Capability.....	203
Section 6 Major Equipment List and Preliminary Plot Plan.....		205
6.1	Coal Beneficiation Plant.....	206
6.2	DICE CRCC Mechanical Equipment.....	208
6.3	30 wt% MEA CO ₂ Capture Plant.....	213
6.4	CO ₂ Compression Plant.....	215
6.5	Electrical Equipment List.....	217
6.6	Plant Equipment Development Status.....	220
6.6.1	Coal Beneficiation Plant.....	220
6.6.2	Power Block Equipment.....	220
6.6.3	Capture Block Equipment.....	221
6.7	Preliminary DICE CRCC Plot Plan.....	222
Section 7 DICE CRCC Operability.....		224
7.1	Operation Philosophy.....	224
7.1.1	RICE-Combined Cycle Configuration.....	224
7.1.2	Turbocompounding.....	225
7.2	Simple Cycle RICE/DICE Startup.....	227
7.2.1	DICE Startup.....	227
7.2.2	Pilot Fueling.....	228
7.2.3	DICE Shutdown.....	228
7.3	Combined Cycle RICE/DICE Startup.....	230
Appendix A References.....		237

Figures in Report

Figure 1-1 Comparison of CPC {1-2-3-4-1} and CVC {1-2-3A-4A-1} cycles	135
Figure 1-2 Simplified Schematic Diagram of Original Embodiment of Turbocompound-Reheat GTCC	136
Figure 1-3 Simplified Schematic Diagram of Coal-Fired DICE CRCC with Hot Gas Expander and Duct-Fired HRSG.....	137
Figure 2-1 Product Ash (Dry Basis) of Coal Beneficiation Techniques with Cost.....	139
Figure 2-2 Coal Preparation Plant Simplified Block Flow Diagram.....	141
Figure 2-3 Coal Beneficiation Plant Process Flowsheet.....	142
Figure 2-4 Raw Coal Handling Diagram.....	143
Figure 2-5 Typical Hammer Mill Installation.....	143
Figure 2-6 Typical Ball Mill Installation.....	144
Figure 2-7 Typical VXPmill Installation.....	145
Figure 2-8 Typical Solid Bowl Centrifuge Installation.....	148
Figure 2-9 Typical Thickener Installation.....	149
Figure 3-1 Low Speed Engine with Generator by MAN (55 MW, 120 rpm)	153
Figure 3-2 MAN Gas Engine Generators (20 MW, 500 rpm).....	154
Figure 3-3 Suggested Fuel Supply System.....	160
Figure 3-4 CSIRO Injector Showing Fuel Return Circulating Flow through the Injector	161
Figure 3-5 SEM Images of Cenospheres from DICE using a Hydrothermally Treated Victorian Coal.....	165
Figure 3-6 Hardness of Materials Relative to Coal Ash.....	166
Figure 3-7 Head Valves after 40 hours of Full-Load Operation Using MRC Produced from Yancoal UCC.....	168
Figure 3-8 Fuel Rheology: Left, Coal Water Fuel for a boiler by JGC; right, MRC for DICE	169
Figure 3-9 Nominal MRC Rheology for a Good and Poor Fuel.....	170
Figure 3-10 Microbial Activity on Pine Char Slurry after 205 Days	171
Figure 3-11 Thermoflex “User-Defined” Reciprocating Engine DICE Model.....	173
Figure 4-1 Main Air Compressor (MAC) Plane View (Siemens).....	179
Figure 4-2 Baker Hughes Hot Gas Expander (HGE) Elevation View.....	180
Figure 4-3 Dresser-Rand DR R/RS Type Steam Turbine.....	182
Figure 5-1 100 MWe Nominal DICE CRCC Process Flow Diagram.....	187
Figure 5-2 MEA-Based CO ₂ Capture Plant Process Flow Diagram.....	190
Figure 5-3 CO ₂ Compression Plant Process Flow Diagram.....	191
Figure 5-4 DICE CRCC Part Load Performance.....	193
Figure 5-5 DICE CRCC in CAES Mode.....	203
Figure 6-1 Preliminary Plot Plan for 100 MWe DICE CRCC Plant.....	223
Figure 7-1 Typical RICE (or DICE) Starting Speed and Load Curves	227
Figure 7-2 Typical RICE CC Startup Speed and Load Trends.....	230
Figure 7-3 Schematic of RICE CRCC.....	231
Figure 7-4 Typical Centrifugal Compressor Startup – Speed and Anti-Surge Valve Position .	233
Figure 7-5 Typical Centrifugal Compressor Startup – Pressure and Flow Path.....	233

Figure 7-6 DICE CRCC Hot Start	234
Figure 7-7 DICE CRCC Load Ramps	235

Tables in Report

Table 2-1 Dewatering Technology Comparison.....	148
Table 2-2 Design Basis Coal Analysis.....	150
Table 2-3 Ultimate Analysis Calculations for Feed, Product, and Reject Streams	151
Table 2-4 Energy Estimates of Beneficiated Coal Product and Reject	151
Table 2-5 Study MRC Composition	152
Table 2-6 Coal Beneficiation Auxiliary Load Breakdown.....	152
Table 3-1 Nominal Engine Component Modifications for DICE.....	157
Table 3-2 Stock Engine Heat and Mass Balance	172
Table 5-1 100 MWe Nominal DICE CRCC Stream Table.....	188
Table 5-2 Power Summary and Net Efficiency	192
Table 5-3 100 MWe Nominal DICE CRCC Overall Utilities Balance	195
Table 5-4 100 MWe DICE CRCC Water Balance	196
Table 5-5 Plant Emissions Summary	197
Table 5-6 Performance Comparison for DICE CRCC with and without PCC.....	200
Table 5-7 Performance Comparison for DICE CRCC with On-site and Centralized Coal Beneficiation Plant.....	202
Table 6-1 Coal Beneficiation Plant Equipment List.....	206
Table 6-2 DICE CRCC Mechanical Equipment List.....	208
Table 6-3 30 wt% MEA CO ₂ Capture Plant Equipment List	213
Table 6-4 CO ₂ Compression Plant Equipment List	215
Table 6-5 DICE CRCC Electrical Equipment List.....	217
Table 7-1 Simple and Combined Cycle Performances for Wärtsila’s 18V50SG Engine (12 Engines)	225

Section 1 Technology Overview


1.1 BASIC OPERATING PRINCIPLE

The fundamental thermodynamic basis behind the Direct Injection Carbon Engine (DICE) Gas Turbine Compound Reheat Combined Cycle (GT CRCC) plant concept is described in detail in the papers and articles by Gülen earlier, e.g., Refs.[1,2]. The thermodynamic cycle of the power plant is a seamless integration and mesh of Atkinson (internal combustion engine) and Brayton (gas turbine) cycles, which combines the two most effective heat engine cycle performance enhancers: constant volume heat addition and reheat. As illustrated in the temperature-entropy diagram in Figure 1-1, the resulting new cycle has six processes (instead of the typical four processes in Carnot, Brayton and Atkinson cycles):

1. Isentropic compression (1 to 2)
2. Constant volume heat addition (2 to 3A)
3. First isentropic expansion (3A to 3B)
4. Constant pressure heat addition (3B to 3)
5. Second isentropic expansion (3 to 4)
6. Constant pressure heat rejection (4 to 1)

This new ideal cycle {1-2-3A-3B-3-4-1} is the thermodynamic basis of the turbocompound-reheat gas turbine cycle. By adding a “bottoming cycle” into the lower triangular area {1-4-4C-1}, cycle waste heat, i.e., heat rejection from 4 to 1, can be utilized for additional work. Thus, one arrives at the *turbocompound-reheat gas turbine combined cycle*.

Figure 1-1
Comparison of CPC {1-2-3-4-1} and CVC {1-2-3A-4A-1} cycles




1.2 OVERVIEW OF DICE CRCC SYSTEM

1.2.1 Original Gas-Fired Turbocompound Reheat Embodiment

The original embodiment of the natural gas-fired turbocompound reheat (TC-RHT) gas turbine combined cycle (GTCC) is disclosed in the US Patent 9,249,723 (Gülen, February 2, 2016). It comprises three pieces of major equipment (a simplified system diagram is shown in Figure 1-2):

1. An intercooled, integrally geared centrifugal turbocompressor with an aftercooler
2. Advanced gas engine with the turbocharger removed
3. An industrial (heavy duty) gas turbine with the compressor section removed

Figure 1-2
Simplified Schematic Diagram of Original Embodiment of Turbocompound-Reheat GTCC




1.2.2 Current Coal-Fired Embodiment

For the pre-FEED design of the coal-water slurry-fired DICE-CRCC, a simplified version is considered for the following reasons:

- Minimum amount of equipment modification
- Shortest possible timeframe from concept to front-end engineering design (FEED) to pilot plant

A simplified system diagram is shown in Figure 1-3.

Figure 1-3
Simplified Schematic Diagram of Coal-Fired DICE CRCC with Hot Gas Expander and Duct-Fired HRSG



Compared to the original embodiment as shown in Figure 1-2, this system has the following differences:

- The heat exchanger between the DICE and the hot gas expander is eliminated
- The reheat combustor and gas turbine are replaced with a hot gas expander due to the following constraints:
 - Limited availability of oxygen in DICE exhaust gas (roughly 10 percent by volume)
 - Necessity for supplementary firing in the HRSG to generate sufficient steam to meet the demand of the stripper reboiler in the post-combustion capture (PCC) block, which required supplementary air to make up for oxygen spent in the reheat combustor
 - The cap put on non-coal fuel consumption (maximum 30 percent)
- Duct-firing heat recovery steam generator (HRSG) is utilized to meet steam demand of PCC system
 - In the presence of diesel pilot fuel in DICE (roughly 5 percent of DICE heat consumption), no supplementary air is supplied to the HRSG duct burner. This would otherwise have made satisfaction of less than 30 percent non-coal fuel consumption requirement impossible to meet with the reheat combustor. The resulting system is simpler and cheaper with very low impact on plant efficiency.
- Particulate matter (PM) removal is achieved with the presence of the “third-stage separator” (TSS) downstream of the DICE exhaust
- SO_x scrubbing is achieved in a *direct contact caustic scrubber* with sodium hydroxide Na(OH) injection along with flue gas cooling to meet the CO₂ capture absorber requirements
- 90 percent of the CO₂ in the HRSG exhaust is captured using a standard 30 wt% MEA-based chemical absorption-desorption process

As shown in Figure 1-3, air compressed in the turbocompressor is sent to the DICE engine intake after being cooled in an aftercooler to a suitable temperature (~120 °F). Since the charge air is already compressed at the engine air intake, there is no need for the engine turbocharger.

Multiple DICEs, operating in parallel, burn MRC slurry to generate power. The DICE exhaust gas temperature, expected to be between 575 and 600 °C, is sent to the hot gas expander for power generation.

The bottoming cycle is a Rankine steam cycle comprising an HRSG and a steam turbine generator with the balance of plant (BOP) including a backpressure steam turbine, myriad pipes, valves, pumps and heat exchangers. The HRSG is a waste heat recovery boiler utilizing hot gas turbine exhaust gas to make steam. Duct firing of natural gas in the HRSG is required in order to generate enough steam to meet the demand of the PCC system.

Superheated steam generated in the duct-fired HRSG is first expanded in the backpressure steam turbine for additional power generation. The expanded steam leaves the backpressure turbine at 60 psia and is desuperheated to saturated conditions. This steam is consumed in the PCC stripper reboiler, which uses the latent heat of the steam to generate the vapor needed to strip CO₂ from the MEA solution. The reboiler returns hot condensate to the HRSG, where it is heated to generate steam to complete the cycle.

The flue gas leaving the HRSG contains about 300 ppm of SO_x. If left untreated, this high level of SO_x in the flue gas will cause unacceptable levels of amine degradation in the PCC unit. The flue gas therefore is desulfurized in a direct contact caustic scrubber, a packed bed column that uses caustic to reduce the SO_x content in the flue gas to less than 10 ppm and reduce amine losses in the downstream PCC unit, while also cooling and condensing water from the flue gas.

The desulfurized flue gas is then sent to the PCC plant for CO₂ removal. This is a standard amine-based chemical absorption-desorption process where 90 percent of the CO₂ in the flue gas is absorbed by lean amine in an absorber column. The treated, CO₂-depleted flue gas leaves at the overhead of the absorber column to the stack for release into the atmosphere. The rich amine containing the absorbed CO₂ is sent to the MEA stripper column where it is stripped of CO₂ with heat supplied by LP steam from the backpressure turbine. The regenerated lean amine is then pumped, cooled, and routed to the absorber column for CO₂ absorption again.

Section 2 Coal Beneficiation


2.1 INTRODUCTION

The fundamental technical and operational challenge in modifying a standard reciprocating internal combustion engine (RICE) – designed for liquid fuel (e.g., heavy fuel oil, HFO) – for coal-fired operation is to protect the mechanical moving parts of the engine that are exposed to either the coal-water fuel (which is abrasive) or the solid particulate products of combustion, which contain both ash and traces of unburned coal. The objective is to ensure acceptable engine life as well as reliability, availability, and maintainability (RAM) without excessive operating and maintenance (O&M) costs.

Coal cleaning/washing, commonly referred to as “beneficiation”, can be “physical” (e.g., froth flotation, selective agglomeration and dense medium separation) or “chemical” (i.e., using solvents). The purpose of beneficiation is to reduce the ash content of the coal fuel to a level acceptable to the engine.

Earlier US DOE work (Clean Coal Diesel Demonstration Project) concluded that coal with 1 to 3 percent (by weight on a dry basis) ash was suitable for DICE [3]. Wibberley reports that, after collaborating with MAN in DICE development R&D in Australia (under the auspices of CSIRO), 1 to 2 percent was deemed acceptable as long as one could live with the trade-off between processing cost and engine and maintenance costs [4]. This is dramatically illustrated by the chart in Figure 2-1 (from [5], original work done by Wibberley in 2013).

Figure 2-1
Product Ash (Dry Basis) of Coal Beneficiation Techniques with Cost



Micronized Refined Coal (MRC) in Figure 2-1 refers to finely ground low ash carbons in a slurry, which is similar in consistency to acrylic paint. For effective atomization when injected into the DICE cylinder, MRC should have a maximum size of around 50 microns and a beneficiated coal

solids concentration of at least 55 percent (i.e. 45 percent water). The average (P50) size is less than 20 microns.

There are a variety of MRC production processes, which are described in some detail in other reports [5]. In generic terms, for high rank coals, the process comprises (in the order listed) [6]:

- Washing
- Micronizing (fine grinding/milling)
- Froth floatation (deashing)
- Partial dewatering to 55 wt% coal MRC

(Micronizing before deashing instead of before injection avoids fuel contamination by the grinding media)


In order to fully understand the coal beneficiation process, as well as the associated technology gaps and risks involved in building a commercial-scale coal-water slurry (CWS) processing plant to serve the needs of the DICE CRCC, the project team has contracted a company with past experience in DICE technology, **Sedgman** (www.sedgman.com). Sedgman has been involved with the **DICEnet**¹ (www.dice-net.org) for a number of years and has previously investigated this process for the coal beneficiation facility in Australia.

¹ DICEnet was established in March 2013 to support DICE development internationally, including pilot and demonstration projects with Generation 3 technology, and R&D for Generation 4

2.2 PROCESS DESCRIPTION

Sedgman utilized its experience in coal and mineral processing technology to investigate various options for design of the MRC plant. A simplified process block diagram of the coal preparation plant is shown in Figure 2-2.

Figure 2-2
Coal Preparation Plant Simplified Block Flow Diagram




A more detailed process flowsheet is shown in Figure 2-3. This scheme was selected for the study as it was considered the most robust, given that it allows for full grinding of the plant feed and is suitable for processing a broad range of feed quality. It consists of the following processes:

- Feed coal receiving and handling
- Hammer mill first stage size reduction
- Ball mill second stage size reduction
- Vertimill (tower mill) fine grinding
- Two-stage (rougher/ cleaner) flotation
- High-rate thickeners for both product and tailings
- Solid bowl centrifuge dewatering of product
- Baffled and agitated tanks for product slurry storage

2.2.1 Feed Coal Receiving and Handling

The feed coal receiving and handling arrangement is presented in Figure 2-4. The feed coal is loaded from the feed coal stockpile into the dump hopper by a front-end loader. Material in the hopper is drawn out of the hopper by a belt feeder and transferred to the hammer mill. In the hammer mill, the coal is broken into smaller pieces. The material then moves to a surge bin, which acts as a temporary storage. From the surge bin, a vibrating feeder feeds the coal onto a ball mill feed conveyor. This conveyor carries the coal to the ball mill station, where further grinding occurs.

**Figure 2-4
Raw Coal Handling Diagram**



2.2.2 First Stage Size Reduction

Based on the feed coal size distribution and the possible reduction ratios of conventional size reduction equipment, two stage size reduction was deemed necessary. The recommended equipment for this application is to use a hammer mill as primary size reduction, followed by a ball mill to reduce the top size of the grinding mill feed material to a P80 of 93 μm . Hammer mills are proven technology which can produce the required primary size reduction down to a P80 of 13 mm at the required throughput with suppliers confirming that capability. A typical hammer mill is shown in Figure 2-5. Fines generation which is typically of concern in a coal washing plant are not an issue here and are encouraged to assist the grinding circuit.

**Figure 2-5
Typical Hammer Mill Installation**



2.2.3 Secondary Size Reduction

The hammer mill product top size is suited to a ball mill for secondary size reduction. Ball mills are a common method of impact grinding and have proven capability of producing the required discharge particle size distribution. A typical ball mill is shown in Figure 2-6.

Figure 2-6
Typical Ball Mill Installation



2.2.4 Primary Grinding Classification

The ball mill will be required to operate in closed circuit with classifying cyclones. The cyclones are used for size separation and to ensure no oversize material is fed through to the regrind mill.

Ball mill product is pumped to the ball mill grinding cyclones. The cyclones will separate the coal slurry based on particle size at a cut-point of $93\mu\text{m}$ (P80). Undersize material will continue on to the regrind mill, while oversize material will be directed back to the ball mill feed for further size reduction.

2.2.5 Fine Grinding

The regrind mill will provide the final stage of size reduction, to the desired P100 of $50\mu\text{m}$ for ash flotation. Stirred mills are a method of wet grinding that are proven to be highly efficient when very fine grinds are required. For this application, a VXPmill will be suitable for achieving the desired level of grinding at the specified throughput. This mill is a medium intensity mill running at higher speed than a Vertimill but lower speeds than and IsaMill. A typical VXPmill is shown in Figure 2-7.

Figure 2-7
Typical VXPmill Installation



The selection of the most suitable fine grinding technology will depend on a number of factors/requirements including:

Required product size (P_{80})

For a given feed size, as the required product sizing gets finer, the energy requirements increase, with some technologies being more suited to ultrafine grinding than others. For the 50 μm product size requirement for this project, rod mills will not be suitable as they have difficulty generating product less than 1mm (1000 μm). Further, rod mills require in excess of 30 percent more power than ball mills performing the same duty. Suitable technologies for this product size include tube mills, stirred mills and tower mills.

Feed sizing (F_{80})

Different milling technologies have different maximum feed sizes that they can handle, depending on the required product size. Some tower mills require very fine feed size (1 mm or less) which typically would require multiple additional crushing and grinding stages to prepare the feed, adding to circuit complexity and maintenance requirements and capital cost.

Grinding efficiency

The amount of energy required to reduce particle size increases as the particle size decreases. The energy requirement to attain the desired PSD can vary depending on the method of grinding employed and ultimately the grinding efficiency. Two common methods are impact (e.g. Ball mill, Tube mill, SAG mill) and attrition (tower or stirred mills). Typically, impact mills are less

efficient for very fine grinding as energy is lost through media impact, noise and the energy required to rotate the shell to lift the media compared to slower moving attrition mills.

Other factors that impact on grinding efficiency include: slurry flow rate, slurry density, and slurry rheology all of which can be controlled to a certain extent.

Operating Costs

Energy is by far the most significant operating cost of any mill, however, other items also contribute to the ongoing operating costs, including wear liners and grinding media. Typically, attrition mills will have reduced wear on liners as they do not operate by impact of media on the ore. The mill operating speed will impact the liner and media wear rate as well as its grinding efficiency and is dependent on the technology selected. Additional testing is recommended to show which technology provides the optimal balance for this application.

2.2.6 Fine Grinding Classification

For this application, the VXPmill will operate in an open circuit with classifying cyclones. Classifying cyclones are used for size separation to ensure limited oversize material is fed through to the flotation circuit. While this is not catastrophic, it will likely impact the final ash content.

Ball mill cyclone cluster overflow is pumped to the fine grinding cyclones. These cyclones separate the material based on particle size at a cut-point of 32 μ m (D95). Undersize material continues to the flotation circuit, while oversize material is recycled to the VXPmill for a final stage of grinding.

Whether the fine grinding cyclone must operate in closed or open circuit with the fine grinding mill is dependent on the technology selected and must be considered in any further technology trade-off.

2.2.7 Ash Removal

The most efficient method for ash removal from the feed material will be dependent on the optimal size requirement. For the purposes of this study, it is assumed that the feed material will need to be reduced to a liberation size that would require flotation as the only feasible conventional processing method.

Operation of the flotation cells have a number of variables that can be adjusted to obtain the required product quality. These include; reagent dosage, froth depth and wash water rate.

There are a number of different flotation technologies available which have different energy and reagent input requirements. Regardless of the technology chosen, flotation of such fine coal to such a low concentrate ash will have the following issues which must be addressed/determined:

Froth carrying capacity

Carrying capacity is the rate at which material can be removed from the cell (t/h/m² cell area). Ultrafine coal typically has a very low carrying capacity compared to 'standard' coal flotation (at most half the value). This will invariably lead to a larger number of cells required to process the material.

Froth washing

To achieve the low concentrate ash, froth washing will be required. High ash slimes will invariably be present in the concentrate with such a fine feed after being liberated in the grinding circuit as it is carried with water into the froth. The best method of removing this material is to wash the froth with clean water. This involves running the cell with a relatively deep froth at depth of 1 to 1.5 m (3 to 5 ft).

Multiple stages

Even with froth washing, it will be necessary to have multiple stages of flotation to achieve the desired ultra-low ash content in the product coal. This will be a cleaner stage which would re-float the concentrate from the first stage (roughers) to allow additional ash removal. The requirement for this would depend on the quality of the feed. A low ash fines feed may not require a second cleaning stage.

Note that if a relatively coarse sizing (e.g. 250-500 micron) is possible to achieve the required ash content, then cheaper processing technologies e.g. spirals, reflux classifiers, could be employed. These technologies do not require any additional reagents and typically require less circulating water volumes and pumping requirements, resulting in operating cost savings.

2.2.8 Dewatering

The use of flotation as the main processing technology for this material results in a slurry product of relatively low solids concentration (approximately 12 wt%) whereas the solids concentration in the final coal water slurry product is 55 wt%. Dewatering of the flotation product is therefore required to reach the desired final slurry concentration.

The philosophy to dewater the MRC product to a higher solids concentration than required in the final slurry to allow a controlled addition of water (and dispersant) to be added back in so that the target solids concentration can be obtained.

Fortunately, due to the low ash content of the product (and given the relatively good quality feed to the system, medium level ash of the tailings), dewatering behavior of the material is not expected to be impacted by excessive slimes or clays, which are detrimental to dewatering performance. However, given the ultrafine size of the material in the plant, dewatering is still a relatively high intensity process to achieve the required moisture.

At this size, the most common dewatering methods are plate and frame filters, belt press filters, screen bowl centrifuges and solid bowl centrifuges. Sedgman evaluated each of these ultrafine dewatering systems on a qualitative basis and provided a high-level comparison of these technologies as shown in Table 2-1.

**Table 2-1
Dewatering Technology Comparison**

Technology	Assessment Criteria*							Total
	Product Moisture	Fines Loss	Flocculant Dosage	Continuous Production	Footprint	Maintenance	Circuit Complexity	
Solid bowl Centrifuge	3	3	3	1	1	1	1	13
Screen bowl Centrifuge	2	4	2	1	1	2	2	14
Plate and Frame	1	1	1	4	1	4	4	16
Belt Press Filter	4	2	4	1	4	3	3	21

*1 = best, 4 = worst

From the comparison table, the solid bowl centrifuge technology, as depicted in Figure 2-8, was deemed the most favorable. It should be noted that this evaluation was conducted in the absence of any test data, and that test work on the various dewatering processes, including items such as flocculant dosage and equipment footprint would need be carried out with the slurry product in order to verify this finding and indicate the specific capacity of the equipment.

**Figure 2-8
Typical Solid Bowl Centrifuge Installation**



All these technologies will require some form of pre-thickening of the feed to help improve dewatering efficiency and minimize the size of equipment required. Therefore, a high rate thickener needs to be installed upstream of the selected dewatering equipment. A typical thickener installation is shown in Figure 2-9.

Figure 2-9
Typical Thickener Installation



2.2.9 Slurry Preparation

Product material is discharged from the solid bowl centrifuges to a product transfer conveyor, which in turn deposits the material into the product slurry agitation tank. It is likely that a dispersant will be added to the slurry to keep the solids in suspension for extended periods before usage. Product slurry is then pumped into one of two product storage tanks.

Once the slurry mixture has been created, moving this material to long term storage will require pumping, however, the high solids concentration of this material make the use of conventional centrifugal pumps unlikely to be viable. A progressive cavity or positive displacement pumping technology will likely be required. Viscosity testing of the final slurry material will be required to determine the best pumping technology for this material.

2.3 COAL BENEFICIATION PROCESS PERFORMANCE

2.3.1 Beneficiated Product Yield

The study coal is low-sulfur, subbituminous PRB coal (a low rank coal) with proximate and ultimate analysis as summarized in Table 2-2.

**Table 2-2
Design Basis Coal Analysis**

Rank	Sub-Bituminous	
Seam	Montana Rosebud	
Source	Montana	
Proximate Analysis (weight %) ^A		
	As Received	Dry
Moisture	25.77	0.00
Ash	8.19	11.04
Volatile Matter	30.34	40.87
Fixed Carbon	35.7	48.09
Total	100.00	100.00
Sulfur	0.73	0.98
HHV, kJ/kg (Btu/lb)	19,920 (8,564)	26,787 (11,516)
LHV, kJ/kg (Btu/lb)	19,195 (8,252)	25,810 (11,096)
Ultimate Analysis (weight %)		
	As Received	Dry
Moisture	25.77	0.00
Carbon	50.07	67.45
Hydrogen	3.38	4.56
Nitrogen	0.71	0.96
Chlorine	0.01	0.01
Sulfur	0.73	0.98
Ash	8.19	10.91
Oxygen ^B	11.14	15.01
Total	100.00	100.00

Sedgman made the following assumptions in estimating the composition of the beneficiated coal product and reject tailings based on the process described in Section 0. The estimation effort was based on Sedgman's work done during the DICE net collaboration and from its overall experience in coal and mineral processing technology.

- The coal feed is sub-bituminous Montana Rosebud, as shown in Table 2-2
- The beneficiated coal product is upgraded to 2% ash on a dry basis (db) and its sulfur content is reduced by 20 percent
- For mass balance purposes, the remaining components related to the organic part of the coal including C, H, N, O and Moisture retain the same proportions in both the product and reject material as in the original feed

- Mass balance calculations from an open circuit mill show a 47.5 percent beneficiated product yield on an *as received* (ar) basis, or 45.8 percent yield on a dry basis
- Final MRC slurry composition is 55 percent dry coal solids and 45 percent moisture
- The calculation methodology entails the following steps:
 - Feed ultimate = Feed (ar) from Table 4-1
 - Feed adjusted to dry basis
 - Product ash set to 2 percent (db) and S set to 80 percent of Feed S percent (db)
 - Product adjusted to (ar) basis after feed moisture is adjusted for ash and S changes
 - Reject (ar) calculated for each component according to yield percent (ar)
 - Reject (db) calculated for each component according to yield percent (db)
 - Check calculation for Reject (db) from Reject (ar).

Table 2-3 shows the calculated Ultimate Analyses for the Feed, Product and Reject streams.

Table 2-3
Ultimate Analysis Calculations for Feed, Product, and Reject Streams

Component	Feed ar (%)	Feed Dry (%)	Prod Dry (%)	Prod ar (%)	Reject ar (%)	Reject Dry (%)
C	50.07	67.45	74.53	53.31	47.14	61.48
H	3.38	4.55	5.03	3.60	3.18	4.15
N	0.71	0.96	1.06	0.76	0.67	0.87
S	0.73	0.98	0.79	0.56	0.88	1.15
Cl	0.01	0.01	0.01	0.01	0.01	0.01
Ash	8.19	11.03	2.00	1.43	14.31	18.66
Moisture	25.77	0.00	0.00	28.47	23.32	0.00
Oxygen	11.14	15.01	16.58	11.86	10.49	13.68
Total	100	100	100	100	100	100

Table 2-4 shows the estimates of the beneficiated coal product and tailings reject energies on both a dry and an-as received basis. The combustible recovery rate is about 50.5 percent on an HHV basis. The beneficiated coal product in final slurry form consists of 55 wt% coal solids and 45 wt% moisture. The resulting MRC fuel composition is listed in Table 2-5.

Table 2-4
Energy Estimates of Beneficiated Coal Product and Reject

			Product	Reject
Dry basis	HHV	kJ/kg	29535	24409
		Btu/lb	12715	10509
Ar basis	HHV	kJ/kg	21125	18719
		Btu/lb	9094	8058
	LHV	kJ/kg	19673	17640
		Btu/lb	8470	7594

**Table 2-5
Study MRC Composition**

	Dry (wt%)	Slurry (wt%)
Moisture	0.00	45.00
Carbon	74.53	40.99
Hydrogen	5.03	2.77
Nitrogen	1.06	0.58
Chlorine	0.01	0.01
Sulfur	0.79	0.43
Ash	2.00	1.10
Oxygen	16.58	9.12
Total	100.00	100.00

For the 100 MWe DICE CRCC power plant, 642 MMBtu/hr (HHV) of MRC feed is required. This translates to about 92,000 lb/hr of MRC slurry at 55 wt% solids/45 wt% moisture. On a dry basis, this is about 50,600 lb/hr of beneficiated coal product. At the stated recovery rate of 45.8 percent (dry) or 47.5 percent (as-received), the coal beneficiation plant therefore has to process about 149,000 lb/hr of as-received PRB coal.

2.3.2 Beneficiation Plant Power Consumption

The estimated power demand for the coal beneficiation plant is shown in Table 2-6 and totals about 5.5 MWe. The power to the plant will be supplied by the DICE CRCC plant, thus reducing the net output of the plant.

**Table 2-6
Coal Beneficiation Auxiliary Load Breakdown**

COAL BENEFICIATION PLANT AUXILIARY LOADS	kWe
Hammer Mill	240
Ball Mill	800
Grinding Mill	2,800
Grinding Cyclones Feed Pumps	44
Flotation	288
Dewatering	529
Slurry Transfer and Storage	333
Miscellaneous	438
TOTAL AUX LOAD	5,472

Section 3 DICE System Design

3.1 CONCEPTUAL DICE PLANT BACKGROUND

The following section details the conceptual DICE power plant based on the current understanding of the technology, and how large 4-stroke medium speed diesel engines could be adapted for DICE.

3.1.1 Base Engine Choice

Although a wide range of engines has been used for MRC coal slurry fuels, including up to 1,900 rpm in the earlier US DOE program, it is generally accepted that the lower speed engines are most suitable:

- Low-speed two-stroke marine type engines (10-100 MW at 90-120 rpm), as depicted in Figure 3-1. Note that the latest super long-stroke versions of these engines (~60 rpm) are considered less likely to be economic for land-based generation due to the cost of the alternator, extra weight and foundations required
- Large four-stroke medium-speed engines (20 MW at 400-500 rpm), as depicted in Figure 3-2

Figure 3-1
Low Speed Engine with Generator by MAN (55 MW, 120 rpm)



Figure 3-2
MAN Gas Engine Generators (20 MW, 500 rpm)



Low engine speed is recommended because this increases the time for ignition and combustion which reduces the requirement for fine atomization of the fuel (requiring lower viscosity fuel and higher nozzle velocity). While fine atomization of slurry fuels is technically possible, this comes at the cost of increased atomizer wear.

Low speed engines also have larger cylinder bores which have two important advantages for MRC fuels:

- Allows for longer fuel jets - important for difficult fuels as fuel jets must not impinge on the liner
- Larger cylinder heads/covers provide more space for a dual injection system

An additional benefit of the large, low-speed engines is their longevity and tolerance to lower quality fuels – for conventional diesel engines, this includes the use of residual fuel oils, which contain up to 0.2 wt% of highly abrasive corundum-like catalyst fines. For MRC, this includes increased tolerance to mineral ash content, coarser coal top size and, higher viscosity.

The choice of engine will also be site- and application-dependent. While the low-speed engine has slightly higher efficiency and lower maintenance costs, the cost of these engines is higher at nominally \$1,300 k/MW compared to \$750 k/MW for medium-speed engines. Overall, installed costs will be location, site, and project-specific.

3.1.2 Recent Developments on Coal-Slurry Fuels Adaptability

Despite being an extremely mature technology, reciprocating engines continue to undergo development that improves suitability for DICE. These developments should result in higher thermal efficiency, higher flexibility, and lower capital cost than for conventional coal-based generation plants. Developments include higher firing pressures (up to 300 bar), electronic control, more efficient turbochargers, new materials for highly stressed components (valve seats, cylinder liner coatings, ring coatings, valve seats/sealing for high-speed gas valves). To some extent, this has been driven by the use of alternative fuels such as biofuels (corrosive), LNG, and bitumen water fuels. For example, electronically controlled (eg MAN ME type) engines are

implemented as “intelligent engines” with auto-tune ability for individual cylinders – highly beneficial for maximizing combustion efficiency for MRC.

3.1.3 Manufacturers

A range of manufacturers produce lower speed 4-stroke engines (say 500 rpm), which could include derating of 600 and 720 rpm engines.

For large marine-type 2-stroke engines, there are only 3 suppliers – MAN, WING&D and MHI. All of these 2-stroke engines are produced in SE Asia (China, Korea, and Japan) under license. Although MAN is presently the only supplier offering large 2-stroke engines for land-based power generation, other suppliers have expressed interest in producing large low-speed 2-stroke engines optimized for (constant speed) power generation given sufficient need.

While most manufacturers have had some previous negative experiences with coal fulling of engines, all acknowledge that the previous work was undertaken without a high level of commitment, and none of the programs were completed because the expected scenario of oil shortages did not materialize or funding ceased.

Future developments will benefit from recent experience with Orimulsion and MSAR (multiphase superfine atomized residue), previous experiences from the USDOE program for black coals, and more recently by CSIRO’s R&D for both black and brown coals and chars.

3.1.4 Bitumen-Water Fuels as Analogs for MRC

The use of bitumen water emulsions and slurries in diesel engines provides a good analog for MRC.

Over the last 25 years, there have been several initiatives to produce bitumen water fuels to replace HFO in boilers, and these fuels have also been used in diesel engines. Fuels include Orimulsion produced from natural bitumen and MSAR produced from refinery residue (an extremely heavy tar) - developed as an Orimulsion replacement for diesel engines. While it is a problematic fuel, giving both poor ignition and highly abrasive catalyst fines, it is used as a marine fuel in adapted engines. Also, as the bitumen component of MSAR has a very high viscosity of >106 mPa.s at ambient temperature, it is essentially a slurry of solid bitumen in water and thus is analogous with MRC (especially from bituminous coals).

Wärtsilä has extensive experience with firing Orimulsion into medium-speed 4-stroke engines (including a 40 MW demonstration power plant at Vaasa, and a 150 MW power plant in Guatemala).

Suitable adaptations have been considered by two large engine manufacturers, and examples are shown below, noting that several of these have already been developed for bio-oils. A fuel testing program is underway between CSIRO and Chinese engine manufacturer Zibo Zichai New Energy Co., Ltd to develop fuel specifications and identify a suitable engine for a demonstration plant.

3.1.5 Humidified Diesel Engines

A summary of humidified diesel engines is given, as water in fuel is associated with poor thermal efficiency in steam plants, and is not normally associated with diesel engines.

Combustion of fuel-water emulsions is the oldest and easiest method of reducing NO_x emissions in diesel engines. In this technology, water is added to the fuel and passed through an emulsifier immediately before injection into the combustion chamber as an effective way of reducing the flame temperature - thereby suppressing the formation of NO_x. An efficiency penalty of ~2% (ie an increase of 4% in fuel consumption) is incurred for a water/fuel volume ratio of 0.87 (equivalent to ~50% water in fuel on a mass basis) – which is considerably less than if used in a steam plant.

3.1.6 Direct Water Injection (DWI)

Several direct water injection technologies have also been used: Wärtsilä has used this in medium-speed engines, and involves injecting water into the cylinder just before injection of the fuel. Injection rates of 0.4-0.7 kg water/kg of fuel are typically used. Special injectors, comprising separate water and fuel nozzles, are used. The advantage of this system is that the water penalty is substantially avoided as the water spray cools the compressed air charge, thereby reducing compression work.

Mitsubishi Heavy Industries has developed a more complicated version of water in fuel for NO_x control. This system is called stratified fuel-water injection (SFWI), and it uses a single injector to inject slugs of fuel-water-fuel sequentially into the combustion chamber to maintain more extended control of peak combustion temperatures.

DWI and SFWI systems generally give a 70% reduction in NO_x for a thermal efficiency penalty of 1 1.5% points (around 2-3% on a heat rate basis).

Scavenge air moisturization (SAM) is the most favored system for reducing NO_x for the larger low-speed engines and involves humidifying the scavenge air immediately before entering the cylinder with warm seawater or freshwater injected and evaporated into the hot air from the turbocharger compressor to saturate the air to the cylinder (around 7-9 vol% water). Wärtsilä has a variant of this for large 4-stroke engines, with fogging nozzles introducing freshwater directly into the charge air stream after the turbocharger, resulting in combustion air with a humidity of around 60 g water/kg of air (10 vol %). This technique reduces NO_x levels by over 70%.

MAN has achieved similar NO_x reduction levels by increasing the humidity of the charge air with seawater. Compressed hot air from the turbocharger is passed through a humidification tower (a packed bed) that is fed with hot seawater heated by the engine's cooling system.

Overall developments in humidification have demonstrated that diesel engines can tolerate high levels of water ingestion (including seawater mist) without a significant impact on fuel consumption, thermal efficiency, or engine longevity. MDT claims an efficiency of 59% (LHV, flywheel) for a 12K98 engine with waste heat recovery using SAM (Jensen, 2009). For stationary power generation, this is equivalent to around 56% sent out basis.

3.2 ENGINE MODIFICATIONS NEEDED FOR MRC

3.2.1 Overall Modifications

Table 3-1 provides nominal engine component modifications for both 2- and 4-stroke engines. The most significant modifications are for the fuel supply (i.e. the low-pressure fuel supply from the service tank) and the high-pressure injection system.

**Table 3-1
Nominal Engine Component Modifications for DICE**

Component	4-stroke	2-stroke
Engine foundations	No change	
Engine frame, bed plate, crankcase	No change	
Crank shaft	No change	
Cylinder liners	Hard coating, optional provision of oil scrapper grooves to allow increased bore lubrication and flushing of solids to reduce filtration load on crankcase lubrication	Hard coating, optional provision of oil scrapper grooves to allow increased bore lubrication and flushing of solids above the scavenge ports
Piston	No change in short term, optimization of bowl shape for MRC rather than low NOx as required for fuel oil	
Rings	Hard coating, improved design to improve down scrape of contaminated bore oil	
Exhaust valves	No change	
Stuffing box	-	Seal oil protection to eliminate the ingress of contaminated cylinder oil
Scavenge box drainage	-	No change if scrapper grooves are used in the cylinder walls otherwise improved drainage
Crankcase oil filtration	200 percent increased filtration capacity; dual systems to allow on-line maintenance, separate centrifuge for cylinder scrape.	No change, but with separate centrifuge for reconditioning cylinder scrape
Fuel supply system	<p>A dual system is required: One for MRC and one for a diesel/fuel oil used for starting, idling and optional pilot injection (1 5% of heat rate, as is currently used for some gas engines).</p> <p>The MRC system should provide a small, controlled circulation flow around the fuel rail and injectors to enable rapid flushing of the system and to eliminate clogging of the fuel system when the engine is not in operation. This circulating flow should be down through the injectors suction valve to the seat of the needle/cut off valve and should be controlled either electronically or from the same oil that actuates the fuel pump plunger. The spring-loaded inertial valves often used with HFO are not recommended due to the variable flow properties of MRC (shear thinning) and seat wear.</p> <p>It is recommended that a twin pump low-pressure fuel system is used, with one pump controlling the pressure in the circulating flow, and the other used to control the return flow.</p>	
Injection system	Seal oil protected sliding surfaces, including the pump plunger and	


Component	4-stroke	2-stroke
	<p>needle valve. For typical hydrocarbon seal oils, the seal oil should be maintained at around 120% of the fuel supply pressure at all times (critical during engine off), and to 120% of the high-pressure fuel pressure during injection. This strategy minimizes seal oil consumption and oil contamination of the fuel return flow (which, if excessive, can cause coal particles to agglomerate).</p> <p>A single high-pressure seal oil system can be used if a water-soluble seal fluid is used (eg a polyglycol such as UCON).</p>	
Pilot injection	<p>Pilot injection is essential for engine conditions where ignition is less reliable - starting, idle, and shutdown. The amount will depend on the MRC properties, engine speed, cylinder size, and whether Miller cycle is used (lowers compression temperatures). Pilot injection is recommended for engine speeds above 400 rpm, and at low load.</p> <p>The electronically controlled pilot injection is essential to allow fine-tuning of MRC combustion.</p>	
Exhaust manifold (low speed 2-strokes)	<p>While the fly ash produced from MRC combustion is likely to be very fine <10µm and to remain in suspension, the 20-40x increase in solids passing through the engine will inevitably cause ash deposits that will shed periodically as larger grit. A grit dropout before turbocharger is therefore recommended (as is sometimes used with residual fuels). Large horizontal exhaust gas ducting should be provided with a positive grit removal system (eg bottom auger, chain conveyer, blowers) – especially for the large main exhaust collector across the top of the engine.</p>	
Exhaust turbine	<p>No change for ash with aerodynamic diameter <10µm. Possible use of coated metal for inlet guide vanes.</p>	
Waste heat recovery	<p>Conventional solid fuel boiler rather than finned heat exchangers common for cleaner fuels. A vertical fire tube or horizontal water tube is preferred to reduce ash clogging. Until experience is gained to prove otherwise (given the different fuel chemistry and combustion conditions) access is required for manual soot blowing with compressed air or steam.</p>	
Exhaust gas cleanup	<p>The same as used for large land mounted 2-stroke engines using heavy fuel oils – ESP or fabric filtration, SCR and FGD</p>	
Lubrication	<p>Adjustment of crankcase oil base number to match sulfur content of the MRC and with increased detergency to keep char and ash in suspension. Base number should take into account any sulfur reporting to the ash.</p>	<p>Adjustment of cylinder lubricant base number to match sulfur content of the MRC. Base number should take into account any sulfur reporting to the ash.</p>

3.2.2 Fuel Supply System

There have been several fuel supply systems proposed for DICE, which all involve some method of agitating the fuel in storage, plus a valving system to enable system flushing of the pump and lines to the injectors. A better system includes a screening system before the main fuel supply pump and controllable return flow. This system is shown schematically in Figure 3-3 and operates as follows:

- Fuel is stored in a 12,000 m³ service tank sufficient for ten days supply for a 100 MWe plant. This tank is equipped with either a live bottom or a very slow speed rake-type agitator (say 1 revolution per hour). Note, that, conventional high-speed tank mixers are ineffective, giving localised agitation only due to the shear thinning behavior of MRC, and are energy intensive.
- Fuel passes through a pulse screen filtration device before a positive displacement supply pump. The speed of the supply pump is controlled to maintain the supply rail pressure. A screen aperture of 350µm would be suitable for an engine with injector orifices of 600-800µm. Various screening devices can be used. However, MRC rapidly clogs filters with apertures finer than 10-15x the maximum particle size unless pulsed. The purpose of screening is to allow the bulk of the fuel to pass but trap major oversize particles and contamination such as flakes of rust, paint etc.
- The fuel supply pump is a positive displacement pump (progressive cavity type) which supplies the fuel supply rail. The speed of the supply pump is controlled to maintain the supply rail pressure.
- Electronically controlled unit injectors are preferred for the MRC (eg HEUI or MEUI type) to allow closer control of injection timing. The injectors should preferably incorporate fuel circulation valves, which allow controlled flow of fuel down through the injector's pump and preferably down the body of the injector to the needle/cut off valve seat, and back out to a return rail.
- A positive displacement (progressive cavity type) return pump operating in reverse is advantageous to control the total return flow to the service tank, or in the case of flushing, to a dump tank. The letdown pump need only be ~10% of the capacity of the supply pump – which would enable complete flushing of the system within (say) 30 seconds. The speed of the return pump is controllable to set the return flow. Operating the return pump in reverse reduces shaft seal wear. Controllers should be tuned to allow dead-heading without damaging the pumps.

Figure 3-3
Suggested Fuel Supply System



3.2.3 Fuel Injection System

A range of high-pressure injection systems have been used for MRC, including:


1. Conventional jerk pump (200 bar) - line - media separator (shuttle piston or diaphragm) – nozzle (GE and Cooper Bessemer during the earlier USDOE programs).
2. Hydraulic actuated pump (600 bar) – media separator (diaphragm) – nozzle (CSIRO)
3. Unit injector: Common rail hydraulics (700 bar) – seal oil protected media separator – nozzle (WING&D/Maersk)
4. Unit injector: Hydraulic ram (150-300 bar) – seal oil protected plunger – nozzle (CSIRO/MAN)

Although all options have been made to work with MRC, the unit injector-types 3 & 4 have the advantage of compactness and controllability. Desirable features include:

- 1) Modular body construction (to facilitate maintenance and component development), comprising a:
 - servo oil valve module containing a high-speed solenoid valve
 - hydraulic actuator module
 - pump module,
 - fuel ring module containing a non-return valve for the fuel inlet
 - lower flanged body which contains the usual spring, push rod, nozzle body and cut-off needle valve.

- 2) An automatically (this could also be electronically actuated) operated return valve to provide positive fuel flushing around the injector whilst the engine is standing. This ensures continuous movement of the fuel, which dramatically reduces the chance of clogging, enables rapid fuel switching, or system flushing – either during engine operation or when stopped. Figure 3-4 shows the circulating flow around the injector required to ensure high reliability. This injector shown is an enlarged version of an injector for a 4L single-cylinder laboratory engine at CSIRO.
- 3) All fuel wetted surfaces are provided with seal oil continuously (this can be hydraulic or motor oil) at a slightly higher pressure than the fuel (say 25 bar).
- 4) The fuel pump and needle spindle are provided with high-pressure seal oil during the actual injection event. The seal oil pressure can be provided by an integral intensifier pump within the injector’s hydraulic ring, or from an external supply. In the case of the latter, a two pressure system should be used to reduce seal oil pressure when the engine is standing, to avoid unnecessary seal oil contamination of the return fuel.
- 5) Although MRC has a much higher viscosity than diesel fuel, CSIRO has found that only a slightly larger orifice size is required (say 10% larger diameter) due to the strongly shear-thinning behavior of MRC fuels (if correctly prepared). Shear-thinning results in marked wall slip, which increases the volumetric flow of a nozzle. Experience has shown that a nozzle size of 500-750 μm will provide a balance between atomization and jet penetration for cylinder bores up to (say) 50 cm.

Figure 3-4
CSIRO Injector Showing Fuel Return Circulating Flow through the Injector



3.3 DICE FUEL SPECIFICATIONS

This section discusses the specifications of MRC required for combustion in DICE. An overall summary of fuel specifications is followed by additional discussion for each of the critical properties.

Fuel for DICE has significantly different quality requirements than for conventional coal slurry fuels used in boilers. This difference is because engines have short combustion times (say 30 ms in engines, versus 1-2 s in boilers), which requires more intense atomisation than for a boiler. Also, in engines, unburnt char and ash particles will cause chronic engine wear, piston ring jamming, and even turbocharger erosion. Also, the exhaust system of engines is not designed to pass significant ash – which for DICE could be 30x that of even the lowest quality residual fuel oil.

In DICE, it is paramount that the fuel 1) gives a high degree of atomization during injection (which ensures rapid ignition, combustion, and complete burnout), 2) forms minimal abrasive ash particles, 3) has the highest coal solids loading. These requirements will be strongly interdependent, and also be strongly influenced by the size of the cylinders, engine speed, and the extent of engine armoring. Overall properties include:

- Low abrasive mineral content – to minimize injector nozzle and cylinder/ring wear especially
- Coal particle size distribution with a d50 of <15µm and a d90 <60µm to ensure burnout
- High coal content to minimize latent heat losses in the engine – subject to meeting the viscosity specifications
- High stability of formulated fuel to prevent settling in the fuel handling equipment, as well as ease of transportation and storage
- Strongly shear thinning behavior to allow injection and effective atomization – essential for controlled heat release and to minimize unburnt char
- Resistance to microbial action – some slurry fuels degrade rapidly, which can affect both stability and shear thinning behavior – in addition to increasing occupational, health, and safety (OH&S) concerns

Nominal target specifications, based on both literature and recent engine experiences are as follows (formulated MRC slurry basis):

- Ash content < 2% (dry basis)
- Residual mineral size <15µm and preferably <5µm
- Coal particle distribution giving a d50 of < 15µm and d98 < 50µm
- Coal content of the fuel should be as high as attainable, while still meeting the following nominal rheology targets:
 - >10,000 mPa-s @ 0.1/s
 - <400 mPa-s @ 100/s
 - <100 mPa-s @ 10,000/s and be shear thinning at higher shear rates
- Heating value > 18 MJ/liter
- pH of 3.5-8.5

- Stable – say exhibiting no settling (coherent cake on the bottom surface) over 90 days when stored in a sealed 500 mL measuring cylinder at (constant) ambient temperature. After 90 days, all MRC should drain from the upturned measuring cylinder

Experience has shown that, while individual properties can be readily met, achieving a balance between all properties is more difficult. For example, a high SE fuel can be produced by increasing the solids content, which will have the advantage of also increasing fuel stability. However, this will also increase the viscosity and may cause shear thickening behavior, which will make the fuel very difficult (even impossible) to inject, resulting in poor atomization. The resulting large fuel droplets (containing many smaller coal particles) will likely dry to form a single large coal agglomerate, resulting in slower ignition and incomplete combustion. This will invariably lead to chronic ring jamming by char. The resulting flash from poor atomization is also likely to be larger due to the interaction and fusing of fine mineral grains and organically bound ash forming components within the coal. These interactions are discussed in more detail below.

3.3.1 Coal Loading

Coal loading has two main effects, 1) strongly affects fuel viscosity – especially at higher coal loadings (say >55 wt%), and 2) water reduces the calorific value of the fuel and increases the latent heat penalty.

It is important to note that while the effect of coal loading on calorific value is linear, the effect on viscosity is exponential at higher coal loadings (say 57wt% for bituminous coals, and above 53% for sub-bituminous coals – depending on the shape of the size distribution). This rapid increase in viscosity means that the maximum coal loading is usually dictated by the highest viscosity - which ensures satisfactory atomization..

3.3.2 Coal Particle Size

As a guide, at 500 rpm, around 30 ms is available for combustion, and practical experience suggests that a coal top size of 50-60 μ m will give satisfactory combustion with minimal unburnt char in the exhaust – providing atomization is sufficient. Sub-bituminous coals (higher oxygen content, more reactive chars) and lower speed engines are likely to allow a coarser tail in the size distribution.

However, there are several other factors that need to be considered, as the particle size distribution of the coal in the MRC strongly affects the fuel’s rheology for a given coal loading, and therefore its atomization, ignition, and combustion. The particle size distribution also affects the degree of mineral liberation during fuel preparation and the size distribution of liberated minerals in the final fuel. In general:

- A wide size distribution allows a higher particle packing efficiency, and therefore coal loading (this can be calculated), which improves thermal efficiency and fuel stability, and reduces fuel transport costs.
- An optimum coal loading and wide particle size distribution should give a high low shear viscosity (essential for fuel stability in storage) and shear thinning behavior, which enables injection and atomization. Coal loadings above the optimum rapidly cause shear-thickening fuel, which causes fuel system clogging and poor atomization.
- Both the quality of atomization and the coal top size affect the effective size of the coal at the time of ignition - which in turn determines the time for combustion. Finer grinds may not be better: For example, overly fine grinds can increase fuel viscosity and result in poor

atomization. Subsequent agglomeration of the coal during heating, and before combustion, results in a coarser effective coal particle size distribution than that of dispersed particles.

In general, the slower the engine, the larger the allowable top size; however, this also depends on the devolatilization behavior of the coal under the extremely rapid heating and intense combustion intensity in an engine. Combustion intensity can exceed 5 GW/m³ – around two orders greater than for pf combustion – some coals are likely to exhibit a large enhancement in volatiles yield, which gives faster ignition and combustion. Overall, combustion data for coal in engines is lacking, and existing data for pulverized coal firing is likely to be misleading for DICE.

3.3.3 Coal Volatiles

Although there is no literature information on the effect of coal volatile content, with previous engine experience using only medium to high volatile coals (28-40%), higher volatile coals are expected to give improved ignition and combustion. However, the standard method of determination of coal volatiles (the Proximate analysis) will underestimate the effective volatiles content under the extremely rapid heating rates of atomized MRC and the high pressures in diesel engines (which can exceed 150 bar at the start of injection). The morphology of the resulting char is also likely to be very different than that for conventional pulverized coal combustion in boilers, and more akin to that in slurry fed gasification.

The effects of volatiles on ignition and combustion are also affected by the oxygen content of the coal. For example, CSIRO has found that low volatile chars (carbonized at 850°C and containing around 5% volatiles) require 40°C higher charge temperature to achieve the same ignition performance as a 30% VM bituminous coal, and hydrothermally treated Victorian brown coal (45% VM and with 25-27% O) giving an ignition temperature 60°C lower. Note that with these low rank coals, a significant proportion of the volatiles content is CO₂ and H₂O).

3.3.4 Ash content


Ash is the residue after complete combustion, and comprises altered mineral particles from the extraneous ash components, plus finer particles from condensed, oxidized and sulfated compounds formed from the fine, organically bound and mineral particles contained within the coal particles. As the latter interact during burnout of the char, these particles are usually a complex mixture of aluminosilicates and sulfates depending on the coal.

After combustion in a diesel engine, all mineral particles below 10µm size are spheroidized, including quartz. However, even highly fused ash particles have the potential to cause cylinder wear unless the diameter is less than the minimum oil film thickness (1-2µm). Larger sand particles will be most problematic.

For low rank coals and wood chars, the ash also comprises ultra-fine micron size particles formed from the volatilized ash components. Cenospheres have also been observed (see Figure 3-5). Neither the submicron fume nor the cenospheres are likely to cause abrasive wear.

The wear implications of ash require that a detailed investigation of the occurrence of the ash forming constituents of the target coal is undertaken to understand the ramifications for engine wear. This also requires collecting fly ash from either an engine or an appropriate high-pressure spray combustion chamber.

Figure 3-5
SEM Images of Cenospheres from DICE using a Hydrothermally Treated Victorian Coal




The present understanding of ash-engine interactions is that:

- Coarse (say, $>5\mu\text{m}$) and hard minerals (quartz, pyrites, rutile) in the fuel will increase abrasive wear of the atomizer nozzles, rings, cylinder wear, exhaust valve seat, and the turbocharger turbine inlet vanes and rotor.
- Ash residues can also deposit in the oil film on the cylinder wall and be scrapped by ring action to pack in the piston ring grooves behind the ring – a potentially serious condition leading to catastrophic scuffing.

Although these issues could theoretically be eliminated by using harder material and changing the design of engine componentry, all previous DICE projects have been on the basis that DICE requires cost-effective production of ultra-low ash coals - the cleaner, the better.

However, coal specifications for commercial deployment of large diesel engines remain to be established, and in particular, there is a lack of data linking engine wear to ash content and the morphology of the mineral content. Also, there is no information on the trade-off between processing cost, fuel ash, and engine component and maintenance costs. For example, abrasive wear can only occur if the abrading particle is 30% (approximately) harder than the underlying material. For coal ash, the dominant hard material is usually quartz with a hardness (Vickers) of around 11 kgf/mm^2 , showing that a wide range of commercially available ceramics could be used to prevent abrasive wear (Figure 3-6) – provided that they can be incorporated into an engine.

Figure 3-6
Hardness of Materials Relative to Coal Ash



The earlier USDOE work generally concluded that coal with 2-3% ash would likely be suitable, thereby enabling the use of physically cleaned coals (as distinct from more costly chemical cleaning). In recent studies with MAN and WING&D/Maersk, the target ash was <1.5% with a maximum of 2%, noting that this limit was set by available fuel quality and the use of unarmored engines, rather than based on a sound techno-economic basis. Also, these targets were set with little consideration of the type and morphology of the starting mineral matter – mostly due to limited capacity to produce tonnage fuel required for the large engine tests involved. The morphology is very significant, as recent wear tests (using a modified HFRR test) by CSIRO has shown that oils contaminated with fine ash from lower rank coals decreases wear of hardened steel by up to 30%. For tungsten carbide HFRR components, there was a negligible difference between clean and contaminated oils regardless of the mineral type.

Overall, the lack of data has caused a divergence of philosophies between the engine manufactures and the coal industry, which has hampered DICE development. To generalize, the engine manufactures have required that the fuel should be made to match the (current) engine componentry, whilst the coal suppliers have pressed for armored engine componentry to allow higher ash MRC. This dilemma requires that a full-size DICE facility (including fuel preparation plant) are established to allow longer-duration engine trials with armored engine componentry, and for a range of MRC quality. Quantifying the effect of ash on engine componentry costs, durability, and other R&M issues would result in a scientifically based coal quality value model needed to progress the technology.

3.3.5 Sulfur

Large diesel engines designed to operate with heavy fuel oil can tolerate relatively high sulfur fuels (2 percent) providing cylinder lubrication uses the appropriate lubricant (i.e. base number) to avoid acid attack of the cylinder walls. As MRC will require deep cleaning of coal, sulfur levels of PRB coals will not be a problem – even if S containing dispersants are used for fuel formulation (e.g., NaPSS – sodium polystyrene sulfonate).

3.3.6 Alkalis

While alkalis are a significant issue for coal-fired boilers (nominally, for $\text{Na}_2\text{O}:\text{SiO}_2$ ratios >0.04 , or in the presence of high S and Cl), to date, there is no evidence that alkalis are an issue for DICE. Recent CSIRO experience with a chemically cleaned coal (a caustic ash removal process) with a high Na: SiO_2 ratio showed negligible ash deposits after 40 hours at full load of a 4-liter single-cylinder test engine – see Figure 3-7. Other indirect evidence is from marine engines, which show no cylinder fouling despite ingesting salt spray (from humidification or aftercooler leaks).

It is surmised that the lack of ash fouling is a result of the large pressure swings (> 100 bar) for each engine cycle, which regularly mechanically sheds the porous particulate ash deposits (ie deposit panting).

Figure 3-7
Head Valves after 40 hours of Full-Load Operation Using MRC Produced from Yancoal UCC



3.3.7 Viscosity/Rheology

Fuel rheology has been largely overlooked in previous RD&D programs to use coal for diesel engines, other than to ensure the fuel's viscosity was sufficiently low to enable injection without nozzle clogging. However, in the recent CSIRO studies, fuel rheology was a major focus due to other important interrelated effects - ignition, burnout, and both injector and cylinder wear.


In general, the coal content must be maximized (at least 50%, and preferably >55%) to reduce latent heat penalty - but also while meeting the following rheological targets:

- High viscosity at low shear rates (say 10,000 mPa.s @ 0.1/s) is essential for good stability
- Rheology that is strongly shear thinning
- Viscosity of <400 mPa.s @ 500/s to ensure good injectability and atomization.

These specifications are very different to that of coal water slurries for boilers, which have a higher coal loading and much higher viscosity at higher shear rates (including being shear-thickening rather than thinning). This difference in rheology is clearly apparent when the different fuels are poured from a beaker, as shown in Figure 3-8.


The first two requirements above – stability and shear thinning - are the most important attributes, as fuel stability is essential to producing a fuel with the correct rheological properties for DICE: Stable and shear thinning fuel (providing the calific value is high enough) will always make a good engine fuel – which can be thinned if necessary prior to injection with trim water additions. However, the reverse is not always the case: Highly injectable fuels will not automatically exhibit good stability. Strongly shear thinning fuel (correlates with good stability, handling, injectability, atomization - and ultimately good combustion and reduced wear issues from unburnt char packing behind piston rings.

Figure 3-8
Fuel Rheology: Left, Coal Water Fuel for a boiler by JGC; right, MRC for DICE



Unstable fuel is particularly problematic, regardless of how well it injects, due to the formation of deposits in fuel handling equipment, which, at worst will clog fuel injector nozzles, or at least increase the effective particle size of the fuel entering the combustion chamber leading to poor combustion and char issues. Once MRC forms a hard pack deposit due to poor stability, mechanical means are required for its removal. Figure 3-9 shows nominal rheology plots for good, and poor MRC fuels.

**Figure 3-9
Nominal MRC Rheology for a Good and Poor Fuel**



3.3.8 Stability

Fuel stability, or lack of build-up of sediment in fuel containers with storage, is essential to avoid serious operational issues from blockages, plus secondary effects described in the rheology section above. An unstable fuel is unacceptable for DICE.

Most established stability tests only require stability over relatively short periods (say) 1 week – this is too short. CSIRO work is aimed at 100% stability for >1 month, and preferably >6 months. This testing period is much longer than specified by most stability tests for coal water fuels for boilers. It is noted that some bulk slurries produced to this specification have been completely

stable with negligible sediment for more than 2 years. In general, lower rank coals will provide more stable fuels.

3.3.9 Control of Microbial Activity

Microbial activity in the fuel has the potential to destabilise the slurry, in addition to causing safety concerns. However, CSIRO experience with MRC fuels from 48 coals from Australia, Venezuela, Indonesia, and Germany have shown no evidence of microbial activity – except for a single NSW coal slurry prepared by others. Microbial activity has however, been observed with MRC produced from low-temperature chars – see Figure 3-10.

Figure 3-10
Microbial Activity on Pine Char Slurry after 205 Days



3.4 DICE PERFORMANCE

3.4.1 DICE Performance Modeling

Engine:

- Stock engine is based on Wärtsila 18V46, but with estimation of many key parameters
- Thermal efficiency loss using MRC slurry is estimated approximately 1.8 percentage points
- Output reduction is estimated as 9 percent (based on Orimulsion experience)

Fuel:

- PRB coal, analysis as supplied, normalized to 2 percent ash dry basis, as specified by the coal beneficiation process
- MRC slurry assumes 55 wt% coal.
- Temperature on injection 90 °C.
- Pilot fuel is diesel at 5 percent of the total heat rate


Stock engine heat and mass balance data fired with HFO and MRC slurry is presented in Table 3-2.

**Table 3-2
Stock Engine Heat and Mass Balance**

		Stock Engine (HFO Fuel)	MRC Slurry	MRC Slurry (Fuel preheat)
Heat Consumption	kWth	37,480	36,578	35,491
Fuel Heating	kWth			389
Charge Air Cooler Heat Rejection	kWth	5,082	5,082	5,082
Lube Oil	kWth	2,294	2,294	2,294
Jacket Water	kWth	1,694	1,694	1,694
Surface heat	kWth	519	519	519
Exhaust	kWth	10,289	10,740	10,042
Mechanical Losses	kW		231	231
Shaft Output	kW	17,602	16,018	16,018
		47.0%	43.8%	45.1%
Heat Balance Error	kW	0	0	0
HB Error / Heat Consumption		0.00%	0.00%	0.00%
Generator Output	kWe	17,303	15,746	15,746
Generator Efficiency		98.30%	98.30%	98.30%
Overall Efficiency		46.17%	43.05%	44.37%
Exhaust Flow	kg/h	106,920	106,920	106,920
	kg/s	29.70	29.70	29.70
Exhaust Temp	°C	342.0	369.0	327.2

With the turbocharger removed, engine charge air is supplied at 5 bar and 70 °C by the MAC with the aftercooler. Exhaust gas is at 4 bar and 530°C. Engine heat and mass balance in the Thermoflex model is shown in Figure 3-11.

Figure 3-11
Thermoflex “User-Defined” Reciprocating Engine DICE Model



3.4.2 Performance Validation

The DICE performance model development was described in great detail in Section 2.2.3 of the Conceptual Design Final Report (submitted on August 13, 2019) and will not be repeated herein. In brief, it was an amalgamation of several sources of data and information, including

- OEM’s specs (tested for heat and mass balance consistency)
- Detailed engine simulation by Czero, Inc (including combustion modeling)
- Published DICE performance reports
- Field experience with Orimulsion

At this point, there is no opportunity to validate the predicted performance in the field or in the laboratory. The only available option was to ask a third party to conduct a rigorous engine simulation study and compare the results with what we have. Consequently, CSIRO, who has done extensive studies on DICE, was contracted to undertake this study as part of their contract.

Due to their unique position of being the most experienced organization in DICE (and their extensive past collaboration with MAN in fuel injector development and testing), CSIRO is in the best position to provide valuable feedback on DICE performance predictions.

Nevertheless, it is important to realize that this type of simulation can only provide a guide to engine performance until detailed information is available on the combustion characteristics of the chosen PRB coal, and engine adaptations are proven with full-scale operational experience. For example, the engine maker may require the derating of the peak firing pressure due to ring wear concerns or may reduce the allowable pressure limit to account for the increase in power (and therefore stresses on other parts of the engine) that is possible with MRC firing.

The CSIRO DICE engine modeling/simulation study is described in detail below and in Appendix C of the overall pre-FEED study package.

An engine model was used to predict the thermal efficiency and exhaust gas of a MAN 18V48/60TS engine using MRC from a Powder River Basin coal (2wt% ash, but otherwise using an as-mined coal composition). This data is required for the assessment of heat recovery/integration options by others.

The engine model used is a 1-dimensional thermodynamic model, using thermodynamic data from the NASA thermo-build system, and free energy minimization from the NASA CEA program. In-cylinder processes assume a homogeneous mixture of air and combustion products, ideal gas behavior and that the system is at thermodynamic equilibrium.

3.4.2.1 Cylinder heat loss

The heat transfer co-efficient is calculated using the Woschini equation². With this equation three stages in an engine cycle considered:

- gas exchange period (between exhaust valve open and inlet valve close)
- compression
- combustion and expansion period

$$h_c = \frac{3.26}{1000} D^{-0.2} P^{0.8} T^{-0.53} \omega^{0.8}$$

where:

h_c = heat transfer coefficient (kW/m².K)

D = cylinder bore (m)

P = cylinder pressure (kPa)

² Woschni, G., "A Universally Applicable Equation for the Instantaneous Heat Transfer Coefficient in the Internal Combustion Engine," SAE Transactions, Vol. 76, p. 3065, 1967

T = cylinder temperature (K)

w = average cylinder gas velocity (m/s)

$$w = C_1 S_{\text{MeanPiston}} + C_2 \frac{V_{\text{displacement}} T_0}{p_0 V_0} (p - p_m)$$

where:

C_1 = constant (6.18 for period 1; 2.28 for periods 2 and 3)

$S_{\text{MeanPiston}}$ = mean piston speed (m/s)

C_2 = constant (0 for periods 1 and 2; 3.24×10^{-3} for period 3)

$V_{\text{displacement}}$ = cylinder displaced volume (m^3)

T_0, p_0, V_0 = temperature, pressure and volume

3.4.2.2 Equilibrium Products

Additionally, during combustion, the equilibrium composition is calculated using free energy minimization. A limited number of species are modeled, Ar, CO, CO₂, H, H₂, H₂O, N, N₂, NO, NO₂, N₂O, O, O₂, OH, SO₂. These species are the only ones that will occur at any significant concentrations and were included mostly to account for dissociation at higher temperatures, rather than the amounts of minor species. SO₂ levels in the exhaust gas assumed that there is no partitioning of S to fly ash components. While the latter does occur in boiler off-gases (especially for coals with high alkali/alkaline ash), the extent is unknown for DICE with much shorter residence times below 1000°C.

3.4.2.3 Friction Calculations

The model uses the Chen-Flynn friction model³ which has the form:

$$\text{FM EP} = C_{\text{FM EP}} + (C_{\text{PCP}} * P_{\text{Peak}}) + (C_{\text{MPS}} * S_{\text{MeanPiston}}) + (C_{\text{MPSS}} * V_{\text{MeanPiston}}^2)$$

where:

FM EP = friction mean effective pressure (bar)

$C_{\text{FM EP}}$ = constant for FM EP

C_{PCP} = constant factor for peak cylinder pressure

³ Chen, S.K., and Flynn, P.F., "Development of a Single Cylinder Compression Ignition Research Engine," SAE Paper 650733

P_{Peak}	=	peak Cylinder Pressure (bar)
C_{MPS}	=	constant factor for mean cylinder velocity
$S_{MeanPiston}$	=	mean piston velocity (m/s)
C_{MPSS}	=	constant factor for mean cylinder velocity squared

3.4.2.4 Heat Release Rate

The most important aspect of the combustion phase is the calculation of the rate at which the fuel will combust, generally referred to as the heat release rate (HRR). The model using a three term Weibe heat release model⁴ fitted with actual heat release rate data from a hydrothermally treated Victorian lignite, which imposes a non-predictive burn rate based on crank angle.

Its single term form is

$$C_A = \left(\frac{D_A}{2.302^{-(1+E_A)} - 0.105^{-(1+E_A)}} \right)^{-(1+E_A)}$$

where:

C_A	=	Weibe constant for part of the combustion
D_A	=	duration of that part of the combustion (°)
E_A	=	exponent for that part of the combustion

In the three-term form used in the model, the combustion profile is separated into three section, a premix phase, a main diffusive phase and a tail diffusive phase. With these three phases an overall expression for the fraction of fuel consumed is as follows:

$$F_t = 1 - (F_p + F_d)$$

$$\mathcal{F}_{Fuel}(\theta) = F_p(1 - e^{-C_p(\theta - \mathcal{T}_{SOI} - \mathcal{T}_{IgnD})^{(E_p+1)}}) + F_d(1 - e^{-C_d(\theta - \mathcal{T}_{SOI} - \mathcal{T}_{IgnD})^{(E_d+1)}}) + F_t(1 - e^{-C_t(\theta - \mathcal{T}_{SOI} - \mathcal{T}_{IgnD})^{(E_t+1)}})$$

where:

$$\mathcal{F}_{Fuel}(\theta) = \text{Fraction of fuel burnt at crank angle } \theta$$

⁴ Wiebe I., Halbempirische Formel für die Verbrennungsgeschwindigkeit, in Kraftstoffaufbereitung und Verbrennung bei Dieselmotoren, ed. G Sitkei, pp. 156-159, Springer-Verlag, Berlin, 1964

F_p	=	Fraction of fuel burnt in premix phase
F_d	=	Fraction of fuel burnt in diffusive phase
F_t	=	Fraction of fuel burnt in tail phase

The values of the constants can be varied to match actual heat release data from experimental data. In the model this has been done with the data for coal, while recommended values have been used for diesel.

During the exhaust phase the cylinder contents discharge to an exhaust chamber, which is assumed to remain at a constant pressure.

To calculate the exhaust mass flow, compressible flow through the exhaust valve in both choked and un-choked conditions must be modeled – based on the criteria of Streeter and Wiley.

The effective area for the exhaust port is calculated as the annular area created between the actual exhaust port and the exhaust valve as it is opened multiplied by a discharge coefficient. The lift profile is modeled initially with a sinusoidal function based on a specified lift rate. The area is then unchanging until the valve closes again based on the same lift rate. The shape of the curve can be varied by changing the value of the lift rate as well as the opening and closing positions.

3.4.2.5 Base Engine Parameters

The model was based on engine parameters obtained from MAN Energy Solutions, and missing parameters (some key information are proprietary) estimated from best available literature data – e.g., valve timing. The procedure was to:

- Obtain a reasonable fit with published data using diesel fuel, and using the same parameters repeat for PRB coal assuming 50 and 55wt% coal in the fuel (Cases PRB-1 and PRB-2 respectively).
- Repeat the calculations for two different firing strategies: PRB-3--fixed heat input rate and PRB 4--fixed peak combustion pressure. These cases were included to simulate likely operating extremes using MRC (because the water content and heat release rate are significantly different from diesel fuel oil, resulting in lower combustion pressure).

The ignition delay for fuel oil was 2.5 ms, and for MRC 5 ms was used (experimentally determined for hydrothermally treated Victorian brown coal).

3.4.2.6 Results

The full set of modeling results are presented in CSIRO DICE Study Report in Appendix C. The modeling results for the four combinations described above show that Cases PRB-1 and PRB-2 (with the same heat input as for diesel fuel oil) give the closest match in engine performance, with:

- Thermal efficiency of 45.1-45.8% LHV.
- A 40 bar (15%) reduction in the peak combustion pressure.
- A decrease in power output of 6-8%.

- An increase in coal loading from 50 to 55%, giving an increase in thermal efficiency of 0.7% points, or a decrease in the heat rate of 1.6%.

These findings fully confirmed the findings from the conceptual design study. **Consequently, it was decided to continue the pre-FEED study with the DICE engine performance used in the conceptual design study.**

The modeling results with the same peak pressure as for diesel fuel oil, Cases PRB-3 and PRB-4, gave a radical change in engine output and exhaust conditions. If practical (at this point not deemed to be likely), this method of firing would

- Increase power output by around 68%.
- Increase exhaust temperature significantly and reduce the oxygen content to 6-7 mol% (and thereby increase CO content).
- Reduce engine thermal efficiency by 4.5% points compared to diesel fuel.
- Overall, this option would be best suited for plants additional heat integration – including with waste heat recovery by turbo compounding and/or steam plant, or post-combustion capture of CO₂.


Section 4 DICE CRCC Other Major Plant Components

The remaining major plant system components were previously described in the Phase 1 Conceptual Design Report and reported here for completeness and clarity. These system components are standard off-the-shelf equipment that are commercially available and do not need further development.

4.1 MAIN AIR COMPRESSOR

The main air compressor (MAC) is an integrally-gearred, intercooled centrifugal process compressor, which supplies the charge air to the DICE. For the present plant concept, Siemens Turbocompressor STC-GV (200-3) is considered. The compressor package includes the main driver (electric motor), air inlet filter, auxiliary support systems and the control system. The compressor has three stages with a 78 in. first stage impeller. Power consumption is about 110 hp (about 85 kW) per lb/s of airflow. The unit can be turned down to 50 percent flow with cooled bypass.

Figure 4-1
Main Air Compressor (MAC) Plane View (Siemens)




A: 8,490 mm (overall length), B: 10,400 mm (width), C: 8,500 mm (overall height), D: 6,900 mm (shaft centerline height), E: 9,500 mm (crane hook height)

4.2 HOT GAS EXPANDER

The hot gas expander (HGE) is a product of Baker Hughes (BHGE, formerly Nuovo Pignone of General Electric). BHGE had previously designed and commissioned several units of the same frame size proposed for this application (up to a pressure ratio of 4 and inlet temperature of 1,400 °F). An elevation view of the HGE is shown in Figure 4-2. The machine has four major parts: Intake casing and nose cone, rotor assembly, inner exhaust casing and exhaust casing. The rotor assembly comprises the following parts: shaft, rotor disc (from austenitic nickel-based superalloy), seal ring, tie bolt and rotor blades. At 4 bara and 760 °C inlet conditions, the unit can generate about 140 kW per lb/s of gas flow. At the introductory pre-FEED conditions, i.e., pressure ratio of about 3.6 and inlet temperature of about 980°F, the specific power output is about 95 kW per lb/s.

Hot gas turbo-expanders are widely employed in *Fluid Catalytic Cracking* (FCC) industry for conversion of flue gas pressure into useful shaft power. For reliable operation and long blade life (up to four years before replacement), catalytic fines in the flue gas must be removed prior to entry into the expander⁵. Otherwise, extremely abrasive particles can catastrophically damage the blades and casing walls within a few hundreds of hours of operation.

Figure 4-2
Baker Hughes Hot Gas Expander (HGE) Elevation View



⁵ Catalytic (or catalyst) fines, cat fines in short, are hard aluminum and silicon oxide particles that are normally present in heavy fuel oil. For refineries relying on catalytic cracking, cat fines are added to the crude oil to enhance low temperature fuel cracking.

4.3 THIRD-STAGE SEPARATOR

For the hot gas expander, BHGE requires that the abrasive particle concentration in the flue gas to the expander shall be maintained at less than 100 ppm. Furthermore, abrasive particle size distribution should not exceed 12 microns with D75 of two microns. In FCC applications, cat fines are removed in large-diameter primary/secondary cyclones in the FCC regenerator and in the “third-stage separator” (TSS) prior to entry into the HGE.

In refineries, typically, 2 to 8 primary and 2 to 8 secondary cyclones are utilized in FCC regenerators because of mechanical constraints and pressure drop concerns. These cyclones have a fairly large diameter, which restricts the amount of centrifugal acceleration which can be achieved. These cyclones let particles below 15 to 20 micron range pass through. Thus, a Third-Stage Separator (TSS) is installed upstream of the turbo-expander to reduce the catalyst fine loading and protect the blades. In essence, TSS is a containment vessel with a multitude of small-diameter cyclones inside. They are designed to withstand very abrasive service at a temperature of 1,450 °F. As such, TSS is the ideal choice for particle removal equipment in DICE CRCC.

4.4 HRSG

The HRSG is single-pressure with no-reheat and includes the SCR and CO catalyst sections. It is equipped with a duct burner upstream of the HP superheater section. The scope of supply of the HRSG vendor is complete from the combustion turbine outlet flange through the exhaust stack including all of the required pressure parts necessary to generate the desired HP steam production, LP system for generation of deaerating steam (either to an integral deaerator supplied by the vendor or a remote deaerator supplied by others), interconnecting ASME Section I Code piping local to the boiler, ASME boiler trim including feedwater control valve stations and water and steam flow measurement devices, recirculation system to elevate the temperature of the incoming condensate to 60 °C (140 °F), exhaust stack with CEMS ports, ladders, platforms and stair-tower.

During the study, several design modifications are adopted:

- The LP section is omitted; condensate return from the PCC stripper reboiler at a high pressure (i.e., above 50 psia), operating the deaerator at a high pressure (say, 45 to 50 psia) and venting steam is sufficient to maintain the dissolved O₂ limit (typically, 7 ppb).
- When the PCC block is off-line, steam extracted from the HP section is utilized to heat the condensate coming from the steam turbine condenser for deaeration.


Sulfuric acid dew point is calculated as 291 °F (144 °C). Condensate temperature at the economizer inlet is 283 °F (139 °C) (247 °F [119 °C] when PCC block is offline). In order to ensure minimum tube surface temperature to prevent sulfuric acid condensation on the economizer tubes, the feedwater is recirculated from the economizer discharge to economizer inlet to maintain 150 °C (302 °F) tube temperature.

The HRSG is supplementary (or “duct”) fired with natural gas to produce the requisite amount of steam for the MEA stripper reboiler in the PCC plant.

4.5 BACK-PRESSURE STEAM TURBINE (BPST)

The study concept incorporates PCC with amine-based chemical absorption technology. The main purpose of the bottoming cycle is to supply 60 psia nominally saturated steam to the PCC stripper's kettle reboiler. This precludes the utilization of an efficient bottoming cycle design with a condensing steam turbine. The steam turbine in the plant is a backpressure, non-condensing unit, nominally rated at 20,000 hp, which can be supplied off-the-shelf by a multitude of OEMs, e.g., Siemens' Dresser-Rand (D-R) subsidiary. The specific unit that fits the requirements of the application is D-R R/RS standard multi-stage steam turbine, as shown in Figure 4-3. This machine can handle steam inlet conditions up to 915 psia and 900°F. It is designed in compliance with API 611/612 standards with impulse-type blading. The steam turbine rating can be up to 33,500 hp and turbine speed is 15,000 rpm (or less depending on the rating). In this conceptual design, steam conditions are set to 650 psia and 750°F. The turbine is connected to the generator via a gearbox.

Figure 4-3
Dresser-Rand DR R/RS Type Steam Turbine



4.6 LP CONDENSING TURBINE AND SURFACE CONDENSER

Additionally, the DICE CRCC plant is designed for maximum power generation with the addition of a low-pressure (LP) condensing turbine for use exclusively when the PCC is offline. The turbine generates additional power from the steam that is normally routed to the PCC when it is in operation.

The LP turbine is connected to the generator via a SSS (“triple S”) clutch. The clutch separates the LP turbine from the generator when the PCC is online. When the PCC is offline, steam from the backpressure is routed to the LP turbine, which starts spinning and the SSS clutch automatically engages for additional power generation. The condenser pressure during LP turbine operation is set to 2.5 in Hg. Condenser cooling water system forms a closed loop with the plant cooling tower.

4.7 DIRECT CONTACT CAUSTIC SCRUBBER/COOLER

For the 100 MWe DICE CRCC plant, a direct contact cooler (DCC) with caustic injection is used to cool the flue gas and remove the bulk of the SO_x in the flue gas. This is a packed bed absorber with circulating water to condense out most of the moisture in the flue gas feed. In the DCC, water is directed downward through a packing media to counter the upward flow of the flue gas and to cool it to the required temperature. It also removes acid gases down to around 10 ppm SO₂ equivalent, using caustic injection as determined by pH control.

4.8 POST-COMBUSTION CO₂ CAPTURE (PCC) PLANT

A single-train MEA-based PCC plant treats the flue gas leaving the HRSG to recover 90 percent of the CO₂. The PCC plant consists of two sections: a CO₂ Capture Plant to extract the CO₂ from the flue gas; and a CO₂ Compression Plant to pressurize the CO₂ product for delivery to final sequestration. The CO₂ Capture Plant will be designed with state-of-the-art generic 30 wt% MEA technology. All equipment in the CO₂ Capture Plant is constructed of stainless steel to minimize corrosion effects associated with 30 wt% MEA.

4.8.1 CO₂ Capture Plant

The CO₂ capture plant process scheme consists of flue gas CO₂ absorption and amine solution regeneration.

A flue gas blower located between the scrubber and absorber boosts the pressure of the flue gas in order to overcome the pressure drop associated with the CO₂ absorber. The boosted flue gas with enters the bottom of the absorber column and is scrubbed counter-currently by lean 30 wt% MEA solution to remove 90 percent of its CO₂ content. The CO₂-depleted flue gas continues to travel upwards to the water wash section of the tower, where it is contacted counter-currently with wash water to remove any amine and volatile organic compounds (VOCs) present in the gas, before it is routed to the stack for venting to atmosphere.

The CO₂-rich MEA solvent is collected at the bottom of the absorber and pumped to the stripper column for CO₂ regeneration. Heat is recovered in a rich/lean amine heat exchanger to recover some of the energy in the hot lean amine to minimize steam consumption in the stripper reboiler.

The heated rich solution is then stripped of CO₂ in a reboiled amine stripper to regenerate the lean MEA solution. Overhead vapor from the stripper is cooled with cooling water in an overhead condenser and sent to a reflux drum. The vapor leaving the drum is the recovered CO₂ and needs to be compressed in the CO₂ compression plant before it can be delivered to the battery limit.

The stripper reboiler, a kettle-type heat exchanger, is heated with 60 psia saturated steam leaving the BPST to generate the vapor used to strip the CO₂ from the MEA solution. The steam is condensed in the reboiler and is pumped back to the HRSG to be heated by the hot flue gas again.

4.8.2 CO₂ Compression Plant

The CO₂ from the CO₂ capture plant needs to be delivered to the battery limit at 2215 psia. This is accomplished first by compressing the CO₂ vapor to 1,315 psia in a 3-stage centrifugal CO₂ compressor with inter-stage cooling. Each stage has an average compression ratio of approximately 4. The cooled supercritical CO₂ at 1,315 psia is then pumped to the final delivery pressure of 2,215 psia (152 bara).

In order to meet the 50 ppm water specification for the CO₂ product, the CO₂ is dried in a heatless dehydration unit after the second stage of compression at approximately 365 psia. This unit is a pressure swing absorption system that utilizes molecular sieve adsorbents to remove water. It consists of two tanks storing the adsorbents and alternating with each other in drying the inlet gas. About 7 percent of the inlet gas volume is purged in a stream containing the adsorbed moisture. This purge stream is recycled back to the first stage of CO₂ compression where the moisture is removed in the first stage knockout. The net condensate collected from the CO₂ compression section is sent back to the amine stripper for recovery.

Section 5 DICE CRCC Plant Performance

5.1 PROCESS FLOW DIAGRAM

The overall DICE CRCC power plant PFD is shown in Figure 5-1 and comprises the following:

- Coal beneficiation plant
- 5 DICE (nominally 20 MWe each)
- 1 main air compressor (MAC)
- 1 hot gas expander
- Bottoming cycle consisting of HRSG with natural gas duct firing and back pressure steam turbine
- 30 wt% MEA-based PCC unit capturing 90 percent of CO₂ in the flue gas

The overall cycle is described as follows:


- Charge air for the DICE is supplied by the MAC (an integrally geared and intercooled process compressor)
- Exhaust gas from the DICE generates additional power in a hot gas expander
- Gas turbine exhaust is utilized in a natural gas duct fired HRSG to produce enough steam for CO₂ capture
- Superheated steam produced in the HRSG is expanded in a backpressure steam turbine (BPST) to generate additional power
- BPST exhaust steam is desuperheated and sent to the PCC amine stripper reboiler, where its latent heat of condensation is used to regenerate the lean MEA solution
- The hot condensate leaving the stripper reboiler is routed back to the HRSG to be heated and make steam

Additional process flow diagrams depicting in more detail, the CO₂ capture plant, and CO₂ compression plant, are shown in Figure 5-2 and Figure 5-3 respectively. The coal beneficiation plant simplified block flow diagram and detailed process flowsheet have previously been shown in Figure 2-2 and Figure 2-3 respectively.

5.2 HEAT AND MATERIAL BALANCE

The corresponding heat and material balance details of the major streams shown in Figure 5-1 are presented in Table 5-1.

Figure 5-1
100 MWe Nominal DICE CRCC Process Flow Diagram




**Table 5-1
100 MWe Nominal DICE CRCC Stream Table**

V-L Mole Fraction	1	2	3	4	5	6	7	8	9	10
N2	0.0000	0.0000	0.0000	0.7729	0.7729	0.7116	0.0000	0.7116	0.7116	0.0000
O2	0.0000	0.0000	0.0000	0.2074	0.2074	0.1006	0.0000	0.1006	0.1006	0.0000
H2O	0.0000	0.0000	0.0000	0.0101	0.0101	0.0990	0.0000	0.0990	0.0990	0.0000
CO2	0.0000	0.0000	0.0000	0.0003	0.0003	0.0799	0.0000	0.0799	0.0799	0.0000
Ar	0.0000	0.0000	0.0000	0.0093	0.0093	0.0086	0.0000	0.0086	0.0086	0.0000
SO2	0.0000	0.0000	0.0000	0.0000	0.0000	0.0003	0.0000	0.0003	0.0003	0.0000
SO3 (ppmvd)	0.0000	0.0000	0.0000	0.0000	0.0000	17	0.0000	17	17	0.0000
Total	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	0.0000	1.0000	1.0000	0.0000
Natural Gas Flowrate, klb/hr	0	0	0	0	0	0	0	0	0	10.6
V-L Flowrate, klb/hr	0	0	0	1085.9	1085.9	1178.6	0	1178.6	1178.6	10.6
V-L Flowrate, lbmol/hr	0	0	0	37631	37631	40936	0	40936	40897	614
Coal Flowrate, klb/hr	148.8	0	0	0	0	0	0	0	0	0
Diesel Flowrate, klb/hr	0	0	1.7	0	0	0	0	0	0	0
Slurry Flowrate, klb/hr	0	91.9	0	0	0	0	0	0	0	0
Ash, klb/hr	0	0	0	0	0	1.1	1.1	0	0	0
Pressure, psia	--	--	--	14.7	72.5	56.3	--	56.3	15.3	430
Temperature, °F	--	--	--	59.0	158.0	985.8	--	985.8	642.2	80

**Table 5-1 (continued)
100 MWe Nominal DICE CRCC Stream Table**

V-L Mole Fraction	11	12	13	14	15	16	17	18	19	20
N2	0.7011	0.7633	0.8382	0.0002	0.0003	0.0000	0.0000	0.0000	0.0000	0.0000
O2	0.0689	0.0751	0.0824	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H2O	0.1271	0.0500	0.0581	0.0326	0.0000	1.0000	1.0000	1.0000	1.0000	1.0000
CO2	0.0941	0.1024	0.0112	0.9670	0.9997	0.0000	0.0000	0.0000	0.0000	0.0000
Ar	0.0084	0.0092	0.0101	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
SO2	0.0003	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
SO3 (ppmvd)	46	0	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Total	1.0000									
Natural Gas Flowrate, klb/hr	0	0	0	0	0	0	0	0	0	0
V-L Flowrate, klb/hr	1189.2	1127.6	974.7	156.9	154.8	263.5	0	263.4	263.6	263.6
V-L Flowrate, lbmol/hr	41529	38143	34735	3636	3518	14625	0	14620	14632	14632
Coal Flowrate, klb/hr	0	0	0	0	0	0	0	0	0	0
Diesel Flowrate, klb/hr	0	0	0	0	0	0	0	0	0	0
Slurry Flowrate, klb/hr	0	0	0	0	0	0	0	0	0	0
Ash, klb/hr	0	0	0	0	0	0	0	0	0	0
Pressure, psia	14.85	14.70	16.1	21.4	2215	671.4	--	63.0	60.0	54.1
Temperature, °F	345.4	91.6	108.6	90.0	90.0	753.5	--	296.6	293.7	286.1

Figure 5-2
MEA-Based CO₂ Capture Plant Process Flow Diagram



Stream Number	Stream Description	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35
MAJOR COMPONENTS																									
	CO ₂	29.11	29.11	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	CO	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	Argon	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	O ₂	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	MEA Vapor	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	H ₂ O Vapor	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	Total H ₂ O Vapor	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
LIQUID COMPONENTS																									
	N ₂	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	CO ₂	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	Argon	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	O ₂	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	Water	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	Total H ₂ O Liquid	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	Total Steam (lb/hr)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	Total Steam (lb/yr)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	Total Steam (lb/ton of CO ₂ Captured)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	Total Steam (lb/ton of F ₂ Produced)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Rev	Job No.	Rev
0	892098	DICE CRCC Conceptual Design
1	217020	DICE CRCC Pre-Feed Design
2	100000	DICE CRCC Pre-Feed Design
3	100000	DICE CRCC Pre-Feed Design
4	100000	DICE CRCC Pre-Feed Design
5	100000	DICE CRCC Pre-Feed Design
6	100000	DICE CRCC Pre-Feed Design
7	100000	DICE CRCC Pre-Feed Design
8	100000	DICE CRCC Pre-Feed Design
9	100000	DICE CRCC Pre-Feed Design
10	100000	DICE CRCC Pre-Feed Design
11	100000	DICE CRCC Pre-Feed Design
12	100000	DICE CRCC Pre-Feed Design
13	100000	DICE CRCC Pre-Feed Design
14	100000	DICE CRCC Pre-Feed Design
15	100000	DICE CRCC Pre-Feed Design
16	100000	DICE CRCC Pre-Feed Design
17	100000	DICE CRCC Pre-Feed Design
18	100000	DICE CRCC Pre-Feed Design
19	100000	DICE CRCC Pre-Feed Design
20	100000	DICE CRCC Pre-Feed Design
21	100000	DICE CRCC Pre-Feed Design
22	100000	DICE CRCC Pre-Feed Design
23	100000	DICE CRCC Pre-Feed Design
24	100000	DICE CRCC Pre-Feed Design
25	100000	DICE CRCC Pre-Feed Design
26	100000	DICE CRCC Pre-Feed Design
27	100000	DICE CRCC Pre-Feed Design
28	100000	DICE CRCC Pre-Feed Design
29	100000	DICE CRCC Pre-Feed Design
30	100000	DICE CRCC Pre-Feed Design
31	100000	DICE CRCC Pre-Feed Design
32	100000	DICE CRCC Pre-Feed Design
33	100000	DICE CRCC Pre-Feed Design
34	100000	DICE CRCC Pre-Feed Design
35	100000	DICE CRCC Pre-Feed Design
36	100000	DICE CRCC Pre-Feed Design
37	100000	DICE CRCC Pre-Feed Design
38	100000	DICE CRCC Pre-Feed Design
39	100000	DICE CRCC Pre-Feed Design
40	100000	DICE CRCC Pre-Feed Design
41	100000	DICE CRCC Pre-Feed Design
42	100000	DICE CRCC Pre-Feed Design
43	100000	DICE CRCC Pre-Feed Design
44	100000	DICE CRCC Pre-Feed Design
45	100000	DICE CRCC Pre-Feed Design
46	100000	DICE CRCC Pre-Feed Design
47	100000	DICE CRCC Pre-Feed Design
48	100000	DICE CRCC Pre-Feed Design
49	100000	DICE CRCC Pre-Feed Design
50	100000	DICE CRCC Pre-Feed Design
51	100000	DICE CRCC Pre-Feed Design
52	100000	DICE CRCC Pre-Feed Design
53	100000	DICE CRCC Pre-Feed Design
54	100000	DICE CRCC Pre-Feed Design
55	100000	DICE CRCC Pre-Feed Design
56	100000	DICE CRCC Pre-Feed Design
57	100000	DICE CRCC Pre-Feed Design
58	100000	DICE CRCC Pre-Feed Design
59	100000	DICE CRCC Pre-Feed Design
60	100000	DICE CRCC Pre-Feed Design
61	100000	DICE CRCC Pre-Feed Design
62	100000	DICE CRCC Pre-Feed Design
63	100000	DICE CRCC Pre-Feed Design
64	100000	DICE CRCC Pre-Feed Design
65	100000	DICE CRCC Pre-Feed Design
66	100000	DICE CRCC Pre-Feed Design
67	100000	DICE CRCC Pre-Feed Design
68	100000	DICE CRCC Pre-Feed Design
69	100000	DICE CRCC Pre-Feed Design
70	100000	DICE CRCC Pre-Feed Design
71	100000	DICE CRCC Pre-Feed Design
72	100000	DICE CRCC Pre-Feed Design
73	100000	DICE CRCC Pre-Feed Design
74	100000	DICE CRCC Pre-Feed Design
75	100000	DICE CRCC Pre-Feed Design
76	100000	DICE CRCC Pre-Feed Design
77	100000	DICE CRCC Pre-Feed Design
78	100000	DICE CRCC Pre-Feed Design
79	100000	DICE CRCC Pre-Feed Design
80	100000	DICE CRCC Pre-Feed Design
81	100000	DICE CRCC Pre-Feed Design
82	100000	DICE CRCC Pre-Feed Design
83	100000	DICE CRCC Pre-Feed Design
84	100000	DICE CRCC Pre-Feed Design
85	100000	DICE CRCC Pre-Feed Design
86	100000	DICE CRCC Pre-Feed Design
87	100000	DICE CRCC Pre-Feed Design
88	100000	DICE CRCC Pre-Feed Design
89	100000	DICE CRCC Pre-Feed Design
90	100000	DICE CRCC Pre-Feed Design
91	100000	DICE CRCC Pre-Feed Design
92	100000	DICE CRCC Pre-Feed Design
93	100000	DICE CRCC Pre-Feed Design
94	100000	DICE CRCC Pre-Feed Design
95	100000	DICE CRCC Pre-Feed Design
96	100000	DICE CRCC Pre-Feed Design
97	100000	DICE CRCC Pre-Feed Design
98	100000	DICE CRCC Pre-Feed Design
99	100000	DICE CRCC Pre-Feed Design
100	100000	DICE CRCC Pre-Feed Design

5.3 DICE CRCC PLANT NET EFFICIENCY

Table 5-2 summarizes the overall performance based on the design of the nominal 100 MWe DICE CRCC power plant. Overall fuel mix to the plant consists of 71.5 percent coal, 3.5 percent diesel fuel and 25.0 percent natural gas, on an LHV basis. The net efficiency of the plant is 30.8 percent on an LHV basis (29.1 percent HHV), not including the heating value associated with the rejects as these do not participate in the combustion reactions. With the heating value of the rejects included i.e. efficiency is calculated based on total heating value from the raw PRB coal, the overall efficiency is 18.0 percent LHV (17.2 percent HHV).

**Table 5-2
Power Summary and Net Efficiency**


Power Summary	
POWER GENERATION, kWe	
5 x DICE	78,730
Turboexpander	31,787
Steam Turbine	14,676
Total Power Generation	125,192
AUXILIARY LOAD SUMMARY, kWe	
MRC Fuel Prep	5,472
Main Air Compressor	26,301
SCR	88
Fabric Filter	69
Boiler Feed Water Pump	261
Economizer Recirculation Pump	5
Steam Turbine Auxiliaries	31
DCC Circulating Pump	400
CO ₂ Capture	2,549
CO ₂ Compression	7,838
Circulating Water Pumps	2,407
Makeup Water Pumps	70
Cooling Tower Fans	977
Wastewater Pumps	14
Miscellaneous Auxiliaries	135
Transformer Losses	626
Total Auxiliaries, kWe	47,242
Net Power, kWe	77,950
As-Received PRB Coal Feed, lb/hr	148,818
Beneficiated Coal Slurry Fuel Feed, lb/hr	91,934
Diesel Fuel Feed, lb/hr	1,651
Natural Gas Feed Flow, lb/hr	10,640
Coal LHV Thermal Input, MMBtu/hr	619
Diesel LHV Thermal Input, MMBtu/hr	30
Gas LHV Thermal Input, MMBtu/hr	216
Total LHV Thermal Input, MMBtu/hr	865
LHV Efficiency %, based on beneficiated coal feed	30.8%
%, based on as-received PRB coal feed	18.0%

Coal HHV Thermal Input, MMBtu/hr	643
Diesel HHV Thermal Input, MMBtu/hr	32
Gas HHV Thermal Input, MMBtu/hr	239
Total HHV Thermal Input, MMBtu/hr	914
HHV Efficiency %, based on beneficiated coal feed	29.1%
HHV Efficiency %, based on as-received PRB coal feed	17.2%

Plant part load performance (normalized) is summarized in Figure 5-4. The horizontal axis indicates the part load net output expressed as a fraction of the full load (5 DICE, with PCC) net output, and is based on an operational range of two DICE through the maximum of all five DICE. The right-most point on the graph shows the net efficiency of the plant when the PCC is not in service and steam is routed to a condensing turbine to generate additional power instead of the PCC reboiler.

The coal beneficiation plant is expected to operate in batch mode and will run intermittently at full capacity to fill up the beneficiated coal slurry buffer tank when its levels are low. The auxiliary load consumed by the coal beneficiation plant is hence not included in the part load performance plot.

**Figure 5-4
DICE CRCC Part Load Performance**



5.4 OVERALL UTILITIES BALANCE

The overall utilities balance that summarizes the DICE CRCC plant's various utilities consumption and generation, including power, steam, water, water-cooled and air-cooled duties, are shown in Table 5-3.

5.5 DICE CRCC WATER BALANCE

Water demand represents the total amount of water required for a particular process. Some water is recovered within the process and is re-used as internal recycle. The difference between demand and recycle is raw water withdrawal. Raw water withdrawal is defined as the water removed from the ground or diverted from a POTW for use in the plant and was assumed to be provided 50 percent by a POTW and 50 percent from groundwater. Raw water withdrawal can be represented by the water metered from a raw water source and used in the plant processes for all purposes, such as DCC makeup, BFW makeup, and cooling tower makeup. The difference between water withdrawal and process water discharge is defined as water consumption and can be represented by the portion of the raw water withdrawn that is evaporated, transpired, incorporated into products or otherwise not returned to the water source from which it was withdrawn. Water consumption represents the net impact of the plant process on the water source balance.

Table 5-4 summarizes the water balance for the 100 MWe DICE CRCC power plant.

Raw water demand is minimized by reusing the condensate (125 gpm) from the flue gas DCC column in the PCC plant as cooling tower makeup water. Additionally, cooling tower blowdown water (228 gpm) is used for slurring both the tailings and beneficiated coal to be fed to the DICE, thereby minimizing the raw water needed for the overall operation of the plant.

Table 5-3
100 MWe Nominal DICE CRCC Overall Utilities Balance

Item Name	DICE CRCC Bract Power KW	Steam		DCC Condensate 54 psia/ 286 F	Desupnat Condensate	Domini Makeup	Treated Water	Makeup Water		Internal Recycle	Wastewater		Cooling Water		Air Cooling Mitsubishi Absorbed	Remarks
		671 psia/ 754 F	80 psia/ 286 psia/ 318 F					Ground Water	Municipal Water		Internal Recycle	Sewage Water	Process Wastewater	CW, MMbtuhr C.W. circ. GPM		
DICE-CT CRCC POWER ISLAND																
COAL BENEFICIATION																
COAL HANDLING & CONVEYING																
COAL BENEFICIATION & SLURRYING							0.0			114.3						
COAL BENEFICIATION	5,472															
DICE																
DICE MAIN AIR COMPRESSOR	26,501															
DICE MAIN AIR COMPRESSOR FAN COOLER	(15,746)															
DICE #1	(15,746)															
DICE #2	(15,746)															
DICE #3	(15,746)															
DICE #4	(15,746)															
DICE #5	69															
FABRIC FILTER																
TURBOCOMPRESSOR																
TURBOCOMPRESSOR	(31,787)															
HOT GAS TURBOEXPANDER																
STEAM CYCLE																
SCR	86															
HRSG	263.5				(0.2)	11.8										
HP STEAM TURBINE	(14,679)															
DESUPERHEATER	263				0.2											
BEW PUMPS	261															
ECONOMIZER REGULATION PUMP	9															
STEAM TURBINE AUXILIARY LOAD	31															
CRCC ISLAND																
CO2 CAPTURE																
DCC																
DCC CRCC COOLER	400															
DCC CRCC COOLER PUMP	1,547															
FLUE GAS BLOWER																
MEA STORAGE MAKEUP TANK																
WASH WATER COOLER	89															
WASH WATER PUMP	464															
RICH AMINE PUMP																
MEA STRIPPER REBOLER	65															
CONDENSATE RETURN PUMP																
STRIPPER CONDENSER	8															
STRIPPER OVERHEAD RECEIVER																
STRIPPER PUMP	376															
LEAN AMINE PUMP																
LEAN AMINE COOLER																
CO2 COMPRESSION																
1ST STAGE CO2 COMPRESSOR	2,820															
1ST CO2 COMPRESSOR INTERCOOLER																
1ST STAGE CO2 FEED KD DRUM																
2ND STAGE CO2 COMPRESSOR	2,638															
2ND CO2 COMPRESSOR INTERCOOLER																
3RD CO2 COMPRESSOR	2,090															
3RD CO2 COMPRESSOR INTERCOOLER																
SUPERCritical CO2 PUMP	320															
SUPERCritical CO2 AFTERCOOLER																
ELECTRICAL AND MISCELLANEOUS																
MISCELLANEOUS																
TRANSFORMER LOSSES	626															
MISCELLANEOUS AUXILIARIES	135															
SUBTOTAL DICE CRCC ISLAND	(81,417)	0	0	(14)	0	0	0	0	0	0	0	0	0	0	0	0
COOLING WATER - COOLING TOWER AND WATER TREATMENT																
COOLING TOWER																
COOLING WATER PRODUCTION	2,407						905.1									
CIRCULATING WATER PUMP	977															
COOLING TOWER FANS																
DEMINERALIZER																
DEMIN SYSTEM																
MU WATER SUPPLY & TREATMENT																
MU WATER PUMP	70															
MU WATER FILTER PACKAGE																
POTABLE WATER																
POTABLE WATER TREATMENT																
WASTEWATER TREATMENT	14															
WASTEWATER PUMPS																
SUBTOTAL CW & CT	3,467	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
OVERALL DICE-CT CRCC	(77,950)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0



DICE CRCC PRE-FEED UTILITIES SUMMARY REVISIONS

REV.	610522.005.01	DS-UTIL-001
JOB NUMBER	0	0
REV.	A	

**Table 5-4
100 MWe DICE CRCC Water Balance**

Water Use	Water Demand	Internal Recycle	Raw Water Withdrawal	Process Water Discharge	Raw Water Consumption
	gpm	gpm	gpm	gpm	gpm
MRC Slurrying	228	228	0	--	--
Demin Water Makeup	31	--	31	--	31
Demin System Discharge	--	--	--	7	-7
Steam Cycle Blowdown	--	--	--	5	-5
Deaerator Vent	--	--	--	18	-18
DCC Discharge Water	--	-125	--	--	--
MEA Absorber Discharge	--	-1	--	2	-2
MEA Storage Tank Makeup	1	1	0	--	0
MEA Regenerator Ovhd Makeup	4	4	0	--	--
CO ₂ Compression KO Water	--	-4	--	--	--
Cooling Tower Makeup	1,134	125	1,009	--	1,009
Cooling Tower Blowdown	--	-228	--	55	-55
Makeup Water Treatment Net Demand	178	--	178	--	178
Potable Water Demand	2	--	2	--	2
Makeup Water Treatment Discharge	--	--	--	178	-178
Discharge to Sewage	--	--	--	2	-2
Total	1,579	--	1,220	268	952

5.6 PLANT EMISSIONS

Table 5-5 summarizes the various DICE CRCC plant emissions and control measures undertaken to achieve these emissions. For this report, given the low chloride content (0.01 wt%) in the PRB coal, HCl emissions are estimated to be 0.06 lb/MWh-gross in a worst-case, unabated scenario. However, in the DOE Bituminous Baseline report, SO₂ emissions were utilized as a surrogate for HCl emissions, and HCl was not reported. Similarly, assuming HCl control follows SO₂ emissions control technology per the Bituminous Baseline Report, the HCl emissions for the DICE CRCC plant would be at trace level.

Mercury levels for PRB coal is estimated to be 0.056 ppm on a dry basis. It has been shown in literature than conventional beneficiation methods using cyclones and froth flotation can remove up to 62 percent of the mercury in the coal⁶. Assuming no other mercury control method in the power plant, the mercury emissions as a result of using flotation in the coal beneficiation process is 9 x 10⁶ lb/MWh-gross. However, in the presence of emissions control equipment such as the TSS and SCR, whose vanadium-based catalyst promotes the oxidation of elemental mercury Hg to water-soluble Hg²⁺ in the flue gas, which can then be captured in the DCC, the mercury emissions for the DICE CRCC is expected to meet the emissions limits of 3 x 10⁶ lb/MWh-gross. If mercury emissions are shown to exceed, the limits, the industry-standard activated carbon injection (ACI) can be utilized to further reduce these emissions. The DOE Bituminous Baseline Report states that a combination of ACI with the above-mentioned control technology can reduce mercury emissions by upwards of 97 percent of mercury, which will easily meet the 3 x 10⁶ lb/MWh-gross target.

**Table 5-5
Plant Emissions Summary**

Pollutant	Env. Target	Est. Emissions	Control Technology
	lb/MWh-gross		
SOx	1.00	Trace (0.000)	DCC + MEA reaction with residual SOx in flue gas to effectively reduce to zero
NOx	0.7	0.7 (estimated)	SCR + MEA reaction with NO ₂ to effective scrub out all NO ₂ , reducing NOx content by 10% (assume 90:10 NO/NO ₂ ratio in flue gas) while all NO passes through. While NOx emissions are hard to predict, it has been found that DICE emits half the NOx as engines running on diesel at the same load. Based on CSIRO's experience, DICE exhaust is likely to achieve 350 ppmv NOx or lower, given the longer ignition delay, better mixing of fuel and air, and progressive burn of MRC. At < 350 ppmv NOx in the exhaust, the resulting NOx emissions at the stack will meet the 0.07 lb/MWh-gross emissions limit

⁶ Emissions Control Strategies for Power Plant, Bruce G. Miller, Clean Coal Engineering Technology pp 375-481, 2011

PM	0.09	Trace (0.000)	DCC water wash in PCC plant further scrubs out residual PM in flue gas
Hg	3×10^{-6}	3×10^6 (estimated)	TSS + SCR + DCC. If mercury is still an issue, activated carbon injection (ACI) can be utilized at a location with appropriate temperature before the cyclone.
HCl	0.010	0.000 (SOx surrogate)	Per Bituminous Baseline Report, SO ₂ emissions are used as a surrogate for HCl. Provided the SO ₂ emissions limit is not exceeded, it can be assumed per the MATS regulation that the HCL emissions limit is also satisfied as the caustic scrubber and MEA absorber operations are able to remove the HCl.
CO ₂	90 percent removal	90 percent removal (221 lb/MWh-net)	30 wt% MEA
VOC	N/A	1 ppm	Water wash at the top of the PCC absorber is expected to remove VOC in flue gas before venting to atmosphere

5.7 POTENTIAL VARIANTS

5.7.1 No Post-Combustion Capture

Implementing post-combustion capture (PCC) to the DICE CRCC system imposes a significant penalty on its efficiency, capital cost, and operating cost, thereby resulting in a high LCOE. A parametric scenario without PCC was evaluated to quantify the performance and cost impact. For this case, exhaust steam from the main steam turbine that would have been diverted to the PCC is sent to a condensing turbine to produce more power, resulting in greater power generation from the steam cycle. Additionally, auxiliary power consumed by the PCC is eliminated, resulting in a 35 percent increase in net power generation. The calculated efficiency of this case is 39.9 percent on an LHV basis (37.7 percent HHV).

Table 5-6 presents a side-by-side comparison of the performance breakdown between the DICE CRCC plant with and without PCC.

**Table 5-6
Performance Comparison for DICE CRCC with and without PCC**

Description	DICE CRCC with PCC (On-site coal beneficiation)	DICE CRCC No PCC
POWER GENERATION		
DICE	78,730	78,730
Turboexpander	31,787	31,900
Steam Turbine	14,676	31,299
Total Power Generation, kWe	125,192	141,929
AUXILIARY LOAD SUMMARY, kWe		
Coal Beneficiation	5,472	5,472
Main Air Compressor	26,301	26,277
SCR	88	88
Fabric Filter	69	69
Boiler Feed Water Pump	261	302
Economizer Recirculation Pump	5	310
Steam Turbine Auxiliaries	31	31
DCC Circulating Pump	400	400
CO2 Capture	2,549	0
CO2 Compression	7,838	0
Circulating Water Pumps	2,407	2,117
Makeup Water Pumps	70	60
Cooling Tower Fans	977	859
Wastewater Pumps	15	11
Miscellaneous Auxiliaries	135	135
Transformer Losses	626	710
Total Auxiliaries, kWe	47,243	36,840
Net Power, kWe	77,949	105,089
As-Received PRB Coal Feed, lb/hr	148818	150435
Coal Slurry Fuel Feed, lb/hr	91934	92932
Diesel Fuel Feed, lb/hr	1651	1669
Natural Gas Feed Flow, lb/hr	10640	12000
Coal LHV Thermal Input, MMBtu/hr	619	625
Diesel LHV Thermal Input, MMBtu/hr	30	31
Gas LHV Thermal Input, MMBtu/hr	216	244
Total LHV Thermal Input, MMBtu/hr	865	899
LHV Efficiency, %	30.8%	39.9%
Coal HHV Thermal Input, MMBtu/hr	643	649
Diesel HHV Thermal Input, MMBtu/hr	32	33
Gas HHV Thermal Input, MMBtu/hr	239	270
Total HHV Thermal Input, MMBtu/hr	914	952
HHV Efficiency, %	29.1%	37.7%

5.7.2 Centralized Coal Beneficiation Plant

For a small, modular power plant such as the DICE CRCC (< 100 MW for this introductory variant), the performance and cost estimates presented in previous reports suggest that it makes no economic sense to install a coal beneficiation plant on-site, analogous to building a crude oil refinery on-site at every gas station. For the modular DICE CRCC plant to be feasible, there must be multiples of such power plants, each receiving fuel from a centralized coal beneficiation plant, thereby taking advantage of the economies-of-scale benefits that the large central beneficiation plant possesses. The performance and impact of such a scenario is quantified in Table 5-7.

Table 5-7
Performance Comparison for DICE CRCC with On-site and Centralized Coal Beneficiation Plant

Description	DICE CRCC with PCC (On-site coal beneficiation)	DICE CRCC with PCC (Centralized coal beneficiation)
POWER GENERATION		
DICE	78,730	78,730
Turboexpander	31,787	31,787
Steam Turbine	14,676	14,676
Total Power Generation, kWe	125,192	125,192
AUXILIARY LOAD SUMMARY, kWe		
Coal Beneficiation	5,472	0
Slurry Pumping	incl w/ beneficiation	500
Main Air Compressor	26,301	26,301
SCR	88	88
Fabric Filter	69	69
Boiler Feed Water Pump	261	261
Economizer Recirculation Pump	5	5
Steam Turbine Auxiliaries	31	31
DCC Circulating Pump	400	400
CO2 Capture	2,549	2,549
CO2 Compression	7,838	7,838
Circulating Water Pumps	2,407	2,407
Makeup Water Pumps	70	70
Cooling Tower Fans	977	977
Wastewater Pumps	15	26
Miscellaneous Auxiliaries	135	135
Transformer Losses	626	626
Total Auxiliaries, kWe	47,243	42,282
Net Power, kWe	77,949	82,910
Coal Slurry Fuel Feed, lb/hr	91934	91934
Diesel Fuel Feed, lb/hr	1651	1651
Natural Gas Feed Flow, lb/hr	10640	10640
Coal LHV Thermal Input, MMBtu/hr	619	619
Diesel LHV Thermal Input, MMBtu/hr	30	30
Gas LHV Thermal Input, MMBtu/hr	216	216
Total LHV Thermal Input, MMBtu/hr	865	865
LHV Efficiency, %	30.8%	32.7%
Coal HHV Thermal Input, MMBtu/hr	643	643
Diesel HHV Thermal Input, MMBtu/hr	32	32
Gas HHV Thermal Input, MMBtu/hr	239	239
Total HHV Thermal Input, MMBtu/hr	914	914
HHV Efficiency, %	29.1%	31.0%

5.8 ENERGY STORAGE CAPABILITY


One unique feature of the DICE CRCC concept with separate air compressor and gas turbine/expander trains is its amenability to **compressed air energy storage (CAES)** with *no redesign of plant configuration and/or any major piece of equipment*. The only requirement for DICE CRCC with CAES is the availability of a suitable air storage cavern, e.g., a saline aquifer or depleted natural gas reservoir. DICE CRCC in CAES arrangement is shown in Figure 5-5.

Unlike the existing CAES technology (as demonstrated in Huntsdorf, Germany and McIntosh, Alabama), once constructed and commissioned, DICE CRCC can operate as a straightforward coal-fired power plant or in CAES mode.

In CAES charging mode, the MAC is powered by cheap grid power and supplies air into the storage cavern via a booster compressor (which is the only piece of additional major equipment – the rest is additional piping to/from the cavern and requisite valves), say, at 10 bara.

In CAES generation mode, the MAC is shut down. Charge air to the DICE (at 5 bara) is supplied from the storage cavern through a pressure regulation valve. The rest of the power plant is running in its normal operation mode. In generation mode, even with the PCC on, the plant can deliver 115 MWe at more than 40% net LHV efficiency.

Figure 5-5
DICE CRCC in CAES Mode



It should also be pointed out that the inherent CAES capability of the turbocompound-reheat technology is not limited to DICE (i.e., firing coal fuel). For a standard RICE CRCC with natural gas-fired engines, the same can be accomplished with excellent efficiency (68% net LHV in generation mode) at outputs as low as below 50 MWe (with small, off-the-shelf RICE rated at 5 MWe each). This is described in detail in the Final Report of the DOE/NETL Technical Grant (DE-FE0031618), “Turbocompound Reheat Gas Turbine Combined Cycle”

Section 6 Major Equipment List and Preliminary Plot Plan

Equipment lists for each of the five areas that comprise the overall 100 MWe DICE CRCC plant are provided in this section. These five areas are:

- Coal beneficiation
- DICE CRCC
- CO₂ capture (30 wt%)
- CO₂ compression
- Electrical plant

6.1 COAL BENEFICIATION PLANT

The equipment list for the coal beneficiation plant is provided in Table 6-1.

**Table 6-1
Coal Beneficiation Plant Equipment List**

Site Quantity	System Code	Description	Rating	Comments
COAL BENEFICIATION EQUIPMENT LIST				
RAW COAL HANDLING				
1	FE-201	Feedstock Coal Receival Dump Hopper Feeder	55 kW	
1	CV-101	Hammer Mill Feed Conveyor	11 kW	Design Capacity/Size: 110 t/h
1	CR-301	Hammer Mill	300 kW	Design Capacity/Size: 42" x 60"
1	CV-201	Surge Bin Feed Conveyor	11 kW	Design Capacity/Size: 110 t/h
1	WT-201	Plant Feed Weigher		
1	BN-301	Surge Bin		Design Capacity/Size: 100 t
1	FE-202	Surge Bin Discharge Feeder	7.5 kW	
PROCESS PLANT				
1	CV-301	Ball Mill Feed Conveyor	7.5 kW	Design Capacity/Size: 110 t/h
1	CR-302	Ball Mill	1,300 kW	Design Capacity/Size: 3.7m x 6.75m
1	PP-301	Ball Mill Cyclones Feed Pump	55 kW	
2	CY-301	Ball Mill Cyclones Cluster		
1	PP-401	Grinding Cyclones Feed Pump	55 kW	
2	CY-401	Grinding Cyclones Cluster		
1	PP-403	Grinding Mill Feed Pump	75 kW	
1	GM-401	Grinding Mill	3,500 kW	Design Capacity/Size: 63 t/h
3	PP-501	Rougher Cell Feed Pump	75 kW	
3	FC-501	Rougher Flotation Cell		
3	PP-521	Cleaner Cell Feed Pump	45 kW	
3	FC-521	Cleaner Flotation Cell		
1	TH-601	Product Thickener	7.5 kW	Design Capacity/Size: 20m ø
1	PP-601	Product Thickener Underflow Pump	11 kW	
1	SM-601	Product Solid Bowl Feed Sump		
2	PP-602	Product Solid Bowl Feed Pump	11 kW	
2	CF-601	Product Solid Bowl	300 kW	Design Capacity/Size: 28 t/h
2	CF-601	Main Drive	200 kW	
2	CF-601	Back Drive	100 kW	
1	PP-605	Solid Bowl Effluent Pump	5.5 kW	

1	CV-601	Product Transfer Conveyor	7.5 kW	Design Capacity/Size: 52 t/h
1	WT-601	Product Weigher		
1	SA-601	Product Cross Belt Sampler	5.5 kW	
1	AN-601	Moisture Meter	1.0 kW	
1	TK-610	Product Slurry Agitation Tank		Design Capacity/Size: 35 m ³
2	TK-620	Product Storage Tank		Design Capacity/Size: 1,000 m ³
1	AG-610	Product Slurry Agitator	15 kW	
1	PP-610	Product Slurry Transfer Pump	7.5 kW	
2	AG-620	Product Slurry Agitator	185 kW	
2	PP-620	Product Distribution Pump	5.5 kW	
1	TH-701	Tailings Thickener	7.5 kW	Design Capacity/Size: 20m ø
1	PP-701	Tailings Thickener Underflow Pump	7.5 kW	
1	PP-901	Process Water Pump	175 kW	
1	PP-510	Plant Water Pump	45 kW	
1	FT-950	Gland Water Filter	0.37 kW	
1	PP-950	Gland Water Pump	22 kW	
2	PP-960	Thickener Area Sump Pump	15 kW	
1	CN-501	Overhead Crane	43 kW	Design Capacity/Size: 20 t
COAL PROCESSING PLANT SERVICES				
1	FL-901	Anionic Flocculant Dosing System	5.55 kW	
1	FL-901a	Polymer Bulk Storage Tank		
1	FL-901b	Blower	3.0 kW	
1	FL-901c	Screw Feeder	0.37 kW	
1	FL-901d	Agitator	1.50 kW	
1	FL-901e	Dust Filter Unit	0.37 kW	
1	FL-901f	Mixing Tank		
1	FL-901g	Dilute Flocculant Storage Tank		
1	FL-901h	Heated Hopper	0.06 kW	
1	FL-901i	Hopper Vibrator	0.25 kW	
2	DP-901	Collector Dosing Pump	0.55 kW	
4	DP-910	Frother Dosing Pump	0.37 kW	
2	DP-930	Dispersant Dosing Pump	0.55 kW	
1	AD-950	Instrument Air Dryer	1.53 kW	
1	AR-901	Air Receiver		

6.2 DICE CRCC MECHANICAL EQUIPMENT

The mechanical equipment list for the main DICE CRCC plant is shown in Table 6-2.

**Table 6-2
DICE CRCC Mechanical Equipment List**

Site Quantity	System Code	Description	Type	Material	Rating	Capacity (%)	Comments
DICE MECHANICAL EQUIPMENT LIST							
1	AAA	Heat Recovery Steam Generator (HRSG)	Single-Pressure, No-Reheat, Horizontal Gas Flow. With CO Catalyst			1 X 100% Per Unit	276,800 lbs/hr steam @ 668.7 psia & 753.5F
1	AAA	CO Catalyst	Oxidizing Catalyst for 90% CO Reduction			1 X 100% Per HRSG	Provided by HRSG Supplier
1	AAA	HRSG Duct Burner Skid	263 MMBtu/hr			1 X 100% Per HRSG	Provided by HRSG Supplier
1	AAA	Selective Catalytic Reduction (SCR) System For HRSG Flue Gas NOx Reduction	19 % Aqueous Ammonia System			1 X 100% Per HRSG	Provided by HRSG Supplier
1	AB	Steam Turbine Bypass Valve				1 X 100% Per Unit	1
1 Lot	AB	Main Steam Relief Valve Silencers		CS		1 Lot Per HRSG	1 Lot
1	AC	Steam Turbine Generator	Steam Turbine With Separate HP And LP Casings Connected With SSS Clutch		37 MW	1 X 100% Per Unit	Based on Siemens Bid
1	AC	ST Lube Oil Skid				1 X 100% Per Unit	Supplied by STG Vendor
1	AC	ST Control Oil Skid				1 X 100% Per Unit	Supplied by STG Vendor
1	AD	Steam Surface Condenser	Thermal Duty = 64 MW;			1 X 100% Per Unit	
1	AD	Condensate Deaerator	2800 Gallon Storage Volume	CS		1 X 100% Per Unit	
2	AD	Condensate Extraction Pump	Centrifugal, Vertical, CAN Type, Constant Speed, Motor Driven ; 300 GPM @ 130 ft. TDH		15 HP	2X50% Per Unit	

1	AE	Boiler Feedwater Pump	Horizontal Ring-Section Pump, 3600 RPM 600 GPM @ 3000 ft. TDH		655 HP	1 X 100% Per Unit	
1	AG	Hot Gas Expander (HGE)			32 MW	1 X 100% Per Unit	Based on Dresser-Rand Generator Gear E148 Train
1	AG	HE Lube Oil Skid				1 X 100% Per HGE	Supplied by HGE Vendor
1	AG	HE Cooling & Sealing Steam Skid				1 X 100% Per HGE	Supplied by HGE Vendor
1	AJ	Ammonia Dosing Skid	Diaphragm Metering Pumps And Tank	316 / PTFE		1 X 100% Per HRSG	
1	AJ	Oxygen Dosing Panel For HRSG				1 X 100% Per HRSG	
5	ANB	Direct Injection Carbon Engine (DICE)	Wartsila Model 18V46 Modified For Coal Slurry		15.8 MW	5 X 20% Per Site	Tier 3 Machines W/ Coal Slurry Fuel
5	ANB	DICE Auxiliary Module				1 X 100% Per DICE	Supplied by DICE Vendor
1	ANA	Process Compressor	GV(200-3) Compressor Package; Incl. Motor, Air Inlet Filter, Aux. Support & Control Systems		37,000 HP	1 X 100% Per Unit	Based on Dresser-Rand Quote
1	AR	Vacuum Skid	2 Steam Jet Air Ejectors or 2 Liquid Ring Vacuum Pumps			2 X 100% Per Unit	Capacity based on Holding Duty
5	BA	Third Stage Separator (TSS)				1 X 100% Per DICE	Based on UOP Quote
1	BA	Direct Contact Cooler (DCC)	304L SS Column Internals; Sulzer MellapakPlus Packing			1 X 100% Per Unit	Based on Sulzer Chemtech Quote
1	BM	HRSG Blowdown Tank		CS		1 X 100% Per HRSG	
1	BM	Blowdown Heat Exchanger	Shell & Tube Type	CS/ SS Tubes		1 X 100% Per HRSG	
1	BM	Blowdown Tank Vent Silencer		CS		1 X 100% Per HRSG	
1	BS	19% Aqueous Ammonia Storage Tank		CS		1 X 100% Per Unit	Unloading Via Truck Unloading

							Pump (Self Contained).
2	BS	Ammonia Forwarding Pumps	Positive Displacement	316 SS		2 X 100% Per Unit	
1	FG	Fuel Gas Knockout Drum				1 X 100% Per CT	
1	FG	Fuel Gas Drain Tank				1 X 100% Per CT	
1	HA	Boiler Feedwater Pump Maintenance Hoist	Manual Hoist			1 X 100%	
1	HF	Fly Ash Silo				1 X 100% Per Site	Provided by Fly Ash Vendor
2	HF	Fly Ash Blowers				2 X 50% Per Unit	Provided by Fly Ash Vendor
5	HF	Air Lock Feeders				1 X 100% Per TSS	Provided by Fly Ash Vendor
1	PA	Plant Air Compressor	Oil Free Screw		150 HP	1 X 100% Per Unit	Provides Compressed Air to instrument and Service Air Systems
1	PA	Compressed Air Dryer	Dual Tower Heatless Desiccant Type With Dew Point Of -40 Deg. F Or Lower With Pre-Filter, After-Filter, And Bypass Filter			2 X 100% Per Unit	
1	PA	Compressed Air Receiver		CS	150 PSIG	1 X 100% Per Unit	Provides Compressed Air To Instrument And Service Air Systems
1	PF	Electric Fire Pump	Horizontal Centrifugal, 2000 GPM @ 300 ft TDH	316 SS Internals	250 HP	1 X 100% Per Site	Packaged Fire Pump System
1	SL	Gland Steam Condenser				1 X 100% Per Unit	Provided by Steam Turbine Vendor
1	VB	Admin/Control Building HVAC	Air Handling Unit With Heating And Cooling Coils			1 X 100% Per Unit	

1	WBA	Closed Cooling Water Heat Exchanger	Plate And Frame Type, Thermal Duty = 24 MW	316 SS		1 X 100% Per Unit	
2	WBA	Closed Cooling Water Pumps	Horizontal Centrifugal Type; 31,000 GPM @ 65 ft TDH	CI Casing and Impeller	300 HP	2 X 50% Per Unit	
1	WBA	Closed Cooling Water Expansion Tank	Vertical; Atmospheric;	CS		1 X 100% Per Unit	
1	WBA	Closed Cooling Water Chemical Feed System				1 X 100% Per Unit	
1	WBB	DICE Jacket Cooling Water Storage Tank			TBD	1 X 100% Per Unit	
2	WBB	DICE Jacket Cooling Water Pumps	Horizontal, Centrifugal Type	CI Casing and Impeller	TBD	2X 50% Per Unit	
1	WD	Demin Water Storage Tank	Field Erected Bolted Tank	CS W/ Epoxy Lining	50,000 Gal	1 X 100% Per Site	
2	WD	Demin Transfer Pumps	Horizontal, Centrifugal Pumps	SS Casing and Impeller	2 HP	2X100% Per Site	
2	XW	HGE Area Sump Pumps	Vertical Line Shaft	CI Casing and Impeller		2 X 100% Per Sump	Duplex
2	XW	STG Area Sump Pumps	Vertical Line Shaft	CI Casing and Impeller		2 X 100% Per Sump	Duplex
2	XW	Demin Area Sump Pumps	Vertical Line Shaft	CI Casing and Impeller		2 X 100% Per Sump	Duplex
2	XW	Oil/Water Separator (Including 2x100% Effluent Pumps)	Horizontal Centrifugal Pumps Coalescing Type Media Separator			1 X 100% Per Unit	Package by Oil Water Separator Vendor. One Oil/Water Separator With One Positive Displacement Waste Oil Pump and 2x100% Effluent Forwarding Pumps.

2	XW	HRSG Blowdown Sump Pumps	Vertical Line Shaft	CI Casing and Impeller		2 X 100% Per Sump	Duplex
---	----	-----------------------------	---------------------	---------------------------------	--	----------------------	--------

1) The mechanical equipment list provides preliminary data, scope and quantities that may be subject to change during final engineering design

2) Assumptions: STG is not hydrogen cooled; backend recirculation pumps not required for HRSG

6.3 30 WT% MEA CO₂ CAPTURE PLANT

The equipment list for the CO₂ capture plant utilizing 30 wt% MEA is provided in Table 6-3

**Table 6-3
30 wt% MEA CO₂ Capture Plant Equipment List**

Site Quantity	System Code	Description	Type	Material	Rating	Capacity (%)	Comments
POST-COMBUSTION CAPTURE (30 WT %) EQUIPMENT LIST							
VESSELS & TANKS							
1	C-101	Flue Gas Absorber	Vertical	Kill CS + 304Clad Top		1 Lot Per Unit	Includes overhead wash section (Pall Ring) and absorption section (Structured packing)
1	C-102	Amine Stripper	Vertical	Kill CS + 304Clad Top		1 Lot Per Unit	Includes overhead wash section and stripping section with random packing (Pall Ring)
1	C-103	Stripper OVHD Receiver	Vertical	304Clad		1 Lot Per Unit	
1	C-106	Condensate Flash Drum	Horizontal	Carbon Steel		1 Lot Per Unit	
1	C-108	Carbon Drum(Part of V-102)	Vertical	Carbon Steel		2 Lot Per Unit	
1	D-101	MEA Storage Tank	Cone Roof	Carbon Steel		1 Lot Per Unit	
SHELL & TUBE EXCHANGERS AND AIR COOLERS							
2	E-101	Rich/Lean Exchanger	Plate & Frame	304SS		2 X50% Per Unit	Duty: 274 MMBTU/hr
1	E-102	Lean Amine Cooler	Plate & Frame	304SS		1 X100% Per Unit	Duty: 168 MMBTU/hr
1	E-103	Stripper Condenser	Weld Plate & Frame	304SS		1 X100% Per Unit	Duty: 64 MMBTU/hr
4	E-104	Stripper Reboiler	Kettle	Shell 304SS/ Tube 304SS		4 X25% Per Unit	Duty: 242 MMBTU/hr
1	E-105	Wash Water Cooler	Plate & Frame	304SS		1 X100% Per Unit	Duty: 16 MMBTU/hr
1	E-106	Reclaimer	Kettle	Shell Kill CS/ Tube 304SS		1 X100% Per Unit	Duty: 12 MMBTU/hr

COMPRESSORS, BLOWERS & DRIVERS							
1	K-101	Flue Gas Blower	Centrifugal w/ VFD Motor	304 SS	2,073 BHP	1 X100% Per Unit	
PUMPS & DRIVERS							
2	G-101	Rich Amine Pump	Centrifugal	Impeller: 12 Cr Casing: CS	616 BHP	2 X100% Per Unit	
2	G-102	Lean Amine Pump	Centrifugal	Impeller: 12 Cr Casing: CS	500 BHP	2 X100% Per Unit	
2	G-103	Wash Water Pump	Centrifugal	Impeller: 12 Cr Casing: CS	124 BHP	2 X100% Per Unit	
2	G-104	Stripper Reflux Pump	Centrifugal	Impeller: 12 Cr Casing: CS	11 BHP	2 X100% Per Unit	
1	G-106	Makeup Amine Pump	Centrifugal	Impeller: 12 Cr Casing: CS	28 BHP	1 X100% Per Unit	
1	G-107	Amine Sump Pump	Centrifugal	Impeller: 12 Cr Casing: CS	9 BHP	1 X100% Per Unit	
1	G-108	Soda Ash Pump(Part V-103)	Centrifugal	Impeller: CI Casing: CS	1 BHP	1 X100% Per Unit	
2	G-109	Condensate Return Pump	Centrifugal	Impeller: CS Casing: CS	90 BHP	2 X100% Per Unit	
PACKAGED & MISC EQUIPMENT							
4	V-102	Carbon + Pre&Post Filters	Package	Kill CS		4 X25% Per Unit	
1	V-101	Soda Ash Feed System Pkg	Package	CS		1 X100% Per Unit	
1	L-101	Flue Gas Fd & Exhaust Ducts	Duct	CS		1 X100% Per Unit	

6.4 CO₂ COMPRESSION PLANT

The equipment list for the CO₂ compression plant is shown in Table 6-4

**Table 6-4
CO₂ Compression Plant Equipment List**

Site Quantity	System Code	Description	Type	Material	Rating	Capacity (%)	Comments
CO₂ COMPRESSION EQUIPMENT LIST							
VESSEL & TANK							
1	C-301	1st Stage Compressor Feed KO Drum	Vertical	304SS		1 Lot Per Unit	
1	C-302	2nd Stage Compressor Feed KO Drum	Vertical	304SS		1 Lot Per Unit	
1	C-303	Dryer Feed KO Drum	Vertical	304SS		1 Lot Per Unit	
1	C-304	SuperCritical CO ₂ Separator	Horizontal	304SS		1 Lot Per Unit	
SHELL & TUBE EXCHANGERS AND AIR COOLERS							
1	E-301	1st Stg Comp CW AfterCooler	Shell & Tube	304SS		1 X100% Per Unit	Duty: 11 MMBTU/hr
1	E-302	2nd Stg Comp CW AfterCooler	Shell & Tube	304SS		1 X100% Per Unit	Duty: 10 MMBTU/hr
1	E-303	3rd Stg Comp CW AfterCooler	Shell & Tube	Shell CS/ Tube 304SS		1 X100% Per Unit	Duty: 19 MMBTU/hr
1	E-304	SC CO ₂ Product CW Cooler	Shell & Tube	Shell CS/ Tube 304SS		1 X100% Per Unit	Duty: 3 MMBTU/hr
1	E-305	Recycle Cooler	Shell & Tube	304SS		1 X100% Per Unit	Duty: 7 MMBTU/hr
COMPRESSORS, BLOWERS & DRIVERS							
1	K-301	CO ₂ Compressor	Centrifugal w/ VFD	CS	10,053 BHP	1 X100% Per Unit	

PUMPS & DRIVERS							
2	G-301	Condensate Pump	Centrifugal	Impeller: CS Casing: CS	0.1 BHP	2 X100% Per Unit	
1	G-302	Super-Critical CO2 Pump	Centrifugal w/ VFD	Impeller: CS Casing: CS	409 MHP	1 X100% Per Unit	
PACKAGED & MISC EQUIPMENT							
1	V-301	CO2 Dryer	Package	CS		1 X100% Per Unit	

6.5 ELECTRICAL EQUIPMENT LIST

The equipment list for DICE CRCC electrical plant is shown in Table 6-5

**Table 6-5
DICE CRCC Electrical Equipment List**

Site Quantity	Description	Type	Comments
6	115kV Circuit Breaker and Associated Buswork	High Voltage Circuit Breaker	115kV, 50kA, 1200A, HVCB with Disconnect Switch and Grounding Switch. Dead Tank SF6 Circuit Breaker
6	115kV System, 84kV MCOV Surge Arrestors	70kV MCOV Surge Arrestors for 115kV System	Switchyard Surge Arrestors
21	115kV PT or CCVT	Potential Transformers or Coupling Capacitor Voltage Transformer	Potential Transformer for Synchronizing and Voltage Measurement
9	115kV CT	Current Transformer, Extended Range	Protection and Metering Current Transformers
1	115kV Motorized Disconnect and Grounding Switch	Disconnect and Grounding Switch	115kV, 50kA, 1200A, 3 pole
1	Switchyard Control Building	Switchyard Electrical Building	Electrical Building for Protective Relaying, SCADA and Switchyard Control Equipment
3	Step-Up Transformer	13.8kV to 115kV Transformer	30/40MVA, 13.8-115kV, ONAN/ONAF, 65 DEG C, Z=8% at 30MVA, HV DETC (STG, Gas Exp, DICE-2)
1	Station Service Transformer	115kV to 13.8kV Transformer	42/56MVA, 13.8-115kV, ONAN/ONAF, 65 DEG C, Z=8% at 42MVA, HV On-Load Tap Changer (Station Service)
1	Step-Up Transformer	13.8kV to 115kV Transformer	45/60MVA, 13.8-115kV, ONAN/ONAF, 65 DEG C, Z=8% at 45MVA, HV DETC (DICE-1)
1	Emergency Diesel Generator	13.8kV, 2MW, Tier 2	2.0MW Emergency Diesel Generator, 13.8kV, Tier 2, with outdoor, sound attenuated enclosure and minimum 12 hour belly tank
1	Boiler Feed Pump VFD	13.8kV Variable Frequency Drive	13.8kV Variable Frequency Drive for 655 HP motor
2	Cooling Pump VFD	13.8kV Variable Frequency Drive	13.8kV Variable Frequency Drive (MV/LV) for 300 HP motor
1	Gas Compressor VFD	13.8kV Variable Frequency Drive	13.8kV Variable Frequency Drive for 37,000 HP synchronous motor. Starting VFD with Bypass Switch.
1	Zig-Zag Grounding Transformer with Resistor	13.8kV Grounding Transformer for Delta System	13.8kV, 250kVA, Zig-Zag Grounding Transformer with Resistor
1	Distribution Transformer	13.8kV - 480V Transformer	Control Building 750kVA transformer, ONAN, Delta-Wye, HV DETC, 5.75% Z
2	Distribution Transformer	13.8kV - 480V Transformer	Common Load Center 2000kVA transformer, ONAN, Delta-Wye, HV DETC, 5.75% Z

1	Distribution Transformer	13.8kV - 480V Transformer	MV EEM MCC 2500kVA transformer, ONAN, Delta-Wye, HV DETC, 5.75% Z
1	DICE MV Switchgear-1	13.8kV Switchgear	Arc Resistant Metal Clad Switchgear, Type 2B, 13.8kV, 3000A, 63kA, 3PH, 3W, 60HZ
1	DICE MV Switchgear-2	13.8kV Switchgear	Arc Resistant Metal Clad Switchgear, Type 2B, 13.8kV, 2000A, 63kA, 3PH, 3W, 60HZ
1	Station MV Switchgear-3	13.8kV Switchgear	Arc Resistant Metal Clad Switchgear, Type 2B, 13.8kV, 3000A, 50kA, 3PH, 3W, 60HZ
1	Common Load Center, 480V	480V Load Center, Arc Resistant	480V Load Center, 480V, 3000A, 50kA, 3PH, 3W, 60HZ with two 2500A ACB incomer & 2000A ACB tie breaker
1	Common MCC-1, 480V	480V Motor Control Center	480V MCC, 480V, 1600A, 65kA, 3PH, 3W, 60HZ, 1600A incomer (10 stacks)
1	Common MCC-2, 480V	480V Motor Control Center	480V MCC, 480V, 800A, 65kA, 3PH, 3W, 60HZ, 800A incomer (6 stacks)
1	MV EEM MCC, 480V	480V Motor Control Center	480V MCC, 480V, 3000A, 40kA, 3PH, 3W, 60HZ, 3000A ACB incomer (8 stacks)
2	Isophase Bus Duct, Gas Exp & STG	13.8kV Isophase Bus Duct	Isophase Bus Duct, 13.8kV, 2000A
1	Non-Seg Bus Duct (DICE Swgr-1 Incomer)	Non-Seg Bus Duct	Non Seg Bus Duct, 13.8kV, 3000A, 63kA
1	Non-Seg Bus Duct (DICE Swgr-2 Incomer)	Non-Seg Bus Duct	Non Seg Bus Duct, 13.8kV, 2000A, 63kA
Lot	Lighting System	Lighting fixtures, panelboards, photocells, transformers, controllers, switches, cabling and raceway	Interior and task lighting shall be 120/208VAC, roadway and floodlighting shall be 480/277VAC. Emergency and egress lighting shall be self-contained battery packs. Lighting is provided at site access points and for all operating areas to support planned maintenance. Perimeter fence lighting is not provided.
Lot	Fire Detection System	System includes Fire protection panels, smoke and fire detectors, horns, strobes, cabling and raceway	Each electrical building is provided with fire alarm panel, smoke and fire detectors, horns, strobes, auditory and visual alarms, and all required wiring and raceway.
Lot	Plant Security & Intrusion Detection System	System includes CCTV, recording & monitoring servers, access points (card readers) for site buildings, gate intercom and controls, cabling and raceway.	Site perimeter and access points monitored by CCTV, video monitoring and recording, card readers for personnel doors in all site buildings, gate access controls, gate card reader, and gate intercom are provided.
Lot	Freeze Protection & Process Heating System	System includes Heat trace panelboards, transformers, thermostats, controllers, power connection boxes, heat trace cabling, cabling and raceway.	Freeze protection system for all exposed piping and equipment subject to damage from ambient temperatures below freezing. Heat trace is 120V, installed directly on pipe and equipment, under insulation, and is controlled by local controllers (mounted on pipe) or from freeze protection panels. Heating and heat tracing required for process fluid temperature regulation and sensitive chemicals will be provided as required.

Lot	Plant Communications System	System includes facility communications and local area network (LAN) including installation of primary phone lines to interface point at plant perimeter, cabling, raceway and outlets for voice and data in all site buildings.	Communications system will provide connectivity for voice and data in all site buildings, including switchyard. Cabling, raceway, data and voice ports are provided, hardware (including telephones) to be supplied by owner.
Lot	DC & UPS System	Batteries, chargers, regulating voltage & bypass transformers, static transfer switch, manual bypass switch, DC switchboard, inverters, and UPS panelboards, cabling and raceway.	DC system will supply DC power to critical loads, including UPS system, STG and Gas Exp turning gear, and emergency lube oil pumps. Chargers are 125VDC, 550A and batteries are UPS system will supply 120VAC single phase power to critical AC loads (including CEMS, DCS, fire protection, communications, security, etc.)
Lot	Welding and Convenience Receptacles	Welding receptacles, disconnect switches, convenience receptacles.	Convenience receptacles (120V, GFCI, weatherproof) provided so that outdoor plant equipment areas are accessible with 100 foot cord. Building interiors provided with receptacles per NEC or as required to support planned maintenance activities. Welding receptacles (480V, 3PH, 3W) are located in all areas where welding is expected to occur.
Lot	Grounding System	Site and switchyard ground grids, including buried bare copper conductors, ground rods, connectors, test wells, and taps to equipment and structure.	Buried stranded copper conductors, ground rods, equipment and structure bonding. Grounding system is designed to NEC, IEEE 142, and IEEE 80 requirements.
Lot	Lightning Protection System	Building, stack, and switchyard lightning protection systems. Air terminals, main conductors, down conductors, connectors, buried conductors and rods.	Building lightning protection systems designed to NFPA 780, but will not be UL Master Labelled. Switchyard lightning protection system designed to IEEE 998.
Lot	Cathodic Protection System	Protection system for buried, coated, carbon steel, cast iron and ductile iron piping. Materials include sacrificial anodes, insulating flanges, over-voltage protectors, test stations, reference electrodes, cable, and cable connectors.	Cathodic protection system is designed to NACE standards.
Lot	MV, LV, Control and Instrumentation Cables	Power, Control and Instrumentation Cables	UL listed cables

6.6 PLANT EQUIPMENT DEVELOPMENT STATUS

6.6.1 Coal Beneficiation Plant

According to Sedgman, each plant unit operation of the flowsheet is currently commercially available and has been demonstrated previously in the mineral processing industry. However, in some cases, the application to coal, or finely ground coal, is novel, and needs to be validated with test work.

6.6.1.1 Flotation Cells

Sedgman C-Cell, an induced air-style flotation cell, was selected as its deep froths with washing is likely to achieve the desired low-ash content in the beneficiated product. Other flotation technologies, such as mechanically agitated flotation cells and column flotation cells may also be suitable for this application. Further test work is required to determine the benefits, if any, of these alternative technologies.

6.6.1.2 Fine Grinding Mill

The FLSmidth VXP Mill selected for the concept flowsheet was based on low capital cost, with the tradeoff being that it is a vertical, high intensity grinding mill. Alternate suitable technologies are available from Outotec (HIG Mill) and Glencore Technology (IsaMill). Samples of the coal feed should be provided to these three suppliers to identify which technology provides the most economical solution.

6.6.2 Power Block Equipment

6.6.2.1 Main Air Compressor

Commercially available, procured per material requisition (MR). Siemens Turbocompressor is the potential vendor. Intercooler and aftercooler (shell-tube heat exchangers) are typically in the compressor OEM's scope.

6.6.2.2 DICE

Stock engine is commercially available, procured per MR. (Turbocharger kit is removed to fit into the turbocompound configuration)

Fuel injection system design and development requires R&D as described in Section 3.1.

6.6.2.3 Third Stage Separator

Commercially available, procured per MR. Honeywell UOP is the potential vendor.

6.6.2.4 Hot Gas Expander

Commercially available, procured per MR. Baker Hughes (or Siemens) is the potential vendor.

6.6.2.5 HRSG (Including Duct Burner and SCR/CO Catalyst)

Commercially available, procured per MR. Nooter-Eriksen is the potential vendor.

6.6.2.6 *Steam Turbine Generator (Including SSS Clutch)*

Commercially available, procured per MR. Siemens Dresser-Rand is the potential vendor. The clutch is manufactured by SSS.

6.6.2.7 *STG Heat Rejection System*

Commercially available, procured per MR (air- or water-cooled condenser and cooling tower). Many potential vendors.

6.6.2.8 *Balance of Plant (BOP) Pumps*

Commercially available, each procured per MR.

6.6.2.9 *Balance of Plant (BOP) Heat Exchangers*

Commercially available, each procured per MR. They can be shell-and-tube or plate-frame type. This includes the MRC slurry preheater.

6.6.2.10 *Direct Contact Cooler*

Commercially available, procured per MR

6.6.3 **Capture Block Equipment**

6.6.3.1 *Flue Gas Blower*

Commercially available, procured per MR. Most blower vendors (Howden, Buffalo Blower, New York Blower, Clarage) should be able to provide this piece of equipment.

6.6.3.2 *Absorber/Stripper Columns*

Commercially available, procured per MR. Packing for these columns are also commercially available with Sulzer as the potential vendor.

6.6.3.3 *CO₂ Compressors*

Commercially available, procured per MR. Potential vendors are Dresser-Rand, GE, and MAN among others.

6.6.3.4 *Pumps*

Commercially available, each procured by MR.

6.6.3.5 *Heat Exchangers*


Commercially available, each procured per MR. With the exception of the kettle-type reboiler, heat exchangers will be of plate-and-frame type.

6.7 PRELIMINARY DICE CRCC PLOT PLAN

Figure 6-1 shows the overall plot plan for the coal beneficiation facility, DICE power plant, and carbon capture plant. Also included are a coal yard and cooling tower that will serve as the heat sink for the entire facility.

The complete facility will require approximately 30 to 35 acres of land to accommodate the three parts of the facility as well as administrative and maintenance buildings. The final arrangement for a specific site may change from that shown depending on local conditions.

**Figure 6-1
Preliminary Plot Plan for 100 MWe DICE CRCC Plant**



Section 7 DICE CRCC Operability

7.1 OPERATION PHILOSOPHY

From a high-level thermodynamic perspective, DICE CRCC is not different from a conventional combined cycle power plant comprising

- a “topping cycle” with one or more “internal combustion” engines and
- a “bottoming cycle” with one “external combustion” engine.

In a conventional gas turbine combined cycle power plant, the topping cycle comprises one or more gas turbines operating in **Brayton** cycle.

In a conventional reciprocating internal combustion engine (RICE) combined cycle power plant, the topping cycle comprises multiple engines operating in **Atkinson** cycle.

In either type of combined cycle, the bottoming cycle is a **Rankine** steam cycle comprising a waste heat recovery boiler (commonly referred to as “heat recovery steam generator” or HRSG) and steam turbine generator.

7.1.1 RICE-Combined Cycle Configuration

Strictly speaking, RICE is not suitable to combined cycle configuration due to its low exhaust energy, flow as well as temperature, which precludes efficient steam generator and turbine design. This difficulty is commonly avoided by using a large number of engines so that the total exhaust energy is commensurate with reasonably efficient bottoming (Rankine) steam cycle design. The number can be as high as 10, 20 or even more than 30 as demonstrated by recent projects in the Middle East and Pakistan.

Modern RICE CC power plants almost always utilize modern spark-ignition, medium speed (i.e., about 500 RPM) and large bore engines firing natural gas. Typical rating of these engines is nominally 20 MW with very high thermal efficiency, i.e., 45% or higher. The thermodynamic cycle of these engines can be approximated (for conceptual studies and analysis) by the Atkinson cycle.

High RICE efficiency, pushing towards 50% benchmark in simple cycle, is a direct result of the cycle heat addition process in the cylinder, i.e., constant volume or “explosive” combustion, which simultaneously increases cycle peak temperature and pressure. This limits the parasitic power consumed during the power stroke resulting in high net power output for a given cycle peak temperature.

Furthermore, all modern RICE engines are turbocharged. In this configuration, cycle “charge air”, which otherwise would be at ambient conditions, is compressed to a higher pressure via compression in a centrifugal compressor. If the compressor is driven by taking power directly from the engine shaft through an accessory gearbox, it is referred to as a “supercharger”. If the compressor is driven by a small (usually also centrifugal) turbine utilizing engine exhaust gas, it is referred to as a “turbocharger”, which is essentially a small gas turbine with a balanced shaft – akin to the “gas generator” of an aeroderivative gas turbine. Supercharging increases inlet air density and mass flow for given cylinder volume and enhances engine power output.

Note that multiple engine RICE-CC power plants have large exhaust energy in “quantity” (i.e., high exhaust gas mass flow rate) but not in “quality” (i.e., still relatively low exhaust temperature). This is the reason why the Rankine steam bottoming cycle is still a minor contributor to the overall plant efficiency. For example, for a modern gas turbine combined cycle power plant (GTCC) with advanced class machines, the bottoming cycle enhances simple cycle output and efficiency by almost 50%. In other words, a net 300 MW and 42% simple cycle rating, GTCC performance becomes about 450 MW and nearly 60%. In comparison, the output/efficiency boost in changing from simple to combined cycle is significantly more modest for RICE as demonstrated by the data in Table 7-1.

Table 7-1
Simple and Combined Cycle Performances for Wärtsilä’s 18V50SG Engine (12 Engines)

Parameter	Simple Cycle Mode	Combined Cycle Mode
Output at 25°C, 50 / 60 Hz	220 / 225 MW	240 / 246 MW
Output at 40°C, 50 / 60 Hz	220 / 225 MW	239 / 244 MW
Efficiency at 100% load/25°C	46.3%	50.6%
Efficiency at 50% load/25°C	46.3%	50.0%
Minimum plant load	5 MW	37 MW ****
Minimum load per engine	30%*	30%*
Startup time from COLD	100% load 3h***	100% load 8h***
Startup time from HOT	100% load 10min	100% load 60min **
Stopping from 100% load	1 minute	10 minutes
Standard loading rate	11% / minute	~10% / minute
Water consumption at full load	No water consumption	~120 m ³ /h

* Can be higher due to emission limits

** Without SCR

*** Auxiliary boiler in hot stand-by

**** Minimum amount of engines kept running at minimum load for keeping the steam turbine in operation

7.1.2 Turbocompounding

Turbocompounding is a technique that removes the turbocharger kit from the stock engine and modifies it so that, instead of being a net 0 kW shaft output accessory, it actually contributes to the plant’s net shaft output and efficiency. When combined with a second combustor between the RICE exhaust and the turboexpander inlet (i.e., “reheat” or “reheat combustion”, the impact is fortified via two mechanisms in a combined cycle configuration:

1. higher topping cycle output and efficiency
2. higher bottoming cycle efficiency (higher exhaust gas temperature)

In the introductory version of **DICE CRCC**, which is the subject of the CoalFIRST pre-FEED study, the second (reheat) combustor is eliminated for simplicity. The cycle can still be considered a “reheat” cycle in the sense that the second combustion is moved downstream to the HRSG duct

burners. This was necessary for generating enough steam to satisfy the demand of the stripper reboiler in the post-combustion capture (PCC) block. While the five DICE in the power plant are fired with MRC slurry, the HRSG duct burners utilize natural gas. It should be noted that modification requisite for translation from RICE to DICE is exclusively limited to engine accessories, i.e.

1. removal of the turbocharger accessory (its functionality transferred to outside components)
2. replacement of fuel delivery skid and engine fuel injectors


In summary, the DICE CC under investigation is essentially a RICE CC with the only difference being that the five turbocharger accessory kits of the stock RICE engines are replaced by a single air compressor (an intercooled, multi-stage centrifugal process compressor) and a single **hot gas turboexpander**. Consequently, it retains all the operability characteristics of a RICE CC.

7.2 SIMPLE CYCLE RICE/DICE STARTUP

A typical natural gas-fired RICE startup sequence is shown in Figure 7-1. Unlike the gas turbine power plants, overall startup time is 10 minutes or lower. The requirements for the sequence shown are:

1. cooling water is preheated and maintained above 70°C,
2. engine bearings are continuously pre-lubricated (a “lift” pump supplies oil to the generator bearings) and
3. the engine is on turning gear

Figure 7-1
Typical RICE (or DICE) Starting Speed and Load Curves



If necessary, RICE/DICE can be started “fast”, i.e., the engine can be synchronized in 30 seconds (instead of 60 seconds shown in Figure 7-1, and can ramp up to full load in 5 minutes (instead of 9 minutes shown in Figure 7-1), and when needed, be ramped down and stopped in less than a minute.

7.2.1 DICE Startup

It is recommended that engine starting and warm-up to operating temperatures should use fuel oil or diesel. Cold starting of large engines (which tend to use lower quality fuel) is always somewhat marginal, as the heat losses from a cold cylinder and a slow compression stroke, plus cold injection equipment, means that the charge temperature at the start of injection is lower (say 400°C) than when hot and at speed (say 650°C). This is an issue, as all coals have a higher autoignition temperature (530-575°C) than fuel oils (250-375°C).

It is, therefore, unlikely that MRC will be suitable to start a cold engine. Even if the engine started, the higher unburnts from a cold engine would cause problematic contamination of the cylinder bore, with unburnt coal packing behind the piston rings. This packing would cause accelerated ring and cylinder wear, and possibly ring breakage.

The use of diesel fuel oil for starting will require a dual injection system – a small capacity one for starting, and a larger one for MRC. An additional benefit is that the smaller capacity system for diesel fuel oil could also be used for pilot fueling

7.2.2 Pilot Fueling

DICE may require some pilot fueling – an established technology with natural gas engines, especially those needed to operate as dual-fuel engines (i.e., as distinct from lower compression spark ignition gas-only engines – Otto cycle). The amount of pilot fuel required needs experimental data. It will depend on the engine (speed, cylinder size, boost, aftercooling etc., which affect the charge temperature at the start of injection) and the effective volatiles content of the MRC. However, it is expected that a fixed 2-5% of the heat rate at maximum output would be sufficient – which automatically provides a higher proportion of heat input when required at idle and lower load settings.

For low-speed engines (<400 rpm), and based on practical experience, it is expected that the engine could operate reliably on 100% MRC, providing the engine is hot and above (say) 35% load. For lower load and higher speed engines, minimum pilot fueling with fuel oil is likely to be required. As both startup and pilot injection will require a separate injection system, operationally, some minimum pilot injection will likely be preferred to provide cooling of the pilot injector nozzles.

Injection timing for the pilot injection would normally be just before, or at the same time, as the MRC –both being electronically timed to allow optimization for different engine conditions and fuel variations.

In addition to a lower speed, derating the engine by reducing the amount of aftercooling (a higher air inlet temperature would give a reduction in cylinder charge, with a disproportionate increase in compression heating) – which may also reduce the need for pilot fueling.

The requirement for assisting ignition with pilot fuel provides an additional implementation strategy: installation of dual fuel NG engines now, being progressively switched to DICE as required using a retrofit kit.

7.2.3 DICE Shutdown


With a correctly designed fuel system, engine shut down can be achieved without any precautions. To achieve this, the fuel system will require some method of controlling a circulating flow of fuel down the injector to the needle valve and back to the service tank – as described in the engine modifications section. If this feature is not included, then a full flush of the fuel system from the feed pump through the injector will be required while the engine is operating to eliminate the possibility of stagnant coal fuel clogging the hot injection system while stopped. With the latter system the engine shut down would be under pilot fueling.

While diesel fuel has been used as the flushing fluid in some previous trials by simply switching the fuel supply to the engine from MRC to diesel, this arrangement is not recommended. In contrast to MRC, diesel fuel requires perfect sealing of valve seats (i.e., the needle or cut off valve in the injector) to ensure that fuel does not leak into the cylinder under the influence of the fuel supply pump. Also, any MRC that is not flushed from the system by the diesel fuel will highly likely result in agglomeration of the residual coal particles, potentially causing blockages. If this method of flushing is chosen, then an alternative flushing fluid should be used, for example, a mixture of long chain polyglycol (e.g., UCON) and water. This fluid would have the advantage of being miscible with MRC. In both cases, the switchover to the flushing fluid needs to be undertaken at less than half-load to avoid overfueling the engine.

7.3 COMBINED CYCLE RICE/DICE STARTUP


A typical RICE CC fast startup sequence (12 engines) is shown in Figure 7-2. All engines are started simultaneously; thus, 90% of plant full load is reached in slightly over five minutes. Steam turbine roll starts at the 30-minute mark and full plant load is reached 15 minutes after that.

Figure 7-2
Typical RICE CC Startup Speed and Load Trends



A simplified schematic diagram of DICE CRCC is shown in Figure 7-3. During startup the **main air compressor** (MAC) is started by the **variable frequency drive** (VFD). Surge control is accomplished by recirculation and/or blow-off by the MAC controller. Engines are started simultaneously in a manner similar to that shown in Figure 7-1 but in a “fast start” mode.

**Figure 7-3
Schematic of RICE CRCC**



Note the bypass lines to and around the hot gas expander, which is started using the hot exhaust gas coming from the engines, mixed with air extracted from the MAC to cool it. According to the OEM, the general rule is to control the warming rate at about 100°C/hour until the unit reaches the design temperature.

For a “cold start”, the turboexpander startup sequence can be split into four phases after standard pre-start check list including instrumentation, lubrication, etc. (note that the unit is driven by the exhaust gas, i.e., there is no starter motor):

- acceleration to the idle speed (~800-1,500 rpm);
- warming time at idle speed;
- once temperature reaches the 500°C, flue gas valves are set to fully open position, the speed increases to the design value;
- synchronization to the grid is followed by the last temperature increase step, which is completed in few minutes.

At the start of the idle time, gas/air enter into the machine and, in a few minutes, it reaches ~300°C. It takes about 2 to 3 hours for the unit to warm up to 530 °C at idle speed. In this time frame, disc cooling air is activated, machine drains are closed, standard checks are performed (bearing temperatures, vibration readings and so on). During startup, inlet pressure and flow through the unit is controlled by the inlet guide vanes and bypass valve.

Main air compressor startup is straightforward and fast whether it is a “cold” or “hot” start because there is no warm-up period involved. The critical item in process control startup is surge control, which is typically accomplished by recirculation (or recycling) of discharge air through the anti-surge valve into the compressor suction. In intercooled, multi-casing units, each compressor section has its own surge control setup.

Due to the large motor size of the MAC (> 25 MW), a VFD is necessary to prevent current inrush during starting. Typical compressor start sequence is shown in Figure 7-4 using speed and anti-surge valve position trends. The startup process on the performance map is depicted in Figure 7-5. Prior to startup, intercooler circulating water flow starts and anti-surge valves are opened. Unit drains are closed, and standard checks are performed (bearings temperature, vibrations readings, etc.). Typically, inlet guide vanes (IGVs) are set to their lowest setting, which helps with current inrush as well. As shown in Figure 7-5, as the machine is cranked by the VFD, volume flow increases but recycling prevents pressure buildup, which ensures that the unit goes through the low speeds safely removed from the surge line. Once the operating pressure is reached, IGVs are opened and anti-surge valve is closed in a controlled manner to bring the unit to full flow and full load.

The last step is going to be coordinated with the engine startup by the controller. The exact sequence and control algorithm will be determined by dynamic simulation runs during detail engineering. Similarly, dynamic simulation runs are also going to be used to coordinate the turboexpander startup controls with the engines.

Figure 7-4
Typical Centrifugal Compressor Startup – Speed and Anti-Surge Valve Position






Figure 7-5
Typical Centrifugal Compressor Startup – Pressure and Flow Path



DICE CRCC startup after an overnight shutdown is shown in Figure 7-6. As shown in the figure, MAC is started first by the VFD using power from the grid. Thereafter, first all five DICE are cranked to FSNL, synchronized to the grid and loaded to full load. Once there is enough exhaust gas generated to crank the turboexpander to FSNL, which is about 40% DICE load (equivalent of two engines running at full load), turboexpander roll starts. After the turboexpander is synchronized to the grid and ramped to full load, steam turbine roll and load process starts. Once all the five engines have started, the HRSG receives its full exhaust gas flow. After the turboexpander start has been completed, the duct burners are lit. Steam produced by the HRSG until the steam turbine roll and loading is rerouted to the condenser via the bypass line. Steam turbine is loaded by the controller via synchronized opening and closing of the admission and bypass valves, respectively. Plant full load is reached at twenty-minute mark. During the startup sequence shown in Figure 7-6, the PCC block is off-line.


**Figure 7-6
DICE CRCC Hot Start**



PCC startup is started at the 30-minute mark. Detailed pre-start preparation and startup procedure are described in detail below. Once steam starts to be directed from the HP turbine exhaust to the stripper reboiler, steam turbine starts going down. Once the steam flow through the LP turbine reaches its minimum value, it is taken off-line by the SSS clutch. Steam turbine generator is driven by the HP turbine in a backpressure operating mode.

DICE CRCC can be ramped down to about 30% plant load (two DICE operating) by turning down the engines in sequence. In this mode, hot gas turbo expander and the steam turbine are in a load following mode. This is shown in **Error! Reference source not found.** with a ramp-down rate corresponding to 90 seconds for shutting down one DICE, which is typical and easily doable. Even shorter times are possible based on OEM requirements and input. Note that load ramps (up or down) with all engines in operation are practically instantaneous. As noted above, bringing up an engine from standstill to full load is about 5 minutes.

**Figure 7-7
DICE CRCC Load Ramps**



Conceptually, as shown in Figure 7-7, the plant can be brought down to one DICE on-line with the plant running at 10% load. This has to be confirmed by the MAC and turboexpander OEMs during detail design, i.e., whether their equipment can run at that low level of load. In the case that this is an issue for the MAC, it can be alleviated during the detail design by specifying two parallel MAC trains. While this would increase the total installed equipment cost, it would be countered by the cost saving from the elimination of the VFD and associated electrical BOP. Even if the plant equipment can take the lowest flow and stay in operation, there is the question of whether the PCC can operate at such low flue gas flow. This requires careful engineering design of the capture block for maximum turndown.

It should be mentioned that the plant can run with only one (or more) DICE in operation. This can be easily accomplished by providing a bypass stack downstream of the DICE (upstream of the hot gas expander) or between the turboexpander and the HRSG. While this is a straightforward plant option, it should be carefully investigated at the beginning of the project based on the environmental regulations at the chosen site. The bypass stack can discharge directly to the atmosphere (the most economic option) or its flue gas can be directed to the PCC (unlikely to be cost-effective).

7.4 STARTUP TIME AND RAMP RATES SUMMARY

A summary of the DICE CRCC startup times for various conditions is shown per the following. The values cited are based on starting up from cold iron to 100 percent load but exclude PCC start.

- Hot start (overnight shutdown) in 30 minutes
- Warm start (48-72 hours down) in 1 to 2 hours
- Cold start (> 72 hours down) in 2 to 3 hours

Exact values for these start up times depend on the hot gas turboexpander allowable ramp rate. Operation at less than 100 percent load can be achieved in 30 minutes, regardless of hot, warm or cold start.

RICE is able to ramp at ~20% per minute from full speed no load (FSNL) to full speed full load (FSFL). From 100% plant (not engine) load to 60% engine load is 4 minutes, at which point the plant is at 50% load. Therefore, the % MCR/min is 12.5% (plant) normal.

On an emergency basis, two engines can be tripped instantaneously, ramping down to 60% engine load (50% plant load). With the inertia of the other systems, at 2 minute maximum, the MCR can be as high as 25% per minute under emergency circumstances.

Appendix A References

1. Turbocompound Reheat Gas Turbine Combined Cycle, S. C. Gülen, M. S. Boulden, POWER-GEN International, December 8-10, 2015, Las Vegas, NV.
2. Turbocompound Reheat Gas Turbine Combined Cycle "The Mouse That Roars", S.C. Gülen, Gas Turbine World, November/December 2015, pp. 22-28.
3. DOE/NETL-2007/1287, Clean Coal Diesel Demonstration Project - A DOE Assessment, July 2007, U.S. Department of Energy, Office of Fossil Energy, National Energy Technology Laboratory.
4. Wibberley, L.J., DICE - the best option for coal?, www.dice-net.org, 18 May 2014.
5. Nicol, K., 2014, The Direct Injection Carbon Engine. London, UK: IEA Clean Coal Centre. Retrieved from www.iea-coal.org
6. Wibberley, L.J., 2013, *Development of the Direct Injection Carbon Engine (DICE)*, Presented at the 38th Clearwater Clean Coal Conference, 2-6 June 2013

100 MWe COAL-FIRED DIRECT INJECTION CARBON ENGINE (DICE)
COMPOUND REHEAT COMBINED CYCLE (CRCC) WITH 90 PERCENT
POST-COMBUSTION CO₂ CAPTURE

VOLUME V: COST RESULTS REPORT

U. S. Department of Energy (DOE)

Contract No. 89243319CFE000025, Coal-Based Power Plants of the Future

By



Nexant, Inc

and



Bechtel Power and Infrastructure

Table of Contents

Section 1 Capital Cost Estimate.....241

 1.1 Cost Estimation Methodology.....241

 1.2 Capital Cost Estimate244

 1.2.1 Total Plant Cost (TPC).....244

Section 2 Plant Operating Costs249

 2.1 Fuel Specifications249

 2.1.1 PRB Coal.....249

 2.1.2 Beneficiated Coal Yield249

 2.1.3 Natural Gas Price249

 2.1.4 Diesel Price.....249

 2.2 Operating Cost.....250

 2.3 Operation & Maintenance (O&M) Costs at Turndown Conditions252

Section 3 Estimated Levelized Cost of Electricity and Sensitivity Analysis.....253

 3.1 Design Levelized Cost of Electricity (LCOE)253

 3.2 LCOE of Potential Variants254

 3.2.1 No Post-Combustion Capture.....254

 3.2.2 Centralized Coal Beneficiation Plant.....254

 3.2.3 LCOE Estimates of Variants255

 3.3 LCOE at Turndown Conditions257

 3.4 Reference Supercritical PC Plant LCOE258

 3.5 Sensitivity Analysis260

 3.5.1 Coal Beneficiation Yield.....260

 3.5.2 Beneficiation Process Reject Disposal.....262

 3.5.3 DICE and Coal Beneficiation Plant Capital Cost264

 3.5.4 Equivalent Beneficiated Coal Cost265

 3.5.5 Gas Pricing267

 3.5.6 Tornado Chart.....268

Tables in Report

Table 1-1 100 MWe DICE CRCC Cost Accounts and Estimation Methodology.....	242
Table 1-2 100 MWe Nominal DICE CRCC Capital Cost Breakdown.....	245
Table 1-3 100 MWe DICE CRCC Total Overnight Cost Breakdown.....	248
Table 2-1 100 MWe Nominal DICE CRCC Annual Operating Cost Breakdown	251
Table 3-1 LCOE Parameters and Cost Breakdown	253
Table 3-2 Performance and LCOE Summary Comparison for DICE CRCC Parametric Cases.	255
Table 3-3 Reference NETL 650 MWe SC PC Plant Performance and Cost Summary.....	258
Table 3-4 Scaled Modular 78 MWe SC PC Plant Performance and Cost Summary	259

Figures in Report

Figure 2-1 DICE CRCC Part Load Variable O&M Costs	252
Figure 3-1 DICE CRCC Part Load LCOE	257
Figure 3-2 Plant LCOE vs Beneficiated Coal Yield.....	261
Figure 3-3 Plant LCOE vs Coal Tailings Disposal Cost.....	263
Figure 3-4 Plant LCOE vs Coal Beneficiation Plant and DICE Bare Erected Cost	264
Figure 3-5 Plant LCOE vs Beneficiated Coal Cost	266
Figure 3-6 Plant LCOE vs Natural Gas Cost.....	267
Figure 3-7 LCOE Tornado Chart.....	268

Section 1 Capital Cost Estimate

1.1 COST ESTIMATION METHODOLOGY

Capital costs for the small-modular DICE CRCC plant (nominally a 100 MW “power block” but less than 100 MW with post-combustion capture for this introductory variant) were derived based on the following methodology:

- Capital costs for the coal beneficiation system were estimated by Sedgman and presented as a turnkey subcontract cost in this report. The capital cost estimate is reflective of the facility fully designed, supplied, fabricated and delivered to site, constructed and commissioned in accordance with the coal beneficiation plant scope of work detailed in the pre-FEED performance results study. For this study phase, Sedgman has utilized its historical cost information for procurement, fabrication and installation pricing and rate and this information will be validated in future study phases.

Sedgman’s bulk material and labor cost estimating procedures are based on quantity take-offs and construction rates respectively. The Sedgman in-house cost estimating database for the development, design and construction of coal handling and preparation plants and associated mine infrastructure is comprehensive and is continuously being updated.

- The costs for certain specialized, commercial equipment associated with the DICE CRCC plant, such as the air compressor, hot gas combustor, hot gas expander and the various generator equipment, were estimated and verified with budgetary quotes from equipment vendors. These were then developed up to the total plant cost level, which includes bulk material, labor, and construction indirect costs based on historical factors for similar equipment type. Costs associated with common equipment types (pumps, heat exchangers) were estimated using commercial cost estimation software (Aspen In-Plant Cost Estimator, Thermoflow PEACE)
- Post combustion capture (PCC) plant cost was determined via a bottoms-up cost estimate based on major equipment sizing and using past quotes from equipment vendors or cost curves derived from commercial cost estimate software
- DICE CRCC balance of plant (BOP) systems were estimated via a bottoms-up cost estimate based on major equipment sizing and developed to total plant cost level using historical factors
- The DICE CRCC solids handling systems (coal handling and ash handling) were scaled via capacity factor, using appropriate scaling parameters and capacity factoring exponents stated in NETL’s Quality Guidelines for Energy System Studies (QGESS) Cost Scaling Report

Table 1-1 shows the methodology used to estimate the costs for each of the major accounts and subaccounts of the DICE CRCC plant.

**Table 1-1
100 MWe DICE CRCC Cost Accounts and Estimation Methodology**

Acct No.	Item/Description	Cost Estimate Methodology
1	COAL HANDLING	Included in Sedgman scope
2	COAL & SORBENT PREP & FEED	Each area estimated as turnkey subcontract cost based on Sedgman's in-house estimation database
2.1	Coal Receiving, Conveying & Crushing	
2.2	Grinding	
2.3	Flotation	
2.4	Product Dewatering	
2.5	Product Slurry Storage	
2.6	Tailings Dewatering	
2.7	BOP and Reagents	
3	FEEDWATER & MISC BOP SYSTEMS	
3.1	Feedwater System	Included in HRSG cost
3.2	Deaerator, Water Treatment & Tanks	Bottoms-up, major equipment factored estimate
3.3	Service Water Systems	Bottoms-up estimate, includes service water pumps and headers
3.4	Natural Gas Pipeline	Bottoms-up estimate based on inch-mile of pipeline; pipeline used is 6" ID, 10 mile length
3.5	Waste Treatment Equipment	Bottoms-up estimate, includes waste water discharge pumps, tanks, and headers
3.6	Plant Instrument Air System	High-level estimate based on plant and instrument air consumption
3.7	Fire Protection System	Bottoms up estimate based on fire water requirement
3.8	Miscellaneous Pumps and Tanks	Bottoms-up cost estimate
4	DICE GT	
4.1	DICE and Generator (5)	Per MAN, equipment engines of this type are between \$6 and \$7 million
4.2	Air Compressor	Equipment cost quoted by Siemens Dresser-Rand
4.3	Hot Gas Expander + Generator (1)	Equipment cost quoted by Siemens Dresser-Rand
4.4	MRC Preheater	Estimated from Thermoflow PEACE
4.5	Fin-Fan Air Cooler	Estimated from Thermoflow PEACE
4.9	DICE-GT Foundation	Bulk foundation material and labor factored from DICE GT equipment costs
5	FLUE GAS CLEANUP	
5.1	Caustic scrubber/direct contact cooler	Sulzer quote for packing/internals and literature
5.2	Third-Stage Separator	Quote from UOP Honeywell
5B	CO2 REMOVAL & COMPRESSION	
5B.1	MEA CO2 Capture	Nexant bottoms-up cost estimate
5B.2	CO2 Compression & Drying	Nexant bottoms-up cost estimate
5B.9	CO2 Capture & Compression Foundation	Bulk foundation material and labor factored from CO2 capture and compressions equipment costs
7	HRSG, DUCTING & STACK	
7.1	Heat Recovery Steam Generator (w/ SCR)	Nooter & Eriksen bid for TC-RHT GTCC
7.2	Ductwork	From layout using other CCS cost estimates as guide
7.9	HRSG, Duct & Stack Foundations	Bulk foundation material and labor factored from HRSG equipment costs
8	STEAM TURBINE GENERATOR	
8.1	Steam TG & Accessories	Siemens Industrial bid
8.2	Condenser & Auxiliaries	Thermoflow PEACE
8.3	Steam Piping	From layout using other Bechtel power projects as guide
8.9	TG Foundations	Bulk foundation material and labor factored from steam turbine equipment costs
9	COOLING WATER SYSTEM	
9.1	Cooling Towers	Quote from Cooling Tower Depot
9.2	Circulating Water Pumps	Bottoms-up cost estimate based on pump sizing
9.3	Circ. Water Piping	Estimate based on underground CW piping length
9.4	Make-up Water System	Bottoms-up estimate, includes makeup water pump, filter, and headers
9.9	Circ. Water System Foundations	Bulk foundation material and labor factored from cooling water/cooling tower equipment costs

Table 1-1 (cont'd)
100 MWe DICE CRCC Cost Accounts and Estimation Methodology

Acct No.	Item/Description	Cost Estimate Methodology
10	ASH/SPENT SORBENT HANDLING SYS	} Scaled via QGESS capacity factoring using Low Rank Coal Baseline Report as reference
10.6	Ash Storage Silos	
10.7	Ash Transport & Feed Equipment	
10.9	Ash/Spent Sorbent Foundation	
11	ACCESSORY ELECTRIC PLANT	} Bottoms-up cost estimate based on electrical single-line
11.1	Electical Equipment	
11.2	Transmission Lines and Switchyards	
11.9	Electrical Bulks and Foundations	
12	INSTRUMENTATION & CONTROL	
12.1	DICE GT-CRCC Control Equipment	Factored from DICE GT-CRCC equipment costs
12.2	PCC Control Equipment	Factored from CO2 capture and compression equipment costs
13	IMPROVEMENTS TO SITE	
13.1	DICE GT-CRCC Sitework	Factored from DICE GT-CRCC equipment costs
13.2	PCC Sitework	Factored from CO2 capture and compression equipment costs
14	BUILDINGS & STRUCTURES	
14.1	DICE Area	Factored from DICE GT equipment costs
14.2	Steam Turbine Building	Factored from steam turbine equipment costs
14.3	Administration Building	Based on labor position requirements
14.4	Circulating Water Pumphouse	Factored from cooling water associated equipment costs
14.5	Water Treatment Buildings	} Based on rough square footage requirements
14.6	Machine Shop	
14.7	Warehouse	
14.8	Other Buildings & Structures	
14.9	Waste Treating Building & Structures	

1.2 CAPITAL COST ESTIMATE

1.2.1 Total Plant Cost (TPC)

Table 1-2 provides a breakdown of the DICE CRCC total plant cost (TPC), in 2018 dollars, reported in a similar format, with similar code of accounts as the NETL baseline reference cases for combustion-based coal and natural gas-fired power plants.

The estimated TPC for the small, modular (nominal 100 MW “block”) DICE CRCC plant is \$422.4 million (MM), or \$5,419/kW-net,

Table 1-3 presents the breakdown of the additional costs required to develop the TPC to total overnight cost (TOC), per the assumptions used in the NETL coal and natural gas baseline power plant cases. The resulting TOC, at \$525 MM, or \$6,732/kW-net is used for the calculation of the levelized cost of electricity (LCOE).

Table 1-2
100 MWe Nominal DICE CRCC Capital Cost Breakdown

Acct No.	Item/Description	Cost Basis										TOTAL PLANT COST \$	\$/kW		
		2018 (\$x1000)													
		Equipment Cost	Material Cost	Labor Direct	Labor Indirect	Sub Contract	Bare Erected Cost \$	Eng'g CM H.O & Fee	Contingencies Process	Project					
5x1x1x1 100 MW DICE CRCC PLANT WITH 30 WT% MEA CO2 CAPTURE															
1	COAL HANDLING														
2	COAL BENEFICIATION														
2.1	Coal Receiving, Conveying & Crushing	\$0	\$0	\$0	\$0	\$4,648	\$0	\$0	\$0	\$0	\$4,648	\$1,118	\$937	\$577	\$7,280
2.2	Grinding	\$0	\$0	\$0	\$0	\$16,159	\$0	\$0	\$0	\$0	\$16,159	\$3,887	\$3,257	\$2,005	\$25,308
2.3	Flotation	\$0	\$0	\$0	\$0	\$4,050	\$0	\$0	\$0	\$0	\$4,050	\$974	\$816	\$502	\$6,343
2.4	Product Dewatering	\$0	\$0	\$0	\$0	\$4,705	\$0	\$0	\$0	\$0	\$4,705	\$1,132	\$948	\$584	\$7,369
2.5	Product Slurry Storage	\$0	\$0	\$0	\$0	\$2,838	\$0	\$0	\$0	\$0	\$2,838	\$683	\$572	\$352	\$4,445
2.6	Tailings Dewatering	\$0	\$0	\$0	\$0	\$1,997	\$0	\$0	\$0	\$0	\$1,997	\$480	\$403	\$248	\$3,128
2.7	BOP and Reagents	\$0	\$0	\$0	\$0	\$5,383	\$0	\$0	\$0	\$0	\$5,383	\$1,295	\$1,085	\$668	\$8,431
	SUBTOTAL 2.	\$0	\$0	\$0	\$0	\$39,780	\$0	\$0	\$0	\$0	\$39,780	\$9,568	\$8,019	\$4,935	\$62,302
3	FEEDWATER & MISC BOP SYSTEMS														
3.1	Feedwater System	\$145	\$425	incl w/ HRSG	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
3.2	Deaerator, Tanks and Water Treatment	\$71	\$83	\$137	\$0	\$0	\$0	\$0	\$0	\$0	\$703	\$70	\$0	\$155	\$928
3.3	Service Water Systems	\$0	\$9,076	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$290	\$29	\$0	\$64	\$383
3.6	Natural Gas Pipeline	\$196	\$220	\$330	\$0	\$0	\$0	\$0	\$0	\$0	\$9,076	\$908	\$0	\$1,497	\$11,481
3.7	Waste Treatment Equipment	\$911	\$902	\$720	\$0	\$0	\$0	\$0	\$0	\$0	\$747	\$75	\$0	\$164	\$986
3.8	Plant and Instrument Air System	\$150	\$179	\$237	\$0	\$0	\$0	\$0	\$0	\$0	\$2,533	\$253	\$0	\$418	\$3,204
3.8	Fire Protection System	\$500	\$607	\$773	\$0	\$0	\$0	\$0	\$0	\$0	\$565	\$57	\$0	\$93	\$715
3.9	Misc Pumps and Tanks	\$1,973	\$11,481	\$2,329	\$0	\$0	\$0	\$0	\$0	\$0	\$1,880	\$188	\$0	\$310	\$2,378
	SUBTOTAL 3.	\$1,973	\$11,481	\$2,329	\$0	\$0	\$0	\$0	\$0	\$0	\$15,794	\$1,579	\$0	\$2,702	\$20,075
4	DICE-GT SYSTEMS														
4.1	DICE and Generator (5)	\$30,000	\$4,500	\$5,400	\$0	\$0	\$0	\$0	\$0	\$0	\$39,900	\$3,990	\$8,778	\$7,900	\$60,568
4.2	Air Compressor	\$8,300	\$3,633	\$4,259	\$0	\$0	\$0	\$0	\$0	\$0	\$16,192	\$1,619	\$0	\$2,672	\$20,483
4.3	Compressor, Expander and Generator	\$17,000	\$837	\$1,274	\$0	\$0	\$0	\$0	\$0	\$0	\$19,111	\$1,911	\$0	\$3,153	\$24,175
4.4	MRC Preheater	\$150	\$130	\$133	\$0	\$0	\$0	\$0	\$0	\$0	\$413	\$41	\$0	\$88	\$522
4.5	Fin-Fan Air Cooler	\$1,000	\$867	\$884	\$0	\$0	\$0	\$0	\$0	\$0	\$2,751	\$275	\$0	\$454	\$3,479
4.9	DICE-GT Foundation	\$0	\$2,469	\$4,805	\$0	\$0	\$0	\$0	\$0	\$0	\$7,274	\$727	\$0	\$1,200	\$9,202
	SUBTOTAL 4.	\$56,450	\$12,435	\$16,755	\$0	\$0	\$0	\$0	\$0	\$0	\$85,640	\$8,564	\$8,778	\$15,447	\$118,429
5	FLUE GAS CLEANUP														
5.1	Direct Contact Cooler	\$1,275	\$1,284	\$1,325	\$0	\$0	\$0	\$0	\$0	\$0	\$3,884	\$388	\$0	\$427	\$4,700
5.3	Third Stage Separator	\$6,000	\$4,916	\$5,426	\$0	\$0	\$0	\$0	\$0	\$0	\$16,342	\$1,634	\$0	\$1,798	\$19,774
5.3	Flue Gas Cleanup Foundation	\$0	\$575	\$1,120	\$0	\$0	\$0	\$0	\$0	\$0	\$1,695	\$169	\$0	\$186	\$2,051
	SUBTOTAL 5.	\$7,275	\$6,775	\$7,871	\$0	\$0	\$0	\$0	\$0	\$0	\$21,921	\$2,192	\$0	\$2,411	\$26,525
5B	CO2 REMOVAL & COMPRESSION														
5B.1	CO2 Removal System	\$12,984	\$5,838	\$11,595	\$0	\$0	\$0	\$0	\$0	\$0	\$30,416	\$3,042	\$0	\$5,019	\$38,476
5B.2	CO2 Compression & Drying	\$11,061	\$4,060	\$5,175	\$0	\$0	\$0	\$0	\$0	\$0	\$20,296	\$2,030	\$0	\$3,349	\$25,674
5B.3	CO2 Removal & Compression Foundation	\$0	\$877	\$1,417	\$0	\$0	\$0	\$0	\$0	\$0	\$2,284	\$229	\$0	\$378	\$2,802
	SUBTOTAL 5B.	\$24,044	\$10,775	\$18,186	\$0	\$0	\$0	\$0	\$0	\$0	\$53,006	\$5,301	\$0	\$8,746	\$67,052
7	HRSG, DUCTING & STACK														
7.1	Heat Recovery Steam Generator (w/ SCR)	\$6,000	\$2,775	\$6,018	\$0	\$0	\$0	\$0	\$0	\$0	\$14,792	\$1,479	\$0	\$2,441	\$18,712
7.2	Deaerator	\$1,675	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$1,675	\$168	\$0	\$276	\$2,119
7.3	Ductwork	\$0	\$287	\$679	\$0	\$0	\$0	\$0	\$0	\$0	\$976	\$98	\$0	\$215	\$1,288
7.9	HRSG & Duct Foundations	\$7,675	\$3,072	\$6,696	\$0	\$0	\$0	\$0	\$0	\$0	\$17,443	\$1,744	\$0	\$2,932	\$22,119
	SUBTOTAL 7.	\$14,350	\$6,134	\$13,393	\$0	\$0	\$0	\$0	\$0	\$0	\$33,886	\$3,386	\$0	\$5,654	\$42,626

Table 1-2 (cont'd)
100 MWe Nominal DICE CRCC Capital Cost Breakdown

Acct No.	Item/Description	Equipment Cost	Material Cost	Labor		Sub Contract	Bare Erected Cost \$	2018 (\$x1000)			TOTAL PLANT COST \$	TOTAL PLANT COST \$/kW	
				Direct	Indirect			Eng'g CM H.O & Fee	78 MWe, net				Project
									Process	Contingencies			
	13 IMPROVEMENTS TO SITE												
13.1	DICE GT-CRCC Sitework	\$0	\$623	\$1,360	\$0	\$0	\$1,983	\$198	\$0	\$436	\$2,617		
13.2	PCC Sitework	\$0	\$682	\$1,472	\$0	\$0	\$2,154	\$215	\$0	\$474	\$2,843		
	SUBTOTAL 13.	\$0	\$1,305	\$2,832	\$0	\$0	\$4,137	\$414	\$0	\$910	\$5,460	\$70	
	14 BUILDINGS & STRUCTURES												
14.1	DICE-GT Building	\$0	\$370	\$0	\$0	\$0	\$370	\$37	\$0	\$61	\$468		
14.2	Steam Turbine Building	\$0	\$216	\$0	\$0	\$0	\$216	\$22	\$0	\$36	\$273		
14.3	Administration Building	\$0	\$252	\$0	\$0	\$0	\$252	\$25	\$0	\$42	\$319		
14.4	Circulating Water Pumphouse	\$0	\$120	\$0	\$0	\$0	\$120	\$12	\$0	\$20	\$152		
14.5	Water Treatment Buildings	\$0	\$180	\$0	\$0	\$0	\$180	\$18	\$0	\$30	\$228		
14.7	Warehouse	\$0	\$211	\$0	\$0	\$0	\$211	\$21	\$0	\$35	\$267		
14.9	Waste Treating Building & Structures	\$0	\$59	\$0	\$0	\$0	\$59	\$6	\$0	\$10	\$75		
	SUBTOTAL 14.	\$0	\$1,409	\$0	\$0	\$0	\$1,409	\$141	\$0	\$232	\$1,782	\$23	
	CALCULATED TOTAL COST	\$128,530	\$66,327	\$84,147	\$0	\$44,485	\$323,489	\$38,600	\$17,745	\$49,921	\$422,387	\$5,419	

**Table 1-3
100 MWe DICE CRCC Total Overnight Cost Breakdown**

Description	\$/1,000	\$/kW
Preproduction Costs		
6 Months All Labor	\$6,197	\$79
1 Month Maintenance Materials	\$388	\$5
1 Month Non-Fuel Consumables	\$878	\$11
1 Month Waste Disposal	\$2,388	\$31
25% of 1 Months Fuel Cost at 100% CF	\$712	\$9
2% of TPC	\$8,448	\$108
Total	\$19,010	\$244
Inventory Capital		
60-day supply of fuel at 100% CF	\$4,130	\$53
60-day supply of non-fuel consumables at 100% CF	\$1,242	\$16
0.5% of TPC (spare parts)	\$2,112	\$27
Total	\$7,484	\$96
Other Costs		
Initial Cost for Catalyst and Chemicals	\$782	\$10
Land	\$300	\$4
Other Owner's Cost	\$63,358	\$813
Financing Costs	\$11,404	\$146
Total Overnight Costs (TOC)	\$524,724	\$6,732

Section 2 Plant Operating Costs

2.1 FUEL SPECIFICATIONS

2.1.1 PRB Coal

The design fuel for the DICE CRCC is low-sulfur sub-bituminous Montana Rosebud Powder River Basin (PRB) coal, with an as-received heating value of 8,564 Btu/lb HHV (8,252 Btu/lb LHV).

Based on the QGESS Cost Estimation Methodology for NETL Assessments of Power Plant Performance document, the levelized fuel price for PRB coal delivered to the U.S. Midwest is \$38.21/ton.

2.1.2 Beneficiated Coal Yield

The raw coal has an ash content of 11.03 percent by weight (wt%) on a dry basis, and needs to be micronized and de-ashed to an appropriate level in order to protect the moving parts of the engine that are exposed to either the micronized coal-water fuel or the solid particulate products of combustion which contain both ash and traces of unburned coal.

The DICE CRCC conceptual design utilizes physical beneficiation to remove the minerals and sulfate/pyritic sulfur in the PRB coal. Sedgman's physical beneficiation process, as described in the Performance Results Report, reduces the ash content to about 2 wt% on a dry basis, which is considered suitable for combustion in DICE. On a mass basis, the yield of beneficiated coal product to raw coal feed is 47.5 percent.

2.1.3 Natural Gas Price

Based on the most recent DOE Bituminous Baseline Report (rev 4, 2019), the current levelized natural gas price is \$4.19/GJ (\$4.42/MMBtu) on an HHV basis, delivered to the Midwest, and reported in 2018 U.S. dollars.

In its reference Midwestern NGCC case, DOE assumes that the natural gas feed is delivered to the power plant via a 10-mile long underground, carbon steel gas pipeline. The DICE CRCC plant in this conceptual design accounts for the cost associated with the same pipeline length but for a smaller diameter (6 inch-piping) due to the much smaller natural gas demand.

2.1.4 Diesel Price

Based on EIA data, the average annual wholesale price for U.S. No.2 diesel is \$2.12/gallon. For this study, a price of \$2.50/gallon of No.2 diesel is assumed to account for transportation costs to the DICE CRCC plant. Since the real escalation rate is assumed to be zero percent, all real dollar amounts stay the same as in the base year, 2018, and thus the levelized cost of fuel is the same as the estimated 2018 cost at \$2.50/gallon.

2.2 OPERATING COST

Table 2-1 presents a breakdown of the nominal 100 MWe DICE CRCC fixed and variable operating costs related to operations and maintenance (O&M) of the facility, including the cost of fuel, in 2018 dollars, based on the performance of the plant as presented in the Pre-FEED Performance Results Report.

It is notable that the low recovery of beneficiated product from processing PRB coal, at less than 50 percent, results in a large consumption of the PRB coal feed. Additionally, it generates a significant quantity of coal tailings slurry that needs to be disposed of. While these tailings still contain significant heating value, there appears to be no commercial or non-monetary disposal methods for the tailings slurry. A conventional wet disposal method is proposed and a \$38/ton disposal cost was used in the cost estimate, as referenced from the DOE Bituminous Baseline Report.

This disposal cost is considered conservative, since the tailings contain significant heating value, as much as the product itself, albeit with higher ash content and in the form of a slurry. Its quality can be comparable to that of lignite coals found in the Gulf Coast region, which have heating values as low as 4,000 Btu/lb, and moisture contents as high as 55 percent). It could therefore be potentially useful as a fuel for slurry-based gasification or for combustion after suitable processing (e.g. briquetting). Additionally, research has shown that such wastes can be used as a material for filling abandoned workings in mines or to seal surface stockpiles. Post-flotation wastes from beneficiation of coking coals with calorific value more than 5,000 kJ/kg can be used as fuel for the production of building construction ceramics, and after further beneficiation as an additive to energy fuel.

A sensitivity analysis is conducted in a later section which assumed a disposal cost ranging from -\$10/ton to \$38/ton. The former assumes that the tailings are a useful byproduct with a free on board (FOB) price of \$10/ton, or about \$1.4/MMBtu. The latter, as used in this base case analysis, simply assumes that there is no market for this product, and it must be disposed of at the full-on disposal cost of \$38/ton.

**Table 2-1
100 MWe Nominal DICE CRCC Annual Operating Cost Breakdown**


INITIAL & ANNUAL O&M EXPENSES						
Case:	DICE GT-CRCC					
Plant Size (MWe)	78					
Primary/Secondary Fuel:	Wyoming PRB		Fuel Cost (\$/MMBtu):			
Design/Construction	3 years		Book Life (yrs):			20
Capacity Factor (%)	85		Cost Base			Dec-18
			CO2 Captured (TPD)			1857
OPERATING & MAINTENANCE LABOR						
Operating Labor						
Operating Labor Rate (base):	\$38.50		\$/hr			
Operating Labor Burden:	30.0 %		of base			
Labor Overhead Charge	25.0 %		of labor			
Coal Beneficiation Plant Operating Labor Requirements						
					per Shift	
Skilled Operator					1.0	
Operator					5.0	
Foreman					1.0	
Lab Tech's etc					1.3	
DICE GT-CRCC Operating Labor Requirements						
					per Shift	
Skilled Operator					2.0	
Operator					4.3	
Foreman					1.0	
Lab Tech's etc					1.0	
TOTAL Operating Jobs					16.6	
				Annual Cost		
				\$		\$/kW-net
Annual Operating Labor Cost				\$7,278,071		\$93.37
Maintenance Labor Cost				\$2,636,417		\$33.82
Administration & Support Labor				\$2,478,622		\$31.80
Property Taxes and Insurance				\$8,447,741		\$108.37
TOTAL FIXED OPERATING COSTS				\$20,840,851		\$267.36
VARIABLE OPERATING COSTS						
				\$		\$/MWh-net
DICE GT-CRCC Plant Maintenance Material Cost				\$3,954,626		\$6.81
Coal Beneficiation Plant Maintenance Cost				\$2,043,113		\$3.52
Consumables						
	Consumption		Unit	Initial Fill		
	Initial	/Day	Cost	Cost		
Water(/1000 gallons)	0	902	1.90	\$0	\$531,901	\$0.92
Chemicals						
MU & WT Chem (ton)	0	3.87	550.00	\$0	\$660,221	\$1.14
MIBC Frother (ton)	0	1.1	4082	\$0	\$1,332,000	\$2.29
Collector (diesel) (gal)	0	315	2.50	\$0	\$244,386	\$0.42
Flocculant (ton)	0	0.2	2948.38	\$0	\$168,350	\$0.29
Lube Oil for DICE					\$468,979	\$0.81
SCR Catalyst (ft2)	0	0.43	150.00	\$0	\$19,815	\$0.03
Ammonia (19% NH3) (ton)	0	0.18	300.00	\$0	\$16,615	\$0.03
NaOH (tons)					\$1,515,531	\$2.61
Carbon (Mercury Removal) (ton)	0	0.1	1600.00	\$0	\$64,871	\$0.11
MEA Solvent (ton)	279	3.8	2721.80	\$759,280	\$3,208,156	\$5.53
Corrosion Inhibitor					\$339,454	\$0.58
MEA Reclaimer Additive (ton)					\$212,436	\$0.37
Lean Amine Carbon Filter Package (lb)	6723	242	1.2	\$8,336	\$93,113	\$0.16
Pre- and Post- Cartridge Filter (ea)	2	0.04	6964	\$13,928	\$77,784	\$0.13
Subtotal Chemicals				\$781,544	\$8,421,712	\$14.51
Waste Disposal:						
Coal Beneficiation Slurry Reject	0	2054	38.00	\$0	\$24,213,934	\$41.72
Fly Ash (ton)	0	12.1	38.00	\$0	\$143,069	\$0.25
PCC Thermal Reclaimer Waste	0	3.8	38.00	\$0	\$44,492	\$0.08
Subtotal Waste Disposal				\$0	\$24,401,495	\$42.04
TOTAL VARIABLE OPERATING COSTS				\$781,544	\$39,352,846	\$67.80
FUEL COSTS						
PRB Coal (ton)	0	1786	38.21	\$0	\$21,170,246	\$36.47
Diesel (gal)	0	238	2.50	\$0	\$184,471	\$0.32
Natural Gas (MMBtu)	0	5743	4.42	\$0	\$7,875,770	\$13.57
TOTAL FUEL COSTS				\$0	\$29,230,487	\$50.36
TOTAL VARIABLE OPERATING + FUEL COSTS					\$68,583,333	\$118.16

2.3 OPERATION & MAINTENANCE (O&M) COSTS AT TURNDOWN (PART LOAD) CONDITIONS

The variable O&M costs associated with the plant part load operating conditions are shown in Figure 2-1. These costs include the consumables (water, chemicals and catalysts), waste disposal, and fuel costs, while excluding fixed O&M costs associated with operating and maintenance labor costs, as well as maintenance material costs. These are reported on a normalized basis. For reference purposes, the variable operating cost associated with the base case of 5 DICE with PCC is \$100.7/MWh.

The horizontal axis indicates the part load variable O&M cost expressed as a fraction of the full load (5 DICE, with PCC) net output, and is based on an operational range of two DICE through the maximum of all five DICE. The right-most point on the graph shows the variable O&M cost of the plant when the PCC is not in service and steam is routed to a condensing turbine to generate additional power instead of the PCC reboiler.

**Figure 2-1
DICE CRCC Part Load Variable O&M Costs**



Section 3 Estimated Levelized Cost of Electricity and Sensitivity Analysis

3.1 DESIGN LEVELIZED COST OF ELECTRICITY (LCOE)

Based on the overall performance, TOC, and annual operating cost of the 100 MWe DICE CRCC plant, its levelized cost of electricity (LCOE) was estimated to be \$223.9/MWh. The LCOE was estimated based on the methodology established in the previously submitted Design Basis Report. The parameters used in estimating the LCOE are summarized in Table 3-1.

**Table 3-1
LCOE Parameters and Cost Breakdown**

Plant	DICE CRCC
Size	78 MWe
Capacity Factor (CF)	85%
Years of Construction	3
Total As-Spent Cost/Total Overnight Cost Ratio	1.093
Fixed Charge Rate (FCR)	0.0707
Total Overnight Cost (TOC), \$MM	525
Total As-Spent Cost (TASC), \$MM	574
Fixed Operating Cost, \$MM/yr	20.8
Variable Operating Cost @ 100% CF, \$MM/yr	46.3
Fuel Cost @ 100% CF, \$MM/yr	34.4
Annual 1000 MWh (100% CF)	683
LCOE (excl. CO₂ T&S), \$/MWh	223.9
LCOE Breakdown, \$/MWh	
Fuel (incl. coal beneficiation)	50.4
Variable O&M	67.8
Fixed O&M	35.9
Capital Charges	69.9
Total LCOE, \$/MWh	223.9

Note: 3 year construction for DICE CRCC is consistent with NGCC construction period assumption as used by NETL in its reference reports. TASC/TOC ratio used for LCOE evaluation for such 3-year capital projects is 0.0707

3.2 LCOE OF POTENTIAL VARIANTS

3.2.1 No Post-Combustion Capture

Implementing post-combustion capture (PCC) to the DICE CRCC system imposes a significant penalty on its efficiency, capital cost, and operating cost, thereby resulting in a high LCOE. A parametric scenario without PCC was evaluated to quantify the performance and cost impact. For this parametric case, exhaust steam from the main steam turbine that would have been diverted to the PCC is sent to a condensing turbine to produce more power, resulting in greater power generation from the steam cycle. As shown in the Performance Results Report of this pre-FEED study, eliminating PCC results in a 35 percent increase in net power generation. The calculated efficiency of this case is 39.9 percent on an LHV basis (37.7 percent HHV).

3.2.2 Centralized Coal Beneficiation Plant

For a small, modular power plant such as the DICE CRCC (< 100 MW for this introductory variant), the performance and cost estimates presented in previous reports suggest that it makes no economic sense to install a coal beneficiation plant on-site, analogous to building a crude oil refinery on-site at every gas station. For the modular DICE CRCC plant to be feasible, there must be multiples of such power plants, each receiving fuel from a centralized coal beneficiation plant, thereby taking advantage of the economies-of-scale benefits that the large central beneficiation plant possesses.

A parametric case was run to denote the ideal future deployment of the DICE CRCC technology. This case utilizes a centralized coal beneficiation plant which distributes beneficiated coal to the multiple small-scale DICE CRCC power plants in operation. The performance of this plant was presented in the Performance Results Report, which was estimated by eliminating all auxiliary loads and utilities associated with the coal beneficiation plant. The gross power remains the same as the on-site beneficiation case but the auxiliary power is reduced by about 10.5 percent or 5 MW. The net power increases similarly by 5 MW, or a 7 percent increase. The estimated efficiency for this case is 32.7 percent LHV (31.0 percent HHV).

3.2.3 LCOE Estimates of Variants

Table 3-2 presents the summary comparison of the capital costs, operating costs, and LCOE breakdown of the DICE CRCC plant with and without PCC, and the envisioned “ideal” DICE plant that receives coal feed from a centralized coal beneficiation plant.

**Table 3-2
Performance and LCOE Summary Comparison for DICE CRCC Parametric Cases**

Plant	DICE CRCC No PCC	DICE CRCC with PCC (on-site beneficiation)	Ideal DICE CRCC with PCC (centralized beneficiation)
Size	105 MWe	78 MWe	83 MWe
Plant Efficiency, LHV	39.9%	30.8%	32.7%
Plant Efficiency, HHV	37.7%	29.1%	31.0%
Capacity Factor (CF)	85%	85%	85%
Total Overnight Cost (TOC), \$MM	433	525	450
TOC, \$/kW	4,123	6,732	5,558
Total As-Spent Cost (TASC), \$MM	474	573	492
Fixed Operating Cost, \$MM/yr	17.6	20.8	15.2
Variable Operating Cost @ 100% CF, \$MM/yr	40.8	46.3	13.4
Fuel Cost @ 100% CF, \$MM/yr	35.8	34.4	33.7
Annual 1000 MWh (100% CF)	921	683	726
LCOE (excl. CO₂ T&S), \$/MWh	148.6	223.9	145.7
LCOE Breakdown, \$/MWh			
Fuel (incl. coal beneficiation)	38.9	50.4	46.4
Variable O&M	44.4	67.8	18.4
Fixed O&M	22.5	35.9	24.6
Capital Charges	42.8	69.9	56.4
Total LCOE, \$/MWh	148.6	223.9	145.7

For the case without PCC, the capital costs and operating costs associated with the PCC were eliminated in the parametric cost analysis. The resulting TOC is about 18 percent lower at \$433MM. The fixed operating cost is about 15 percent lower while the variable operating cost is 12 percent lower, primarily because the amine make-up requirement, the largest PCC variable cost contributor, has been eliminated. Fuel cost is slightly higher due to the higher natural gas consumption requirement in the supplementary fired HRSG in order to raise the steam quality such that it is suitable for the condensing turbine downstream of the HRSG.

The DICE CRCC plant without PCC has an LCOE of \$148.6/MWh, or 66 percent of the same plant with PCC. Essentially, adding the PCC plant to capture 90 percent of the CO₂ in the DICE CRCC flue gas increases its cost of electricity by 50 percent.

For the ideal DICE CRCC plant, the capital and operating costs associated with the modular coal beneficiation plant were eliminated in the analysis. The resulting TOC is 14 percent lower at \$450MM. Fixed operating cost is about 27 percent lower due to the much lower staffing requirement as a result of eliminating the labor-intensive on-site beneficiation plant. In terms of fuel cost, the beneficiated coal cost was estimated to be \$4.3/MMBtu, in line with CSIRO’s estimates from **DICEnet** literature, and the resulting fuel cost, at \$33.7MM/yr, is about 2 percent


lower than the base case. Additionally, the variable operating cost is significantly reduced as there are no reject tailings to dispose of on-site since the plant uses beneficiated coal directly. Elimination of the tailings slurry waste disposal operating cost results in a 71 percent reduction in variable operating cost.

The ideal DICE CRCC plant using coal received from a centralized beneficiation plant and with 90 percent CO₂ capture has a more reasonable LCOE of \$145.7/MWh, or about 65 percent of the base case plant with on-site beneficiation.

3.3 LCOE AT TURNDOWN CONDITIONS

The LCOEs associated with the plant part load operating conditions are reported on a normalized basis in Figure 3-1 and includes the estimated part load conditions for a DICE CRCC plant receiving coal from a centralized coal beneficiation facility.

**Figure 3-1
DICE CRCC Part Load LCOE**



3.4 REFERENCE SUPERCRITICAL PC PLANT LCOE

For reference purposes, the cost and performance estimates of a conventional 650 MWe supercritical pulverized coal (SC PC) plant with CO₂ capture (Case B12B) from the most recent NETL Bituminous Baseline Report (BBR rev4) are shown in Table 3-3.

**Table 3-3
Reference NETL 650 MWe SC PC Plant Performance and Cost Summary**

Plant	SC PC (NETL)
Size	650 MWe
Gross Power Production, MWe	770
Total Auxiliaries, MWe	120
Net Efficiency, HHV	31.5%
, LHV	32.7%
Capacity Factor (CF)	85%
Years of Construction	5
Total As-Spent Cost/Total Overnight Cost Ratio	1.154
Fixed Charge Rate (FCR)	0.0707
Total Overnight Cost (TOC), \$MM	3,023
TOC, \$/kW	4,654
Total As-Spent Cost (TASC), \$MM	5,372
Fixed Operating Cost, \$MM/yr	78.1
Variable Operating Cost @ 100% CF, \$MM/yr	79.7
Fuel Cost @ 100% CF, \$MM/yr	137.3
Annual 1000 MWh (100% CF)	5,694
LCOE (excl. CO₂ T&S), \$/MWh	105.3
LCOE Breakdown, \$/MWh	
Fuel (incl. coal beneficiation)	24.1
Variable O&M	14.0
Fixed O&M	16.1
Capital Charges	51.0
Total LCOE, \$/MWh	105.3

While the base case DICE CRCC plant has almost double the LCOE of that of a conventional 650 MW SC PC with CO₂ capture, it utilizes the modular coal beneficiation plant, oft-repeated in this report to be not cost-competitive. With the centralized beneficiation plant variant, the DICE CRCC plant's LCOE is reduced to \$145.7/MWh. While still almost 40 percent higher than the SC PC plant, it is important to note that the SC PC plant's LCOE is for a base-loaded, 650 MWe plant, with huge economy-of-scale benefits compared to that of the modular DICE CRCC plant.

A comparable modular SC PC plant generating 78 MW net was estimated based on the performance and cost estimates for the reference plant and the results are shown in Table 3-4. The TOC for this modular 78 MWe plant was estimated by scaling the costs using a capacity factor exponent of 0.7 to arrive at $3,023 \times (78/650)^{0.7} = \685 million. The same exponent of 0.7 was used to calculate the modular plant's fixed operating cost.

Variable and fuel costs were estimated by pro-rating the consumptions for 78 MW of net power generation, assuming that the plant net efficiency remains the same, while maintaining the same

unit costs. The resulting LCOE of this plant is \$164.9/MWh, which is 13 percent higher than the DICE CRCC plant burning beneficiated coal from a centralized facility.

**Table 3-4
Scaled Modular 78 MWe SC PC Plant Performance and Cost Summary**

Plant	Modular SC PC
Size	78 MWe
Net Efficiency, HHV	31.5%
, LHV	32.7%
Capacity Factor (CF)	85%
Years of Construction	5
Total As-Spent Cost/Total Overnight Cost Ratio	1.154
Fixed Charge Rate (FCR)	0.0707
Total Overnight Cost (TOC), \$MM	685
TOC, \$/kW	8,786
Total As-Spent Cost (TASC), \$MM	791
Fixed Operating Cost, \$MM/yr	17.7
Variable Operating Cost @ 100% CF, \$MM/yr	9.6
Fuel Cost @ 100% CF, \$MM/yr	16.5
Annual 1000 MWh (100% CF)	683
LCOE (excl. CO₂ T&S), \$/MWh	164.9
LCOE Breakdown, \$/MWh	
Fuel (incl. coal beneficiation)	24.1
Variable O&M	14.0
Fixed O&M	30.4
Capital Charges	96.3
Total LCOE, \$/MWh	164.9

3.5 SENSITIVITY ANALYSIS

3.5.1 Coal Beneficiation Yield


Based on Section 2.1.2, the beneficiated coal product yield from the as-received PRB coal is only 47.5 percent on a mass basis. Sedgman, the coal beneficiation process OEM, has indicated that its experience with low rank bituminous coal with high inherent moisture levels such as PRB shows that they are not amenable to upgrading with conventional coal flotation reagents, due to the high inherent moisture rendering the coal particle surface hydrophilic. It can thus be concluded that the design PRB coal used in this study was not an ideal choice for the beneficiation process.

Additionally, beneficiated product yield is inversely proportionate to its ash target. The relatively low ash target of 2 percent thus renders its low yield based on Sedgman's experience. A more ideal choice would therefore be a hydrophobic coal such as a bituminous coal with low inherent moisture and low ash content. Nevertheless, Sedgman acknowledged that the stated product recovery rate was on the conservative end and the actual yield could potentially be higher.

A sensitivity analysis was conducted to determine the impact of the coal beneficiation yield on the DICE CRCC plant LCOE, with a product recovery rate ranging from 40 percent to 85 percent. The high end of the recovery rate can be justified by using a coal that is more amenable to upgrading as well as a more developed DICE that can potentially tolerate higher ash beneficiated coal.

Figure 3-2 illustrates the relationship between the DICE CRCC plant LCOE and coal beneficiation yield. The effect of a larger beneficiation yield is twofold. First, a higher recovery rate leads to less as-received coal feed required for the process, resulting in a lower fuel cost. Second, the tailings reject rate is also reduced since more of the coal is recovered as product, thus reducing the waste disposal cost. At the most optimistic recovery rate of 85 percent beneficiated coal product yield, the plant LCOE is estimated to be \$173/MWh.

Figure 3-2
Plant LCOE vs Beneficiated Coal Yield




3.5.2 Beneficiation Process Reject Disposal

The current study assumes that the coal tailings from the beneficiation process have no market value and have to be disposed at the full-on disposal cost of \$38/ton. However, the tailings still contain significant heating value, as much as the product itself, albeit with higher ash content and in the form of a slurry. Its quality is actually comparable to that of lignite coals found in the Gulf Coast region, which have heating values as low as 4,000 Btu/lb, and moisture contents as high as 55 percent). It could therefore be potentially useful as a fuel for slurry-based gasification or for combustion after suitable processing (e.g. briquetting). Additionally, research has shown that such wastes can be used as a material for filling abandoned workings in mines or to seal surface stockpiles. Post-flotation wastes from beneficiation of coking coals with calorific value more than 5,000 kJ/kg can be used as fuel for the production of building construction ceramics, and after further beneficiation as an additive to energy fuel.

For this sensitivity analysis, a disposal cost range of -\$10/ton to \$38/ton was used. The former assumes that the tailings are a marketable byproduct with a free on board (FOB) price of \$10/ton, or about \$1.4/MMBtu. The latter simply assumes that there is no market for this product, and it must be disposed of at the full-on disposal cost of \$38/ton per the base case.

Figure 3-3 depicts how the DICE CRCC plant LCOE varies with the coal beneficiation tailings disposal cost. Due to the large quantity of rejects generated by the coal beneficiation plant, the LCOE is sensitive to the disposal cost, ranging from \$169/MWh when the tailings are considered most valuable to \$222/MWh when they have no value and the full disposal cost has to be paid.

Figure 3-3
 Plant LCOE vs Coal Tailings Disposal Cost




3.5.3 DICE and Coal Beneficiation Plant Capital Cost

The two components considered most critical to the DICE CRCC plant’s success are the DICE itself and the coal beneficiation plant. A sensitivity analysis was therefore conducted to determine the variation of the plant’s LCOE on the capital costs of these components. A range of +/- 50 percent from the baseline cost estimate was assumed for both systems and the results are shown in Figure 3-4.

From Figure 3-4, it can be concluded that the capital cost variation for both the DICE and coal beneficiation plant causes similar impacts on the LCOE. This is not surprising since, as shown in Table 1-2, the DICE and coal beneficiation plants have similar costs at around \$60 MM on a total plant cost basis.

Figure 3-4
Plant LCOE vs Coal Beneficiation Plant and DICE Bare Erected Cost



3.5.4 Equivalent Beneficiated Coal Cost

As described in Section 3.2.2, there is no economic sense in installing a coal beneficiation plant on-site at every modular DICE CRCC power plant. This is somewhat analogous to appending an oil refinery to each fuel oil-fired power generation facility (they rarely exist anymore, at least in the developed world, but makes the point). For the modular DICE CRCC plant to be feasible, there must be multiples of such power plants, each receiving fuel from a centralized coal beneficiation plant to take advantage of its inherent economies-of-scale advantages.


For the base case, an “equivalent beneficiated coal cost” was determined on a \$/ton basis. This was calculated by eliminating all auxiliary power and capital and operating costs associated with the on-site coal beneficiation plant. After removing all coal beneficiation related costs and utilities, the coal cost was back-calculated on a “net-back” basis to arrive at the original LCOE of \$223.9/MWh. This equivalent beneficiated coal cost was calculated to be \$14.2 per MMBtu (HHV), compared to the original PRB coal price of \$2.23 per MMBtu (HHV) based on the \$38.2/ton cost. This represents a more than 6-fold increase in coal cost due to the modular, economically disadvantaged coal beneficiation plant.

Based on CSIRO’s research involving Australian coals, it has been suggested that the cost of beneficiated coal is about AUD 6/GJ (USD 4.3/MMBtu), so a cost of USD 14.2/MMBtu of beneficiated coal in the baseline case is therefore unrealistically high.

A sensitivity analysis was conducted to determine the impact of the beneficiated coal cost on the DICE CRCC plant LCOE, using a range of beneficiated coal costs from \$2/MMBtu (essentially no associated beneficiation costs) to the current calculated value of \$14.2/MMBtu.

Figure 3-5 plots the variation of LCOE against beneficiated coal cost. Clearly, this cost has an extremely large impact on the economic performance of the DICE CRCC plant. With the modular beneficiation plant resulting in a cost of \$14.2/MMBtu of beneficiated coal, the baseline plant’s LCOE stands at \$223.9/MWh. However, if this cost was reduced to \$4.3/MMBtu per CSIRO’s estimates, with a path toward achieving this via a centralized beneficiation plant, then the LCOE could be reduced to a much more reasonable \$145.7/MWh.

Figure 3-5
Plant LCOE vs Beneficiated Coal Cost




3.5.5 Gas Pricing

For this study, a levelized natural gas price of \$4.42/MMBtu (HHV) for delivery to the Midwest was used in the operating cost analysis, which is consistent with that used in the most recent DOE Bituminous Baseline Report (rev 4, 2019). Natural gas delivered to power plants in the Midwest was estimated to be about the same price as those delivered to the Texas area, based on DOE’s most recent QGESS Fuel Pricing document. However, it is noted that current Henry Hub gas prices is only about \$1.9/MMBtu, so the assumed cost of \$4.42/MMBtu (HHV) may be too high.

A sensitivity analysis on gas pricing is therefore conducted to determine its impact on the DICE-GT CRCC LCOE, using a range of \$1.5/MMBtu to \$5/MMBtu. At the current Henry Hub natural gas pricing of \$1.9/MMBtu (HHV)¹, the estimated LCOE is reduced to \$216/MWh.

**Figure 3-6
Plant LCOE vs Natural Gas Cost**




¹ Henry Hub Natural Gas Spot Price was 1.89 USD/MMBtu for Mar 17 2020 https://ycharts.com/indicators/henry_hub_natural_gas_spot_price.

3.5.6 Tornado Chart

Figure 3-7 depicts the tornado chart that provides both a ranking and measure of magnitude of the impact that each of the parameters described above has on the LCOE. It is clear from this figure that the LCOE is most sensitive to the performance and cost of the coal beneficiation plant. It would therefore be most beneficial to the DICE CRCC technology if there was a centralized coal beneficiation plant with maximum economy-of-scale that also maximizes the yield of the beneficiation process (which simultaneously minimizes the tailings to be disposed of), thus reducing the beneficiated coal cost to be delivered to the modular DICE CRCC plant.

**Figure 3-7
LCOE Tornado Chart**





In partnership with:
US DOE/NETL
Bechtel Corporation

Coal-Fired Direct Injection Carbon Engine (DICE) Compound-Reheat Combined Cycle (CRCC)

Contract No. 89243319CFE000025

Coal-Based Power Plants of the Future

Appendix A: Project Execution Plan Presentation

Contents

1. Project Structure and Framework
2. Non-Commercial Component Development
3. Project Financing
4. Site Selection
5. Partnering with Technology Providers
6. Permitting
7. Detailed Design of Project Concept

1. Project Structure and Framework

In the present situation, DICE (“Product”) is an integral part of DICE CRCC (“Project”), a novel concept, requiring development of key components

The development of DICE (“Product”), which is an integral part of a DICE CRCC power plant (“Project”), is presented. The DICE CRCC consists of fuel preparation and post-combustion capture (PCC) blocks which is actually a “Project within a Project”. This presentation provides the Project Structure and Framework:

- **DICE CRCC**¹ is a novel power plant concept for burning a coal-based fuel
- While there is a **need** for a small, modular and flexible power plant to burn coal efficiently and cleanly
- There is no readily identifiable market **demand** for it (in the USA and other developed countries)
- Coal as a power generation fuel has a negative image
- Major engine OEMs do not plan to invest in this technology
- There is ongoing research in DICE technology (CSIRO in Australia)
- In cooperation with Chinese engine manufacturer (licensee not an original OEM)

¹ DICE-Gas Turbined Compound Reheat Combined Cycle (Direct Injection Carbon Engine – i.e., coal-fired diesel engine)

PEP covers prerequisites and acquisitions which are based on key technology innovation, market opportunity, specific components, and development

- Under the light of the present situation stated above, the following **Project Execution Plan (PEP)** is based on following prerequisites and assumptions:
- A new and positive image for coal (already so in Asia – opens up the door to US technology export)
- Market opportunity to entice major engine OEMs into their own R&D and/or cooperation with third-party component R&D organizations (e.g., CSIRO in Australia)
- Fuel injection system basic design already complete
- Customer identified
- Site selection and logistics in place

This PEP is exclusively prepared for the DICE component of the DICE CRCC

PEP addresses key prerequisites and acquisitions related to DICE technology, fuel preparation, and differentiates steps which required additional R&D

- Coal feedstock selection – current preferred study is using PRB coal, which is not the ideal feedstock for widespread deployment of the DICE technology (difficult to store, spontaneous combustion)
- Fuel preparation technology in place (which is predicated upon selected coal feedstock)
 - Grinding/micronizing
 - Washing/cleaning
 - Stabilization
 - Storage
- These steps do not require R&D *per se* (they are not identified as *technology gaps*)
- However, a careful front-end study is needed to settle on these two items before proceeding with the power project


Project overview focuses on the scope related to DICE, key objectives, project execution strategy, permitting, cost and schedule, and other related areas

- Client and Project: TBD
- Contract Basis and Terms: TBD
- Scope of Work: Design, development and manufacturing of a **Direct Injection Carbon Engine (DICE)**
- Project Objective: Delivery of multiple DICE with requisite BOP ready for installation on DICE CRCC construction site (“The Product”)
- Project Execution Strategy
- Project Cost and Schedule

DICE product development pathway requires definitive focus on identifying key OEMs, business case to OEMs, building test facility and risk review

- Should be already in place
 - Fuel selection and assessment
 - Fuel supply secured
 - Basic fuel design completed
- “Piggyback” on existing work (DOE and others)
- Identification of key OEMs
 - Stock engine
 - Fuel injector
- Business case made to the OEMs
- Forming a consortium with an OEM
- Building a test facility
- Test campaign
- Risk review

DICE PEP timeline covers a phased 10 year period leading to a semi-commercial DICE plant by 2030



Fuel development is expected take place concurrently as part of the Stage 1 test programs

2. Non-Commercial Component Development

Product definition of DICE covers engine block (cylinder liners, fuel injectors), air starter, fuel supply system, and other key components

- The product is one DICE comprising
 - Multi-cylinder engine block
 - Crankshaft and main bearings
 - Pistons and connecting rods
 - **Cylinder liners and headers**
 - Valve train (camshaft w/ valves)
 - Flywheel
 - **Fuel Injectors**
 - Air starter
 - Synchronous a/c generator
 - Excitation system
 - Oil skid
 - Flexible coupling
 - Engine coolant system
 - Lube-oil system
 - **Fuel supply system**
 - Exhaust gas system
 - Control system

Majority of DICE product is “off-the-shelf” and there are other product components requiring R&D which consist of several key components

- The product is one DICE comprising

- Multi-cylinder engine block
 - Crankshaft and main bearings
 - Pistons and connecting rods
 - **Cylinder liners and headers**
 - Valve train (camshaft w/ valves)
 - Flywheel
 - **Fuel Injectors**
- Air starter
- Synchronous a/c generator
 - Excitation system
 - Oil skid
 - Flexible coupling
- Engine coolant system
- Lube-oil system
- **Fuel supply system**
- Exhaust gas system
- Control system

- To a great extent, “off-the-shelf”
- Several key components require R&D or further testing and validation


Technology gaps for the product only cover fuel-engine interactions, fuel injector design, combustion stability, exhaust valve wear, and fuel system

- Fuel-engine interactions
 - Special coatings to protect cylinder liners, headers and valves
- Fuel injector design
 - Air-blast atomizer
 - Atomizer nozzle longevity
- Combustion stability
 - Ignition delay
 - Diesel pilot
- Exhaust valve seat wear
- Fuel system design to eliminate blockage
 - Fouling
 - Corrosion

The DICE product R&D requirements which must be addressed consist of specific key components which require further advanced development efforts

- Engine atomizer development
- Ceramic materials development
- Injection configuration development
- Piston shape optimization
- Ducting optimization
- Fuel filtration

Coal Beneficiation Process Flow Diagram



- No components are technology gaps *per se* since each plant unit operation of the flowsheet is currently commercially available but application to coal is novel
- Testing opportunities on coal are limited (market-driven)

Further testing and development required on specific coal types for optimal yield and efficiency

- Fine grinding mill
 - Available technologies include impact and attrition mills
 - Selection of most suitable grinding technology depends on various factors
 - Factors include product size, feed size, energy consumption
- Ash Removal (via flotation)
 - Different flotation technologies available with different energy and reagent input requirements
 - Low ash concentration in product coal (2 wt% db) is a challenge
- Tailings Disposal/Utilization
 - No market value in slurry form
 - Additional energy/cost to process (dewatering, briquetting)
 - Function of product yield (< 50% for PRB coal)

Feed coal selection and development of centralized coal beneficiation plant are vital to success of DICE CRCC

- Feed coal selection
 - PRB coal shown to be not suitable in current pre-FEED study
 - Low product yield results in large as-received feed requirement and tailings for disposal
 - Bench-scale tests needed on various coals to establish and select feed with best available yield
- Centralized beneficiation plant
 - No economy of scale for modular beneficiation plant at every DICE CRCC plant
 - Centralized beneficiation plant maximizes capital and labor effectiveness
 - Need to consider product stability at delivery (slurrying process on-site?)
- Coordination with DICE OEM
 - Need to work in close coordination with DICE developer
 - Ash content, sulfur content, rheology, among other properties, need to be established between DICE and coal beneficiation developers
 - Intend to develop this coordination under DOE CoalFIRST Critical Components development program

Development Needs and Work Plan

- Feed coal analysis and selection
- Coal grain analysis
- Crushing and grinding test work
- Flotation tests
- Thickening and dewatering tests
- Rheology characterization
- Pilot plant operation

Details are provided in the report from coal beneficiation OEM Sedgman

3. Project Financing

Project financing assumptions for DICE–GT CRCC (Project) include TRL, equity, debt, and grants for pilot plant and a next-of-a-kind (NoaK) commercial plant

Key Project Finance Parameter	Pilot Plant	NoaK ¹ Commercial Operation Plant	Commentary
Technology Readiness Level (TRL) ²	5 to 6	9	<ul style="list-style-type: none"> TRL assumes pilot project will be pre-demonstration phase and beyond bench-scale unit TRL for NoaK assumes advanced commercialization of technology and market ready for deployment
Type of Project Financing	Not Applicable	Limited Recourse or Non-Recourse	<ul style="list-style-type: none"> Limited recourse wherein NoaK project assets are mortgaged or hypothecated or collateralized to lenders Non-recourse wherein NoaK project's EBITDA and cash flows provide debt service coverage (DSC) over entire duration of repayment of loans and supported by bankable offtake agreements
Debt : Equity Ratio (DER)	Not Applicable	60 : 40 or 1.5 : 1 70: 30 or 2.33 : 1	<ul style="list-style-type: none"> Typical values are shown. Lower DER is for first 1 to 3 plants May vary depending on lenders requirements
Equity Sources	Venture Capital, Risk Capital, Project Sponsors, and Developers	Private Equity, Project Sponsors and Developers EPC and O&M Contractors	<ul style="list-style-type: none"> Assumes equity investment is made into special purpose Project Company specifically set-up for the Project Equity sources execute Shareholders Agreement with SPC
Debt Sources	Not Applicable	Federal Government Loan Guarantee and syndication by Commercial Banks	<ul style="list-style-type: none"> Pilot plant assumes no debt financing but only equity and grants NoaK commercial plant debt financed based on limited recourse or non-recourse financing. Debt is senior debt, subordinate debt, and working capital
Grants Sources	Federal Government State Government Non-Profits	Not Applicable	<ul style="list-style-type: none"> Grants (e.g. R&D grants and project grants) assumed for pilot plant since technology is in pre-commercial stage Grants not applicable for NoaK plant which is an advanced commercialized stage

Notes:


- Next-of-a-kind (NoaK) commercial operation of modular coal plant
- TRLs defined based on USDOE's Technology Readiness Assessment Guide

Project financing parameters for both pilot and NoaK plant include fiscal/financial incentives, economic/financial analysis, contracts, and key norms

Key Project Finance Parameter	Pilot Plant	NoaK ¹ Commercial Operation Plant	Commentary
Fiscal and Financial Incentives	Subsidies via grants, income tax credits (ITCs), accelerated depreciation, carbon credits (CO ₂)	Loan guarantees, income tax credits (ITCs), accelerated depreciation, carbon credits (CO ₂)	<ul style="list-style-type: none"> At federal level and possibly at state level Both pilot and NoaK plants need to consider potential changes in regulatory framework, policy, and directives
Elements of economic modeling and financial proforma analysis	Capex, Opex, Total Installed Cost, Levelized Cost of Electricity (LCOE)	Same as Pilot Plant plus projections over economic life along with financial profitability indicators	<ul style="list-style-type: none"> NoaK plant must also consider power tariffs, electricity merit-order dispatch scenarios, lifecycle assessment (LCA), and cost insurance, variable//fixed Opex, and working capital margin NoaK plant must include payback period, internal rate of return (IRR), rate of return on equity (RROE), net present value (NPV) and debt service coverage ratio (DSCR)
Requirements for transaction contracts	Technology license agreement (if req'd.), EPC and O&M Contract	Same as Pilot Plant plus fuel supply agreement (FSA) and power purchase agreement (PPA), agreement for purchase of carbon (CO ₂) credits	<ul style="list-style-type: none"> Pilot plant and NoaK plant's EPC contract must consider "wrap" to cover warranties and guarantees NoaK plant's O&M contract must consider long-term service agreement (LTSA) NoaK plant contracts and agreements must be "bankable" with provisions for back-to-back arrangements to mitigate counterparty risks and downside risks
Likely project financing norms	Not applicable	NPV (subject to prevailing interest rates), RROE of 8-10 percent, IRR of 10-12 percent, DSCR of 1.5 to 2.0, Payback period of 5-10 years	<ul style="list-style-type: none"> Project financing norms based on financial proforma analysis over NoaK plant economic life and subject to sponsors and lenders criteria Project financing norms subject to conducting a sensitivity and scenario analysis with respect to schedule delays, cost overruns, changes in interest rates with impact on IRR, RROE, DSCR, and payback period


For the pilot project for DICE CRCC, key technology investing stages and funding gaps cover basic R&D, applied R&D, and demonstration activities

The traditional funding and investment stages of progression of energy technology and investments, including funding sources, development processes and activities:




Any technology investing and funding gaps must be avoided for pilot project as well as pre-commercialization stages in order for success of DICE CRCC

It is important to overcome any potential funding gaps which may arise for the pilot project during the applied R&D phase and post-demonstration phase (prior to advanced Commercialization*).




* "Debt-Equity Gap" as capital requirements for commercializing energy technologies is beyond the risk tolerance and timelines of most existing debt and equity markets.

Definitive O&M experience feedback from DICE CRCC pilot plant can identify, quantify, and mitigate risks for implementing NoAK commercial plant



Next-of-a-kind (NoaK) commercial modular plant for DICE CRCC would most likely attract limited recourse financing initially for the first 1 to 3 plants




- Repayment of loan fully guaranteed project sponsors (total balance sheet exposure)

- Repayment of loans directly related to the success of the project, with limited support from the project sponsors

- Repayment of loans solely dependent on the success of the project

Most Likely

Project financing structure consists of key stakeholders* covering debt, equity, risk guarantors, EPC and O&M contractors along with bankable contracts



*includes insurance providers

Financing norms include three main phases for NoaK DICE CRCC plant which cover pre-, during, and post-financing stages including financial closure




Structuring of project financing for DICE CRCC's NoaK plant with total overnight cost of \$541 million is based on a Debt : Equity Ratio of 60:40 or 1.5:1

An example of structuring of the project financing is provided based on the Cost Report dated February 15, 2020,. Key assumptions are:

- DICE GT-RCCC Project Capacity: 77 MW
- Total Overnight Cost (TOC): \$541 million
- Debt : Equity Ratio: 60 : 40 or 1.5 : 1
- Debt: \$324.60 Million
 - Senior and subordinate debt
 - Sources: US Government loan guarantee and lenders (financial institutions, investment banks, and commercial banks)
- Equity: \$216.40 Million
 - Common and preferred stock
 - Sources: Project sponsors, developers, private equity (PE) firms, OEMs, EPC and O&M contractors
- Grants: Non assumed since this is not at pilot stage

\$ million and percentage



The three stages of project financing for pilot plant and NoaK plant must identify, minimize, and mitigate project risks, external risks, and financing risks

Project financing risks can be divided into 3 key categories which must be considered in order to meet Lender's comfort for the syndication of entire debt for the project:

Project Risks

- Site Selection
- Permitting
- Construction and Completion
- Cost Overruns
- Technology
- Operating
- Sponsor/Developer

External Risks

- Environmental
- Infrastructure
- Political and Regulatory Framework, Policy, and Directives
- Inflation
- Demand and Market

Financing Risks

- Floating Interest Rates (currently very low)
- FX Rate on imported technology and equipment

4. Site Selection

DICE plant description consists of 4 main processing blocks – coal beneficiation, power block, post combustion capture, and utilities and off-sites

- DICE plant will consist of the following processing blocks:
 - Coal Beneficiation Plant
 - Power Block
 - Post Combustion Capture (PCC) Block
 - Utilities and Off-sites
- The coal beneficiation plant receives coal from the mine and processes it into a refined, micronized coal-water slurry which is transported to the DICE engines
- The power block consists of the DICE generators, gas expander generator, Heat Recovery Steam Generator (HRSG), steam turbine generator and direct contact cooler
- The cooled exhaust gas is ducted to the PCC unit which produces supercritical carbon dioxide at a pressure of ~2,250 psig for routing to the end user via pipeline
- A waste slurry stream is produced by the coal beneficiation plant which is disposed off-site

Key site selection criteria is based on process requirements - availability of land, CO₂ storage, access to water, logistics, power interconnection, and others

- Key criteria for site selection are driven by the process requirements including:
 - Availability of adequate land suitable for proposed facilities
 - Access to sufficient volumes of water for cooling tower makeup
 - Proximity to carbon dioxide storage location or end user, alternatively proximity to an existing carbon dioxide pipeline which has spare capacity to transport the produced carbon dioxide
 - Proximity to rail or ocean/river ports for transport of coal or proximity to an existing coal fired plant which is willing to allow sharing of unit coal trains or ocean/river ports for transport of heavy equipment
 - Distance from power grid for inter-connection
 - Site should not be located in a non-attainment area for air pollution standards
 - Proximity to rail

These criteria are elaborated in the following slides.

Availability of suitable land is dependent upon specific pre-requisites, design criteria which will enable proper development, execution, and operations

- Availability of suitable land
 - Land should be reasonably flat and not prone to landslides
 - Land should not be located in 100 year floodplain or on wetlands
 - The land should not be in a high seismic zone prone to frequent earthquakes
 - Proposed site should have satisfactory geological and hydrological characteristics
 - The proposed site should not be located in areas of historical, religious or cultural importance
 - The proposed site should not be too close to urban areas or areas where population may grow rapidly
 - The proposed site should not be in proximity to existing hazardous areas or facilities
 - The proposed site should allow disposal of waste streams from the facility (coal beneficiation waste tailings, fly-ash, process wastes, waste water, etc.)
 - In the event that limited supply of makeup water is available, account for additional land for installing **Air Cooled Condensers (ACC) and Zero Liquid Discharge (ZLD) systems**

Availability of adequate water with proper quality, sufficient volumes, proximity, backup sources, and proper discharge are key to project development

- Access to adequate water
 - Availability of water supply of reasonable quality and sufficient volume for cooling tower and cooling water makeup, coal slurry preparation, and other consumptive uses
 - Source of water should not be too distant from the potential site and the route should not entail significant physical or legal obstacles
 - Allowance should be made for backup/emergency source of water
 - Site should have provision for discharge of waste water streams
 - In the event that limited supply of makeup water is available, consider optional use ACC and ZLD systems

Carbon dioxide, heavy equipment, and coal transport must be addressed as part of project execution plan focusing on proximity, easy access, and transport

- Proximity to carbon dioxide storage location or end user
 - Site should not be too distant from where the carbon dioxide will be used or stored, or near an existing carbon dioxide pipeline that can take the additional carbon dioxide produced by the facility.
 - Pipe route should not present significant physical or legal obstacles
 - If the gas is to be stored in a saline reservoir, conditions in the reservoir need to be considered during site selection

- Proximity to rail or ocean/river ports for transport of heavy equipment, coal, etc.
 - Proposed site should allow for transport of heavy and large pieces of equipment by river and/or ocean freight
 - Adequate facilities should be available to trans-ship equipment by rail and/or truck, as required
 - Proposed site should have rail or road access for transporting coal from the mine and should be located a reasonable distance from the mine

Distance from nearest power grid is key for interconnection and evacuation, and site should address non-attainment areas for air pollution standards

- Distance from power grid for inter-connection
 - Proposed site should be within a reasonable distance from the power grid for evacuation of power
 - The transmission line route should not present significant physical, technical or legal obstacles
- Site should not be located in a non-attainment area for air pollution standards
 - Proposed site should not be located in areas designated as non-attainment for pollutants

Unique requirements for selection of first DICE plant cover preferable location in US Gulf Coast, proximity to PRB coal and CO₂ storage, and other key areas

- Preferable location shall:
 - Be close to the **US Gulf Coast** for ease of transportation of large modules and equipment, including trans-shipment via barge
 - Be close to an existing coal fired plant that uses PRB coal
 - Locate near an end user/storage location for the produced carbon dioxide or to an existing carbon dioxide pipeline with enough spare capacity to handle the additional output from the DICE plant
 - Provide potential users who can receive the tailings from the coal beneficiation plant and use them productively
- **US Gulf Coast** as DICE CRCC plant location of choice:
 - The US Gulf coast has several power plants that use or used PRB coal and get regular shipments from the mines by rail and/or barge. The Big Cajun power plant located in Louisiana is one example of such a facility.
 - In addition, there is an existing carbon dioxide pipeline (Denbury pipeline) located not too far from the Big Cajun power plant that transports CO₂ to customers and points of use that could potentially be used for transporting the carbon dioxide capture in the DICE plant
 - With regards to the use of the tailings from the coal beneficiation process, the potential use will need to be explored and users will need to be developed as part of the next phase of the Project

5. Partnering with Technology Providers

Coal Beneficiation Plant

- Sedgman is able to perform design, supply, fabrication, delivery, construction and commissioning of the coal beneficiation plant
- Technologies of note that require further test work and validation
 - Flotation cells: Sedgman C-Cells
 - Fine Grinding Mill: FLSmidth (VXPMill); Outotec (HIG Mill); Glencore Technology (IsaMill)
- For CoalFIRST Critical Component development, plan to partner with Virginia Tech (Prof Roe-Hoan Yoon) to develop and test beneficiation process on variety of coals, including PRB, Eastern coals, and coal fines
 - Convert low-rank PRB coal from hydrophilic to hydrophobic
 - Electrochemical treatment to remove mineral matter
 - Convert mineral matter to fertilizer

DICE

- Reaching out to major engine OEMs (Wartsila, MAN) did not bear fruit
 - *“Coal slurry is a cheap fuel that is locally available in the world. There are investigations, in accordance with MAN ES’ own experience on that matter, showing that this fuel is very abrasive. First tests on our engines and evaluations from our experts have shown, that it causes high wear in the engine and its subsystems like the Fuel Injection Equipment. Additionally it has to be ignited by an additional pilot fuel (e.g. DMA) by using a high pressure injection system. This would result in a new engine and fuel injection equipment concept, with significant efforts for MAN Energy Solutions to handle this fuel. The current strategy of MAN Energy Solutions does not foresee a development in this direction”*
 - *[Wartsila has] a record of developing recip engines to burn some pretty challenging fuels, such as Orimulsion. But aligning ourselves to explore coal combustion is at odds with our corporate identity of supporting carbon reduction and high renewable systems...[Wartsila is] currently investing in alternative fuel R&D, but more aligned with renewable and carbon-neutral, which fit into a “net zero” paradigm”*
- “Piggyback” on existing work by CSIRO
 - CSIRO has a long history in DICE development
 - Currently working with Yancoal and Chinese engine developer (Zichai)
 - Progress is delayed by the COVID-19 crisis
- For CoalFIRST Critical Component development, plan to partner with CSIRO to further develop DICE fuel injector and cylinders and conduct series of tests for coal-fired engines

Recent CSIRO work on DICE

- A recent study with the Australian Coal Industry and MAN involving a MAN-LGI system modified for MRC by the CSIRO. Tests involved passing nearly 50 tonnes of MRC through the 600 bar injector on a spray bench. Terminated due to disagreements between MAN and the coal industry on engine development, the coal industry's concern over the potential competition with supercritical PC with PCC, and MAN's focus on next-generation engines for ammonia and hydrogen fuels.
- A recent study with Maersk and WING&D on the use of MRC for deepwater marine. CSIRO designed the injectors and fuel system for a 10 MW 4-cylinder engine which was successfully trialed in Switzerland showing excellent combustion results. Terminated due to the IMO's new regulations on the decarbonization of shipping by 2050.
- Use of biomass in DICE to halve the cost and double the benefit of biomass for electricity generation. Includes triple bottom line studies using saltbush (animal feed, fuel and soil carbon).
- Production of high quality MRC fuel from a wide range of coals - Australian (bituminous, sub-bituminous, brown), German, Indonesian (hydrothermally treated), and Venezuelan.

6. Permitting

Permitting for DICE requires prompt action from site selection, emissions estimates, meeting state requirements and timelines, and pre-/post-approval

- The permitting process should be initiated as soon as a site has been selected for the DICE power plant and the scale of the plant is established
- Initial estimates of plant capacity and emissions of regulated pollutants (based on manufacturers data) should be tested against applicable thresholds to determine application requirements
- Permit requirements vary by state and within states as well based on whether an area is classified as attainment or non-attainment
- For planning purposes it may be prudent to allow 12 to 18 months for obtaining the air permit
- Most states have specific guidelines and instructions for preparation of the air permit application
- In general the types of documents required to be submitted with the application include site plans and facility design documents in sufficient detail to establish location, scale, and relationships, horizontally and vertically, to and between adjacent properties

Permitting must address physical locations, equipment emissions, plant load data, air quality impact, EPA's NSR program, and other specific documentation

- Stack and building heights and locations are established in these documents
- Equipment manufacturer's emissions data are required. This information may be representative as actual equipment sources may not be known at this stage of the project
- Estimated plant load data – both peak and annual – should be calculated
- Determine potential emissions by applying the above factors and assuming that all new capacity operates at full rated load for 24 hours per day, 365 days per year
- **Air Quality Impact Assessment** may be required depending on the scale of the project
- The EPA's **New Source Review (NSR)** permitting program will apply, it's goal is to maintain air quality when major new sources of emissions are built
- NSR requirements may fall under one of the following categories:
 - **Prevention of Significant Deterioration (PSD)** permits are required for new sources in areas which meet the **National Ambient Air Quality Standards (NAAQS)**
 - Nonattainment NSR permits are required for major new sources in areas that do not meet NAAQS

DICE permitting must include BACT, LAER, SIPs, regulated GHG emissions, Title V, onsite record keeping, and key certification of compliance requirements

- Under the PSD permit new plants are required to include **Best Available Control Technology (BACT)**
- Non attainment areas require application of **Lowest Achievable Emission Rate (LAER)** technology, in addition to emission offsets and public involvement
- **State Implementation Plans (SIP's)**: Most states have developed SIP's under a mandate by the EPA to issue air permits, while the EPA maintains general oversight
- Regulated emissions include NO_x, SO_x, mercury, VOCs and particulate matter, among others
- When the plant reaches the operational phase a **Title V** permit is required as a means to provide a database for monitoring and enforcement
- Title V applications require as a minimum, a means of reporting air emissions either by CEMS or other means
- Onsite record keeping of relevant data
- Certification of compliance with applicable emission limitations

Indicative list of permits required cover a wide range of federal, state, and local requirements including US Army Corps of Engineers, and other documentation

- Indicative list of other permits required for power plant projects include wetlands permit, water withdrawal permit, waste water discharge permit, natural heritage program permit, certificate of public convenience and necessity, traffic plan consultations and agreements, parks and recreation historic preservation, storm water control permits, no hazard to aviation permit, threatened and endangered species consultation, local jurisdiction permits, **US Army Corps of Engineers** permits, state permits, noise permit, and others as applicable
- An environmental commitments matrix is developed during the project phase to track regulatory based design requirements. That document should tabulate the requirements from the various permits as well as action items, action owner and status
- In addition to the permits described above, there may be others required for construction of power plants that are issued by local and state agencies. Those permits would need to be obtained before start of construction

7. Detailed Design of Project Concept

Detailed design of project concept of process/power units requires proper planning, execution, and coordination with OEMs and lead EPC contractor

- Correct execution of the detailed design phase of the project is critical to ensure project success
- The detailed design of the plant will entail engineering of the following process/power units, carried out by different entities and coordinated by the lead EPC contractor:
 - Coal beneficiation plant
 - DICE CRCC power plant including as expander generator, heat recovery steam generator and steam turbine generator
 - Carbon capture and compression plant
- The detailed design of the plant will entail engineering of the following process/power units, carried out by different entities and coordinated by the lead EPC contractor:
 - Execution strategy, plan and schedule
 - Focus areas based on the overall project schedule
 - Delineation of work performed by various groups during the detailed design phase
 - Staffing forecasts and implementation
 - Major engineering risks and mitigation
 - Detailed design execution budget and performance

Each of the above tasks is discussed in detail in the following slides.

Detailed design execution strategy must be goal driven covering scope and schedule, coordination, 3D models, risk management, and schedule tracking

- Detailed Design Execution strategy has the following goals:
 - The contract will determine the scope and schedule of detailed design engineering
 - Detailed design will be performed in accordance with the contract
 - Develop quality engineering design that minimizes re-work
 - Coordinate detailed design with construction, startup, and overall project schedules for optimizing overall project duration
 - Ensure physical design coordination by developing a 3D model to eliminate interferences and ensure operability and access for maintenance
 - Manage risks associated with detailed design development
 - Control design interfaces with equipment suppliers and sub-contractors
 - Implement a management of change process
 - Engage, challenge and grow engineer's skill in the detailed design process
 - Track key metrics to ensure quality, budget, cost and safety compliance
 - Detailed design to account for sustainability and energy efficiency

Overall project schedule must address task sequencing, impacts, procurement, construction, coordination interfaces, staffing, and design of physical plant

- Focus areas based on the overall project schedule
 - Engineering provides input to Project schedule accounting for construction sequencing, weather related impacts and project turnover and completion dates
 - Project procurement, construction and startup schedules shall drive detailed design execution
 - Develop detailed design plans to cover major systems and equipment
 - Coordinate design interfaces with vendors and sub-contractors to ensure a functional and efficient power plant
 - Identify and manage critical interfaces between the power and coal beneficiation and carbon capture blocks, and coordinate with the entities responsible for their detailed design
 - Develop staffing plans based on project schedule
 - Initial design activities are geared to design of earthworks, foundations and underground structures, underground piping and ducts, grounding and storm water systems

Design phase must cover work execution by groups, coordination, implement design guidelines, staffing forecasts, deliverables, and critical-path milestones

- Delineation of work performed by various groups during the detailed design phase
 - Coordinate schedule and interfaces between the entities designing the coal beneficiation, power plant and carbon capture blocks
 - Develop and implement design guidelines and engineering procedures
 - Set up a design organization that will carry out detailed design and interface with vendors and contractors who will be responsible for certain aspects of the design
 - Identify electronic tools to be used for detailed design for all aspects and disciplines
- Staffing forecasts and implementation
 - Develop organization chart and staffing levels for all teams working on the three blocks of the project
 - Establish division of responsibilities for the detailed design teams
 - Each team will have their own teams and deliverables that support the overall project schedule
 - The lead EPC contractor will be responsible for overall schedule and internal coordination
 - Initiate regular meetings to track status and resolve issues that may impact design progress

Major risks must be identified and mitigated measures implemented along with focus on project execution, budgets, regular tracking, and performance metrics

- Major engineering risks and mitigation
 - Develop a detailed design risk register at the beginning of the project to identify risks and potential strategies for their mitigation
 - Risks to include those related to all parts of the project including coal beneficiation, power block and carbon capture and compression units
 - Risks can be associated with first-of-a-kind equipment, integrated functionality and control, and performance guarantees
 - Include risks associated with unique manufacturers supplying specialized equipment
- Detailed design execution budget and performance
 - Set up detailed design budgets, deliverables and schedule for design deliverables for each discipline for each of three entities designing the coal beneficiation plant, power plant, and carbon capture plant
 - Track progress by each discipline to ensure project stays on track for timely completion
 - Establish plans to mitigate and minimize schedule slippage by adding resources as appropriate, in a timely manner
 - Ensure motivation of the design team by holding team building activities and providing incentives for innovative design and execution that improves quality and reduces cost

DICE GT-CRCC Pre-FEED Study Report



Document No.: A917-D01-02054-0001 - LR/lr
Revision: 1

Revision Status

Revision Number	Author	Description	Date	Approved By
0	MW/LR	Issued for Use	19-Mar-2020	LR
1	MW/LR	Added sections 4.3, 10.1.1, 10.2 and 10.3	30-Apr-2020	LR

Distribution

Company Name	Contact Name	Revision	Date
Nexant	Haoren Lu	0	19-Mar-2020
Nexant	Haoren Lu	1	30-Apr-2020

Vancouver
Unit 1630
505 Burrard St
Vancouver BC V7X 1M6
CANADA

Postal Address
PO Box 26
505 Burrard Street
Vancouver BC V7X 1M6

+1 604 428 8200
mail@sedgman.com
www.sedgman.com

Copyright Notice

Sedgman © 2020

This Document is copyright. Other than for the purposes and subject to the conditions prescribed under the Copyright Act 1968 (Commonwealth), no part of it may in any form or by any means (electronic, mechanical, micro-copying, photocopying, recording or otherwise) be reproduced, stored in a retrieval system or transmitted without prior written permission.

Table of Contents

Executive Summary	1
1 Introduction	2
1.1 MRC Definition	2
1.2 Report Outline	2
2 Concept Definition	3
2.1 Processing at Coarser Sizing	4
3 Design Criteria	5
4 Mass and Energy Balance	6
4.1 Mass Balance	6
4.2 Energy Calculations	6
4.3 Moisture Assumptions	8
5 Flowsheet Development	9
5.1 Assumptions	9
5.2 First Stage Size Reduction	9
5.3 Secondary Size Reduction	10
5.4 Primary Grinding Classification	10
5.5 Fine Grinding	11
5.6 Fine Grinding Classification	12
5.7 Ash Removal	12
5.8 Dewatering	13
5.9 Slurry Preparation	15
5.10 Tailings Handling	15
5.11 Flowsheet Selection	15
6 Plant Description	16
6.1 General	16
6.2 Feed Coal Receival and Handling	17
6.2.1 Dump Hopper & Surge Bin	18
6.2.2 Ball Mill Station	18
6.3 Process Plant	19
6.3.1 Process Plant Buildings	19
6.3.2 Grinding Cyclones	19
6.3.3 Grinding	19
6.3.4 Flotation Circuit	21
6.3.5 Dewatering	23
6.3.6 Product Slurry Preparation	24
6.4 Sampling and Quality Control	25
6.4.1 Plant Feed	25
6.4.2 Product Coal	25
6.4.3 Tailings	25
6.5 Water Services	25
6.5.1 Fire, Washdown & Dust Suppression Systems	25
6.5.2 Fire Protection System	25
6.5.3 Fire Protection System Design Criteria	26
6.5.4 Washdown Water	26
6.5.5 Dust Suppression	26
6.5.6 Gland Water System	26
6.6 Air Services	26
6.7 Reagents	26
6.8 Electrical Description	26
6.8.1 Power Reticulation	27

	6.8.2	Electrical Switchrooms	27
7		Scope of Works	28
	7.1	Earthworks	28
	7.2	Civil Concrete	28
	7.3	Structural/Mechanical	28
	7.4	Process Piping	29
	7.5	Electrical Battery	29
	7.6	Communications and Data Management	30
	7.7	Tailings	30
	7.8	Water	30
	7.9	Compressed Air	31
	7.10	Sewage	31
8		Capital Cost Estimate	32
	8.1	Capital Estimate	32
	8.2	Estimate Qualifications and Exclusions	33
	8.3	Basis of Estimate	33
		8.3.1 Direct Costs	33
		8.3.2 Material Rates	33
		8.3.3 Project Cost	34
9		Operating Cost Estimate	35
	9.1	Battery Limits	35
	9.2	Basis of Estimate	35
		9.2.1 Labour	35
		9.2.2 Consumables	36
		9.2.3 Maintenance	36
		9.2.4 Power	37
		9.2.5 Mobile Equipment	37
	9.3	Estimate Exclusions	38
	9.4	Operating Cost Estimate Summary	38
10		Opportunities	40
	10.1	Feed Coal Selection	40
		10.1.1 Assessment of Energy Content of Bituminous Coal	40
	10.2	Flotation Top Size	42
	10.3	Pre-scalping low ash feedstock using conventional coal preparation technology	43
	10.4	Technology Selection	44
	10.5	Location	45
11		Future Work Plan	46
	11.1	Feed Coal Analysis	46
	11.2	Coal Grain Analysis	46
	11.3	Crushing and Grinding Test Work	46
	11.4	Flotation Tests	46
	11.5	Thickening and Dewatering Tests	47
	11.6	Rheology Characterization	47
	11.7	Pilot Plant Operation	47
12		References	48

Appendices

Appendix A

Flowsheet

Appendix B

Layout Diagrams

Appendix C

Equipment List

Appendix D

General Design Basis for Coal Beneficiation

List of Tables

Table 3-1 Key Design Parameters	5
Table 4-1 Ultimate analysis calculations for Feed, Product and Reject streams	6
Table 4-2 Energy estimates of Feed, Product and Rejects using Dulong Equation	7
Table 4-3 Energy estimates of 55% coal solids slurry compared with Product Coal.	8
Table 5-1 Design and concept development assumptions	9
Table 5-2 Dewatering Technology Comparison	14
Table 8-1 Capital cost summary (USD)	32
Table 8-2 Categories of direct costs	32
Table 8-3 Mechanical equipment direct procurement costs by area	32
Table 9-1 Operating Labour Assumptions	35
Table 9-2 Consumables Usage and Cost Rates	36
Table 9-3 Plant Maintenance Cost Assumptions	37
Table 9-4 Plant power costs	37
Table 9-5: Mobile Equipment Assumptions	37
Table 9-6: Plant Operating Cost Estimate	38
Table 10-1 Ultimate Analysis of 2% ash (db) of Bituminous feed versus Sub-bituminous feed	40
Table 10-2 Comparative Energies for Bituminous versus Sub-bituminous Coals	41
Table 10-3 Comparative Energies for Bituminous versus Sub-bituminous Coals in slurry form	41
Table 10-4 Estimates of Slurry and Feed stock quantities	41
Table 10-5 Limn Simulation Results of Scalping / Thermal Coal Preparation Plant	44

List of Figures

Figure 1-1 Typical MRC slurry	2
Figure 2-1 Finely disseminated ash particles requiring fine grinding to liberate (after O'Brien et. al., 2011)	3
Figure 2-2 Large section ash content requiring coarse crushing/ grinding to liberate (after O'Brien et. al., 2011)	3
Figure 5-1 Typical hammer mill installation	10
Figure 5-2 Typical Ball Mill Installation	10
Figure 5-3 Typical VXPmill Installation	11
Figure 5-4 Typical Solidbowl Centrifuge Installation	14
Figure 5-5 Typical Thickener Installation	14
Figure 6-1 Overall plant view from the feed end.	16
Figure 6-2 Overall plant view from the thickener side.	16
Figure 6-3 Simplified Process Block Diagram	17
Figure 6-4 Raw Coal Handling Diagram	17
Figure 6-5 Typical dump hopper arrangement with FEL feed	18
Figure 6-6 Ball Mill Grinding Circuit	19
Figure 6-7 Simplified Grinding Mill Circuit Diagram	20
Figure 6-8 Grinding Plant Overhead View	20

Figure 6-9 Grinding Plant Side View (outer building not shown)	21
Figure 6-10 Simplified Flotation and Dewatering Circuit Diagram	22
Figure 6-11 Flotation Plant Overhead View	22
Figure 6-12 Flotation Plant Side View	23
Figure 6-13 Dewatering/ Slurry Prep Plant Overhead View	24
Figure 6-14 Dewatering/ Slurry Prep Plant Side View	24
Figure 10-1 Effect of particle topline on flotation yield and concentrate ash	42
Figure 10-2 Notional Flowsheet for Thermal Coal Preparation Plant with pre-scalping of low ash product for each circuit for DICE feedstock	43

Nomenclature

Key Terms, Symbols and Abbreviations

The following terms and abbreviations are used:

(as)	As sampled (equivalent to “as mined” or “as received”)	kg/m ³	Kilograms per cubic metre
(ad)	Air dry	LD	Large diameter
(ar)	As received	LHV	Lower Heating Value
(d)	Dry	Limn	Proprietary plant simulation software package
(db)	Dry basis	LOM	Life of mine
CAPEX	Capital expenditure	MCC	Motor control centre
CCTV	Closed circuit television	Mt	Million tonnes
CHP	Coal handling plant	Mt/a	Million tonnes per annum
CHPP	Coal handling and preparation plant	NPV	Net present value
CPP	Coal preparation plant	OPEX	Operations expenditure
CSN	Crucible swelling number	PDS	Project definition statement
CSR	Coke strength after reaction	PFS	Pre-feasibility study
CV	Calorific Value	PLC	Programmable logic controller
D&C	Design and construct	RD	Relative density
DMC	Dense medium cyclone	ROM	Run of mine
EA	Environmental assessment	RX	Reflux classifier
EIS	Environmental impact study	SCADA	Supervisory control and data acquisition
EOI	Expression of interest	SE	Specific energy
EPCM	Engineering, procurement and construction management	SOP	Standard operating procedure
FS	Feasibility study	TBS	Teetered bed separator
GST	Goods and services tax	t/h	Tonnes per hour
HazAn	Hazard analysis	TLO	Train load out
HazID	Hazard identification study	TM	Total Moisture
HazOp	Hazard and operability study	UCS	Ultimate compressive strength
HGI	Hardgrove Grindability Index	UDL	Ultimate distributed load
HHV	Higher Heating Value	WAP	Work area pack
JSA	Job safety analysis	WBS	Work breakdown structure
JSO	Job safety observation	ww	Wedge wire screen mesh (parallel aperture)
kt	thousand tonnes	wt/wt%	Weight for weight %

Executive Summary

Sedgman have completed a Pre-FEED study on a coal beneficiation facility to produce Micronised Refined Carbon (MRC) as part of an overall Direct Injection Carbon Engine (DICE) Gas Turbine-Compound Reheat Combined Cycle (GT-CRCC) Facility for Nexant. The aim of the study was to develop a plant design with concept level (± 30) capital and operating cost estimates. The key criteria for the MRC plant was to produce 385,000 metric tonnes per annum of MRC slurry at 55% solids (w/w) with no more than 2% ash (ad) over a 10 year life operating at 7,400 hours per annum.

The beneficiation process, capital and operation cost estimate have been developed based on Sedgman's experience and assumptions in collaboration with Nexant. The flowsheet development phase resulted in an overall process design which finely grinds the coal then physically removes the ash component of the feed coal. The flowsheet includes the following, conventional key unit operations:

Unit Operation	Equipment
First Stage Size Reduction	Hammer mill
Second Stage Size Reduction	Ball mill
Fine Grinding	Vertical regrind mill
Ash Removal	Two (2) stage (rougher/cleaner) froth flotation
Product and Tailings Dewatering	High-rate thickeners with solid bowl centrifuge for product dewatering
Product Slurry Storage	Baffled, agitated tanks

Utilizing this flowsheet up to 740,000 t/a of coal would be fed to the MRC plant to achieve the final slurry product output.

The overall capital cost for this facility is estimated at USD62.3M, ± 30 %. The largest component of this is the grinding area that consists of the ball and vertical mills and associated classification circuit.

The operating cost estimate includes all labour, consumables, maintenance, power and mobile equipment required to operate the plant. The operating cost estimate was USD16.81 per dry feed tonne, (USD33.63 per product slurry tonne). These costs are concept level at an accuracy of ± 30 %.

The Nexant and Bechtel Power and Infrastructure Design Basis document specified the use of Powder River Basin Coal as the basis for the beneficiation plant design. Based on the limited information available our analysis shows that this coal type may not respond well to physical separation via froth flotation thus we have used a low estimated combustibles recovery. As the chemical removal of ash from such a low rank coal would render both the capital and operating costs uneconomical it is instead recommended that alternate coal types more amenable to physical separation be explored as the basis of the DICE GT-CRCC process in addition to undertaking test work on Powder River Basin Coal.

Once the target coal or coals have been identified a number of laboratory based tests are required to confirm equipment selection and sizing. Following this it is recommended that a pilot plant simulating the major unit operations be constructed to better understand the overall flowsheet performance.

1 Introduction

Nexant is currently investigating utilizing Micronized Refined Carbon (MRC) as a fuel for Bechtel's coal-fired TC-RHT GTCC power plant concept. As part the investigation Nexant engaged Sedgman to develop a concept process design for a full scale facility to provide a coal beneficiation plant to produce MRC.

1.1 MRC Definition

MRC is ultrafine, refined carbon that is typically an ultra-low ash coal material mixed with water to create slurry. It is a higher quality product compared to other, similar materials, that have been investigated previously, such as Coal Water Fuels (CWF), which use unprocessed coal as its feed source, resulting in high emissions and low efficiency. A typical MRC slurry is shown in, Figure 1-1.



Figure 1-1 Typical MRC slurry

1.2 Report Outline

This study report looks at the requirements to produce an ultra-low ash, ultrafine product coal slurry. The design has considered the required processing strategy based on feed type and the parameters pertinent to each flowsheet unit operation. For the selected processing strategy, a conceptual layout, plant description and estimate (capital and operating) has been developed.

2 Concept Definition

In order to produce a consistent MRC product, the coal feed should meet the following requirements:

- Low ash content
- Low sulphur (and other trace elements) content
- High calorific value.

To produce an ultra-low ash product, significant ash rejection is required. Much of the ash content of 'typical' product coal is locked within the coal particles (i.e. is discrete from the coal), and therefore cannot be removed in a conventional coal processing operation.

To remove this ash material, the solid particles need to be reduced in size to the point where the ash particles are separate from the coal i.e. be liberated so that they can be removed using conventional processing technologies for example flotation.

Figure 2-1 and Figure 2-2 show finely disseminated and large section ash content respectively in coal particles. The coal in Figure 2-1 would require much finer grinding to liberate ash than the coal in Figure 2-2.




Figure 2-1 Finely disseminated ash particles requiring fine grinding to liberate (after O'Brien et. al., 2011)




Figure 2-2 Large section ash content requiring coarse crushing/ grinding to liberate (after O'Brien et. al., 2011)

The particle size required to liberate enough ash to meet product specification is determined by liberation analysis of the coal feed to the plant. This information was not available for this study. In the absence of this data a target grind size of 100% passing 50µm, and 80% passing 20µm was selected. These assumptions are inline with the findings of previous published DICE net work.

2.1 Processing at Coarser Sizing

Depending on the coal type, liberation analysis may suggest a coarser grind size could be used, which would allow for more efficient processing in conventional flotation circuits up to 200 micron topsize, or if coarser, say up to 0.5 mm, it would allow for the utilization of lower cost unit operations for ash removal such as spirals and reflux classifiers. This will also result in lower costs by decreasing the proportion of ash free coal that requires ultrafine grinding.

A universal principle of coal preparation is that the efficiency of processing decreases with particle size. This occurs whether a range of particle sizes is being processed in the same processing unit, or if the top size of the coal is such that the coal feed is processed in different parallel processes, each of which are optimised for different size ranges.

If the recovery of product is to be maximised at target ash, a trade-off has to be made between

- reducing the top-size of the coal fed to the beneficiation process, which increases the liberation of mineral matter (ash content) from the organic coal components, and
- increasing the top-size of the coal fed to the beneficiation process, which allows for improved process efficiency.

The optimal topsize for a particular target ash will vary according to the particle size of the mineral components embedded within the coal as described above in Figures 2-1 and 2-2, and the natural breakage behaviour of the raw coal. In addition, if the interfaces between the mineral particles and remaining organic material represent the weakest bonding planes within the raw coal, liberation of the mineral matter will readily occur during the coal handling and crushing stages, and the natural fines in the feed will already be largely liberated prior to finer grinding stages.

However, this will vary for each feed type, so it is necessary to conduct a laboratory scale testing programme to evaluate the most appropriate topsize for any particular coal to maximise the recovery of the coal component at the target ash. Such a programme should be conducted in the following stages:

- Carefully select representative samples of the coal to be tested which undergo microscopic evaluation of the coal to determine how the mineral particles are dispersed throughout the raw coal feed as described in Figure 1-1 and 1-2.
- Based on that analysis, conduct float/sink testing of representative feed samples at a range of topsizes selected on the basis of the microscopic study.
- Run process plant simulations of alternative coal processing circuits using the above washability data to determine the optimal topsize for processing the coal in the most efficient manner when targeting a 2% ash (db) product.

There are additional advantages to processing the raw coal feed at a coarser topsize:

- Reduced tonnage of low ash concentrate to be presented to the final grinding stage, reducing the unit capacity required and the associated energy. Removal of siliceous reject material in the coal will reduce wear in the fine grinding circuit.
- Reduced energy level in the waste stream due to improved efficiency of the beneficiation process. The coarser nature of the waste stream will allow for lower cost dewatering prior to disposal if sent to waste.

A variation of this approach is to scalp only a small proportion (say 20% or less) of the natural very low ash fines which are sometimes present in selected seams of bituminous coal used for production of thermal using conventional coal processing methods. The remnant stream will then still be suitable for producing a moderate ash thermal product in a second stage of processing using conventional technology. The selected low ash fines may be subjected to further crushing, grinding and processing if necessary to produce a suitable MRC product. Such an operation would need to be located as an adjunct to a much higher capacity conventional thermal coal processing plant.

3 Design Criteria

The General Design Basis for Coal Beneficiation, is provided in Appendix D, (document reference A917-D01-04010-001).

The key design parameters are outlined in Table 3-1.

Table 3-1 Key Design Parameters

Parameter	Unit	Value	
General			
Feed Coal Capacity (Nominal)	t/h	100	
Product Capacity (Nominal)	t/h	48	
Specific Gravity			
Feed Coal (ad)	RD	1.35	
Product Coal (ad)	RD	1.32	
Rejects (ad)	RD	1.50	
Total Moisture			
Feed Coal	% (AR)	25.77	
Bulk Density			
		Volume	Load
Feed Coal	kg/m ³	900	1100
Product Coals	kg/m ³	850	1000
Rejects	kg/m ³	1100	1400
Sizing			
ROM Top-size (Nom)	mm	80	
Product 100% passing size (P ₁₀₀)	µm	50	
Product 80% passing size (P ₈₀)	µm	20	
Ash			
Product	% (ad)	2.0 %	
Hardgrove Index			
HGI	Index	57	

4 Mass and Energy Balance

4.1 Mass Balance

Mass balances for this study are generated on an Ultimate Analysis basis, using the North American convention of including “bed” or “inherent” moisture and ash components on an (ar) basis, or excluding the moisture component for calculations on a dry basis.

Assumptions

- The coal feed is sub-bituminous Montana Rosebud, Table 4-1 Ultimate analysis calculations for Feed, Product and Reject streams
- Product upgraded to 2% ash (db) and sulphur content reduced by 20%.
- For mass balance purposes, the remaining components related to the organic part of the coal including C, H, N, O and Moisture retain the same proportions in both the product and reject material as in the original feed.
- Use mass balance of solids in the open circuit mill calculations resulting in 47.5% yield (ar), (or 45.8% yield on a dry basis).
- Final MRC slurry is 55% coal (ar)
- The calculation methodology includes the following steps:
 - Feed ultimate = Feed (ar) from Table 4-1
 - Feed adjusted to dry basis
 - Product ash set to 2% (db) and S set to 80% of Feed S% (db)
 - The 20% S rejected is organic and reports to the tailings
 - Product adjusted to (ar) basis after feed moisture is adjusted for ash and S changes
 - Reject (ar) calculated for each component according to yield % (ar)
 - Reject (db) calculated for each component according to yield % (db)
 - Check calculation for Reject (db) from Reject (ar).

Table 4-1 shows the calculated Ultimate Analyses for the Feed, Product and Reject streams.

Table 4-1 Ultimate analysis calculations for Feed, Product and Reject streams

Component	Feed ar (%)	Feed Dry (%)	Prod Dry (%)	Prod ar (%)	Reject ar (%)	Reject Dry (%)
C	50.07	67.45	74.53	53.31	47.14	61.48
H	3.38	4.55	5.03	3.60	3.18	4.15
N	0.71	0.96	1.06	0.76	0.67	0.87
S	0.73	0.98	0.79	0.56	0.88	1.15
Cl	0.01	0.01	0.01	0.01	0.01	0.01
Ash	8.19	11.03	2.00	1.43	14.31	18.66
Moisture	25.77	0.00	0.00	28.47	23.32	0.00
Oxygen	11.14	15.01	16.58	11.86	10.49	13.68
Total	100	100	100	100	100	100

The above mass balance was checked using the Proximate Analysis to verify the ash balance. However, it is necessary to use the more complex Ultimate Analyses for a mass balance to provide the necessary data to estimate product and reject CV's.

4.2 Energy Calculations

The Dulong Equation can be used to estimate the energy of thermal coals from the Ultimate Analyses in the absence of laboratory bomb calorimeter data. The specific parameter values

recommended for application of this equation vary somewhat depending on the source, but all result in a similar energy value considering the error in laboratory measurements.

For this study, the following equation is used (Demirbas, 2004) for estimating the HHV (db) as it results in the closest estimate to the 11,516 Btu/lb quoted in Table 4-1 for HHV (db). The units for the elemental analyses in equation (1) are in mass fraction.

$$\text{HHV (kcal/kg)} = 8,080(\text{C}) + 34,460(\text{H}) - 4,308(\text{O}) + 2250(\text{S}) \quad (1)$$

The result from equation (1) is then adjusted to HHV (ar) assuming the moisture component has neutral value in terms of energy.

The calculation of LHV (ar) (corresponding to CV nar) adjusts the available energy in the coal feed for the water and the H component of the coal which forms water during the combustion process. In the laboratory analysis of the energy content of the coal, all the water products are condensed so that the heat of evaporation is recovered and recorded as part of the energy generated from the sample on an HHV basis. However, in commercial applications, the water products for the most part exit the boiler as uncondensed steam, so this heat of evaporation is lost to the process, and the energy value of the feed needs to be reduced accordingly, which is termed LHV (or CV nar).

For the purpose of this study, the ASTM formula for higher rank coals is used as follows:

$$\text{CVnar} = \text{CVgar} - 0.02395 \times (\text{TM} + 8.94 \times \text{Har}) \text{ Mj/kg} \quad (2)$$

Where CVnar is equivalent to HHV (ar)

CVgar is equivalent to LHV (ar)

TM is a combination of the “inherent” or “bed” moisture bound within the coal structure, plus any free moisture present, including the free water present in a coal slurry.

Table 4-2 shows the estimates of the feed, product and reject energies on both a dry and an as received basis using the Dulong Equation (1) above. The LHV values after applying equation (2) are also shown. All energy values are converted from kcal/kg (from equation 1) to kJ/kg using a factor of 4.1868 and to BTU/lb using a factor of 1.80.

Table 4-3 shows the reduction in the energy value of the combined coal and water components in the MRC 55% solids slurry, assuming 55% product solids with an estimated product bed moisture of 28.5% which is absorbed within the coal solids, and free moisture of 45% which is required for suspending the fine solids in the slurry so that it has the necessary rheological properties for use as a MRC liquid fuel.

Table 4-2 Energy estimates of Feed, Product and Rejects using Dulong Equation

			Feed	Prod	Reject
Dry basis	HHV	kJ/kg	26774	29555	24427
		Btu/lb	11518	12715	10509
Ar basis	HHV	kJ/kg	19874	21139	18730
		Btu/lb	8550	9094	8058
	LHV	kJ/kg	18533	19687	17490
		Btu/lb	7973	8470	7524

Note: There is no LHV data listed in table 4-2 for Dry Basis as such a value has no physical meaning, since it requires a total moisture value to be nominated so that the adjustment to usable energy value can be calculated. If a notional value of LHV db is estimated using the standard “change of base” formula, its subsequent use for estimating LHV on an ar basis for other total moisture levels, e.g. in the slurry, will lead to erroneous results due to the disproportionate effect of total moisture on reducing available energy from the dry component of the coal.

Table 4-3 Energy estimates of 55% coal solids slurry compared with Product Coal.

		Prod ar	Slurry ar
HHV	kJ/kg	21139	11627
	Btu/lb	9094	5002
LHV	kJ/kg	19687	9750
	Btu/lb	8470	4195

4.3 Moisture Assumptions

There are a number of factors that contribute to the final MRC product moisture. During the study there was discussion that a lower final product moisture than that used by Sedgman may be achieved due to the liberation of inherent moisture in the feed. It is correct that some of the coal will be ground fine enough to expose the pores, and no doubt there is a proportion of the micronized product where this has happened to some degree. However, it is doubtful that much of the associated water will be released to form part of the free flowing matrix of free water required to suspend the solid particles for two reasons.

- The size and nature of the porosity of coal has been studied at some length over the years, with a great deal of contradictory and confusing conclusions. Perhaps one of the most definitive sources on coal science is “Coal: Typology – Physics – Chemistry – Constitution” by van Krevelen (3rd edn 1992), and in Chapter 7 he discusses the pore structure. The pores (from Dubinin) are described as consisting of different sizes; macropores >20 microns, mesopores 2 – 20 microns and micropores < 2 microns. Table 7.5 lists measurements undertaken for a range of coal ranks, and for the three coals with similar C% maf values to the coal used as a source for the study (76% C maf and ranked as Type C high volatile bituminous in table 7.5), the percentage of pore volume classified as macropores averaged about 20%, with the majority of pores in the finer classifications. Hence for the most part one would expect a substantial pore volume remaining in the micronized coal.
- A second issue is the understanding of how the inherent moisture is bound within the coal. A substantial R & D programme was carried out by CSIRO and the Australian coal industry in the late 80’s to determine this issue, with which Sedgman’s Principal Coal Quality Consultant, Chris Clarkson, was involved. Their general understanding was that the moisture adsorbs onto the coal pore surface in multiple layers, primarily due to Van der Waals forces, hence the substantial heat of wetting when moisture is re-absorbed into coals that have been dried to exclude the inherent moisture. This again is consistent with various sections of van Krevelen. Even if a number of the pores are exposed from fine grinding, it would be expected that such moisture would remain adsorbed on the coal surface as a boundary layer lying within the surface shear zone, so for all practical purposes will not contribute to any significant extent to the low viscosity, free flowing matrix of water required to suspend the solids.

If a lower final product moisture was to be selected, it would therefore be necessary to conduct bench-scale studies in which micronized coal representing the proposed feed source are slurried and the rheological properties measured for different size ranges and percentage moisture.

5 Flowsheet Development

Sedgman utilized its experience in coal and mineral processing technology to investigate various options for design of the MRC plant. The following describes the methodology used to develop the flowsheet.

Each plant unit operation of the flowsheet is currently commercially available. However, in some cases the application to coal, or finely ground coal, is novel. Recommendations regarding the test work required to validate the flowsheet are identified in Section 11

5.1 Assumptions

For the plant description and scope of works outlined above, a number of assumptions have been made to arrive at the final selected concept. Table 5-1 provides a list of the major assumptions and the impact on the design. Testing of these assumptions will be required in future stages of the study to confirm or modify the design as required. Section 11 provides more details regarding the expected future test work requirements.

Table 5-1 Design and concept development assumptions

Assumption	Design/ Concept Impact	Testing required to confirm
Feed quality size independent – all feed processed	<ul style="list-style-type: none"> Pre-sizing requirements Screening requirements Feed handling system (conveyors) 	<ul style="list-style-type: none"> Size/ash analysis of feed Coal Grain Analysis (CGA)
Liberation of carbon requires grinding to 100% passing 50 micron	<ul style="list-style-type: none"> Grinding technology and power requirement Downstream processing technology and size (flotation thickening, dewatering) 	<ul style="list-style-type: none"> Size/ash analysis Coal Grain Analysis (CGA) Grinding characteristics testing
Deep froth and high wash water required for low ash product	<ul style="list-style-type: none"> Flotation technology 	<ul style="list-style-type: none"> Flotation testing (tree flotation)
2 stage flotation required to reach required product ash	<ul style="list-style-type: none"> Flotation plant layout and size Power and consumables requirement 	<ul style="list-style-type: none"> Flotation testing (tree flotation)
24 hour product storage	<ul style="list-style-type: none"> Product slurry storage tank size and number 	None. Client specification.

5.2 First Stage Size Reduction

Based on the feed coal size distribution and the possible reduction ratios of conventional size reduction equipment, two stage size reduction was deemed necessary. The recommended equipment for this application is to use a hammer mill as primary size reduction, followed by a ball mill to reduce the top size of the grinding mill feed material to an 80% passing size (P_{80}) of 93 μm .

Hammer mills are proven technology which can produce the required primary size reduction down to a P_{80} of 13 mm at the required throughput with suppliers confirming that capability. A typical hammer mill is shown in Figure 4-1. Fines generation which is typically of concern in a coal washing plant are not an issue here and are encouraged to assist the grinding circuit.



Figure 5-1 Typical hammer mill installation

5.3 Secondary Size Reduction

The hammer mill product top size is suited to a ball mill for secondary size reduction. Ball mills are a common method of impact grinding and have proven capability of producing the required discharge particle size distribution. A typical ball mill is show in Figure 5-2.



Figure 5-2 Typical Ball Mill Installation

5.4 Primary Grinding Classification

The ball mill will be required to operate in closed circuit with classifying cyclones. The cyclones are used for size separation and to ensure no oversize material is fed through to the regrind mill.

The ball mill product is pumped to the ball mill grinding cyclones. The cyclones will separate the coal slurry based on particle size at a cut-point of 93 μ m (D80). Undersize material will continue on to the regrind mill, while oversize material will be directed back to the ball mill feed for further size reduction.

5.5 Fine Grinding

The regrind mill will provide the final stage of size reduction, to the desired P100 of 50 μ m for ash flotation. Stirred mills are a method of wet grinding that are proven to be highly efficient when very fine grinds are required. For this application, a VXPmill will be suitable for achieving the desired level of grinding at the specified throughput. This mill is a medium intensity mill running at higher speed than a Vertimill but lower speeds than and IsaMill. A typical VXPmill is shown in Figure 5-3.



Figure 5-3 Typical VXPmill Installation

The selection of the most suitable fine grinding technology will depend on a number of factors/requirements including:

Required product size

For a given feed size, as the required product sizing gets finer, the energy requirements increase, with some technologies being more suited to ultrafine grinding than others. For the 50 μ m product size requirement for this project, Rod mills will not be suitable as they have difficulty generating product less than 1000 μ m. Further, Rod mills require in excess of 30% more power than ball mills performing the same duty. Suitable technologies for this product size include tube mills, stirred mills and tower mills.

Feed sizing

Different milling technologies have different maximum feed sizes that they can handle, depending on the required product size. Some tower mills require very fine feed size (1 mm or less) which typically would require multiple additional crushing and grinding stages to prepare the feed, adding to circuit complexity and maintenance requirements and capital cost.

Grinding efficiency

The amount of energy required to reduce particle size increases as the particle size decreases. The energy requirement to attain the desired PSD can vary depending on the method of

grinding employed and ultimately the grinding efficiency. Two common methods are impact (e.g. Ball mill, Tube mill, SAG mill) and attrition (tower or stirred mills). Typically, impact mills are less efficient for very fine grinding as energy is lost through media impact, noise and the energy required to rotate the shell to lift the media compared to slower moving attrition mills.

Other factors that impact on grinding efficiency include: slurry flow rate, slurry density, and slurry rheology all of which can be controlled to a certain extent.

Operating Costs

Energy is by far the most significant operating cost of any mill, however, other items also contribute to the ongoing operating costs, including wear liners and grinding media. Typically, attrition mills will have reduced wear on liners as they don't operate by impact of media on the ore. The mill operating speed will impact the liner and media wear rate as well as its grinding efficiency and is dependant on the technology selected. Test work will show which technology provides the optimal balance for this application.

5.6 Fine Grinding Classification

For this application, the VXP mill will operate in an open circuit with classifying cyclones. Classifying cyclones are used for size separation to ensure limited oversize material is fed through to the flotation circuit. While this is not catastrophic, it will likely impact on the final ash content.

Ball mill cyclone cluster overflow is pumped to the fine grinding cyclones. These cyclones separate the material based on particle size at a cut-point of 32 μ m (D95). Undersize material continues to the flotation circuit, while oversize material is recycled to the VXPmill for a final stage of grinding.

Whether the fine grinding cyclone must operate in closed or open circuit with the fine grinding mill is dependent on the technology selected and must be considered in any further technology trade-off.

5.7 Ash Removal

The most efficient method for ash removal from the feed material will be dependent on the optimal size requirement. For the purposes of this study, it is assumed that the feed material will need to be reduced to a liberation size that would require flotation as the only feasible conventional processing method.

Operation of the flotation cells have a number of variables that can be adjusted to obtain the required product quality. These include; reagent dosage, froth depth and wash water rate. There are a number of different flotation technologies available which have different energy and reagent input requirements. Regardless of the technology chosen, flotation of such fine coal to such a low concentrate ash will have the following issues which must be addressed/ determined.

Froth carrying capacity

Carrying capacity is the rate at which material can be removed from the cell (t/h/m² cell area). Ultrafine coal typically has a very low carrying capacity compared to 'standard' coal flotation (at most half the value). This will invariably lead to larger numbers of cells to process the material.

Froth washing

To achieve the low concentrate ash, froth washing will be required. High ash slimes will invariably be present in the concentrate with such a fine feed after being liberated in the grinding circuit as it is carried with water into the froth. The best method of removing this

material is to wash the froth with clean water. This involves running the cell with a relatively deep froth of 1-1.5 m (3 to 5 ft).

Multiple stages

Even with froth washing, it will be necessary to have multiple stages of flotation to achieve the ultra-low ash. This will be a cleaner stage which would re-float the concentrate from the first stage (roughers) to allow additional ash removal. The requirement for this would depend on the quality of the feed. A low ash fine feed may not require a second cleaning stage.

Note that if a relatively coarse sizing (e.g. 250-500 micron) is possible to achieve the required ash content, then cheaper processing technologies e.g. spirals, reflux classifiers, could be employed. These technologies do not require any additional reagents and typically require less circulating water volumes and pumping requirements, resulting in operating cost savings.

Items to be confirmed

Liberation analysis to determine ideal size to achieve required ash removal

Coal grain analysis (CGA)

Flotation test work to determine:

- Flotation behaviour of ultrafine feed material
- Optimal flotation technology
- Optimal flotation circuit to achieve required performance (ash and yield) e.g. Rougher-cleaner, rougher-scavenger, rougher-cleaner-scavenger
- Reagent dosage required
- Carrying capacity
- Wash water requirements
- Froth depth requirements.

5.8 Dewatering

The use of flotation as the main processing technology for this material results in a slurry product of relatively low solids concentration (approx. 12% w/w). The final slurry solids concentration required is 55 % w/w. Therefore, dewatering of the flotation product is required to reach the final slurry concentration.

The philosophy to dewater the MRC product to a higher solids concentration than required in the final slurry to allow a controlled addition of water (and dispersant) to be added back in so that the target solids concentration can be obtained.

Fortunately, due to the low ash nature of the product (and, given the relatively good quality feed to the system, medium level ash of the tailings), dewatering behaviour of the material will not be impacted by excessive slimes or clays which are detrimental to dewatering performance.

However, given the ultrafine size of the material in the plant, dewatering will still require a relatively high intensity process to achieve the required moisture.

At this size, the most common dewatering methods are plate and frame filters, belt press filters, screen bowl centrifuges and solid bowl centrifuges. Table 5-2 gives a high level comparison of these technologies for ultrafine dewatering. Note that items such as flocculant dosage and footprint will be heavily dependent on test work which will indicate specific capacity of the equipment (t/h/m², t/h/m etc.).

Table 5-2 Dewatering Technology Comparison

Assessment Criteria*								
Technology	Product Moisture	Fines Loss	Flocculant Dosage	Continuous Production	Footprint	Maintenance	Circuit Complexity	Total
Solid bowl Centrifuge	3	3	3	1	1	1	1	13
Screen bowl Centrifuge	2	4	2	1	1	2	2	14
Plate and Frame	1	1	1	4	1	4	4	16
Belt Press Filter	4	2	4	1	4	3	3	21

*1 = best, 4 = worst

Based on the above table, solid bowl centrifuges are the most favourable technology without further test work. A typical solid bowl centrifuge is shown in Figure 5-4.



Figure 5-4 Typical Solidbowl Centrifuge Installation

All these technologies will require some form of pre-thickening of the feed to help improve dewatering efficiency and minimise the size of equipment required. Therefore, a high rate thickener will be installed prior to the selected dewatering equipment. A typical thickener installation is shown in Figure 5-5.



Figure 5-5 Typical Thickener Installation

Items to be confirmed

- Thickener (and flocculant) test work for thickener sizing. This will require assessing the impact of flocculant addition on any downstream dispersant to be used for slurry preparation
- Dewatering test work to assess the different technologies.

5.9 Slurry Preparation

As discussed in Section 5.8, the product material will be dewatered to reach the required slurry solids concentration. It is likely that a dispersant will also be required to be added to the slurry to keep the solids in suspension for extended periods before usage.

Product material will be discharged from the solidbowl centrifuges to a product transfer conveyor, which in turn will deposit the material into the product slurry agitation tank. Product slurry will then be pumped into one of two product storage tanks.

Once the slurry mixture has been created, moving this material to long term storage will require pumping, however, the high solids concentration of this material make the use of conventional centrifugal pumps unlikely to be viable. A progressive cavity or positive displacement pumping technology will likely be required. Viscosity testing of the final slurry material will be required to determine the best pumping technology for this material.

5.10 Tailings Handling

Sedgman considered alternate commercial and non-monetary disposal methods for the tailings of the beneficiation process. One option was to dry the tailings, mix it with a binder (starch) and create briquettes. These briquettes could be marketed as a fuel source for a coal-fired power station or metallurgical smelting operation however would be a lesser quality product compared with raw coal. As this additional processing would add to the plant capital and operating cost it is not likely to be more feasible than a conventional wet disposal method. An alternate use could be to use the tailings slurry as a fuel for slurry-based gasification generating power or chemicals however no investigation of this option was undertaken. For the purposes of the study a conventional wet tailings disposal method was assumed with the tailings being thickener to a high weight percent solids slurry using a high rate thickener then the underflow slurry pumped to a tailings impoundment facility. Water could be decanted from this facility and recovered for use in the processing facility. The impoundment facility is to be supplied by others.

5.11 Flowsheet Selection

The final flowsheet selected for this concept study consists of:

- Hammer mill first stage size reduction
- Ball mill second stage size reduction
- Vertimill (tower mill) fine grinding.
- 2 stage (rougher/ cleaner) flotation
- Hi-rate thickeners for both product and tailings
- Solid bowl centrifuge dewatering of product.
- Baffled and agitated tanks for product slurry storage.

A flowsheet with typical expected flows for the selected circuit is given in Appendix A. This flowsheet is considered the most robust as it allows for full grinding of the plant feed and has a broad range of suitable of feed coal quality.

6 Plant Description

Based on the discussion in Section 4, the new facility will be as generally outlined in the layout drawings attached in Appendix B and as described as follows. An elevation views of the overall plant is shown in Figure 6-1 and Figure 6-2.




Figure 6-1 Overall plant view from the feed end.




Figure 6-2 Overall plant view from the thickener side.

6.1 General

The MRC Facilities are designed to achieve the following objectives:

- Receive and process –80 mm coal feed material at a nominal rate of 100 t/h (design = 110 t/h)
- To transfer thickener tailings at a maximum rate of up to 58 t/h
- To transfer dewatered MRC product into mixing and agitation tanks to produce a stable high solids content slurry
- To transfer and store MRC slurry material for downstream use.

A simplified process block diagram of the CPP is shown in the following Figure 6-3.




Figure 6-3 Simplified Process Block Diagram

6.2 Feed Coal Receival and Handling

Reference Material:

- Site Layout (Appendix B)
- Equipment List (Appendix C).

The feed coal receival and handling arrangement is presented in Figure 6-4.




Figure 6-4 Raw Coal Handling Diagram

6.2.1 Dump Hopper & Surge Bin

The feed coal will be loaded from the feed coal stockpile into the dump hopper by a front-end loader (FEL). Material in the hopper will be drawn out of the hopper by a belt feeder and transferred to the Hammer mill.

A typical dump hopper arrangement with FEL feed is shown in Figure 6-5.




Figure 6-5 Typical dump hopper arrangement with FEL feed

The belt feeder will regulate the feed rate to the process plant. The feed rate will be set from the control room by the plant operator.

Discharge from the belt feeder will be directed to the hammer mill, which will provide the first stage of crushing the raw coal. The hammer mill product will discharge onto the 100 t/h surge bin feed conveyor.

The surge bin feed conveyor will deliver the raw coal to the surge bin. The surge bin will have a 100 t capacity, which will allow for approximately 1 hour of continued operations if the hammer mill is not operating.

The surge bin will discharge onto the ball mill feed conveyor. weigh scale will be located on this conveyor and used to control the feed rate of the belt feeder. This conveyor will deliver the material to the ball mill feed box.

6.2.2 Ball Mill Station

The ball mill feed conveyor will discharge into the ball mill. Discharge from the ball mill will be collected in the ball mill cyclones feed sump.

Material will be pumped from the ball mill cyclones feed sump to the ball mill cyclones cluster. The cyclones will cut the material at 93 μm (D_{80}) and direct oversize material back to the ball mill for further size reduction. Undersize material will report to the grinding cyclones feed sump in the process plant.

The simplified circuit configuration is shown in Figure 6-6




Figure 6-6 Ball Mill Grinding Circuit

6.3 Process Plant

Reference Material:

- Nominal Flowsheet (Appendix A)
- Plant Layout (Appendix B)
- Equipment List (Appendix C).

6.3.1 Process Plant Buildings

The processing facility will consist of a number of fully enclosed buildings to provide protection for the equipment from the expected cold weather during winter months.

An overhead crane will be installed within the buildings to provide maintenance access to the equipment within the buildings, and a crane bay for ground access.

6.3.2 Grinding Cyclones

Undersize material from the ball mill cyclones discharges into the grinding cyclones feed sump, where the raw coal is mixed with dilution water to create slurry and then pumped to the grinding cyclone cluster. Grinding cyclone overflow (undersize material) will gravitate to the rougher flotation feed sump for further processing. Cyclone underflow (oversize) will report to the grinding mill feed sump to undergo secondary grinding.

6.3.3 Grinding

The grinding circuit will be a standard open circuit grinding facility.

Oversize material from the grinding cyclone underflow is diluted with water and subsequently pumped to the grinding mill. The grinding mill will produce solids with a top size of 50 μm and the product will gravitate to the rougher flotation feed sump.

The simplified circuit configuration is shown in Figure 6-7.




Figure 6-7 Simplified Grinding Mill Circuit Diagram

The conceptual grinding plant layout (overhead and side) is shown in Figure 6-8 and Figure 6-9




Figure 6-8 Grinding Plant Overhead View




Figure 6-9 Grinding Plant Side View (outer building not shown)

6.3.4 Flotation Circuit

Grinding mill product and grinding cyclone overflow are fed to the rougher flotation feed sump, where they are combined with rougher flotation recirculated tailings and solid bowl effluent. The slurry is then fed to the rougher flotation cell. Collector (chemical used to assist flotation), typically diesel, is added to the cyclone overflow collector to provide time for mixing of the collector onto the coal particles prior to reaching the flotation cells. Rougher flotation product will gravitate to the cleaner flotation feed sump for further flotation treatment. Rougher flotation tailings will report to a splitter box, which will split the tailings between a feed to the tailings thickener and a recirculation stream back to the rougher flotation sump.

Product from the rougher flotation cell will be pumped to the cleaner flotation cell. Cleaner flotation product will then report to the product thickener feed box which will discharge into the product thickener. Cleaner flotation tailings will report to a splitter box, which will split the tailings between a feed to the tailings thickener and a recirculation stream back to the cleaner flotation sump.

Flotation reagents will be stored in and distributed from a bunded storage area located remote from the plant. This facility will include one collector storage tank and one frother storage tank.

The collector will be dosed directly into the flotation cell feed by a collector dosing pump (fitted with a variable speed drive) located in the reagent storage area.

The frother will be dosed directly into the flotation cell feed pump suction by a frother dosing pump (fitted with a variable speed drive) located in the reagent storage area.

The simplified circuit configuration is shown in Figure 6-10.




Figure 6-10 Simplified Flotation and Dewatering Circuit Diagram

A conceptual flotation plant layout (overhead and side) is shown in Figure 6-11 and Figure 6-12.




Figure 6-11 Flotation Plant Overhead View




Figure 6-12 Flotation Plant Side View

6.3.5 Dewatering

The froth concentrate from the cleaner cells will gravitate to the product thickener de-aeration tank and then into the centre well of the thickener. Flocculant is added to the coal thickener feed launder to assist settling of the solids. The flocculant will be provided from a powder-based flocculant preparation plant which prepares and doses anionic flocculant to the coal thickener.

Thickened solids from the product thickener underflow will be pumped to the product solid bowl feed sump, with each centrifuge individually pump fed to ensure a controlled feed.

Dewatered product is discharged onto a transfer conveyor which delivers the product into agitation tanks where it is subsequently pumped to the product storage tanks. Overflow from the product thickener is used as clarified water for the plant. Effluent from the solid bowls is recycled back to flotation feed. This maximises the recycling of frother contaminated water in the flotation circuit and avoids transfer of this water into other areas of the plant.

The tailings from both the rougher and cleaner flotation cells will gravitate to the tailings thickener de-aeration tank and then into the centre well of the high rate thickener. Flocculant is added to the tailings thickener feed launder to assist settling of the solids prior. The flocculant will be provided from a powder-based flocculant preparation plant which prepares and doses anionic flocculant to the coal thickener. Thickened solids from the tailings thickener underflow will be pumped to the tailings impoundment area.

If required, flocculant can also be added into the centrifuge feed stream to assist with dewatering of the product and tailings.

A conceptual dewatering and slurry preparation plant layout (overhead and side) is shown in Figure 6-13 and Figure 6-14.




Figure 6-13 Dewatering/ Slurry Prep Plant Overhead View




Figure 6-14 Dewatering/ Slurry Prep Plant Side View

6.3.6 Product Slurry Preparation

Dewatered product coal discharges from the product transfer conveyor into the product slurry agitation tank. A weigh scale located on the transfer conveyor will record instantaneous product rate to enable accurate metering of water and dispersant for slurry preparation. Agitated slurry is subsequently pumped into one of two (2) product storage tanks. Each storage tank is equipped with a discharge pump, the discharge of which is the battery limit of the beneficiation plant. It is assumed that these pumps with discharge in batch operation to the DICE plant.

6.4 Sampling and Quality Control

6.4.1 Plant Feed

A cross belt sampler will be located on the plant feed conveyor. This sampler will be used primarily for audit purposes. Primary sample increments discharged from the sampler will be directed by chute work to a collection drum.

6.4.2 Product Coal

A microwave type moisture analyser on the product transfer conveyor will provide the real-time moisture of the coal product allowing the determination of water and reagent addition requirements. Final product can be manually sampled from the discharge of the product mixing tank pump.

6.4.3 Tailings

Final tailings can be manually sampled from the discharge of tailings thickener underflow pump.

6.5 Water Services

6.5.1 Fire, Washdown & Dust Suppression Systems

A combined fire, washdown and dust suppression reticulation system will be provided around the plant. Water for this system will be held in fire water storage tanks which will be fed from the raw water supply.

6.5.2 Fire Protection System

The fire protection system for the plant will be based on the philosophy of early fire detection, emergency warning and taking a pro-active response to an emergency fire situation.

The fire protection system will consist of the following:

- Materials handling wash down, fire water and dust suppression pipeline servicing the plant and materials handling facilities
- Fire hydrants appropriately spaced around the materials handling buildings and plant facilities according to relevant Standards, Statutory and Local Authority requirements. Make and model of fire hydrant to be standardised across the site.
- Standard 0.75 inch diameter x 118 ft long hose reels along conveyor gantries spaced at 100 ft intervals on alternate sides of conveyors
- Standard 0.75 inch diameter x 118 ft long hose reels throughout the plant facilities according to relevant Standards, Statutory and Local Authority requirements
- Portable fire extinguishers consisting of dry chemical powder, carbon dioxide and wet chemical types installed in designated areas of the site as per relevant Standards, Statutory and Local Authority requirements
- Manual call points will be located at exits from switch rooms being connected to a fire indication panel (FIP)
- Sub-fire indicator panels with automatic detection and alarm system for fault detection in the plant switch room.

6.5.3 Fire Protection System Design Criteria

For the purposes of this concept study, the Fire Protection System will comply with the relevant standards of the International Building Code, International Fire Code, and National Fire Protection Association to the extent such reference is applicable to the facility.

6.5.4 Washdown Water

Washdown water will be provided at all stations and bins.

All washdown water will be supplied from the raw water tie-in point.

Washdown water will generally be provided through 1 inch hoses in all stations and bins. Additional couplings and ball valves will be provided at other locations as necessary.

Pressure requirements for washdown system will be as specified by Sedgman.

6.5.5 Dust Suppression

Dust suppression sprays will be provided at appropriate transfer points in the raw coal handling system including the receival bin. Based on best industry practice, the flow rates at the transfer points will be 0.05 % of the transfer capacity.

6.5.6 Gland Water System

A gland water tank will be provided to supply water for pump gland seal and flocculant make-up. This tank will be fed from the raw water supply.

6.6 Air Services

Compressed air will pass through a drier prior to being reticulated around the plant for use as plant and instrument air.

6.7 Reagents

The reagents required to operate the flotation cell (diesel and MIBC) and for slurry preparation (dispersant) will be provided and stored in a purpose built facility (fuel farm). The fuel farm will consist of one storage tank for each of the reagents located in a fully bunded area. Pumps and piping to transport the reagents from the storage tanks to the flotation and slurry preparation circuits will be supplied.

6.8 Electrical Description

The electrical design, installation and equipment will conform to American Standards (ANSI, NE, NFPA, NEMA, UL, IEEE etc.) with the inclusion of State specific requirements.

All electrics, instrumentation and controls will be provided to service the MRC processing facility.

The control circuit design will hardwire the essential personnel and equipment safety devices in failsafe mode for enhanced security.

A local control station (LCS) with start and stop pushbuttons and lockable isolator will be provided for each motor. These LCSs will be in the vicinity of the equipment, readily accessible and clearly marked.

Lighting and general purpose power will be provided to service the MRC processing facility.

A modern control system will be provided to control and monitor the MRC. Plant control and monitoring will be implemented using a Programmable Logic Controller (PLC).

The operator interface system will communicate with the PLC to allow control and monitoring of all items of plant and equipment from a central point. The operator interface system will use a SCADA package specifically configured for the plant.

6.8.1 Power Reticulation

Power will be provided by others at 13.8 kV AC at specified locations and will be reticulated from these supply points to the processing plant.

Within corresponding areas of the plant, motors and loads will be powered from central MCCs (Motor Control Centres) and switchgear. The voltage of the MCCs and switchgear will either be 480 VAC, 4,160 VAC or 13.8 kV AC. Electrical MCCs and switchgear are to be located within electrical rooms in various locations across the site. The distribution of the electrical system is designed to manage fault current, where possible.

The protection system, circuit breakers/fuses and relays for the power distribution system, contained within the infrastructure scope, will be designed to ensure protection system grading is maintained throughout the site installation. The settings and grading of the protection system will be determined during the detailed design phase.

6.8.2 Electrical Switchrooms

The MRC and area switchrooms include a 13.8 kV/480 V transformer bay and a transportable switch room building to house the Motor Control Centre(s) Switchboard. The electrical rooms will generally be supported approximately 1.8 m (6 ft) above ground level by a steel frame structure. Air conditioning unit(s) would be provided to maintain the internal temperature within the electrical rooms. In general, the electrical rooms will be provided with two doors, one double door for equipment access and another single door for personnel access.

Transformers will be installed on concrete plinths situated centrally within a bunded and fenced area near the corresponding electrical room. Mineral oil filled transformers have been considered. Low voltage (480 VAC) delta-wye transformers are considered to be solidly grounded while medium voltage (4,160 VAC) delta-wye transformers are utilizing neutral grounded resistance. Large motors will be operated on 4,160 VAC depending on their size and power system.

Grounding will be provided around all switchrooms and steel structures and will be bonded back to the main 13.8 kV supply ground.

7 Scope of Works

The following scope of works and battery limits have been assumed as the basis for the study and identify the commencement and termination points for the extent of works to be completed. They are based on the selected flowsheet as described in section 6.

7.1 Earthworks

Assumptions

Sedgman has assumed for the purpose of this study phase and information available at the time that a suitable flat pad is provided by others. No allowance for clearing, grubbing and re-grading the existing ground profile, the excavation and installation of subgrade/pavement materials for plant, equipment and buildings foundations, stockpile pads and vehicle access roads has been allowed for in this study phase.

Once a location is defined, in later stages of the project, Sedgman will incorporate suitable earthworks scope into the capital estimate aligned with the final MRC plant footprint requirements.

Exclusions

All Earthworks outside of the Scope of Works, including but not limited to:

- Site administration offices and laboratory facilities
- Plant change rooms
- Maintenance workshops.

7.2 Civil Concrete

It is assumed that the site will be cleared and a suitable pad with a bearing capacity of 200 kPa or greater will be prepared by Others. All bulk earthworks, excavation in rock, and removal/replacement of unsuitable soil material is excluded.

Detailed excavation for plant foundations and final backfill and trim to as-received condition is assumed to be performed in this scope. Battery limits are the underside of concrete for the following structures:

- Crushing
- Grinding Station
- Flotation facility
- Product and tailings thickeners
- Dewatering and slurry preparation facility
- Product storage tanks
- Motor Control Centres (MCCs) throughout the site (number TBC)
- Control room.

7.3 Structural/Mechanical

It is assumed Sedgman shall provide all necessary structures, chutework and equipment required to process feed material through the processing plant.

Inclusions

Concentrator Area:

- Processing plant process platework (sumps, tanks, boxes, collectors)
- Processing plant process equipment (mills, pumps, cyclones, flotation cells, thickeners, centrifuges, agitators, samplers)
- Processing plant structures, including equipment support structures and enclosure sheds
- Feed Coal receival hopper
- Conveyors, transfer stations and chutework
- Control room/ crib room building.

Exclusions

- Any structural/ mechanical item not listed above in the inclusions
- Distribution system (pumps and pipework) out of long term slurry storage tanks
- Supply and placement of raw coal material onto the raw coal stockpile
- Any item associated with areas on the site not associated with the processing plant or materials handling facility including but not limited to:
 - Workshops
 - Administration office facilities
 - Laboratory.

7.4 Process Piping

It is assumed Sedgman shall provide all piping required to process plant feed through the processing plant. Services (fire/ water/ air) battery limits are listed in other sections of this document.

Battery Limits

Discharge into product slurry storage tanks.

7.5 Electrical Battery

Battery Limits

It is assumed Sedgman shall provide all electrical and instrumentation/control works required to feed and operate the plant up to the mechanical battery limits stated. Battery limits are:

- Outgoing terminals of 13.8 kV supply point.

Inclusions

- 13.8 kV reticulation to MRC processing
- Distribution substations
- Switchrooms
- Motor control centres
- Field electrical and Instrumentation installation
- Cable support and protection systems.

Exclusions

- Nil within battery limits.

7.6 Communications and Data Management

It is assumed Sedgman shall interconnect the plant's new switchrooms' and control room's control, fire protection, and CCTV systems as required to produce an operating system.

Inclusions

- Fibre optic reticulation
- Control and communications hardware
- CCTV hardware and software where required
- Network cabling reticulation within switchrooms and control room
- Network cabinets
- Control system (PLC) software implementation
- Control room furniture and fitout
- Operator interface (SCADA) software implementation.

Exclusions

- Higher level management systems (e.g. asset management, IT systems, downtime monitoring)
- Telephone handsets
- Radio communications
- Security systems.

7.7 Tailings

Battery Limits

- Discharge of the tailings thickener underflow pump.

Inclusions

- Tailings thickener underflow pump.

Exclusions

- Pipeline from beneficiation plant to tailings disposal facility
- Disposal facility for tailings.
- Decant water recovery from tailings facility.

7.8 Water

Raw/ Washdown / Dust suppression

Raw water, to be used for clarified, gland and fire water make-up, washdown and dust suppression will be supplied by Others at a nominated point for the required flow and pressure.

Inclusions

- All reticulation from the tie in point to supply points of the make-up, washdown and dust suppression systems throughout the processing plant and materials handling facilities.

Exclusions

- Any pumps or piping system to supply water to the tie-in point at the nominated flows and pressures required.
- Reticulation to any areas not associated with the processing plant or associated material handling facilities (e.g. Workshops, administration offices).

7.9 Compressed Air

It is assumed Sedgman shall provide all compressed air required to process plant feed through the processing plant and materials handling facilities.

Inclusions

Compressors, air dryers, reticulation within processing plant and materials handling facilities.

Exclusions

Compressed air supply in any workshop, mining area or office facilities.

7.10 Sewage

Sewage system supply and reticulation is to be provided by the Client.

8 Capital Cost Estimate

8.1 Capital Estimate

Capital cost concept level ($\pm 30\%$) summary is provided in Table 8-1. Overall pricing is provided in USD based on >85% USD prices with 8.8% of the balance being in Chinese Yuan Renminbi (CNY) as Chinese steel fabrication has been assumed. The estimate validity is December 2019.

Table 8-1 Capital cost summary (USD)

Process Plant Area	Total (USD)
Direct Costs	
ROM Coal and Crushing	\$4,648,000
Grinding	\$16,159,000
Flotation	\$4,050,000
Product De-Watering	\$4,705,000
Product Slurry Storage	\$2,838,000
Tailings De-Watering	\$1,997,000
Process Plant Services	\$5,015,000
Reagents	\$368,000
Direct Costs Total	\$39,780,000
Engineering Allowances	
Design and Project Management	\$9,170,000
Warranty	\$398,000
Engineering Allowances Total	\$9,568,000
Commercial Allowances	
Contingency	\$4,935,000
Contractor's Margin	\$8,019,000
Commercial Allowances Total	\$12,954,000
TOTAL	\$62,302,000

A breakdown of the major components of the direct costs is provided in Table 8-2.

Table 8-2 Categories of direct costs

Direct Cost Type	Total (USD)
Equipment Procurement	\$12,708,000
Material Procurement	\$11,392,000
Delivery	\$2,182,000
Direct Labor	\$13,489,000

The vendor supplied mechanical equipment procurement costs have been provided by area in Table 8-3. Note that this excludes fabricated items.

Table 8-3 Mechanical equipment direct procurement costs by area

Plant Area	Total (USD)
ROM Coal and Crushing	\$ 716,000
Grinding	\$ 4,875,000
Flotation	\$ 351,000
Product De-Watering	\$ 1,669,000
Product Slurry Storage	\$ 640,000
Tailings De-Watering	\$ 328,000
Process Plant Services	\$ 782,000
Reagents	\$ 182,000

8.2 Estimate Qualifications and Exclusions

The cost estimates presented herein are based on the following qualifications:

- Interconnection between services has been based on battery limits described within
- Cost estimate pricing has been based on total project execution
- No allowances have been made for third party testing or any performance testing.

The following exclusions apply to the estimate presented herein:

- Escalation has been excluded from the current estimate
- The Principal's project management costs and other owner's costs, including but not limited to:
 - All past and future study costs
 - All financing and legal provisions
 - Project approval and permitting costs
- Sales tax and any relevant duties and other taxes
- Capitalised spare parts
- Allowances for any lost time for example relating to industrial relations issues and unseasonable inclement weather
- Supply of power and water for construction
- Building and environmental approvals
- Cultural heritage matters.

8.3 Basis of Estimate

The capital cost estimate is reflective of the facility fully designed, supplied, fabricated and delivered to site, constructed and commissioned in accordance with the scope of work detailed within this report.

At this initial study phase Sedgman have utilised previous information for procurement, fabrication and installation pricing and rates typically. This will be validated in future study phases to align with the selected site location.

8.3.1 Direct Costs

Sedgman estimating procedures are based on quantity take-offs and construction rates. The Sedgman in-house estimating database for the development, design and construction of coal handling and preparation plants and associated mine infrastructure is comprehensive and is continuously being updated.

The basis for the determination of capital costs is summarised as follows.

8.3.2 Material Rates

The estimate was based on unit rates from recent supply contracts for fabricated supply of light, medium and heavy duty steel and platework against nominal quantities similar to this project. For the purpose of this estimate the rates applied to these items have assumed offshore low cost centre fabrication with shipping costs to the site.

Installation hours for equipment was based on the database of historical information for similar work. Each of the following commodities used common project specific supply and installation unit rates:

- Concrete
- Structural steel, plate work and pipework
- Installation of process and materials handling equipment.

Labour Rate

Labour rates were built into gang rates for mechanical, civil and electrical trades. These gang rates were based on of rates used for recent Sedgman U.S.A. projects.

The labour rates applied included supervision, cranes, plant and equipment costed against nominal durations.

Equipment Pricing

The study typically used historical equipment pricing that was deemed as less than 12 months old. Where equipment pricing was sought from the market place the level of accuracy of the pricing received was deemed within the levels of concept study.

Material Quantities

As part of the design developed for the study the bulk material quantities for concrete, structural steel, pipework and platework, were calculated using sketches, preliminary layout drawings, and previous project drawings or by calculation. For plant components similar in design and layout to previous projects, final design take-off (FDT) quantities from the previous project were used.

Delivery

The capital cost estimates include delivery of all items and materials to site. The delivery costs are based logistics costs applied to recent U.S.A jobs.

8.3.3 Project Cost

In addition to the direct costs the estimates include allowances for the following project costs:

- The electrical and instrumentation estimate was developed from a percentage of direct costs based on Sedgman study guidelines
- Engineering, procurement and construction management costs. The engineering costs and allowances for the project were developed from a percentage of direct costs using previously completed projects experience, considering total equipment count and project duration.
- Contractor's profit and an overhead recovery fee were each applied as a percentage against the direct costs and direct allowances.

The total cost reflects the price the Principal could expect to pay a competent engineering contractor to design and construct the options as outlined in this study. The estimate does not include any owners costs.

9 Operating Cost Estimate

An indicative operating cost estimate for the facility described in this study report has been developed to an accuracy of $\pm 30\%$. The costs are primarily presented in terms of Dry Feed Tonnes (DFT), with the operating cost summary table, Table 9-1, also showing the comparative cost in terms of Product Slurry Tonnes (@55% solids w/w).

9.1 Battery Limits

The scope of the operating cost estimate is based on the following battery limits.

- Feedstock coal receival pad within 75 m (82 yards) of the feed coal receival hopper
- Discharge of product slurry storage tank pumps
- Discharge of tailings stockpile thickener underflow pump
- Pipe flange of raw water supply line adjacent to plant
- Power supply point at the local 11 kV switchboard.

9.2 Basis of Estimate

The operating cost estimate has been based on the following assumptions and inclusions. It is assumed that the plant will be owner operated.

9.2.1 Labour

Operating labour including management, operating and maintenance labour as defined in Table 9-1. Operating crews are assumed to be engaged on an even time roster, e.g. 4 on/4 off, to provide 24/7 production coverage.

Contract labour as required for maintenance is included in the maintenance costs.

Table 9-1 Operating Labour Assumptions

Labour Costs	No. of Employees			Cost per Employee			
	No. per Shift	No. of Shifts	Total	Unit	Base Annual	On-costs 25%	Total Cost
Operations Superintendent	1	1	1	US\$/a	137,989	170,444	170,444
Production General Supervisor	1	2	2	US\$/a	112,624	139,113	278,227
Processing Clerk	2	1	2	US\$/a	36,732	45,372	90,743
Foreman - Shift	1	4	4	US\$/a	93,437	115,413	461,652
Control Room Operator	1	4	4	US\$/a	83,649	103,324	413,294
Loader Operator	1	4	4	US\$/a	70,774	87,420	349,681
Crushing/Grinding Operator	1	4	4	US\$/a	80,060	98,890	395,559
Flotation Operator	1	4	4	US\$/a	80,060	98,890	395,559
Reagents/Services	1	4	4	US\$/a	72,985	90,151	360,603
Laboratory Sampler	1	4	4	US\$/a	57,985	71,623	286,492
Senior Metallurgist	1	1	1	US\$/a	110,883	136,963	136,963
Maintenance General Supervisor	1	1	1	US\$/a	118,846	146,799	146,799
Maintenance Planner – Elec and Mech	1	1	1	US\$/a	101,352	125,190	125,190

Labour Costs	No. of Employees			Cost per Employee			
	No. per Shift	No. of Shifts	Total	Unit	Base Annual	On-costs 25%	Total Cost
Tradespersons (Mech/Elec/Instr)	3	1	3	US\$/a	70,469	87,043	261,129
Trade's Assistants	2	1	2	US\$/a	57,809	71,406	142,812
Total			41	US\$/a			4,015,148
						US\$/ROM t	5.43

9.2.2 Consumables

Consumables were based on the usage and cost rates as detailed in Table 9-2.

Table 9-2 Consumables Usage and Cost Rates

Parameter	Value	Unit	Annual	Unit
Throughput			740,000	t/a (ad)
CONSUMPTION				
Comminution				
Hammer Mill hammers	2	sets/a		
Ball Mill Liners, Steel	1	sets/a		
Ball Mill Media, Cast Steel Balls	0.6	kg/ROM t		
Regrind Mill Liners, Steel	1	sets/a		
Regrind Mill Media, Ceramic Beads	0.26	kg/regrind mill feed t		
Process				
Frother (MIBC)	400	g/t	296,000	kg
Collector (Diesel)	500	mL/t	370,000	L
Flocculant (powder)	70	g/t	51,800	kg
Dewatering				
Solid bowl Centrifuge Rotating Assemblies	0.7	sets/a		
COST				
Comminution				
Hammer Mill hammers	\$20,235	US\$/set	\$40,470	US\$/annum
Ball Mill Liners, Steel	\$153,000	US\$/set	\$153,000	US\$/annum
Ball Mill Media, Cast Steel Balls	\$1.07	US\$/kg	\$475,080	US\$/annum
Regrind Mill Liners, Steel	\$14,500	US\$/set	\$14,500	US\$/annum
Regrind Mill Media, Ceramic Beads	\$5.50	US\$/kg	\$1,054,130	US\$/annum
Process				
Frother (MIBC)	\$4.50	US\$/kg	\$1,332,000	US\$/annum
Collector (Diesel)	\$0.80	US\$/L	\$296,000	US\$/annum
Flocculant (powder)	\$3.25	US\$/kg	\$168,350	US\$/annum
Dewatering				
Solid bowl Centrifuge Rotating Assemblies	\$458,900	US\$/set	\$305,933	US\$/annum
TOTAL			\$3,839,463	US\$
			5.19	US\$/ROM t

9.2.3 Maintenance

Maintenance including labour (site labour and contractors) and working spares, based on a factorised maintenance allowance is shown in Table 9-3. Maintenance on mechanical equipment is based on an annual cost factor, which varies by equipment type based on data collected from similar operations. For electrical equipment, a factor of 4.0% was applied to all the electrical capital procurement components, and 20% of the electrical install costs.

Table 9-3 Plant Maintenance Cost Assumptions

Parameter	Value	Unit	Annual	Unit
Throughput			740,000	t/a (ad)
Mechanical Capex	29	US\$M	1,846,174	US\$/a
Electrical Capex	3.8	US\$M		
Electrical Install	2.9	US\$M	174,181	US\$/a
	4.0	%/a		
Total Maintenance Cost			2,020,355	US\$
			2.73	US\$/t

9.2.4 Power

Power costs were based on the estimated demand power as shown in Table 9-4, and a cost charge of US\$0.053 /kWh.

Table 9-4 Plant power costs

Plant Area	Installed Power		Demand Power		Consumed Power		
Hammer Mill	300	kW	240	kW	1,776,000	kWh	
Ball Mill	1,300	kW	800	kW	7,696,000	kWh	
Grinding Mill	3,500	kW	2,800	kW	20,720,000	kWh	
Grinding Cyclones Feed Pumps	55	kW	44	kW	325,600	kWh	
Flotation	360	kW	288	kW	2,131,200	kWh	
Dewatering	661	kW	529	kW	3,913,120	kWh	
Slurry Transfer and Storage	418	kW	333	kW	2,471,600	kWh	
Services/Miscellaneous usage	547	kW	438	kW	3,240,549	kWh	
Totals	7,141	kW	5,713	kW	40,492,149	kWh	
					Power Cost Rate	0.053	US\$/kWh
					Total Power Cost	2,240,526	US\$/a
						3.03	US\$/ROM t

9.2.5 Mobile Equipment

Operation, maintenance and fuel costs for the mobile equipment are detailed in Table 9-5. A single stockpile front end loader has been nominated, and the run hours calculated on the basis that it can operate at 150 t/h loading capacity. Therefore, its total run hours are less than the plant operating hours.

Table 9-5: Mobile Equipment Assumptions

Unit Description	Qty	Operating Hours		Diesel Consumption		Maintenance Costs	
		h/a, each	Total h/a	L/h	L/a	US\$/h	Total US\$
Front End Loader (Cat 966 size)	1	4,933	4,933	15	74,000	\$45.00	\$222,000
Mobile crane (20t)	1	750	750	25	18,750	\$55.00	\$41,250
Skidsteer loader	1	1,200	1,200	8	9,600	\$15.00	\$18,000
Light Forklift	1	1,000	1,000	7	7,000	\$15.00	\$15,000
Integrated Tool Carrier (Cat 938 size)	1	750	750	12	9,000	\$40.00	\$30,000
Totals	5		8,633		118,350		\$326,250
					Fuel Cost (US\$/L)	0.80	
					Fuel Cost (US\$/a)	\$94,680	
					Total Mobile Equipment Cost	\$420,930	US\$/a

Unit Description	Qty	Operating Hours		Diesel Consumption		Maintenance Costs	
		h/a, each	Total h/a	L/h	L/a	US\$/h	Total US\$
						\$0.57	US\$/ ROM t

9.3 Estimate Exclusions

The following are excluded from the operating cost estimate:

- Supply and placement of raw coal material onto the raw coal stockpile
- Mobile equipment capital and ownership costs
- Sustaining capital costs and capital improvement projects
- Critical or strategic spares
- Sampling and analysis
- Water supply costs
- Heating costs. These are heavily dependant on the final plant location.
- Site environmental monitoring and compliance
- Security and fencing
- Third party plant audits
- Research and Development activities and pilot scale test work
- Local, State and Federal Government charges
- Authority charges such as rail and port charges
- Easement and land costs
- Owner's management, overhead and executive costs
- Taxes, royalties, levies and license fees
- Costs of foreign exchange and/or currency hedging
- Escalation.

9.4 Operating Cost Estimate Summary

The operating costs are based on the following criteria and assumptions.

- Operating hours per annum – 7,400 hours
- Annual raw coal feed tonnes (with Flotation) – 740,000 t/a (ad).
- Annual product slurry tonnes – 385,000 t/a @ 55% solids (w/w)

Estimated operating costs for the facility are shown in Table 9-6 at an accuracy of ±30%.

Table 9-6: Plant Operating Cost Estimate

Parameter	Annual Cost	Unit
Feed Throughput	740,000	t/a (ad)
	100	t/h (ad)
Run Hours	7,400	h/a
Total Cost, US\$		
• Labour	4,015,148	US\$/a
• Consumables	3,839,463	US\$/a
• Maintenance	2,020,355	US\$/a

Parameter	Annual Cost	Unit
• Power	2,146,084	US\$/a
• Mobile Equipment	420,930	US\$/a
TOTAL	12,441,981	US\$/a
Total Cost, US\$/dry feed t		
• Labour	5.43	US\$/t
• Consumables	5.19	US\$/t
• Maintenance	2.73	US\$/t
• Power	2.90	US\$/t
• Mobile Equipment	0.57	US\$/t
TOTAL per Dry FEED tonne	16.81	US\$/ROM T
TOTAL per PRODUCT SLURRY tonne	33.63	US\$/slurry t

10 Opportunities

Given the conceptual nature of the proposed flowsheet there are a number of opportunities to investigate possible capital or operating cost savings. These have been summarised below.

10.1 Feed Coal Selection

The selection of a Montana sub-bituminous coal feed results in a relatively low energy value for the final MRC on a LHV basis despite the intensive level of coal processing to remove mineral matter. This is due to the impact of the as received bed moisture content in the coal.

It is recommended that alternative sources of bituminous coal be considered which will result in greatly enhanced slurry energy values on an LHV basis for the same free moisture content (45%) of the slurry.

It is recommended that the next stage of the study include bench-scale tests to generate samples of expected product and reject solids, and the resultant samples then be formally analysed for Ultimate Analysis and CV using a “bomb calorimeter” test to generate confidence in the final estimates of the energy content of the product and reject streams.

10.1.1 Assessment of Energy Content of Bituminous Coal

To demonstrate the impact that substituting a medium volatile bituminous thermal coal for the sub-bituminous Montana coal proposed as feed stock the following assessment was undertaken.

The energy calculations of Section 4.2 were re-worked using a typical medium volatile bituminous thermal coal feed stock from the Hunter Valley in NSW, Australia. This data was used due to the ready availability of comprehensive public domain coal quality data for such coals, but use of Pennsylvania or other US sourced medium volatile thermal coals would result in similar outcomes (subject to sulphur limitations).

An upgraded final micronised product ash of 2% (db) is again assumed, using a similar ultrafine flotation process to the recent study. Again a 55% solids (w/w) coal slurry is assumed.

Note the convention used for bituminous coals is “air dried” or “ad” basis for analysis of the coal when it still contains the inherent moisture within the coal pores and on the coal particle surface when in equilibrium with the laboratory atmosphere. This is the equivalent basis to the “bed” moisture in sub-bituminous coals. A suitable alternative terminology for both is “as analysed”.

Table 10-1 Ultimate Analysis of 2% ash (db) of Bituminous feed versus Sub-bituminous feed

	Bituminous Feed		Sub-bituminous Feed	
	ad	db	ad	db
C	77.2	79.6	53.3	74.5
H	4.8	5.0	3.6	5.0
N	1.8	1.9	0.8	1.1
S	0.6	0.6	0.6	0.8
C	0.03	0.03	0.01	0.01
Ash	1.9	2.0	1.4	2.0
Moisture	3.0	0.0	28.5	0.0
Oxygen	10.6	11.0	11.9	16.6
	100.0	100.0	100.0	100.0

Table 10-1 Ultimate Analysis of 2% ash (db) of Bituminous feed versus Sub-bituminous feedshows a comparison of the Ultimate Analysis of the Bituminous coal compared with the Sub-bituminous coal used for the recent study.

Table 10-2 shows the resultant estimates of energy using the Dulong Equation on both a dry and ad (or “bed” moisture) basis, and both HHV and LHV basis. This shows that the inherent increase in energy level on a dry basis due to the greater degree of coalification of the bituminous coal is further enhanced when allowance is made for the inherent moisture content of the coal on both an HHV and a LHV basis.

Table 10-2 Comparative Energies for Bituminous versus Sub-bituminous Coals

			Bituminous	Sub-bituminous	% change
dry basis	HHV	kcal/kg	7686	7059	109
		kJ/kg	32178	29555	
		Btu/lb	13843	12715	
ad basis	HHV	kcal/kg	7455	5049	148
		kJ/kg	31213	21139	
		Btu/lb	13428	9094	
	LHV	kcal/kg	7191	4702	153
		kJ/kg	30107	19687	
		Btu/lb	12952	8470	

Table 10-3 shows the estimated energy values of both the “as sampled” product coal including inherent moisture, and the 55% solids (w/w) coal slurry.

Table 10-3 Comparative Energies for Bituminous versus Sub-bituminous Coals in slurry form

		Bituminous		Sub-bituminous	
		Prod ar	Slurry ar	Prod ar	Slurry ar
HHV	kcal/kg	7455	4100	5049	2777
	kJ/kg	31213	17167	21139	11627
	Btu/lb	13428	7385	9094	5002
LHV	kcal/kg	7191	3698	4702	2329
	kJ/kg	30107	15481	19687	9750
	Btu/lb	12952	6660	8470	4195

When applied to the estimates of slurry quantities and so original feedstock required for generating 619 Mbtu/hr, Table 10-4 shows the significant reduction in both the volume of slurry fed to the DICE machine as well as the original feed tonnes of feed stock. This assumes the same yield in the flotation process.

Table 10-4 Estimates of Slurry and Feed stock quantities

			Bituminous	Sub-bituminous	% change
slurry	Mbtu/hr	LHV ar	619	619	100
slurry	Btu/lb	LHV ar	6,660	4,195	159
slurry	lb/hr	ar	92,941	147,572	63
prod coal	lb/hr	ad	51,117	81,165	63
PRB feed	lb/hr	ad	107,615	170,873	63
PRB feed	kg/hr	ad	48,805	77,493	63

10.2 Flotation Top Size

Depending on the sensitivity of flotation efficiency to an increase flotation top-size for a given coal there exists a possibility to increase this and enable the coal to be upgraded prior to the final ultra-fine grinding stage.

The flotation process increases in efficiency as the particle size increases due to improved selectivity between low ash and high ash particles. However, as the topsize approaches 0.5 mm or greater, the recovery is impaired as the coarsest, low ash particles are readily dislodged from the bubbles due to turbulence in the froth zone, and report to tailings.

Figure 10-1 shows the results of Limn modelling of increasing topsize to flotation of a naturally low ash feed in a similar two stage rougher / cleaner circuit to that proposed in the study. For simplicity, the washability characteristics of each size fraction are assumed to be identical in this example. It shows both an increase in yield and a corresponding decrease in concentrate ash as the topsize is increased from 38 microns up to a maximum 350 microns.




Figure 10-1 Effect of particle topsize on flotation yield and concentrate ash

This effect for many coals is likely to outweigh any improved liberation at the finer topsizes.

Therefore it is recommended that consideration be given to directing the ball mill product to flotation so that it can be processed at a coarser topsize to allow for a more efficient and cost effective flotation circuit, followed by ultra-fine grinding of the flotation concentrate only. This will have the added benefit of substantially reducing the feed to the ultrafine grinding circuit with resultant savings in Capex and Opex, reduction in wear, and the generation of a lower energy value, easier to handle tailings stream for subsequent dewatering and disposal.

10.3 Pre-scalping low ash feedstock using conventional coal preparation technology

The generation of micronised coal is relatively expensive and is an energy intensive process compared with conventional coal processing technology. A significant reduction in overall size and so cost of the crushing, grinding and beneficiation plant would be achieved by upgrading the feed-stock by scalping off the lowest density, low ash fractions from a suitable mid volatile bituminous thermal coal which naturally contains a high level of low ash, low density material.




Figure 10-2 Notional Flowsheet for Thermal Coal Preparation Plant with pre-scalping of low ash product for each circuit for DICE feedstock

Figure 10-2 shows a notional flowsheet for a conventional DMC/reflux classifier/flotation circuit with a pre-scalping stage for each circuit to produce a low ash product to be used as 50 mm topsize feedstock to the micronized coal plant. The second stage of each circuit is directed to a conventional thermal product.

Table 10-5 shows the results of Limn simulations when processing a Hunter Valley medium volatile bituminous coal which has naturally low ash (raw ash 11.2% ad excluding mining loss and dilution).

Table 10-5 Limn Simulation Results of Scalping / Thermal Coal Preparation Plant

	Stream	% Feed	Ash
Feed Streams	01 Raw Feed	100.0	11.2
	01_02 Prim DMC Feed	82.9	11.2
	01_04 Class Cyclone Feed	17.1	11.6
	05_06 Prim RC Feed	11.7	9.9
	04 05_08 Flotation Feed	5.4	15.2
DICE Feedstock	03 DICE Coarse Product	55.2	4.5
	07 DICE Fine Product	7.3	3.2
	09 DICE Flotation Product	2.9	2.7
	DICE Combined Product	65.4	4.2
Thermal Product	03 Thermal Coarse Product	23.2	18.7
	07 Thermal Fine Product	3.6	10.8
	09 Thermal Flotn Product	0.7	7.5
	Thermal Combined Product	27.5	17.4
Reject Streams	02 Coarse Rejects	4.5	55.4
	06 Fine Rejects	0.8	66.2
	08 Flotation Tailings	1.8	38.1

A combined 50 mm TS product of 4.2% ash ad could be produced at a yield of 65.4% ad plus a secondary thermal product of 17.4% ash ad at 27.5% yield ad for a total yield of 92.8% ad. Typically this yield will drop by approximately 7% due to mining dilution, with negligible effect on the product ashes for the primary DICE streams.

Such a feedstock could then be crushed and ground to ultimately produce a 2% ash (db) micronised product with additional flotation circuits. Flotation tailings from the final micronized coal product circuit is likely to have moderate ash levels (say 15 to 20% ash ad if the target 2% ash concentrate is to be achieved), so may be dewatered and briquetted to produce a useful addition to the thermal product stream. Hence the only waste streams from the original as mined feed will be conventional combined coarse and reject streams from the 50 mm TS preparation plant, with maximum utilisation of overall energy from the resource.

10.4 Technology Selection

The technology selected for the concept flowsheet has been chosen to provide a robust, efficient operation. Other technologies may also be suitable and provide advantages, however, would require test work and/or further information to confirm their suitability. Of note are the following flowsheet items:

- Flotation cells:
 - Sedgman C-Cells, an induced air style flotation cell, have been selected as deep froths with washing are likely required to achieve such low ash products
 - Other flotation technologies may be suitable such as mechanically agitated flotation cells and column flotation cells, however test work is required to determine if they offer any benefits over the Sedgman C-Cell.
- Fine Grinding Mill:
 - The FLSmith VXP Mill selected for the concept flowsheet was based on low capital cost. This is a vertical, high intensity grinding mill.
 - Alternate suitable technologies are available from Outotec (HIG Mill) and Glencore Technology (IsaMill). Outotec declined to quote on account of the lack of test work results in which to design a full scale mill and Glencore used a very high energy requirement which resulted in a high capital cost. If samples of the feed types could be provided to

these three suppliers then it would assist in identifying which technology provides the most economical solution.

10.5 Location

The exact location of the plant has not been defined however based on the Powder River Basin coal geographical origin we have assumed a cold weather, seismic, environment. Therefore, there exists opportunity to realise savings in structure and ancillaries if the plant were to be in a more temperate climate. Cold environment plants require enclosure structures and heating to be installed, as well as insulation/heating of process piping exposed to the external areas of the plant adding significant capital and operating cost.

11 Future Work Plan

Following on from this study the items listed below, in proposed order of testing, should be included in an ongoing work plan to progress the MRC project. These tests will confirm the equipment selection and sizing. The exact testing regime will be dependant on the final coal type/s selected, availability of sample, and test work budget.

11.1 Feed Coal Analysis

Carry out analysis on a selection of possible feed coals. A shortlist of possible feed coals with suitable properties (ash, sulphur, energy levels) could be selected based on known existing coal quality from different mine sites.

The selection of the preferred coal type is a critical component of any ongoing work as this will drive the downstream test work, the results of which will determine equipment sizing and final project costs (capital and operating).

11.2 Coal Grain Analysis

Once a preferred coal source, or sources, are identified, Nexant should carry out detailed coal grain analysis on this coal to determine liberation requirements to reach the required product ash level. The results of this analysis is critical to both the grinding and flotation equipment selection.

11.3 Crushing and Grinding Test Work

Laboratory scale comminution tests should be carried out on the selected coal to determine the energy inputs required for crushing and grinding. These tests can be performed by a metallurgical testing laboratory or by sending samples to equipment suppliers. The following tests are recommended:

- Drop shatter
- Hargrove grindability
- Abrasion index testing
- Bond crushing work index or JK drop weight test
- Bond rod mill index
- Bond ball mill work index
- Signature plot and/or jar test

11.4 Flotation Tests

Flotation tests should be performed on freshly ground coal sample to avoid oxidation of the particle surfaces which will adversely impact flotation performance. These can be performed as part of a metallurgical laboratory suite of testing or samples can be sent to different suppliers/technology providers. These tests will assist in determining:

- Flotation behaviour of ultrafine feed material
- Suitable flotation technology

- Suitable flotation circuit configuration to achieve required performance (ash and yield) e.g. Rougher-cleaner, rougher-scavenger, rougher-cleaner-scavenger
- Reagent dosage required
- Froth carrying capacity
- Wash water requirements
- Froth depth requirements.

The results of the flotation test work may require an iteration of the grinding work to be done. The coal grain analysis will give a target value for liberation size, however, the variability of coal feed and inefficiencies of the flotation process may necessitate a finer grind to be performed to realise the target ash. If this is the case then iterative tests may need to be performed.

11.5 Thickening and Dewatering Tests

Both the product (concentrate) and tailings material from the flotation test work would need to be collected to perform thickening and dewatering testing.

Thickener testing will help to determine thickener size, flocculant type and dosage rates.

Dewatering test work will help to size the dewatering equipment and assist in selection of the final dewatering technology to use.

11.6 Rheology Characterization

To support the sizing and selection of agitators, pumps and piping a range of rheology characterization should be undertaken on the key intermediate and final product and tailings slurry streams. This testing will provide information on the deformation and flow behaviour of the slurry compositions expected in the plant.

11.7 Pilot Plant Operation

The proposed flowsheet utilises commercially available equipment however for most major equipment, the application is novel. It is therefore recommended that following the completion of the above initial laboratory scale analysis, a pilot plant be constructed and operated to provide an indication of the expected continuous performance. A nominal throughput of 1 ton per hour should be considered as basis however the throughput will likely be based upon the size of the equipment available. Often equipment can be leased from one or more laboratory testing companies or equipment suppliers. Evaluation of a suitable location for undertaking the test work should consider the proximity to the feed coal, the disposal method for the tailings/waste, and if the product will be tested/utilised in the same location, i.e. a DICE pilot plant included with the coal beneficiation pilot plant.

12 References


Demirbaş, A. and Hilal Demirbaş. A., 2004, Estimating the Calorific Values of Lignocellulosic Fuels, *Energy Exploration and Exploitation* Vol. 22, No. 2, pp. 135-143.

Krevelen, D.W. van. 1993. *Coal : typology, chemistry, physics, constitution*. Elsevier Science.

O'Brien, G., Firth, B. and Adair, B., 2011, The Application of the Coal Grain Analysis Method to Coal Liberation Studies, In *International Journal of Coal Preparation and Utilisation*, Vol 31, Issue 2, pp. 96-106.

Appendix A

Flowsheet




CLIENT NEXANT										DRAWN	MW	08.01.20	PROJECT NEXANT PROJECT	
										CHECKED			TITLE COAL BENEFICIATION SYSTEM	
										DESIGNED			PROJECT NO A917-D01	
										LEAD ENG			DRAWING NO A917-P-2-1000	
										APPROVED			REVISION 0	
DRAWING NO										SCALE NTS		OR AS SHOWN A1	DRAWING NO A917-P-2-1000	
TITLE										DO NOT SCALE			DRAWING NO A917-P-2-1000	
REV DESCRIPTION										PRELIMINARY NOT FOR CONSTRUCTION				REVISION 0
BY DRG CHK ENG CHK DATE APPROVED														
REFERENCE DRAWINGS														
DRAWING REVISIONS														

© THIS DRAWING IS COPYRIGHT. NO PART OF THIS DRAWING MAY IN ANY FORM OR BY ANY MEANS BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM OR TRANSMITTED

Appendix B

Layout Diagrams



PLOT DATE: 2020/03/03 10:59:40 AM File: F:\Working\A917 - DICE Layout.dwg - By: Mitch Carter

DRAWING NO	TITLE	REV	DESCRIPTION	BY	DRG CHK	ENG CHK	DATE	APPROVED
		A	PRELIMINARY	MDC			24/02/20	
REFERENCE DRAWINGS			DRAWING REVISIONS					

CLIENT NEXANT INC		
DRAWN	MDC	24/02/20
CHECKED		
DESIGNED		
LEAD ENG		
APPROVED		
SCALE	OR AS SHOWN	
	DO NOT SCALE	A1

PRELIMINARY
NOT FOR CONSTRUCTION

PROJECT DICE GT-CRCC PRE FEED STUDY


TITLE BENEFICIATION PLANT PLAN VIEW

PROJECT NO A917-D01

DRAWING NO A917-D1-01-0001_01

REVISION A

© THIS DRAWING IS COPYRIGHT. NO PART OF THIS DRAWING MAY IN ANY FORM OR BY ANY MEANS BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM OR TRANSMITTED



PLOT DATE: 03/03/2020 11:11:57 AM File: F:\Working\A917 - DICE\A917 - DICE Layout.dwg - By: Mitch Carter

CLIENT NEXANT INC										DRAWN	MDC	24/02/20	PROJECT	DICE GT-CRCC PRE FEED STUDY		
										CHECKED			TITLE	BENEFICIATION PLANT ELEVATION VIEW		
										DESIGNED						
										LEAD ENG				PROJECT NO	DRAWING NO	REVISION
										APPROVED				A917-D01	A917-D1-01-0001_02	A
DRAWING NO	TITLE	REV	DESCRIPTION	BY	DRG CHK	ENG CHK	DATE	APPROVED	SCALE	OR AS SHOWN						
REFERENCE DRAWINGS		DRAWING REVISIONS								DO NOT SCALE	A1					

© THIS DRAWING IS COPYRIGHT. NO PART OF THIS DRAWING MAY IN ANY FORM OR BY ANY MEANS BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM OR TRANSMITTED

Appendix C

Equipment List

Area	Cost Centre	Equipment	Design Capacity/Size	Installed Power (kW)
Raw Coal Handling	FE-201	Feedstock Coal Receival Dump Hopper Feeder		55
	CV-101	Hammer Mill Feed Conveyor	110 t/h	11
	CR-301	Hammer Mill	42" x 60"	300
	CV-201	Surge Bin Feed Conveyor	110 t/h	11
	WT-201	Plant Feed Weigher		
	BN-301	Surge Bin	100 t	
	FE-202	Surge Bin Discharge Feeder		7.50
Process Plant	CV-301	Ball Mill Feed Conveyor	110 t/h	7.50
	CR-302	Ball Mill	3.7 m x 6.75 m	1,300
	PP-301	Ball Mill Cyclones Feed Pump		55
	CY-301	Ball Mill Cyclones Cluster		
	CY-302	Ball Mill Cyclones Cluster		
	PP-401	Grinding Cyclones Feed Pump		55
	CY-401	Grinding Cyclones Cluster		
	CY-402	Grinding Cyclones Cluster		
	PP-403	Grinding Mill Feed Pump		75
	GM-401	Grinding Mill	63 t/h	3,500
	PP-501	Rougher Cell Feed Pump		75
	PP-502	Rougher Cell Feed Pump		75
	PP-503	Rougher Cell Feed Pump		75
	FC-501	Rougher Flotation Cell		
	FC-502	Rougher Flotation Cell		
	FC-503	Rougher Flotation Cell		
	PP-521	Cleaner Cell Feed Pump		45
	PP-522	Cleaner Cell Feed Pump		45
	PP-523	Cleaner Cell Feed Pump		45
	FC-521	Cleaner Flotation Cell		
	FC-522	Cleaner Flotation Cell		
	FC-523	Cleaner Flotation Cell		
	TH-601	Product Thickener	20 m ø	7.50
	PP-601	Product Thickener Underflow Pump		11
	SM-601	Product Solid Bowl Feed Sump		
	PP-602	Product Solidbowl Feed Pump		11
	CF-601	Product Solidbowl	28 t/h	300
	CF-601	Main Drive		200
	CF-601	Back Drive		100
	PP-603	Product Solidbowl Feed Pump		11
	CF-602	Product Solidbowl	28 t/h	300
	CF-602	Main Drive		200
	CF-602	Back Drive		100
	PP-605	Solidbowl Effluent Pump		5.50
	CV-601	Product Transfer Conveyor	52 t/h	7.50
	WT-601	Product Weigher		
	SA-601	Product Cross Belt Sampler		5.50
	AN-601	Moisture Meter		1.00
	TK-610	Product Slurry Agitation Tank	35 m ³	
	TK-620	Product Storage Tank	1,000 m ³	
	TK-630	Product Storage Tank	1,000 m ³	
AG-610	Product Slurry Agitator		15	
PP-610	Product Slurry Transfer Pump		7.50	
AG-620	Product Slurry Agitator		185	
PP-620	Product Distribution Pump		5.50	
PP-630	Product Distribution Pump		5.50	
AG-630	Product Slurry Agitator		185	
TH-701	Tailings Thickener	20 m ø	7.50	

Area	Cost Centre	Equipment	Design Capacity/Size	Installed Power (kW)
	PP-701	Tailings Thickener Underflow Pump		7.50
	PP-901	Process Water Pump		175
	PP-510	Plant Water Pump		45
	FT-950	Gland Water Filter		0.37
	PP-950	Gland Water Pump		22
	PP-960	Thickener Area Sump Pump		15
	PP-961	Thickener Area Sump Pump		15
	CN-501	Overhead Crane	20 t	43
CPP Services	FL-901	Anionic Flocculant Dosing System		5.55
	FL-901a	Polymer Bulk Storage Tank		
	FL-901b	Blower		3.00
	FL-901c	Screw Feeder		0.37
	FL-901d	Agitator		1.50
	FL-901e	Dust Filter Unit		0.37
	FL-901f	Mixing Tank		
	FL-901g	Dilute Flocculant Storage Tank		
	FL-901h	Heated Hopper		0.06
	FL-901i	Hopper Vibrator		0.25
	DP-901	Collector Dosing Pump		0.55
	DP-902	Collector Dosing Pump		0.55
	DP-910	Frother Dosing Pump		0.37
	DP-911	Frother Dosing Pump		0.37
	DP-912	Frother Dosing Pump		0.37
	DP-913	Frother Dosing Pump		0.37
	DP-930	Dispersant Dosing Pump		0.55
	DP-931	Dispersant Dosing Pump		0.55
	AD-950	Instrument Air Dryer		1.53
	AR-901	Air Receiver		
	AC-901	Air Compressor	40 m ³ /h	5
		Total Installed Power (kW)		7,141
		Total Demand Power (kW)*		5,713

*Total Demand Power based on 80% Utilization Rate

Appendix D

General Design Basis for Coal Beneficiation

SEDGMAN

DICE GT-CRCC Pre-FEED Study

General Design Basis for Coal Beneficiation



Document No.: A917-D01-04010-DC-0100_B - LR/lr
Revision: B

Sedgman Canada Limited
Registration number: A0088793



Revision Status

Revision Number	Author	Description	Date	Approved By
A	MW/LR	Issued for Use	20-Jan-2020	LR
B	MW/LR	Issued for Client Information	03-Mar-2020	LR

Distribution

Company Name	Contact Name	Revision	Date
Nexant	Haoren Lu	B	03-Mar-2020

Vancouver
 Unit 1630
 505 Burrard St
 Vancouver BC V7X 1M6
 CANADA

Postal Address
 PO Box 26
 505 Burrard Street
 Vancouver BC V7X 1M6

+1 604 428 8200
 mail@sedgman.com
 www.sedgman.com

Copyright Notice
 Sedgman © 2020

This Document is copyright. Other than for the purposes and subject to the conditions prescribed under the Copyright Act 1968 (Commonwealth), no part of it may in any form or by any means (electronic, mechanical, micro-copying, photocopying, recording or otherwise) be reproduced, stored in a retrieval system or transmitted without prior written permission.

Table of Contents

Nomenclature	1
1 Introduction	2
1.1 General	2
1.2 Scope	2
1.3 Beneficiation Plant Objectives	2
1.4 Design Basis Reference	3
2 Process Design	4
2.1 Coal Feed	4
2.1.1 Origin	4
2.1.2 Plant Supply	4
2.2 Product	4
2.3 Process Parameters	5
2.4 Utilities and Reagents	6
2.5 Water Quality Basis	7
3 Facility Design Criteria	8
3.1 Site Related Conditions	8
3.2 Facility Life and Availability	8
3.3 Facility Construction	8
3.4 Mobile Equipment Basis	9
3.5 Structural Design Basis	9
3.6 Transport and Lifting Design Basis	9
3.7 Safety Design Basis	10
3.8 Quality Management	11
4 Specifications and Standards	12
4.1 Paint Specifications	12
4.2 Equipment	12
4.3 Abrasion Resistant Linings	12
4.4 Fabricated Platework	13
4.5 Pipework	13
4.6 Conveyors	13
4.7 Valves	15
4.8 Structures	1
4.9 Electrical	1
4.10 Supply and Voltage	3
4.11 Electrical Materials of Construction	3
4.12 Control System	4
4.13 Control System Specifications and Standards	5
5 Design Philosophy	6
5.1 Key Design Objectives	6
5.2 Health and Safety	7
5.3 Time Definitions	8

Appendices

List of Tables

Table 2-1 MRC Product Specification	4
Table 2-2 Process Parameters	5
Table 2-3 Plant air supply conditions	6
Table 2-4 Instrument air supply conditions	7
Table 3-1 Site-Related and Meteorological Data	8
Table 4-1: Relevant Specifications and Standards	12
Table 4-2: Paint Specifications	12
Table 4-3: Abrasion Resistant Linings	12
Table 4-4: Pipework	13
Table 5-1 Performance Indicator Definitions	8

List of Figures

Figure 1-1 Bechtel DICE Turbocompound Reheat Facility Diagram (Source:Bechtel)	2
--	---

Nomenclature

Key Terms, Symbols and Abbreviations

The following terms and abbreviations are used:

(as)	As sampled (equivalent to "as mined" or "as received")	kg/m ³	Kilograms per cubic metre
(ad)	Air dry	LD	Large diameter
(ar)	As received	LHV	Lower Heating Value
(d)	Dry	Limn	Proprietary plant simulation software package
(db)	Dry basis	LOM	Life of mine
CAPEX	Capital expenditure	MCC	Motor control centre
CCTV	Closed circuit television	Mt	Million tonnes
CHP	Coal handling plant	Mt/a	Million tonnes per annum
CHPP	Coal handling and preparation plant	NPV	Net present value
CPP	Coal preparation plant	OPEX	Operations expenditure
CSN	Crucible swelling number	PDS	Project definition statement
CSR	Coke strength after reaction	PFS	Pre-feasibility study
CV	Calorific Value	PLC	Programmable logic controller
D&C	Design and construct		RD Relative density
DMC	Dense medium cyclone	ROM	Run of mine
EA	Environmental assessment	RX	Reflux classifier
EIS	Environmental impact study	SCADA	Supervisory control and data acquisition
EOI	Expression of interest	SE	Specific energy
EPCM	Engineering, procurement and construction management	SOP	Standard operating procedure
FS	Feasibility study	TBS	Teetered bed separator
GST	Goods and services tax	t/h	Tonnes per hour
HazAn	Hazard analysis	TLO	Train load out
HazID	Hazard identification study	TM	Total Moisture
HazOp	Hazard and operability study	UCS	Ultimate compressive strength
HGI	Hardgrove Grindability Index	UDL	Ultimate distributed load
HHV	Higher Heating Value	WAP	Work area pack
JSA	Job safety analysis	WBS	Work breakdown structure
JSO	Job safety observation	ww	Wedge wire screen mesh (parallel aperture)
kt	thousand tonnes	wt/wt%	Weight for weight %

1 Introduction

1.1 General

Nexant Inc and Bechtel Power and Infrastructure are currently developing an integrated coal-based power plant concept known as the Coal-Fired Direct Injection Carbon Engine Gas Turbine Compound Reheat Combined Cycle (DICE GT-CRCC). Currently in pre-FEED study phase, the DICE GT-CRCC plant is designed to generate a nominal 100 MWe on a net basis. It is to be equipped with a CO₂ capture plant that captures 90 percent of the total CO₂ in the flue gas. The process requires the generation of Micronized Refined Coal (MRC) as an intermediate product via a coal beneficiation process and Sedgman has been contracted to develop and cost this flowsheet.




Figure 1-1 Bechtel DICE Turbocompound Reheat Facility Diagram (Source:Bechtel)

1.2 Scope

This document outlines the basis for the Coal Beneficiation Facility design which includes:

- Fine grinding
- Flotation
- MRC product thickening and dewatering
- Coal tailings thickening

1.3 Beneficiation Plant Objectives

The following are the general design objectives for the beneficiation plant:

- Develop a safe, economical, durable, and functional facility to receive, size, process, and deliver 385,000 metric tonnes per year of a <2% ash (ad) MRC product as a 55% solids / 45% water slurry on a w/w basis.
- Modularise the facility structure/layout wherever possible to reduce the footprint and reduce construction duration.

1.4 Design Basis Reference

The following are the sources for the beneficiation plant design.

1. *Design Basis for Coal Beneficiation*, Nexant Inc and Bechtel Power and Infrastructure, November 22, 2019
2. Data from Nexant Inc or Bechtel Power and Infrastructure (Client)
3. Sedgman assumed value based on typical or similar operations
4. Vendor data or recommendation
5. Calculated from other data
6. ASCE 7-16 Minimum Design Loads and Associated Criteria for Buildings and Other Structures

2 Process Design

2.1 Coal Feed

2.1.1 Origin

The design coal is Montana Rosebud PRB coal. The coal properties stated in Table from the 2019 revision of the QGESS document “Detailed Coal Specifications”.

Coal seam nomenclature	Montana Rosebud	
Coal field	PRB, Area D	
Mine	Western Energy Co.	
ASTM D388 Rank	Subbituminous	

Proximate Analysis²	As-Received	Dry
Moisture ³	25.77%	0.00%
Volatile Matter	30.34%	40.87%
Ash	8.19%	11.04%
<u>Fixed Carbon</u>	<u>35.70%</u>	<u>48.09%</u>
Total	100.00%	100.00%

Ultimate Analysis²	As-Received	Dry
Carbon	50.07%	67.45%
Hydrogen	3.38%	4.56%
Nitrogen	0.71%	0.96%
Sulfur	0.73%	0.98%
Chlorine	0.01%	0.01%
Ash	8.19%	11.03%
Moisture ³	25.77%	0.00%
<u>Oxygen</u>	<u>11.14%</u>	<u>15.01%</u>
Total	100.00%	100.00%

Heating Value^{1,2}	As-Received	Dry (Dulong calc.)
HHV (Btu/lb)	8,564	11,516
LHV (Btu/lb)	8,252	11,096
HHV (kJ/kg)	19,920	26,787
LHV (kJ/kg)	19,195	25,810

Hardgrove Grindability Index	57
-------------------------------------	----

2.1.2 Plant Supply

Coal is mined and delivered to the run of mine pad (ROM pad) and stockpiled by Others. It is assumed that the ROM coal is sized at 8 cm x 0 (3" x 0). A front ender loader will be used to reclaim coal from the stockpile and feed the beneficiation plant.

2.2 Product

The specifications for the MRC product are detailed in Table 2-1.

The facility shall have capacity to store 24 hours production of MRC product.

Table 2-1 MRC Product Specification

Detail	Unit	Value	Ref.
MRC Product Composition			

-	Moisture	% w/w	45.00	1
-	Carbon	% w/w	40.87	1
-	Hydrogen	% w/w	2.76	1
-	Nitrogen	% w/w	0.58	1
-	Chlorine	% w/w	0.01	1
-	Sulfur	% w/w	0.48	1
-	Ash	% w/w	1.21	1
-	Oxygen	% w/w	9.09	1
MRC Product General				
-	P ₉₈	µm	50	1
-	P ₈₀	µm	10-15	2
-	Solids content	% w/w	55	1

2.3 Process Parameters

The parameters in Table 2-2 were used as the basis for the beneficiation plant design.

Table 2-2 Process Parameters

Detail	Unit	Value	Ref.
Plant Yield	%	50	
Hammer Mill			
- Feed flow	tph	110	
- Feed top size	mm	80	1
- Product size P ₈₀	mm	13	3
Ball Mill			
- Feed flow (fresh)	tph	110	
- Product size P ₈₀	µm	93	1
Ball Mill Cyclone			
- Feed flow	tph	110	
- Cut-point D ₈₀	µm	93	1
Grinding Cyclone			
- Feed flow	tph	110	
- Overflow slurry solids	% w/w	11	3
- Underflow slurry solids (max)	% w/w	25	
- Standby cyclones in cluster	%	20	3
- Product size P ₈₀	µm	93	1
Fine Grinding			
- Feed flow (fresh)	tph	63	
- Feed particle size (F ₈₀)	µm	93	
- Product particle size (P ₈₀)	µm	17	
- Specific energy consumption	kWh/t	13	

- Hardgrove Grindability Index	-	57	1
Rougher Flotation			
- Feed flow (fresh)	tph	246	
- Carrying capacity	t/h/m ²	1.9	3
- Wash water ratio	-	1.5:1	3
- Yield	%	55	3
- Frother addition rate	g/t of fresh feed	400	
- Collector addition rate	g/t of fresh feed	1000	
Cleaner Flotation			
- Feed flow (fresh)	tph	73	
- Carrying capacity	t/h/m ²	1.7	3
- Wash water ratio	-	1.5:1	3
- Yield	%	91	3
- Frother addition rate	g/t of fresh feed	400	
- Collector addition rate	g/t of fresh feed	1000	
Product Thickener			
- Feed flow	tph	55	
- Specific settling rate	m ³ /h/m ²	3.9	
- Solids flux	t/h/m ²	0.3	
- Underflow slurry solids	% w/w	25	
- Flocculant addition rate	g/t	100	
Product Screen Bowl			
- Feed flow	tph	52	3
- Solids Capture	%	95	3
- Product Discharge Moisture	% w/w	40	
Tailings Thickener			
- Feed flow	tph	58	
- Specific settling rate	m ³ /h/m ²	3.4	3
- Solids flux	t/h/m ²	0.2	3
- Underflow slurry solids	% w/w	35	3
- Flocculant addition rate	g/t	100	

2.4 Utilities and Reagents

The coal beneficiation circuit will require the addition of collector, frother and flocculant reagents. Collector and frother will be received as a liquid in 1000L IBC containers from which the reagents will be dosed neat. A vendor supplied flocculant plant will be provided to mix, store and dose flocculant which will be received as bulk bags of dry powder.

Both plant and instrument air are to be supplied by Others. Plant air will be compressed and cooled ambient and will be supplied to the beneficiation plant at the conditions detailed in Table 2-3.

Table 2-3 Plant air supply conditions

Detail	Unit	Value	Ref.
--------	------	-------	------

Nominal Temperature	°F	100	1
Maximum Temperature	°F	120	1
Nominal Pressure	psig	125	1
Maximum Pressure	psig	150	1
Minimum Pressure	psig	100	1

Part of the plant air will be dried to -40°F dew point for use as instrument air for the beneficiation plant. Instrument air will be supplied to it at the conditions detailed in Table 2-4.

Table 2-4 Instrument air supply conditions

Detail	Unit	Value	Ref.
Nominal Temperature	°F	100	1
Maximum Temperature	°F	120	1
Nominal Pressure	psig	100	1
Maximum Pressure	psig	150	1
Minimum Pressure	psig	80	1

2.5 Water Quality Basis

Water supplies for the plant should be clean and generally have the following properties. Failure to observe these conditions may result in excess maintenance or premature failure of items of the plant.

The following is a recommended water quality specification which is attainable with relatively inexpensive filtration treatment equipment:

- pH 6.5 - 8.0
- Solids content:
 - Dissolved: 1,000 ppm (mg/L)
 - Suspended: 100 ppm (mg/L)
 - 100% of +250 mesh (60 µm) particles removed.
- Maximum individual dissolved ions:
 - Hardness (Ca⁺, Mg⁺) 200 ppm (mg/L) as CaCO₃
 - Calcium Carbonate (CaCO₃) 10 ppm (mg/L)
 - Sulphate (SO₄⁻) 50 ppm (mg/L)
 - Chloride (Cl⁻) 1,000 ppm (mg/L).

3 Facility Design Criteria

3.1 Site Related Conditions

The data in Table 3-1 has been extracted from the Client document Coal Beneficiation EOM Design Basis Rev1

Table 3-1 Site-Related and Meteorological Data

Detail	Unit	Value	Ref.
Location	-	Midwestern USA	1
Elevation above sea level	ft	0	1
Topography	-	Level	1
Site Size	acres	300	1
Coal delivery	-	Rail	1
Gas delivery		Pipeline	1
Atmospheric pressure	psia	14.7	1
Maximum ambient dry bulb temperature (DBT)	°F / C	59 / 15	1
Maximum ambient wet bulb temperature (WBT)	°F / C	51.5 / 10.8	1
Minimum ambient temperature	°F / C	18 / -8	3
Design ambient relative humidity	%	60	1
Cooling water temperature	°F	60	1
Structural Risk Category	-	II	6
Wind			
- Basic wind speed, V	mph	110	6
- Exposure Category	-	C	6
Ground snow load, p _g	lb/ft ²	30	6
Seismic			
- Site Class		D	6
- S _s	g	0.15	6
- S ₁	g	0.05	6
- MCE PGA	g	0.15	6

3.2 Facility Life and Availability

The facility will be designed for a 10 year plus life, operating 24 hours per day, 7 days per week.

The facility will be required to operate at 7,400 h/a to meet the required product output.

3.3 Facility Construction

The beneficiation plant is to be of a modular construction consistent with the philosophy of the DIE-GT CRCC concept.

3.4 Mobile Equipment Basis

The plant has been designed to interface with mobile equipment as listed below.

- Raw coal receipt into the ROM hopper for the feeder breaker option is from a front end loader no larger than a Cat 980 or equivalent.
- Raw coal receipt into the ROM hopper for the mobile crushing plant option is from an excavator no larger than 45 tonnes.
- Removal of both product and rejects from the respective stockpiles is by front end loader.

3.5 Structural Design Basis

- Normal building importance category, i.e. ultimate limit state importance factors = 1.0.
- Footing design criteria: The site shall be cleared, prepared and graded by others to meet the specified finished surface profile as shown on the bulk earthworks drawing. Minimum bearing capacity is 150 kPa (and minimum ultimate bearing capacity is 300 kPa). Total settlement, caused by the aforementioned bearing pressures, shall not exceed 20 mm. Differential settlement across the plant shall not exceed 10 mm. Finished surface level tolerance is ± 20 mm, with a surface profile tolerance of 10 mm vertical over 3 m horizontal. All reactive materials (e.g. expansive clays, etc.) shall be removed and replaced with engineered fill by others. No allowance has been made for groundwater effects.
- Design live loads for fixed platforms, walkways and stairways:
 - Stair treads = 2.5 kPa or 2.2 kN/m or 1 kN
 - Handrails and guardrails = 0.35 kN/m or 0.6 kN
 - Floor plate = 5.0 kPa or 4.5 kN
- Exposure classification = C1 (as defined by CSA A23.1)
- No provision has been made for the structure to be subject to abnormal loads such as vehicle impact, cranes or lifting gear, static line systems, etc.
- Welding to CWB certification

3.6 Transport and Lifting Design Basis

For transportation the Plant modules shall not be stacked and must be loaded on the deck of the ship and truck with nothing stacked above them.

Modules must not exceed the allowable project transport limits. The maximum overland transportable dimension is 100 feet (30.4m) long by 15 feet (4.5m) wide by 15 feet (4.5m) height (including carriage height). The maximum equipment height is 13.5 feet (4.1m) assuming using 1.5 feet (1.5m) height low boy carriage. The maximum overland transportable weight is 120 US tons (108.8 tonnes).

Design parameters that pre-assembled modules may be subjected to during sea voyage and land transport, and during lifting:

- Sea transport
 - Transverse acceleration (generated through roll) ± 0.8 g
 - Acceleration due to heave (combined acceleration perpendicular to the ship's deck generated through direct heave and vertical component of angular acceleration) ± 0.5 g
 - Longitudinal acceleration (generated through pitch) ± 0.4 g
 - Wind speed = 30 m/s

- Road transport
 - Forwards acceleration (from braking) + 0.8 g
 - Rearwards acceleration (from accelerating and braking in reverse) - 0.5 g
 - Sideways acceleration (from cornering) ± 0.5 g
 - Upwards acceleration (from rough roads) ± 0.2 g.
- Lifting
 - Module lifting load factors applied to self-weight of structure and pipework, and transport mass of equipment:
 - > Load factor = 1.2
 - > Dynamic factor = 1.35
 - > Wear and tear factor = 1.0
 - > Load redistribution factor = 1.1.
 - Lifting lug design safety factors applied to hoisted mass:
 - > Load factor = 1.2
 - > Dynamic factor = 1.35
 - > Wear and tear factor = 1.0
 - > Load redistribution factor = 1.25.

3.7 Safety Design Basis

Moving machine parts have been risk assessed to identify those that pose material risk to operations personnel. The machine parts that pose risk of injury to personnel have been designed and fitted with suitable guards to ensure safe operation. Guarding of proprietary equipment is to the manufacturer's standard.

All equipment has an emergency stop button located within easy access of the equipment.

All knife-gate isolation valves are lockable. All valves are clearly labelled as to their open and shut position.

Where inspection openings are provided, they include an appropriate means of locking the hatch open or closed.

Lighting has been provided for all working areas. Emergency lighting with backup power supply has been provided where necessary. Lighting has been mounted to fixed light mounts incorporated into the Plant plant structure.

All chute-work has been designed to minimise spillage to areas below.

Over walkways there are minimum vertical clearances of 6.9 feet (2.1 m). Access around pumps and other equipment is minimal, but sufficient to achieve the required maintenance activities. To remove specific large processing components that are very infrequently accessed, there may be a requirement to remove the next levels structure.

All plant and facilities are designed with suitable lifting accessibility to ensure safe working procedures are practiced when lifting, removing and maintaining equipment.

Handrails and kick-plates are on all walkways and platforms where fall protection is required.

Prominent warning notices for warning of enclosed space, personal protection, ventilation requirements and other hazards are included.

Start-up warning sirens are fitted and clearly audible in all required areas when conveying equipment is started automatically or remotely from the operator interface. All conveyors are fitted with suitably located pull wire emergency stop switches.

The fire system consists of fire extinguishers located appropriately around the facility.

Dust suppression sprays are provided where necessary to limit dust emissions.

Washdown hoses for clean-up have been provided in the Plant.

The plant has been designed to vibrate and is not designed for long-term occupation while operating. Operators may feel discomfort from working within operating plant for long durations.

3.8 Quality Management

The plant design will allow for the routine monitoring and control of product quality to ensure compliance with MRC product specifications. It will provide for process control by continuous monitoring together with analysis of shift and daily composite samples for the following parameters. No online analysis ability has been allowed for.

- Moisture
- % Ash
- Particle Top Size
- Rheology
- Calorific value

4 Specifications and Standards

The plant has been designed and selected in accordance with Sedgman’s typical design processes for a design life as nominated in Section 1. The CHPP has generally been designed to the standards detailed in Table 4-1.

Table 4-1: Relevant Specifications and Standards

CHPP Specifications and Standards	
Piping	Designed generally to ASME B31.3, CSA B51-13
Conveyors	Designed generally to ASME B20
Structural	Designed generally to Canadian Standards, unless otherwise specified, including CSA S16.
Concrete	Designed generally to Canadian Standards, unless otherwise specified, including CSA A23.1 to A23.3
Electrical	Designed to IEC Standards and CSA certification

4.1 Paint Specifications

Table 4-2: Paint Specifications

Area	Paint System
Plant Steelwork	Two-coat system consisting of a base coat of a 75 µm zinc rich epoxy primer and a topcoat of 200 µm high build polyamide epoxy for a total DFT of 275 µm – colour cream
Conveyors	Single coat of 75 µm inorganic zinc ethyl silicate primer
Platework	Two-coat system consisting of a base coat of a 75 µm zinc rich epoxy primer and a topcoat of 200 µm high build polyamide epoxy for a total DFT of 275 µm – colour cream
Pipework	Steel pipework – two-coat system consisting of a base coat of a 75 µm zinc rich epoxy primer and a topcoat of 200 µm high build polyamide epoxy for a total DFT of 275 µm – colour cream HDPE, galvanised pipe – not coated
Proprietary Equipment	Manufacturer’s standard specification and colour
Guarding	Two coats of 75µm epoxy zinc phosphate primer, 75µm catalysed acrylic top coat (golden yellow)
Handrails	Two coats of 75µm epoxy adhesion promoting primer, 75µm catalysed acrylic top coat (golden yellow)

Machined surfaces, liners, HDPE and stainless steel platework are not coated with any paint systems.

4.2 Equipment

All equipment bearing life (L10) is 30,000 hours.

4.3 Abrasion Resistant Linings

Table 4-3: Abrasion Resistant Linings

Area	Lining
CPP chutework	Direct constant impact of coarse particles is lined with dry pressed alumina tiles. Constant impact of fine particles and dilute slurries is lined with 10 mm Linatex rubber (or equivalent). All other surfaces are lined with an abrasion resistant epoxy coating with a 300 µm DFT.

CHP chutework	Direct constant impact of coarse particles is lined with plug welded Bisplate 400 (or equivalent).
----------------------	--

4.4 Fabricated Platework

All chutes, underpans, launders and other associated platework are designed to be fabricated from 6 mm carbon steel plate suitably stiffened to resist all process pressures and duties. All conveyor skirts items will be fabricated from 2 mm carbon steel plate. All carbon steel chutework is painted externally and lined or painted internally as appropriate.

Valley angles and surface slopes are sufficient to ensure free flow and complete discharge of material.

Chute profiles are suitable for the characteristics of the material being handled and designed to be self-cleaning.

4.5 Pipework

Piping has been designed as short and as straight as possible. Flanges will generally be to ANSI B16.5 Class 150 and installed square to the axis of the pipe.

Valves and fittings are designed to be removable without disturbing significant adjacent piping.

Piping around pumps and equipment requiring service is designed and supported such that the equipment can be maintained and removed with minimal pipework disturbance or interference.

Piping attached to equipment is designed and anchored such that loads that are transferred to the equipment do not exceed the manufacturer's allowable loads.

Table 4-4: Pipework

	≥ 80mm nominal bore	< 80 mm nominal bore
Pipe	API 5L gr B ERW (or equivalent) standard weight or extra strong	Galvanised steel medium weight to ASTM A53 Gr.B, screwed NPT
Joining	ANSI B16.5 Class 150 slip on flanges carbon steel	Galvanised steel, screwed NPT
Gaskets	Full face (true bore) to ANSI B16.5 Class 150, neoprene rubber <300mm dia 3mm thick full face >300mm dia 6mm thick full face	Nil
Elbows	Long radius 1.5D standard weight (shorter radii may be specified where required)	Medium weight galvanised cast iron to ASTM A126 Gr.A and ASTM A153, screwed NPT
Bolts	ASTM A307 Grade A Bolts	
Screwed Fittings	Carbon steel screwed NPT	
Miscellaneous Fittings	Standard weight or extra strong butt weld ends	Medium weight galvanised steel, screwed NPT

Reagents pipework carrying flammable or combustible liquids is in galvanised steel pipe with welded connections.

4.6 Conveyors

All belt conveyors and stackers are open-style structures and have been designed to provide reliable operation at the nominated capacities. Conveyors have been designed based on normal operating/starting conditions.

Plant conveyors and stackers include the following:

- Three roll 35° trough idlers at nominally 1.5 m centres. Minimum roller diameter is 108 mm.
- Flat return rollers at nominally 3.0 m centres. Minimum roller diameter is 102 mm.
- 10 mm rubber lagged drive pulleys. Pulley diameters have a minimum diameter of 400 mm.
- Screw take-up on tail pulleys
- Helical bevel or helical vee belt drive gear boxes
- Modular skirt panels at loading points
- Single-staged belt scrapers
- Return belt plough
- Bolt-on guarding at drive and tail pulleys and at skirted areas
- Fabric conveyor belting with 5 x 1.5 mm 'N' grade covers.

Walkways have not been included on plant conveyors and stacker maintenance will be by elevated work platform.

Stackers are slewing machines capable of operating at set discharge heights. Positioning of the stackers is by operator controls at each machine.

4.7 Valves

Type	Knifegate - Manual/Handle (or Manual/Chain)	Knifegate - On/Off, Air Actuated	Butterfly - Float	Butterfly - Modulating Control, Air Actuated	Ball Valve - Manual	Ball Valve - On/Off Air Actuated
Valve pressure rating	850 kPa @30°C	1000 kPa @30°C	1000 kPa @30°C	1000 kPa @30°C	1500 kPa @30°C	1500 kPa @30°C
Body material	316 stainless steel full - lugged	316 stainless steel full - lugged	Ductile or cast iron	Ductile or cast iron	316 stainless steel, one-piece reduced bore.	316 stainless steel, one-piece reduced bore.
Gate material	316 stainless steel	316 stainless steel				
Deflection cone/disc material	28% chrome alloy	28% chrome alloy	316 stainless steel	316 stainless steel	316 stainless steel	316 stainless steel
Resilient seat material	316 stainless steel	316 stainless steel	Buna N or equivalent	Buna N or equivalent	Reinforced PTFE or equivalent	Reinforced PTFE or equivalent
Packing material	K-lon, Virgin PTFE or equivalent	K-lon, Virgin PTFE or equivalent			Reinforced PTFE or equivalent	Reinforced PTFE or equivalent
Flange details	Lugged to suit as ANSI B16.5, Class 150 - flat face flanges	Lugged to suit as ANSI B16.5, Class 150 - flat face flanges	General purpose wafer to suit as ANSI B16.5, Class 150 - flat face flanges	General purpose wafer to suit as ANSI B16.5, Class 150 - flat face flanges	Screwed BSP up to 50 mm. Flanged to Table D for 65 mm and above.	Screwed BSP up to 50 mm. Flanged to Table D for 65 mm and above.
Actuator	Hand wheel c/w chain	Double acting pneumatic cylinder suitable for operating valve with a minimum air supply pressure of 550 kPa	Counter weighted design with adjustable float travel and puncture proof float.	Pneumatic double acting cylinder suitable for operating valve with a minimum air supply pressure of 550 kPa.	Stainless steel, vinyl covered handle	Double acting pneumatic actuator for operating valve with a minimum air supply of 550 kPa.
Positioner/ solenoid Valves		Five-way two-position, spring return with manual override (namur mounted).		Electro-pneumatic double acting with span and zero adjustments, pressure gauges, direct and reverse action with 4-20 mA DC input control signal.		Five-way, two-position, spring return with manual override (namur mounted).
Duty	Pump isolation	Thickener isolation	Sump level control	Density control	Air injection isolation, hose point isolation, pipe drain isolation	Flushing, fluidising water isolation

4.8 Structures

For the design life nominated in Section 1 to be achieved, it will be necessary for continual and regular maintenance to be undertaken to protect the integrity of the structure. This may consist of regular inspections and audits, prompt repair, repainting and replacement to damaged and corroded sections of plant, structure and foundations as required during the design life.

- Concrete strength grade = 32 MPa (28-day cylinder strength).
- Reinforcing steel grade 500 deformed bar, normal ductility conforming to CSA standard G30.18)
- Structural steel grades - Designed to be fabricated from Chinese steel grades Q235B and Q345B, using Chinese section sizes, or equivalent to meet CSA and CWB requirements.
- Weld quality equivalent to the relevant part of CWB W59, CWB W48.
- Structural steel connecting bolts are galvanised 8.8 grade conforming to ASTM A2329 and ASTM A325M. All bolts in modules or module components subject to vibration are pre-tensioned.
- Chemical anchors (Ramset 101 or Hilti HIT-HY 200) with galvanised threaded studs (430N/mm² minimum tensile strength and 310 N/mm² minimum yield strength) installed in accordance with manufacturers specifications.
- Engineered fill – CBR15 and CBR60 as noted on drawings, compacted to 95% Standard maximum dry density.
- Flooring is 6 mm thick mild steel pattern floor plate.
- Stair treads are folded 6mm thick mild steel pattern floor plate.
- Handrails for stairs are circular steel sections. Guardrails for floors are steel angle sections.

4.9 Electrical

The electrical design, installation and equipment will conform to American Standards.

Field control devices are constructed for operation in a harsh mining environment. All field instrument transmitters are minimum NEMA 4X rated. Electrical equipment is strategically located with due consideration to shipping modules.

The electrical installation complies with the National Electrical Code (NEC). NFPA70 and other applicable standards.

The ground-neutral connection point for the plant is provided with the supply to the MRS processing plant MCC.

The grounding system includes equipotential bonding of all electrical motors. All MRS motors are connected to a common MCC ground by an ground core integral to the motor cable and a visible ground connected to a dedicated ground cable mounted within the cable ladder.

The MRS includes a series of emergency stop buttons used to stop the plant. The e-stop system is designed to SIL2 as per IEC61508.

Conveyor emergency stop circuits are rated SIL2 as per IEC61508.

The MCC is a plinth mounted outdoor unit constructed to UL Standards. The MCC meets NFPA arc fault containment requirements in lieu of arc flash detection. Indoor MCC enclosures shall be a minimum of NEMA Type 1 Gasketed around perimeter of doors. The MCC is enclosed by either a

painted mild steel outer enclosure or housed within a purpose built shipping container style switchroom.

The MCC houses VVVF drives for selected equipment. These drives comply with EMC compatibility levels as detailed in IEC61000.2.4. When connected to a suitable power supply the harmonic levels at the MCC comply with IEEE519.

Only the main MCC incomer is fitted with ground leakage relays for sensitive ground leakage protection.

Single-phase small power and lighting circuits are fitted with 30mA sensitive earth leakage protection.

UPS or battery supplies are included in the MCC to power electrical protection circuits as required.

All power cabling is run directly from the MCC to the motors without interruption. Power cabling to the motors is Teck cable manufactured to CEC standards. Cables between MCCs and to the stackers within the CHPP arrangement are laid on the ground surface using 241 trailing cable so that no trenching is required.

The CPP structure incorporates lightning air terminal, down comer and site-installed ground rods tied into the building ground system. The lightning protection system is designed with a 45 m rolling sphere design method as per IEC62305. Local climatic conditions need to be considered during installation.

Each MCC is connected to ground by two site-installed ground rods.

Lighting will be designed to achieve levels of illuminance generally in accordance with, and no lower than, the values given in the Illuminating Engineering Society of North America (IES). Yard equipment accessed from natural ground level does not include task lighting. Emergency lights are provided to allow stair locations to be identified in the event of plant evacuation. Maintained emergency lights shall only be used if the predicted lamp life is greater than 20,000 hours.

The lighting design incorporated the following design factors:

- Fitting cleaning cycle of two months
- Lamp life of 10,000 hours.

All electrical cabling is NEMA measurement standard.

The cabling system is designed with consideration of cable voltage drop. The voltage drop at the motors is limited to 3% of the LV supply voltage in normal running and 20% under starting conditions.

Air conditioning is provided to cool the MCC as required, however there is no provision for anti-condensation heaters.

The MRS has some hazardous areas. Hazardous areas are limited to inside raw coal chutes, inside raw coal hoppers and flotation reagent areas if included. Installation of electrical equipment in hazardous areas is avoided. Other areas are not considered hazardous for dust ignition and do not have combustible dust rated equipment based on the assumption the plant is regularly maintained to avoid dust layering.

Electrical equipment in the MIBC reagent area is hazardous area rated, and includes screened cable and thermal protection of motors.

Proprietary plant equipment included within the MRS may have an on board electrical installation built to the equipment manufacturer's standard.

4.10 Supply and Voltage

The plant design is based on a 480V supply voltage with the following specification:

- Maximum voltage fluctuation ±5%
- Average voltage imbalance 0.5%
- Maximum frequency fluctuation ±1.0%
- Maximum voltage sag starting 1%

The following voltages are used within the installation:

- Incoming supply voltage 13.8kV 3 phase 3 wire 60 Hz
- Medium Voltage MCCs 4,160V 3 phase 3 wire 60Hz
- Low voltage MCCs 480V 3 phase 4 wire 60 Hz
- General purpose power 208 V single phase 60 Hz – Neutral grounded
- Instrument supplies 24 VDC Negative ground
- Control Circuits 24 VDC Negative ground
- Solenoids 24 VDC Negative ground
- PLC Inputs 24 VDC Negative ground
- Motor contactors 120Vac - Neutral grounded

The MCC and all installed equipment are rated to a 50kA for one-second three-phase fault level. The maximum current rating of the MCC at the power supply connection point is 2000A.

The main connection point is designed to suit a maximum connection of 9 x 240mm² cable per phase.

4.11 Electrical Materials of Construction

All cables shall be installed in accordance with NFPA 70. Cables shall be installed neatly with a minimum of cross-overs while maintaining sufficient bending radius. Unless otherwise agreed to by the Contractor, no installation of wires and cables shall commence until all construction in the affected area is completed and until immediately prior to installation of the equipment connected to the wires and cables.

The cable ladder is of heavy duty aluminium construction. Gland plates are a minimum of 3 mm brass or aluminium with a gasket seal.

The plant lighting is mounted to steel spigots or mounting plate welded directly to structural steel.

Light fittings are constructed of cast stainless steel construction.

Junction boxes are of polycarbonate or metal construction.

Marshalling boxes used to mount terminals and field I/O modules are of 1 mm thick painted mild steel construction.

Instrumentation in the plant includes one nucleonic density gauge for correct medium control, an ultrasonic correct medium sump level sensor, manual pressure sensors for cyclone pressure monitoring and a flowmeter on the thickener underflow. Equipment protection and critical operating instrumentation as per the manufactures requirements will also be provided.

4.12 Control System

A modern control system is provided to control and monitor the MRS. Plant control and monitoring is implemented using a Programmable Logic Controller (PLC).

Panel mount operator interfaces are used to start and stop the plant in sequence or individual equipment. The operator interface system communicates with the PLC to allow control and monitoring of all items of plant and equipment from a central point. The operator interface system uses a SCADA package specifically configured for the plant. This is the only place that equipment items can be started from.

System integrity and reliability is maintained by ensuring correct selection and installation of network equipment and cabling.

The control system PLC is integrated into the MCCs. Additional distributed I/O is mounted in field mounted I/O boxes local to the process to reduce the requirement for on-site connection of field instrumentation.

As required each drive has its field or MCC devices wired to the programmable controller for monitoring and control. Stop buttons, motor overloads and personnel protection devices (such as conveyor lanyards) are hardwired in a “failsafe” manner into the MCC control circuits for the safety of personnel.

Within the programmable controller I/O racks, modules of each type are grouped together, i.e. discrete inputs, discrete outputs, analogue inputs, analogue outputs. In some locations, remote I/O blocks may be used to reduce control cabling.

All digital and analogue control logic will reside in the programmable controllers. This includes:

- The sequential control and interlocking of all drives
- Analogue control of process variables
- Monitoring of digital and analogue field variables
- Alarm and message generation.

All control functions are performed by the PLC controller.

Windows-based PLC programming software is used for the generation of the PLC code.

The SCADA interface is installed on a panel mount display. This interface is capable of being installed on a windows based PC if required.

Motor currents of selected equipment are monitored by the control system.

4.13 Control System Specifications and Standards

PLC code shall be generated using control language consistent with that specified in IEC61131.

The proposed I/O connection types to be used are:

- Discrete inputs 24 VDC, common negative
- Discrete outputs relay, isolated
- Analogue inputs 4-20 mA
- Analogue outputs 4-20 mA

OIS displays are logically organised to follow the process flow through the plant. The displays contain a mixture of mimic and tabular information.

The displays and functions provided include:

- An overview mimic configured to contain the basic plant operating parameters, and KPIs allowing plant-wide performance to be monitored from a single display.
- Graphical displays configured to mimic the plant. These graphic displays operate and control the process equipment and instrument devices.
- Facility to monitor parameters via trend displays.
- Provision to log alarms.
- The control system is capable of interfacing and sharing data with other enterprise business packages. This connection and configuration is not a standard included.

The control system communicates between the PLC and operator interface hardware via an Ethernet Network. The Ethernet network connects all MCCs via a cabled connection and is capable of being connected to a third party network for monitoring and support if required.

The control system is not intended to be connected to existing Ethernet networks without using equipment that restricts network traffic which may affect control system performance.

5 Design Philosophy

All design will comply with the requirements of the local Acts, Regulations, Rules, By-laws and other requirements of the United States Government, Local Governments and other Statutory Authorities and in particular to:

- In the case of conflicting information the following descending precedence will apply:
 - Statutory Acts and Regulations
 - Project Standards
 - US Standards
 - International Standards.

The facility design will be undertaken in line with Sedgman standard technical specifications. The cost estimates will be considered as being reflective of these expectations.

All materials used will be new. The materials used will be selected on the basis of the application (considering wear and corrosion), life cycle, constructability and cost. The materials used will provide the most effective solution for each application, consistent with past industry history and design.

5.1 Key Design Objectives

The design will be developed according to the following key objectives:

- The design will be based on the use of modern, high capacity equipment with minimal duplication or redundancy.
- The design will include a modern electrical and control system that enables remote monitoring, automatic control and remote operation of the facility
- The facilities will be designed to provide a working environment that is safe and user-friendly for all construction, operating and maintenance personnel.
- The design will facilitate ease of access for inspection, handling, transportation, installation, adjustment, control, maintenance and repair.
- The design will minimise spillage and operational delays during normal operation and provide for ease of cleaning.
- The design will deliver a plant that is highly reliable with appropriately planned and targeted scheduled maintenance and capable of sustainably achieving benchmark performance when compared to peers.
- The design will allow for change-out of non-consumable items, with repairs and overhauls typically being done in a controlled (workshop) environment where practical.
- All major process components will have direct crane or vehicle access. Mono-rail (or similar) will be provided to assist with routine maintenance tasks in areas where direct crane or vehicle access is not possible.
- The design will incorporate good ergonomic principles to minimise soft tissue injury risk to construction, operations, or maintenance personnel.
- The design will allow for rapid and simple isolation of plant components on maintenance days, thereby maximising utilisation of the available scheduled maintenance time. Critical services such as air, power, lights, and water will be able to operate unhindered.

- Equipment design will provide for simple and effective condition monitoring of all components as a key facet of the reliability strategy.
- Lay down areas will be provided so that maintenance consumables and equipment specific tooling can be placed in the plant in preparation for maintenance.
- Where suitable, routine maintenance tasks such as greasing will be piped to a centralised location.
- The design will incorporate standardisation throughout. The number of different items used throughout the facility will be kept to a minimum to reduce the size of strategic spares inventories.

5.2 Health and Safety

- All plant will be designed with consideration for the safety of the construction, operating and maintenance personnel.
- All plant and facilities will be designed with suitable lifting accessibility to ensure safe working procedures are practiced when lifting, removing and maintaining equipment.
- All machinery hazards e.g. rotating pinch points, and drives, will be physically guarded.
- All elevated platforms, regardless of height, will be fitted with handrail and kick plates.
- Large-aperture inspection openings will be provided in all chute work and at appropriate places in machinery with appropriate means of locking the hatch open or closed.
- Where possible the plant will be designed to minimise the need to enter a confined space.
- Provision will be made for the positive drainage of all areas of the facility, both internal and external.
- All elevated concrete floors will be graded to permanent drains. Inlets in elevated floors are to be located in positions that minimise interference and obstruction to normal operations.
- Critical energised equipment including, without limitation, electrical cabling and stations, pipelines, pumps, motors, radiation sources, will be located out of reach of impact by vehicles and mobile plant wherever possible.
- Pipelines or equipment which carries high pressure fluids will be designed to protect all persons from potential fluid injection injuries due to failure or accidental release.
- All isolation valves will be lockable and clearly labelled as to the open and shut position.
- The plant will minimise the need to manually handle tools, equipment or parts.
- The plant will be designed to minimise noise and vibration exposure to personnel.
- The design will consider the use of hazardous substances to construct, operate and maintain the plant.
- The plant design will aim to provide fall prevention controls in preference to fall protection.
- Access
 - Two means of egress will be provided throughout the facility.
 - The following vertical clearances will generally be provided around equipment, piping structures and platforms:
 - Major plant roads around facility (excluding haul roads) 4.5 m
 - Dozer walk paths 5.5 m
 - Over pumps and other rotating equipment Variable (depending on specific equipment change out requirements – height will be sufficient to allow equipment to be lifted and removed via appropriate lifting equipment)

- Clearance to conveyor gantries – vehicles 4.5 m
 (Unless dozers have to pass underneath then) 5.5 m
 - Clearance to conveyor gantries – pedestrians 2.1 m
 - Facility head height clearance 2.1 m
 - A minimum 900 mm clearance will be provided for inspections and maintenance access around equipment. Reduced local clearances may be permitted provided it does not occur at access locations.
- Doorways will open onto a landing or floor of not less than 900 mm x 900 mm and not directly onto stairs.
- Stairway access will be provided between levels and to inspection and maintenance platforms. The use of fixed vertical ladders is not permitted.
- Noise levels of individual pieces of equipment will be limited to a target of 85 dB(A) at 1 metre. Noise exposure to employees from the combined operating plant will need to be modelled to assess the appropriate level of hearing protection (PPE) needed. Standard facility hearing protection 1 will be required as a minimum.
- Air Quality
 - Fugitive dust will be minimised. Refer to dust suppression provisions in section 12.4.
 - All bins and hoppers will be designed to contain (via enclosure) or suppress (via sprays) dust.
 - The ROM hoppers will be fitted with a dust hood and water spraying system.
- Water Management
 - Cleanout / sedimentation pits will be provided at the base of the ROM bins, sizing stations, reject bin and transfer stations. Local wash-down or run-off will discharge by gravity via the cleanout / sedimentation pits.
 - Concrete slabs at the head and tail end of each conveyor to facilitate clean-up in these areas will be provided. Wash down will report to sedimentation pits before discharging to the site wide drainage system.
 - All cleanout / sedimentation pits will be able to be cleaned with an integrated tool carrier (IT 28) or bobcat as nominated.
- Hazardous Goods
 - All hazardous materials storage and handling will be designed to minimise exposure to personnel.
 - All radiation gauges will be located in minimum traffic areas and will ensure compliance with the Maersk Radiation Safety and Protection Plan. A separate radiation store facility will be provided for radiation sources. Alternatives to radiation-based instrumentation will be actively evaluated, with a goal of eliminating or at least minimising the number of sources.
- The use of asbestos is prohibited.

5.3 Time Definitions

The following definitions of time in Table 5-1 to be used for the Inferno Project.

Table 5-1 Performance Indicator Definitions

Performance Indicator and Symbol	Definition
% Availability (A)	The percentage of calendar time the plant was physically available for work. $A = AT/CT * 100$

%Utilisation (U)	The percentage of calendar time the plant was performing its primary function. U= OT/CT " 100
------------------	--

Notes of DICE System Design & Development

Coal-Based Power Plants of the Future

**Louis Wibberley, Doug Palfreyman,
Coralie Lewis & Peter Scaife**

20 March 2020

Disclaimer

CSIRO advises that the information contained in this publication comprises general statements based on scientific research. The reader is advised and needs to be aware that such information may be incomplete or unable to be used in any specific situation. No reliance or actions must therefore be made on that information without seeking prior expert professional, scientific and technical advice. To the extent permitted by law, CSIRO (including its employees and consultants) excludes all liability to any person for any consequences, including but not limited to all losses, damages, costs, expenses and any other compensation, arising directly or indirectly from using this publication (in part or in whole) and any information or material contained in it.

Table of contents

Glossary	421
1 Overview	423
2 DICE System Design	424
2.1 Conceptual DICE plant	424
2.1.1 Background	424
2.1.2 Engine modifications needed for MRC	427
2.1.3 Fuel specifications for DICE.....	433
2.1.4 DICE power plant layout	443
2.1.5 DICE costs	447
2.1.6 DICE performance.....	449
2.1.7 DICE learning curve	456
2.2 Operational strategy.....	458
2.2.1 Startup.....	458
2.2.2 Pilot fuelling.....	458
2.2.3 Shut down	459
3 DICE Technology Gap Analysis & Development Pathway	460
3.1 Limitations/adaptation of current engines for DICE	460
3.2 Technical risks and issues	465
3.3 Key R&D requirements for development	466
3.3.1 Fuel R&D.....	467
3.3.2 Engine component R&D.....	469
3.3.3 Logistics R&D.....	470
3.4 Development pathway	470
3.4.1 Development imperatives	470
3.4.2 De-risking with staged development	471
3.4.3 Scale up risk	472
3.4.4 Staged development program.....	472

GLOSSARY

ash	the residue formed after combustion of coal comprising both altered minerals and organically bound inorganics
BOP	balance of plant
BTDC	before top dead centre
cenosphere	hollow fly ash formed from gas evolution within a molten ash droplet
DWI	direct (<i>ie</i> into the cylinder) injection of water
GW	gigawatts
EERC	Energy & Environmental Research Centre, Grand Forks, North Dakota
FGD	fluegas desulfurization
HAM	humidified air motor
Heat rate	fuel consumption expressed as energy content in the fuel (<i>eg</i> kJ/kWh)
HFO	heavy fuel oil
HHV	higher heating value
HRSG	heat recovery steam generator
JGC	Japanese Gasoline Corporation
JCF	JGC coal water fuel
kW	kilowatts
LHV	lower heating value (<i>ie</i> without the heat of condensation of the products of combustion)
MAN	MAN Diesel and Turbo
MJ	megajoules
MRC	micronised refined coal; a generic term being used for coal water fuel produced by finely milling coal and cleaned by various methods to reduce the mineral ash content. It is proposed that the feed coal could include any coal, and hydrothermally treated and dried coals.
Mtpa	megatonnes per annum
MW	megawatts
MW _e	megawatts electrical
O&M	operation and maintenance
pf	pulverised fuel
R&M	repairs and maintenance, <i>cf</i> O&M
SAM	scavenge air moisturisation (sometimes termed charge air humidification), a type of HAM
SCR	selective catalytic reduction of nitrogen oxides to N ₂
SE	specific energy
TRL	technology readiness level
VM	volatiles content (as determined by heating to 915°C in a lidded crucible)

WIF water in fuel (an emulsion formed by high shear mixing of water into fuel oil), a type of HAM

1 OVERVIEW

This report provides our current view for the system design of a direct injection carbon engine (DICE) and a technology gap analysis and development pathway. Specific items covered under these areas are as follows:

DICE System Design

1. Estimated technical and performance information on conceptual DICE design, including:
 - a. Conceptual engine modifications needed for coal-water slurry combustion
 - b. Discussion on specifications of coal-water slurry required for combustion in DICE
 - c. DICE machinery equipment dimensions
 - d. DICE machinery material selection
 - e. Overall plot layout
 - f. Pertinent information needed to enable the development of heat and material balances and process flow diagrams (PFDs) as inputs for modeling of the DICE system
 - g. Conditions and composition of the exhaust gas leaving DICE, including criteria pollutants such as SO_x, NO_x, and particulate matter (PM)
 - h. Fuel consumption and utility consumption required by DICE
2. Expected Nth-of-a-kind capital cost for DICE and discussion of a pathway towards cost reduction
3. Discussion on startup, turndown and shutdown of DICE system

DICE Technology Gap Analysis and Development Pathway

This will consist of the following components:

1. A current-state-of-the-art for internal combustion engines and application for firing coal, including key shortcomings, limitations, and challenges.
2. How the engine modifications made for DICE will overcome such shortcomings, limitations, and challenges.
3. Key technical risks and issues associated with developing DICE.
4. Addressing perceived technology gaps.
5. R&D that is needed for commercialization by 2030 (including key stages of pilot, demonstration, and scale-up plans for advanced commercialization).
6. A development pathway description for DICE that will overcome key technical risks and issues.
7. The need for a DICE pilot-scale demonstration with the size of such a plant justified.
8. Details, if available, of anticipated test plans, including information on ramp-up and part-load operation, and intended hours of continuous operation.

2 DICE SYSTEM DESIGN

2.1 Conceptual DICE plant

The following section details the conceptual DICE power plant based on the current understanding of the technology, and how large 4-stroke medium speed diesel engines could be adapted for DICE.

Engine adaptations for coal-water slurry (termed micronized refined carbon or MRC) are dependent on both the type and speed rating of the engine and the quality of the MRC fuel.

The section includes a short history of DICE development, and to provide further context, an analogy with water injection and bitumen emulsions recently used in diesel engines.

2.1.1 Background

Base engine choice

Although a wide range of engines has used MRC fuels, including up to 1900 rpm in the earlier USDOE program, lower speed engines are most suitable:

- Low-speed two-stroke marine type engines (10–100 MW at 90–120 rpm). Note that the latest super long-stroke versions of these engines (~60 rpm) are considered less likely to be economic for a land-based generator due to the cost of the alternator, extra weight, and foundations required.
- Large four-stroke low-speed¹ engines (20 MW at 400-500 rpm)

Low engine speed is recommended for coal because this increases the time for ignition and combustion, which reduces the requirement for fine atomization of the fuel. While fine atomization of slurry fuels is technically possible, this comes at the cost of increased atomizer wear and thermal efficiency, as it requires lower viscosity fuel (more water) and higher nozzle velocity.

Low-speed engines also have larger cylinder bores which have two significant advantages for MRC fuels:

- Allows for longer fuel jets – important for difficult fuels as fuel jets must not impinge on the cylinder liner, and
- Larger cylinder heads/covers provide more space for a dual injection system.

An additional benefit of the large, low-speed engines is their longevity and tolerance to lower quality fuels – for conventional diesel engines, this includes the use of residual fuel oils, which contain up to 0.2 wt% of highly abrasive corundum-like catalyst fines. For MRC, this includes increased tolerance to mineral ash content, coarser coal top size and, higher viscosity.

The choice of engine will also be site and application dependent. While the low-speed engine has slightly higher efficiency and lower maintenance costs, the cost of these engines is higher at nominally \$1,300 k/MW compared to \$750 k/MW for medium-speed engines. Overall, installed costs will be location, site, and project-specific.

¹ Industry nomenclature: low speed <400 rpm, medium speed 400-1000 rpm, high speed >1000 rpm

Recent developments improve adaptability for coal slurry fuels

Despite being an extremely mature technology, reciprocating engines continue to undergo development that improves suitability for DICE. These developments should result in higher thermal efficiency, higher flexibility, and lower capital cost than for conventional coal-based generation plants. Developments include higher firing pressures (up to 300 bar), electronic control, more efficient turbochargers, new materials for highly stressed components (valve seats, cylinder liner coatings, ring coatings, valve seats/sealing for high-speed gas valves). To some extent, this has been driven by the use of alternative fuels such as biofuels (corrosive), LNG, and bitumen water fuels. For example, electronically controlled (eg MAN ME type) engines are implemented as “intelligent engines” with auto-tune ability for individual cylinders – highly beneficial for maximizing combustion efficiency for MRC.




Figure 1 A low speed engine with generator by MAN (55 MW, 120 rpm)



Figure 2 MAN gas engine generators (20 MW units at 500 rpm)

Manufacturers

A range of manufacturers produce lower speed 4-stroke engines (say 500 rpm), which could include derating of 600 and 720 rpm engines.

For large marine-type 2-stroke engines, there are only 3 suppliers – MAN, WING&D and MHI. All of these 2-stroke engines are produced in SE Asia (China, Korea, and Japan) under license. Although MAN is presently the only supplier offering large 2-stroke engines for land-based power generation, other suppliers have expressed interest in producing large low-speed 2-stroke engines optimized for (constant speed) power generation given sufficient need.

While most manufacturers have had some previous negative experiences with coal fuelling of engines, all acknowledge that the previous work was undertaken without a high level of commitment, and none of the programs were completed because the expected scenario of oil shortages did not materialize or funding ceased.

Future developments will benefit from recent experience with Orimulsion and MSAR (multiphase superfine atomized residue), previous experiences from the USDOE program for black coals, and more recently by CSIRO's R&D for both black and brown coals and chars.

Bitumen-water fuels – an analog for MRC

The use of bitumen water emulsions and slurries in diesel engines provides a good analog for MRC.

Over the last 25 years, there have been several initiatives to produce bitumen water fuels to replace HFO in boilers, and these fuels have also been used in diesel engines. Fuels include Orimulsion produced from natural bitumen and MSAR produced from refinery residue (an extremely heavy tar) - developed as an Orimulsion replacement for diesel engines. While it is a problematic fuel, giving both poor ignition and highly abrasive catalyst fines, it is used as a marine fuel in adapted engines. Also, as the bitumen component of MSAR has a very high viscosity of $>10^6$ mPa.s at ambient temperature, it is essentially a slurry of solid bitumen in water and thus is analogous with MRC (especially from bituminous coals).

Wärtsilä has extensive experience with firing Orimulsion into medium-speed 4-stroke engines (including a 40 MW demonstration power plant at Vaasa, and a 150 MW power plant in Guatemala).

Humidified diesel engines

A summary of humidified diesel engines is given, as water in fuel is associated with poor thermal efficiency in steam plants, and is not normally associated with diesel engines.

Combustion of fuel-water emulsions is the oldest and easiest method of reducing NO_x emissions in diesel engines. In this technology, water is added to the fuel and passed through an emulsifier immediately before injection into the combustion chamber as an effective way of reducing the flame temperature - thereby suppressing the formation of NO_x. An efficiency penalty of ~2% (*ie* an increase of 4% in fuel consumption) is incurred for a water/fuel volume ratio of 0.87 (equivalent to ~50% water in fuel on a mass basis) – which is considerably less than if used in a steam plant.

Direct water injection (DWI)

Several direct water injection technologies have also been used: Wärtsilä has used this in medium-speed engines, and involves injecting water into the cylinder just before injection of the fuel. Injection rates of 0.4-0.7 kg water/kg of fuel are typically used. Special injectors, comprising separate water and fuel nozzles, are used. The advantage of this system is that the

water penalty is substantially avoided as the water spray cools the compressed air charge, thereby reducing compression work.

Mitsubishi Heavy Industries has developed a more complicated version of water in fuel for NO_x control. This system is called stratified fuel-water injection (SFWI), and it uses a single injector to inject slugs of fuel-water-fuel sequentially into the combustion chamber to maintain more extended control of peak combustion temperatures.

DWI and SFWI systems generally give a 70% reduction in NO_x for a thermal efficiency penalty of 1-1.5% points (around 2-3% on a heat rate basis).

Scavenge air moisturization (SAM) is the most favored system for reducing NO_x for the larger low-speed engines and involves humidifying the scavenge air immediately before entering the cylinder with warm seawater or freshwater injected and evaporated into the hot air from the turbocharger compressor to saturate the air to the cylinder (around 7-9 vol% water). Wärtsilä has a variant of this for large 4-stroke engines, with fogging nozzles introducing freshwater directly into the charge air stream after the turbocharger, resulting in combustion air with a humidity of around 60 g water/kg of air (10 vol %). This technique reduces NO_x levels by over 70%.

MAN has achieved similar NO_x reduction levels by increasing the humidity of the charge air with seawater. Compressed hot air from the turbocharger is passed through a humidification tower (a packed bed) that is fed with hot seawater heated by the engine's cooling system.

Overall developments in humidification have demonstrated that diesel engines can tolerate high levels of water ingestion (including seawater mist) without a significant impact on fuel consumption, thermal efficiency, or engine longevity. MDT claims an efficiency of 59% (LHV, flywheel) for a 12K98 engine with waste heat recovery using SAM (Jensen, 2009). For stationary power generation, this is equivalent to around 56% sent out basis.

2.1.2 Engine modifications needed for MRC

Overall modifications

Table 1 below gives nominal engine component modifications for both 2- and 4-stroke engines. The most significant changes are for the fuel supply (*ie* the low-pressure fuel supply from the service tank) and the high-pressure injection system.

Table 1 Nominal engine component modifications for DICE

Component	4-stroke	2-stroke
Engine foundations	No change	
Engine frame, bedplate, crankcase	No change	
Crankshaft	No change	
Cylinder liners	Hard coating, optional provision of oil scrapper grooves to allow increased	Hard coating, optional provision of oil scrapper grooves to allow increased bore lubrication and

Component	4-stroke	2-stroke
	bore lubrication and flushing of solids to reduce filtration load on crankcase lubrication	flushing of solids above the scavenge ports
Piston	No change in short term, optimization of bowl shape for MRC rather than low NOx as required for fuel oil	
Rings	Hard coating, improved design to improve down scrape of contaminated bore oil	
Exhaust valves	No change	
Stuffing box	-	Seal oil protection to eliminate the ingress of contaminated cylinder oil
Scavenge box drainage	-	No change if scrapper grooves are used in the cylinder walls otherwise improved drainage
Crankcase oil filtration	200% increased filtration capacity; dual systems to allow on-line maintenance, separate centrifuge for cylinder scrape	No change, but with separate centrifuge for reconditioning cylinder scrape
Fuel supply system	<p>A dual system is required: One for MRC and one for a diesel/fuel oil used for starting, idling and optional pilot injection (1-5% of heat rate, as is currently used for some gas engines).</p> <p>The MRC system should provide a small, controlled circulation flow around the fuel rail and injectors to enable rapid flushing of the system and to eliminate clogging of the fuel system when the engine is not in operation. This circulating flow should be down through the injectors suction valve to the seat of the needle/cut off valve and should be controlled either electronically or from the same oil that actuates the fuel pump plunger. The spring-loaded inertial valves often used with HFO are not recommended due to the variable flow properties of MRC (shear thinning) and seat wear.</p> <p>It is recommended that a twin pump low-pressure fuel system is used, with one pump controlling the pressure in the circulating flow, and the other used to control the return flow.</p>	
Injection system	Seal oil protected sliding surfaces, including the pump plunger and needle valve. For typical hydrocarbon seal oils, the seal oil should be maintained at around 120% of the fuel supply pressure at all times (critical during engine off), and to 120% of the high-	

Component	4-stroke	2-stroke
	<p>pressure fuel pressure during injection. This strategy minimizes seal oil consumption and oil contamination of the fuel return flow (which, if excessive, can cause coal particles to agglomerate).</p> <p>A single high-pressure seal oil system can be used if a water-soluble seal fluid is used (eg a polyglycol such as UCON).</p>	
Pilot injection	<p>Pilot injection is essential for engine conditions where ignition is less reliable - starting, idle, and shutdown. The amount will depend on the MRC properties, engine speed, cylinder size, and whether Miller cycle is used (lowers compression temperatures). Pilot injection is recommended for engine speeds above 400 rpm, and at low load.</p> <p>The electronically controlled pilot injection is essential to allow fine-tuning of MRC combustion.</p>	
Exhaust manifold (low speed 2-strokes)	<p>While the fly ash produced from MRC combustion is likely to be very fine <10µm and to remain in suspension, the 20-40x increase in solids passing through the engine will inevitably cause ash deposits that will shed periodically as larger grit. A grit dropout before turbocharger is therefore recommended (as is sometimes used with residual fuels). Large horizontal exhaust gas ducting should be provided with a positive grit removal system (eg bottom auger, chain conveyer, blowers) – especially for the large main exhaust collector across the top of the engine.</p>	
Exhaust turbine	<p>No change for ash with aerodynamic diameter <10µm. Possible use of coated metal for inlet guide vanes.</p>	
Waste heat recovery	<p>Conventional solid fuel boiler rather than finned heat exchangers standard for fuel oil or natural gas. A vertical fire tube or horizontal water tube is preferred to reduce ash clogging. Until experience is gained to prove otherwise (given the different fuel chemistry and combustion conditions), access is required for manual soot blowing with compressed air or steam.</p>	
Exhaust gas cleanup	<p>The same as used for large land mounted 2-stroke engines using heavy fuel oils – ESP or fabric filtration, SCR and FGD</p>	
Lubrication	<p>Adjustment of crankcase oil base number to match sulfur content of the MRC and with increased detergency to keep char and ash in suspension. Base number should take into</p>	<p>Adjustment of cylinder lubricant base number to match sulfur content of the MRC. Base number should take into account any sulfur reporting to the ash.</p>

Component	4-stroke	2-stroke
	account any sulfur reporting to the ash.	

Fuel supply system

There have been several fuel supply systems proposed for DICE, which all involve some method of agitating the fuel in storage, plus a valving system to enable system flushing of the pump and lines to the injectors. A better system includes a screening system before the main fuel supply pump and controllable return flow. This system is shown schematically in Figure 3 and operates as follows:

- Fuel is stored in a 12,000 m³ service tank sufficient for ten days supply for a 100 MWe plant. This tank is equipped with either a live bottom or a very slow speed rake-type agitator (say 1 revolution per hour). Note, that, conventional high-speed tank mixers are ineffective, giving localised agitation only due to the shear thinning behavior of MRC, and are energy intensive.
- Fuel passes through a pulse screen filtration device before a positive displacement supply pump. The speed of the supply pump is controlled to maintain the supply rail pressure. A screen aperture of 350µm would be suitable for an engine with injector orifices of 600-800µm. Various screening devices can be used. However, MRC rapidly clogs filters with apertures finer than 10-15x the maximum particle size unless pulsed. The purpose of screening is to allow the bulk of the fuel to pass but trap major oversize particles and contamination such as flakes of rust, paint *etc.*
- The fuel supply pump is a positive displacement pump (progressive cavity type) which supplies the fuel supply rail. The speed of the supply pump is controlled to maintain the supply rail pressure.
- Electronically controlled unit injectors are preferred for the MRC (*eg* HEUI or MEUI type) to allow closer control of injection timing. The injectors should preferably incorporate fuel circulation valves, which allow controlled flow of fuel down through the injector's pump and preferably down the body of the injector to the needle/cut off valve seat, and back out to a return rail.
- A positive displacement (progressive cavity type) return pump operating in reverse is advantageous to control the total return flow to the service tank, or in the case of flushing, to a dump tank. The letdown pump need only be ~10% of the capacity of the supply pump – which would enable complete flushing of the system within (say) 30 seconds. The speed of the return pump is controllable to set the return flow. Operating the return pump in reverse reduces shaft seal wear. Controllers should be tuned to allow dead-heading without damaging the pumps.




Figure 3 Suggested fuel supply system

Fuel injection system

A range of high-pressure injection systems has been used for MRC, including:

1. Conventional jerk pump (200 bar) - line - media separator (shuttle piston or diaphragm) – nozzle (GE and Cooper Bessemer during the earlier USDOE programs).
2. Hydraulic actuated pump (600 bar) – media separator (diaphragm) – nozzle (CSIRO)
3. Unit injector: Common rail hydraulics (700 bar) – seal oil protected media separator – nozzle (WING&D/Maersk)
4. Unit injector: Hydraulic ram (150-300 bar) – seal oil protected plunger – nozzle (CSIRO/MAN)

Although all options have been made to work with MRC, the unit injector-types 3 & 4 have the advantage of compactness and controllability. Desirable features include:

- 1) Modular body construction (to facilitate maintenance and component development), comprising a:
 - servo oil valve module containing a high-speed solenoid valve
 - hydraulic actuator module,
 - pump module,
 - fuel ring module containing a non-return valve for the fuel inlet
 - lower flanged body which contains the usual spring, push rod, nozzle body and cut-off needle valve.

- 2) An automatically (this could also be electronically actuated) operated return valve to provide positive fuel flushing around the injector between injection events and whilst the engine is standing. This ensures continuous movement of the fuel, which dramatically reduces the chance of clogging, enables rapid fuel switching, or system flushing – either during engine operation or when stopped. Figure 4 below shows the circulating flow around the injector required to ensure high reliability. This injector shown is an enlarged version of an injector for a 4L single-cylinder laboratory engine at CSIRO.
- 3) All fuel wetted surfaces are provided with seal oil continuously (this can be hydraulic or motor oil) at a slightly higher pressure than the fuel (say 25 bar).
- 4) The fuel pump and needle spindle are provided with high-pressure seal oil during the actual injection event. The seal oil pressure can be provided by an integral intensifier pump within the injector's hydraulic ring, or from an external supply. In the case of the latter, a two pressure system should be used to reduce seal oil pressure when the engine is standing, to avoid unnecessary seal oil contamination of the return fuel.
- 5) Although MRC has a much higher viscosity than diesel fuel, CSIRO has found that only a slightly larger orifice size is required (say 10% larger diameter) due to the strongly shear-thinning behavior of MRC fuels (if correctly prepared). Shear-thinning results in marked wall slip, which increases the volumetric flow of a nozzle. Experience has shown that a nozzle size of 500-750 μm will provide a balance between atomization and jet penetration for cylinder bores up to (say) 50 cm.




Figure 4 CSIRO injector showing fuel return circulating flow through the injector

2.1.3 Fuel specifications for DICE

This section discusses the specifications of MRC required for combustion in DICE. An overall summary of fuel specifications is followed by additional discussion for each of the critical properties.

Fuel for DICE has significantly different quality requirements than for conventional coal slurry fuels used in boilers. This difference is because engines have short combustion times (say 30 ms in engines, versus 1-2 s in boilers), which requires more intense atomisation than for a boiler. Also, in engines, unburnt char and ash particles will cause chronic engine wear, piston ring jamming, and even turbocharger erosion. Also, the exhaust system of engines is not designed to

pass significant ash – which for DICE could be 30x that of even the lowest quality residual fuel oil.

In DICE, it is paramount that the fuel 1) gives a high degree of atomization during injection (which ensures rapid ignition, combustion, and complete burnout), 2) forms minimal abrasive ash particles, 3) has the highest coal solids loading. These requirements will be strongly interdependent, and also be strongly influenced by the size of the cylinders, engine speed, and the extent of engine armoring. Overall properties include:

- Low abrasive mineral content – to minimize injector nozzle and cylinder/ring wear especially.
- Coal particle size distribution with a d50 of <15 μ m and a d90 <60 μ m to ensure burnout.
- High coal content to minimize latent heat losses from fuel water – subject to meeting viscosity specifications.
- High stability of formulated fuel to prevent settling in the fuel handling equipment, as well as ease of transport and storage.
- Strongly shear thinning behavior to allow injection and effective atomization – essential for controlled heat release and to minimize unburnt char.
- Resistance to microbial action – some slurry fuels are prone to bacterial degradation, which can affect both stability and shear thinning behavior – in addition to increasing OH&S concerns.

Nominal target specifications, based on both literature and recent engine experiences are as follows:

- Ash content <2% (dry coal basis)
- Residual mineral size <15 μ m and preferably <5 μ m
- Coal particle size distribution giving a d50 of <15 μ m and d98 <50 μ m
- Coal content of the fuel should be as high as attainable, while still meeting the following nominal rheology targets:
 - >10,000mPa.s @ 0.1/s
 - <400 mPa.s @ 100/s
 - <100 mPa.s @ 10,000/s and be shear thinning at higher shear rates
- Specific energy >18 MJ/liter
- pH of 3.5-8.5
- Stable – say exhibiting no settling (coherent cake on the bottom surface) over 90 days when stored in a sealed 500 mL measuring cylinder at (constant) ambient temperature. After 90 days, all MRC should drain from the upturned measuring cylinder.

Experience has shown that, while individual properties can be readily met, achieving a balance between all properties is more difficult. For example, a high SE fuel can be produced by increasing the solids content, which will have the advantage of also increasing fuel stability. However, this will also increase the viscosity and may cause shear thickening behavior, which will make the fuel very difficult (even impossible) to inject, resulting in poor atomization. The resulting large fuel droplets (containing many smaller coal particles) will likely dry to form a single large coal agglomerate, resulting in slower ignition and incomplete combustion. This will

invariably lead to chronic ring jamming by char. The resulting flash from poor atomization is also likely to be larger due to the interaction and fusing of fine mineral grains and organically bound ash forming components within the coal. These interactions are discussed in more detail below.

Coal loading

Coal loading has two main effects, 1) strongly affects fuel viscosity – especially at higher coal loadings (say >55 wt%), and 2) water reduces the calorific value of the fuel and increases the latent heat penalty.

It is important to note that while the effect of coal loading on calorific value is linear, the effect on viscosity is exponential at higher coal loadings (say 57wt% for bituminous coals, and above 53% for sub-bituminous coals – depending on the shape of the size distribution). This rapid increase in viscosity means that the maximum coal loading is usually dictated by the highest viscosity - which ensures satisfactory atomization.

Coal particle size

As a guide, at 500 rpm, around 30 ms is available for combustion, and practical experience suggests that a coal top size of 50-60 μ m will give satisfactory combustion with minimal unburnt char in the exhaust – providing atomization is sufficient. Sub-bituminous coals (higher oxygen content, more reactive chars) and lower speed engines are likely to allow a coarser tail in the size distribution.

However, there are several other factors that need to be considered, as the particle size distribution of the coal in the MRC strongly affects the fuel's rheology for a given coal loading, and therefore its atomization, ignition, and combustion. The particle size distribution also affects the degree of mineral liberation during fuel preparation and the size distribution of liberated minerals in the final fuel.

In general:

- A wide size distribution allows a higher particle packing efficiency, and therefore coal loading (this can be calculated), which improves thermal efficiency and fuel stability, and reduces fuel transport costs.
- An optimum coal loading and wide particle size distribution should give a high low shear viscosity (essential for fuel stability in storage) and shear thinning behavior, which enables injection and atomization. Coal loadings above the optimum rapidly cause shear-thickening fuel, which causes fuel system clogging and poor atomization.
- Both the quality of atomization and the coal top size affect the effective size of the coal at the time of ignition - which in turn determines the time for combustion. Finer grinds may not be better: For example, overly fine grinds can increase fuel viscosity and result in poor atomization. Subsequent agglomeration of the coal during heating, and before combustion, results in a coarser effective coal particle size distribution than that of dispersed particles.

In general, the slower the engine, the larger the allowable top size; however, this also depends on the devolatilization behavior of the coal under the extremely rapid heating and intense combustion intensity in an engine. Combustion intensity can exceed 5 GW/m³ – around two

orders greater than for pf combustion –some coals are likely to exhibit a large enhancement in volatiles yield, which gives faster ignition and combustion. Overall, combustion data for coal in engines is lacking, and existing data for pulverized coal firing is likely to be misleading for DICE.

Coal volatiles

Although there is no literature information on the effect of coal volatile content, with previous engine experience using only medium to high volatile coals (28-40%), higher volatile coals are expected to give improved ignition and combustion. However, the standard method of determination of coal volatiles (the Proximate analysis) will underestimate the effective volatiles content under the extremely rapid heating rates of atomized MRC and the high pressures in diesel engines (which can exceed 150 bar at the start of injection). The morphology of the resulting char is also likely to be very different than that for conventional pulverized coal combustion in boilers, and more akin to that in slurry fed gasification.

The effects of volatiles on ignition and combustion are also affected by the oxygen content of the coal. For example, CSIRO has found that low volatile chars (carbonized at 850°C and containing around 5% volatiles) require 40°C higher charge temperature to achieve the same ignition performance as a 30% VM bituminous coal, and hydrothermally treated Victorian brown coal (45% VM and with 25-27% O) giving an ignition temperature 60°C lower. Note that with these low rank coals, a significant proportion of the volatiles content is CO₂ and H₂O).

Ash content

Ash is the residue after complete combustion, and comprises altered mineral particles from the extraneous ash components, plus finer particles from condensed, oxidized and sulfated compounds formed from the fine, organically bound and mineral particles contained within the coal particles. As the latter interact during burnout of the char, these particles are usually a complex mixture of aluminosilicates and sulfates depending on the coal.

After combustion in a diesel engine, all mineral particles below 10µm size are spheroidized, including quartz. However, even highly fused ash particles have the potential to cause cylinder wear unless the diameter is less than the minimum oil film thickness (1-2µm). Larger sand particles will be most problematic.

For low rank coals and wood chars, the ash also comprises ultra-fine micron size particles formed from the volatilized ash components. Cenospheres have also been observed (see Figure 5). Neither the submicron fume nor the cenospheres are likely to cause abrasive wear.




Figure 5 SEM images of cenospheres from DICE using a hydrothermally treated Victorian coal

The wear implications of ash require that a detailed investigation of the occurrence of the ash forming constituents of the target coal is undertaken to understand the ramifications for engine wear. This also requires collecting fly ash from either an engine or an appropriate high-pressure spray combustion chamber.

The present understanding of ash-engine interactions is that:

- Coarse (say, $>5\mu\text{m}$) and hard minerals (quartz, pyrites, rutile) in the fuel will increase abrasive wear of the atomizer nozzles, rings, cylinder wear, exhaust valve seat, and the turbocharger turbine inlet vanes and rotor.
- Ash residues can also deposit in the oil film on the cylinder wall and be scrapped by ring action to pack in the piston ring grooves behind the ring – a potentially serious condition leading to catastrophic scuffing.

Although these issues could theoretically be eliminated by using harder material and changing the design of engine componentry, all previous DICE projects have been on the basis that DICE requires cost-effective production of ultra-low ash coals - the cleaner, the better.

However, coal specifications for commercial deployment of large diesel engines remain to be established, and in particular, there is a lack of data linking engine wear to ash content and the morphology of the mineral content. Also, there is no information on the trade-off between processing cost, fuel ash, and engine component and maintenance costs. For example, abrasive wear can only occur if the abrading particle is 30% (approximately) harder than the underlying material. For coal ash, the dominant hard material is usually quartz with a hardness (Vickers) of around 11 kgf/mm^2 , showing that a wide range of commercially available ceramics could be used to prevent abrasive wear (Figure 6 below) – provided that they can be incorporated into an engine.




Figure 6 Hardness of materials relative to coal ash

The earlier USDOE work generally concluded that coal with 2-3% ash would likely be suitable, thereby enabling the use of physically cleaned coals (as distinct from more costly chemical cleaning). In recent studies with MAN and WING&D/Maersk, the target ash was <1.5% with a maximum of 2%, noting that this limit was set by available fuel quality and the use of unarmoured engines, rather than based on a sound techno-economic basis. Also, these targets were set with little consideration of the type and morphology of the starting mineral matter – mostly due to limited capacity to produce tonnage fuel required for the large engine tests involved. The morphology is very significant, as recent wear tests (using a modified HFRR² test) by CSIRO has shown that oils contaminated with fine ash from lower rank coals decreases wear of hardened steel by up to 30%. For tungsten carbide HFRR components, there was a negligible difference between clean and contaminated oils regardless of the mineral type.

Overall, the lack of data has caused a divergence of philosophies between the engine manufactures and the coal industry, which has hampered DICE development. To generalize, the engine manufactures have required that the fuel should be made to match the (current) engine componentry, whilst the coal suppliers have pressed for armored engine componentry to allow higher ash MRC. This dilemma requires that a full-size DICE facility (including fuel preparation plant) are established to allow longer-duration engine trials with armored engine componentry, and for a range of MRC quality. Quantifying the effect of ash on engine componentry costs, durability, and other R&M issues would result in a scientifically based coal quality value model needed to progress the technology.

Sulfur

Large diesel engines designed to operate with heavy fuel oil can tolerate relatively high sulfur fuels (>2%), providing cylinder lubrication uses the appropriate lubricant (*ie* base number) to avoid an acid attack of the cylinder walls. As MRC will require deep cleaning of coal, sulfur levels of the proposed Powder River Basin coals should not be a problem – even if S containing dispersants are used for fuel formulation (*eg* sodium polystyrene sulfonate).

Alkalis

While alkalis are a significant issue for coal-fired boilers (nominally, for Na₂O:SiO₂ ratios >0.04, or in the presence of high S and Cl), to date, there is no evidence that alkalis are an issue for DICE. Recent CSIRO experience with a chemically cleaned coal (a caustic ash removal process) with a high Na:SiO₂ ratio showed negligible ash deposits after 40 hours at full load of a 4 litre single-cylinder test engine – see Figure 7. Other indirect evidence is from marine engines, which show no cylinder fouling despite ingesting salt spray (from humidification or aftercooler leaks).

² High frequency reciprocating rubbing test (a lubricity test)



Figure 7 Head valves after 40 hours of full load operation using MRC produced from Yancoal UCC (courtesy Yancoal)

It is surmised that the lack of ash fouling is a result of the large pressure swings (> 100 bar) for each engine cycle, which regularly mechanically sheds the porous particulate ash deposits (*ie* deposit panting).

Viscosity/rheology

Fuel rheology has been largely overlooked in previous RD&D programs to use coal for diesel engines, other than to ensure the fuel's viscosity was sufficiently low to enable injection without nozzle clogging. However, in the recent CSIRO studies, fuel rheology was a major focus due to other important interrelated effects - ignition, burnout, and both injector and cylinder wear.

In general, the coal content must be maximized (at least 50%, and preferably $>55\%$) to reduce latent heat penalty - but also while meeting the following rheological targets:

- High viscosity at low shear rates (say $10,000$ mPa.s @ $0.1/s$) is essential for good stability.
- Rheology that is strongly shear thinning, and
- Viscosity of <400 mPa.s @ $500/s$ to ensure good injectibility and atomisation.

These specifications are very different to that of coal water slurries for boilers, which have a higher coal loading and much higher viscosity at higher shear rates (including being shear-thickening rather than thinning). This difference in rheology is clearly apparent when the different fuels are poured from a beaker – see Figure 8 below.




Figure 8 Fuel rheology. Left, coal water fuel for a boiler by JGC; right, MRC for DICE

The first 2 requirements above – stability and shear thinning - are the most important attributes, as fuel stability is essential to producing a fuel with the correct rheological properties for DICE: Stable and shear thinning fuel (providing the caloric value is high enough) will always make a good engine fuel – which can be thinned if necessary prior to injection with trim water additions. However, the reverse is not always the case: Highly injectable fuels will not automatically exhibit good stability. Strongly shear thinning fuel (correlates with good stability, handling, injectability, atomisation - and ultimately good combustion and reduced wear issues from unburnt char packing behind piston rings).

Unstable fuel is particularly problematic, regardless of how well it injects, due to the formation of deposits in fuel handling equipment, which, at worst will clog fuel injector nozzles, or at least increase the effective particle size of the fuel entering the combustion chamber leading to poor combustion and char issues. Once MRC forms a hard pack deposit due to poor stability, mechanical means are required for its removal.

Figure 9 below shows nominal rheology plots for good, and poor MRC fuels.




Figure 9 Nominal MRC rheology for a good and poor fuel

Stability

Fuel stability, or lack of build-up of sediment in fuel containers with storage, is essential to avoid serious operational issues from blockages, plus secondary effects described in the rheology section above. An unstable fuel is unacceptable for DICE.

Most established stability tests only require stability over relatively short periods (say) 1 week – this is too short. CSIRO work is aimed at 100% stability for >1 month, and preferably >6 months. This testing period is much longer than specified by most stability tests for coal water fuels for boilers. It is noted that some bulk slurries produced to this specification have been completely stable with negligible sediment for more than 2 years.

In general, lower rank coals will provide more stable fuels.

Control of microbial activity

Microbial activity in the fuel has the potential to destabilise the slurry, in addition to causing safety concerns. However, CSIRO experience with MRC fuels from 48 coals from Australia,

Venezuela, Indonesia, and Germany have shown no evidence of microbial activity – except for a single NSW coal slurry prepared by others. Microbial activity has however, been observed with MRC produced from low-temperature chars – see Figure 10.



Figure 10 Microbial activity on pine char slurry after 205 days

2.1.4 DICE power plant layout

The base engine specified for the concept DICE plant is the MAN 48/60 TS – see Figure 11.

Although the model is being replaced with a revised model, the 48/60 engine was chosen for the present study as the type is highly efficient with a 2-stage turbocharging system, and with over 800 units installed since the product was launched in 1988 – for both power generation and marine propulsion. The choice of this engine has not been endorsed by MAN.




Figure 11 MAN 48/60 TS³

A nominal plant layout based on five of these engines (ie 100 MWe) is shown in Figure 12 – with a description of key plant is given in Table 2 below the layout.

³ <https://powerplants.man-es.com/products/liquid-fuel-engines/18v48-60ts>




Figure 12 Nominal plant layout for 100 MWe

Table 2 List of key plant

ID	Comment
ST1-4	Storage tanks 12,000m ³ each - each sufficient for 10 days at full output
FT	Fuel treatment plant to enable screening, and optional reconditioning of off-line tanks for out of specification fuel, including dosing pumps for additives to trim for water content, additives, biocide
D1-5	DICE engines with generators, 5x 20 MWe
HRSG	Heat recovery steam generator
STG	Steam turbogenerator
FF	Fabric filtration
FGD	Optional flue gas desulphurization unit
SCR	Optional denitrification by selective catalytic reduction
S	Stack
CT	Cooling system, dry cooling via radiator banks using a combination of natural convection and forced draft
WTP	Water treatment plant for steam plant and coolant makeup

ID	Comment
AS	Ash storage, elevated hopper, by-product for pozzolanic uses
DR	Desulphurization reagent bin
GS	Gypsum dump
SY	Switchyard
S&EQ	Stores and mobile equipment pool
WKSP	Engine workshop
OB	Office block
CR	Control room
SP	Settling pond for runoff and washdown

Utilities

The utilities for DICE will be very similar to those for a land-mounted low speed 2-stroke diesel engine power plant requiring full exhaust gas cleanup, with allowances for the differences in fuel handling – noting that heavy fuel oil installations also require power for tank agitation, plus high speed centrifuges and heated fuel lines. For DICE, freeze protection of fuel storage and handling equipment will be required.

Table 3 below gives a breakdown of nominal parasitic load for a DICE installation, which amounts to around 2% of power output at the generator terminals.

Table 3 Nominal plant parasitic loads

Plant	Description	Attribute	Power (kW)
DICE specific			
Fuel tank agitation	Live bottom	4 tanks	20
Fuel delivery pump	Progressive cavity	25 bar, 14.5 L/s, 65% effic	57
Fuel return pump	Progressive cavity	Letdown only, 1.5L/s	5
Fuel stainer	Pulse strainer		5
Exhaust ID fan	Centrifical, exhaust gas cleanup pressure drops	System ΔP 15kPa, 80% effic	60
Normal auxiliaries	Cooling system HRSG pump Ventilation Lighting Control/offices		2000 (typically 2% of total output)
		Total	2147 2.1%

2.1.5 DICE costs

DICE costs have been estimated for an Nth-of-a-kind installation, and includes a discussion of a pathway towards cost reduction.

Given that most of the plant is very similar, the installed costs of DICE are likely to be similar to those for a plant fuelled by HFO that is equipped with FGD, SCR and particulates control (around \$1M/MW) - noting that all 3 emissions controls are normally only used for large generating plant using low speed 2-stroke marine-type engines using the heaviest of fuel oil.

The main differences in plant costs for DICE would be:

- Larger bunkering (MRC fuel has only half the volumetric energy content of HFO)
- Differences in fuel pretreatment – MRC would not require preheating (except to prevent freezing), nor the installation of expensive precleaning centrifuges and screen filters – instead self-cleaning pulse filters would be installed to remove extraneous material (eg rust flakes)
- Increased crankcase oil filtration capacity to cope with additional ash and unburnt char
- Armored engine components – fuel pump valves, atomizer valves and nozzles, piston rings, turbocharger inlet nozzles

- Dual fuelling, with a smaller diesel injection system used for starting, warmup and (probably) pilot assisted ignition
- The addition of a grit dropout cyclone before the turbocharger turbine (this is not to collect fly ash or char, but rather flakes of ash deposits which will be continuously shed from the cylinder head and piston).

Previous work has estimated that these changes and additional equipment would add around 20% to the installed cost for a commercial installation, but this would also be dependent on R&M.

R&M will be higher for DICE - as it is for residual and heavy fuel oils compared to lighter diesel fuels. However, this will be highly dependent on the use of premium quality components, with higher initial outlay resulting in lower R&M.

Both capital cost and R&M are expected to decrease significantly as experience is gained with DICE – and its associated fuel cycle – from coal in the ground through to generator terminals and the stack:

- The learning rate for DICE should be steeper than for the highly mature base technology – the diesel engine – and be driven more by that of new component technology.
- Research and development will be critical to driving down costs – both through incremental improvements (*eg* nano boron-nitride or polycrystalline diamond for wear critical components) and step change technology (*eg* blast atomization – lower nozzle wear, higher viscosity fuel, higher overall efficiency).
- Current experience with DICE is minimal – totaling less than a few thousand engine hours, so learning by doing will be essential for developing DICE and driving down costs. Practical experience is also likely to result in a wide range of incremental improvements across the fuel cycle, including logistics.
- Economies of scale, which for DICE are expected to be related to multiplicity – more cylinders and more engines - rather than larger cylinders/engines. It is likely that given the expected high R&M requirements, DICE experience will also result in incremental improvements to both base engine design and maintenance procedures. For example, engine designs with increased modularity to enable rapid switch out of fuel systems and cylinder power units. More units will also give direct learning benefits via installation logistics – which for large engines and inland locations can be considerable.
- Next-generation DICE will gain a step benefit from a multitude of new and incremental technology improvements made since the USDOE funded program in the 1980's – not only for large engines used for stationary generation but also those for automotive and heavy haulage application. Technologies include individual cylinder monitoring and electronic control, many new materials and manufacturing techniques – plus the broader availability of larger engines and highly refined emissions control options. Another essential factor is changed drivers (*eg* nimble, high efficiency at a small scale to support new grid demands)., which provide additional economic benefits to allow increased engine component costs

2.1.6 DICE performance

An engine model was used to predict the thermal efficiency and exhaust gas of a MAN 18V48/60TS engine using MRC from a Powder River Basin coal (2wt% ash, but otherwise using an as-mined coal composition). This data is required for the assessment of heat recovery/integration options by others.

The engine model used is a 1-dimensional thermodynamic model, using thermodata from the NASA thermobuild system, and free energy minimisation from the NASA CEA program. In-cylinder processes assume a homogeneous mixture of air and combustion products, ideal gas behavior and that the system is at thermodynamic equilibrium.

Cylinder heat loss

The heat transfer co-efficient is calculated using the Woschini equation⁴. With this equation three stages in an engine cycle considered:

- gas exchange period (between exhaust valve open and inlet valve close)
- compression
- combustion and expansion period

$$h_c = \frac{3.26}{1000} D^{-0.2} P^{0.8} T^{-0.53} w^{0.8}$$

where:

h_c = heat transfer coefficient (kW/m².K)

D = cylinder bore (m)

P = cylinder pressure (kPa)

T = cylinder temperature (K)

w = average cylinder gas velocity (m/s)

$$w = C_1 S_{\text{MeanPiston}} + C_2 \frac{V_{\text{displacement}} T_0}{p_0 V_0} (p - p_m)$$

where:

C_1 = constant (6.18 for period 1; 2.28 for periods 2 and 3)

$S_{\text{MeanPiston}}$ = mean piston speed (m/s)

C_2 = constant (0 for periods 1 and 2; 3.24×10^{-3} for period 3)

$V_{\text{displacement}}$ = cylinder displaced volume (m³)

T_0, p_0, V_0 = temperature, pressure and volume

Equilibrium products

Additionally, during combustion, the equilibrium composition is calculated using free energy minimization. A limited number of species are modeled, Ar, CO, CO₂, H, H₂, H₂O, N, N₂, NO, NO₂, N₂O, O, O₂, OH, SO₂. These species are the only ones that will occur at any significant concentrations and were included mostly to take into account dissociation at higher temperatures,

⁴ Woschni, G., "A Universally Applicable Equation for the Instantaneous Heat Transfer Coefficient in the Internal Combustion Engine," SAE Transactions, Vol. 76, p. 3065, 1967

rather than the amounts of minor species. SO₂ levels in the exhaust gas assumed that there is no partitioning of S to fly ash components. While the latter does occur in boiler off-gases (especially for coals with high alkali/alkaline ash), the extent is unknown for DICE with much shorter residence times below 1000°C.

Friction calculations

The model uses the Chen-Flynn friction model⁵ which has the form:

$$FMEP = C_{FMEP} + (C_{PCP} * P_{Peak}) + (C_{MPS} * S_{MeanPiston}) + (C_{MPSS} * V_{MeanPiston}^2)$$

where:

FMEP	=	friction mean effective pressure (bar)
C _{FMEP}	=	constant for FMEP
C _{PCP}	=	constant factor for peak cylinder pressure
P _{Peak}	=	peak Cylinder Pressure (bar)
C _{MPS}	=	constant factor for mean cylinder velocity
S _{MeanPiston}	=	mean piston velocity (m/s)
C _{MPSS}	=	constant factor for mean cylinder velocity squared

Heat release rate

The most important aspect of the combustion phase is the calculation of the rate at which the fuel will combust, generally referred to as the heat release rate (HRR). The model using a three term Wiebe heat release model⁶ fitted with actual heat release rate data from a hydrothermally treated Victorian lignite, which imposes a non-predictive burn rate based on crank angle

Its single term form is

$$C_A = \left(\frac{D_A}{2.302^{-(1+E_A)} - 0.105^{-(1+E_A)}} \right)^{-(1+E_A)}$$

where:

C _A	=	Weibe constant for part of the combustion
D _A	=	duration of that part of the combustion (°)
E _A	=	exponent for that part of the combustion

In the three-term form used in the model, the combustion profile is separated into three section, a premix phase, a main diffusive phase and a tail diffusive phase. With these three phases an overall expression for the fraction of fuel consumed is as follows:

$$F_t = 1 - (F_p + F_d)$$

$$F_{Fuel}(\theta) = F_p(1 - e^{-C_p(\theta - \mathcal{T}_{SOI} - \mathcal{T}_{IgnD})^{(E_p+1)}}) + F_d(1 - e^{-C_d(\theta - \mathcal{T}_{SOI} - \mathcal{T}_{IgnD})^{(E_d+1)}}) +$$

⁵ Chen, S.K., and Flynn, P.F., "Development of a Single Cylinder Compression Ignition Research Engine," SAE Paper 650733

⁶ Wiebe I., Halbempirische Formel dur die Verbrennungsgeschwindigkeit, in Kraftstoffaufbereitung und Verbrennung bei Dieselmotoren, ed. G Sitkei, pp. 156-159, Springer-Verlag, Berlin, 1964

$$F_t(1 - e^{-C_t(\theta - \mathcal{T}_{SOI} - \mathcal{T}_{IgnD})^{E_t+1}})$$

where:

$\mathcal{F}_{Fuel}(\theta)$	=	Fraction of fuel burnt at crank angle θ
F_p	=	Fraction of fuel burnt in premix phase
F_d	=	Fraction of fuel burnt in diffusive phase
F_t	=	Fraction of fuel burnt in tail phase

The values of the constants can be varied to match actual heat release data from experimental data. In the model this has been done with the data for coal, while recommended values have been used for diesel.

During the exhaust phase the cylinder contents discharge to an exhaust chamber, which is assumed to remain at a constant pressure.

To calculate the exhaust mass flow, compressible flow through the exhaust valve in both choked and un-choked conditions must be modeled – based on the criteria of Streeter and Wiley.

The effective area for the exhaust port is calculated as the annular area created between the actual exhaust port and the exhaust valve as it is opened multiplied by a discharge coefficient. The lift profile is modeled initially with a sinusoidal function based on a specified lift rate. The area is then unchanging until the valve closes again based on the same lift rate. The shape of the curve can be varied by changing the value of the lift rate as well as the opening and closing positions.

Base engine parameters

The model was based on engine parameters obtained from MAN Energy Solutions, and missing parameters (some key information are proprietary) estimated from best available literature data – eg valve timing. The procedure was to:

- Obtain a reasonable fit with published data using diesel fuel, and using the same parameters repeat for PRB coal assuming 50 and 55wt% coal in the fuel.
- Repeat the calculations for two different firing strategies: 1) fixed heat input rate and 2) fixed peak combustion pressure. These cases were included to simulate likely operating extremes using MRC (because the water content and heat release rate are significantly different from diesel fuel oil, resulting in lower combustion pressure).

The ignition delay for fuel oil was 2.5 ms, and for MRC 5 ms was used (experimentally determined for hydrothermally treated Victorian brown coal).

Important: This type of simulation can only provide a guide to engine performance until detailed information is available on the combustion characteristics of the chosen PRB coal, and engine adaptations are proven with full-scale operational experience. For example, the engine maker may require the derating of the peak firing pressure due to ring wear concerns or may reduce the allowable pressure limit to account for the increase in power (and therefore stresses on other parts of the engine) that is possible with MRC firing.

The results of the modeling are summarized below in Table 4, which includes nominal firing conditions, exhaust gas composition, and thermal efficiencies for the 50 and 55 wt% coal MRCs and the two firing strategies. NOx concentration has been taken from laboratory engine data using a hydrothermally treated brown coal (PRB MRC is expected to have similar combustion

characteristics), and particulates loading is calculated assuming a 2% ash MRC. SO₂ assumes that all coal sulfur reports to the gas (depending on the ash chemistry, some sulfur will also report as sulfates in the fly ash).

Table 4 Summary of engine modelling based on a nominal MAN 18V48/60TS

Case			Stock	PRB-1	PRB-2	PRB-3	PRB-4
Firing strategy				Same heat input rate		Same peak pressure	
Fuel			Diesel	55% PRB	50% PRB	55% PRB	50% PRB
Item	Attribute	Unit					
Pilot fuel	Energy proportion	%	-	1	1	1	1
Ignition delay		ms	2.5	5	5	5	5
Fuel rate		kg/s	1.41	3.62	3.97	6.61	7.33
Fuel temp		°C	90	90	90	90	90
Air to compressor		kg/s	2.31	2.33	2.33	2.34	2.35
Compressor outlet		°C	246	246	246	246	246
		bar	5.8	5.8	5.8	5.8	5.8
Charge air cooler outlet		°C	43	43	43	43	43
Compression start	Crank	° BTDC	220	220	220	220	220
		°C	51	49	48	49.4	48.3
		bar	5	5	5	5	5
Injection	Start	° BTDC	2.5	2.5	2.5	2.5	2.5
	Ignition delay	ms	2.5	5.0	5.0	5.0	5.0
	Charge temp at SOI ¹	°C	674	665	662	665	661
	Charge press at SOI ¹	bar	212	211	211	210	210
Max press	Crank	° ATDC	17	24	24	24	24

Case			Stock	PRB-1	PRB-2	PRB-3	PRB-4
Firing strategy				Same heat input rate		Same peak pressure	
Fuel			Diesel	55% PRB	50% PRB	55% PRB	50% PRB
Item	Attribute	Unit					
Max temp	Press	bar	257	217	218	257	257
	Crank	° ATDC	25.7	33.6	33.5	35.8	35.7
	Temp	°C	1382.	1267	1248	1790 ²	1759 ²
Exhaust start	Crank	° ATDC	140	140	140	140	140
	Gas temp	°C	582	521	494	862	819
Turbine inlet	Cylinder press	bar	13.5	13.1	12.8	19.6	19.1
	Flow	kg/s	57.0	59.5	59.9	62.8	63.6
	Average temp	°C	427	386	376	604 ²	589 ²
	Average press	bar	6.3	6.3	6.3	6.3	6.3
Exhaust	Temp	°C	224	196	188	366	355
	Press	bar	1.0	1.0	1.0	1.0	1.0
	Volume flow	Nm ³ /s	34.6	37.0	37.5	39.1	40.0
	Ar	mol%	0.9	0.8	0.8	0.8	0.8
	CO ₂	mol%	5.0	5.6	5.5	9.6	9.4
	H ₂ O	mol%	5.2	11.3	12.8	18.2	20.7
	N ₂	mol%	75.7	69.9	68.7	64.8	62.9
O ₂	mol%	13.2	12.3	12.2	6.6 ³	6.3 ³	

Case			Stock	PRB-1	PRB-2	PRB-3	PRB-4
Firing strategy				Same heat input rate		Same peak pressure	
Fuel			Diesel	55% PRB	50% PRB	55% PRB	50% PRB
Item	Attribute	Unit					
	SO ₂	ppmv	-	139	136	509	496
	SO ₂	ppmv	-	139	136	509	496
	NOx (lab engine)	ppmv	-	900	1000	? ⁴	? ⁴
	Particulates	g/Nm ³	-	0.81	0.79	1.40	1.37
Cycle summary							
	Net power output	kW	22009	20688	20381	37205 ²	36963 ²
	Heat to coolant + radiation	kJ/s	3586	2700	2532	6554 ²	6302 ²
	Heat to exhaust	kJ/s	18768	18466	18293	34074 ²	34215 ²
	Fuel consumption (diesel equiv)	g/kWh	173	184	187	190	193
	Efficiency indicated	% HHV	51.2	49.42	48.88	46.43	45.76
		% LHV	54.5	51.5	50.9	48.2	47.5
	Efficiency net	% HHV	45.8	44.0	43.3	43.5	42.7
		% LHV	48.7	45.8	45.1	45.2	44.4

¹ Start of injection ² Excessive, likely to be impractical ³ Low, likely to be impractical ⁴ No estimate available

The modeling results show that Cases PRB-1 and PRB-2 (*ie* with the same heat input as for diesel fuel oil) give the closest match in engine performance, with:

- Thermal efficiency of 45.1-45.8% LHV.
- A 40 bar (15%) reduction in the peak combustion pressure.
- A decrease in power output of 6-8%.
- An increase in coal loading from 50 to 55%, giving an increase in thermal efficiency of 0.7% points, or a decrease in the heat rate of 1.6%.

The modeling results with the same peak pressure as for diesel fuel oil, Cases PRB-3 and PRB-4, gave a radical change in engine output and exhaust conditions. If practical, this method of firing would:

- Increase power output by around 68%.
- Increase exhaust temperature by 300°C, and reduce the oxygen content to 6-7 mol% (and thereby increase CO content).
- Reduce engine thermal efficiency by 4.5% points compared to diesel fuel.
- Overall, this option would be best suited for plants additional heat integration – including with waste heat recovery by turbo compounding and/or steam plant, or post-combustion capture of CO₂.

2.1.7 DICE learning curve

The learning curve for DICE is atypical in that 1) there have been two previous periods of development separated by decades, and 2) the technology is only a slight variation of a standard diesel engine, and 3) earlier developments were restricted to individual demonstration engines. The expected learning curve is discussed in the context of generations and thermal efficiency and cylinder size, and is shown schematically in Figure 13 below:

Generation 1: Development of the diesel engine was initiated by Rudolf Diesel's proposal to use coal in a compression ignition engine in 1892. However, shortly afterward he abandoned coal as a fuel and concentrated his work on oil fuels. Serious work on coal-fuelled diesel engines was renewed in 1911 by Rudolf Pawlikowski, a former co-worker of Diesel.

After solving many technological problems, four firms reported the successful operation of 19 engines from 6–400 kW and engine speeds from 160–1600 rpm. All of these 1st generation engines used dust firing – either by aspiration/fumigation into the inlet air, or by air-blast injection. Little development of fuel processing is reported from this period, with the engines using commercially available coals, coke and charcoals (biochar) – some with up to 12% ash, and with engine operation up to 8,000 hours. Thermal efficiencies of around 30% (HHV) were achieved, and the engines ran without fouling and with clean exhausts.

Generation 2: Following World War II, abundant, low-cost oil removed the economic incentive for further development until the early 1970s, when coal-diesel mixtures were investigated as fuel extenders – mostly in small high-speed

engines. A short series of tests were also undertaken in Europe using large slow-speed research engines at Sulzer Bros (now WING&D), and at Burmeister and Wain (now MAN B&W) using coal–fuel oil mixtures in unmodified engines, but chronic wear issues exacerbated by poor atomization prevented development. Much better results were obtained with coal water slurry (*ie* MRC), leading to a larger development program by the USDOE over 1982–92, involving AMAX (fuel production), Cooper-Bessemer/Arthur D Little, Sulzer, General Electric, Adiabatics/Sulzer, General Motors ElectroMotive Division, Detroit Diesel Corporation, Southwest Research Institute, and others. The program not only defined economic and technical conditions under which engines could be commercialized, but also advanced the state of the art through pilot testing of both fuel production and engines. Although these developments progressed through to a technology readiness level (TRL) of 5-6 (component demonstration and pilot testing), the prolonged slump in oil prices and the lack of interest by a suitable (big-bore) engine manufacturer terminated development. Other factors also contributed to the lack of progress, including the high cost (relative to current production costs) of the MRC fuel due to the lack of efficient fine milling technology, and the focus on medium speed engines (up to 1,000 rpm) – which are considerably more challenging to adapt.

- Generation 3 Recent and current developments focussed on larger lower speed engine (500 rpm and lower), but which piggy-back on the earlier USDOE work to adapt current commercial engines (with new materials and with economics based on new drivers – energy security, domestic coal, lower CO₂ intensity). The objective being for new DICE-based coal to replace old coal and natural gas.
- Generation 4 Projected DICE developments in which the engine and fuel are optimized for maximum overall fuel cycle costs and performance. It is envisaged that these would include larger cylinder sizes, the ability to fire paste fuel, co-fuelling with bioenergy, and CO₂ capture.




Figure 13 Generations of DICE development

2.2 Operational strategy

2.2.1 Startup

It is recommended that engine starting and warm-up to operating temperatures should use fuel oil or diesel. Cold starting of large engines (which tend to use lower quality fuel) is always somewhat marginal, as the heat losses from a cold cylinder and a slow compression stroke, plus cold injection equipment, means that the charge temperature at the start of injection is lower (say 400°C) than when hot and at speed (say 650°C). This is an issue, as all coals have a higher autoignition temperature (530-575°C) than fuel oils (250-375°C).

It is, therefore, unlikely that MRC will be suitable to start a cold engine. Even if the engine started, the higher unburnts from a cold engine would cause problematic contamination of the cylinder bore, with unburnt coal packing behind the piston rings. This packing would cause accelerated ring and cylinder wear, and possibly ring breakage.

The use of diesel fuel oil for starting will require a dual injection system – a small capacity one for starting, and a larger one for MRC. An additional benefit is that the smaller capacity system for diesel fuel oil could also be used for pilot fuelling.

2.2.2 Pilot fuelling

DICE may require some pilot fuelling – an established technology with natural gas engines, especially those needed to operate as dual-fuel engines (*ie* as distinct from lower compression spark ignition gas-only engines – Otto cycle). The amount of pilot fuel required needs experimental data. It will depend on the engine (speed, cylinder size, boost, aftercooling *etc*, which affect the charge temperature at the start of injection) and the effective volatiles content of the MRC. However, it is expected that a fixed 2-5% of the heat rate at maximum output would

be sufficient – which automatically provides a higher proportion of heat input when required at idle and lower load settings.

For low-speed engines (<400 rpm), and based on practical experience, it is expected that the engine could operate reliably on 100% MRC, providing the engine is hot and above (say) 35% load. For lower load and higher speed engines, minimum pilot fuelling with fuel oil is likely to be required. As both startup and pilot injection will require a separate injection system, operationally, some minimum pilot injection will likely be preferred to provide cooling of the pilot injector nozzles.

Injection timing for the pilot injection would normally be just before, or at the same time, as the MRC –both being electronically timed to allow optimization for different engine conditions and fuel variations.

In addition to a lower speed, derating the engine by reducing the amount of aftercooling (a higher air inlet temperature would give a reduction in cylinder charge, with a disproportionate increase in compression heating) – which may also reduce the need for pilot fuelling.

The requirement for assisting ignition with pilot fuel provides an additional implementation strategy: installation of dual fuel NG engines now, being progressively switched to DICE as required using a retrofit kit.

2.2.3 Shut down

With a correctly designed fuel system, engine shut down can be achieved without any precautions. To achieve this, the fuel system will require some method of controlling a circulating flow of fuel down the injector to the needle valve and back to the service tank – as described in Section 2.1.2. If this feature is not included, then a full flush of the fuel system from the feed pump through the injector will be required while the engine is operating to eliminate the possibility of stagnant coal fuel clogging the hot injection system while stopped. With the latter system the engine shut down would be under pilot fuelling.

While diesel fuel has been used as the flushing fluid in some previous trials by simply switching the fuel supply to the engine from MRC to diesel, this arrangement is not recommended. In contrast to MRC, diesel fuel requires perfect sealing of valve seats (*ie* the needle or cut off valve in the injector) to ensure that fuel does not leak into the cylinder under the influence of the fuel supply pump. Also, any MRC that is not flushed from the system by the diesel fuel will highly likely result in agglomeration of the residual coal particles, potentially causing blockages. If this method of flushing is chosen, then an alternative flushing fluid should be used, for example, a mixture of long-chain polyglycol (*eg* UCON) and water. This fluid would have the advantage of being miscible with MRC. In both cases, the switch over to the flushing fluid needs to be undertaken at less than half-load to avoid over fuelling the engine.

3 DICE TECHNOLOGY GAP ANALYSIS & DEVELOPMENT PATHWAY

3.1 Limitations/adaptation of current engines for DICE

While atomized MRC burns well in diesel engines, the engines require several essential modifications, and the engine also need to be low-medium speed (preferably <500 rpm) to allow for longer combustion time and to reduce the the fineness of atomisation required to achieve efficient combustion.

To some extent these modifications are already used for commercial engines using Orimulsion and MSAR (bitumen-water emulsions – a close proxy for coal-based slurry in terms of combustion), high pressure gas, liquified gases and alcohols. However, for DICE additional essential modifications are required. While most are straightforward engineering, several critical components will require redesign. The limitations and adaption of current engines for DICE is discussed for the following aspects:

- Cylinder size and speed
- Wear coatings
- Piston
- Ring shape
- Dual injection
- Injector
- Exhaust ducting
- Cylinder drains
- Turbocharger

Size and speed

For coal, the cylinder size should be as large as possible and the engine speed as low as possible – larger and slower, respectively, than economically optimal for comparable installations using fuel oils and gas. Although low-speed engines cost proportionally more per MW, the benefits for coal are a reduction in cylinder wear and an increase in wear tolerance due to larger component sizes. In addition to increased wear tolerance, large bore and low speed mean that fineness of MRC atomization is less critical, and this allows both larger orifices (results in longer fuel jets) in the atomizer nozzle and lower injection pressure. Both are essential to reducing nozzle wear. A larger bore also increases the space available for the injector, which for MRC will likely be larger to accommodate ceramic components.

Fuel supply system

Conventional fuel supply systems are unsuitable for MRC and will require redesign to avoid clogging and wear issues. The MRC supply system should provide a small, controlled circulation flow around the fuel rail and through the injectors to enable rapid flushing of the system and to eliminate clogging of the fuel system when the engine is not in operation. This

circulating flow should be down through the injectors suction valve to the seat of the needle valve and be controlled either electronically or from the same oil that actuates the fuel pump plunger. The spring-loaded inertial valves often used with HFO are not recommended desirable due to the variable flow properties of MRC (shear thinning) and seat wear.

It is recommended that a twin pump low-pressure fuel system is used, with one pump controlling the pressure in the circulating flow, and the other used to control the return flow – as described in more detail above in Section 2.1.2.

Injectors

Conventional injection equipment, including pump-line-nozzle, hydraulically actuated electronically controlled unit injectors (HEUI), mechanically actuated electronic controlled unit injectors (MEUI) and common rail injectors are completely unsuitable for MRC due to instantaneous jamming of sliding parts with coal particles, clogging of fuel galleries and rapid wear due to erosion/cavitation. Required modifications are summarised in below.

Jamming of any sliding surfaces wetted by the fuel. This is especially the case for the fuel pump plunger and the cut-off needle valve spindle, which will jam solid within several injection cycles unless protected by a higher-pressure seal oil. This also precludes the use of a conventional jerk pump with spill ports to control injection rate.

Clogging of fuel ways if the fuel is allowed to remain stagnant – especially if the engine is hot and the fuel has been repeatedly pressurized to injection pressure (which can destabilise the fuel). This means that the flushing of the fuel system is necessary either before stopping the engine or immediately after stopping.

Erosive wear of fuel system components, especially the atomizer orifices, but also for the non-return valve seat and the needle valve seat. The size of fuel galleries must also be increased to reduce fuel velocities to below 10 m/s if possible. Velocities over 20 m/s will cause galleries to wear. Erosive wear is further accelerated by corrosion-erosion mechanism if materials subjected to high-velocity fuel are not sufficiently hard and corrosion-resistant.

Cavitation wear is increased with MRC due to the higher vapor pressure of the fuel's continuous phase (water), and also due to its higher viscosity. Other fuel properties may contribute to cavitation, including the high particulates loading and the strongly shear-thinning nature of MRC, which tends to channel flow.

Piston

The piston bowls of modern engines are shallow and wide for less intense fuel-air mixing to reduce peak combustion temperatures and NO_x formation: NO_x should not be an issue due to the cooling effect of the fuel water – but requires full scale demonstration. Although the optimum shape for MRC has not been identified, it is probable that the older-style, deeper bowl, higher squish piston will give better results by providing faster and more complete fuel air mixing, which effectively increases the combustion time and allows the use of lower excess combustion air. The latter will also result in a higher charge temperature at the start of injection, further improving both ignition and combustion. Fuel-air mixing for DICE is also likely to be enhanced by the need for additional nozzle orifices to pass the higher fuel volume of MRC. A deeper bowl piston is also expected to reduce fuel contamination of the upper cylinder bore.

Piston rings

There has been little published R&D on ring design for MRC. Conventional ring designs with hard coatings have given reasonable performance with MRC – but tests appear to have been of short duration (a maximum of 200 hours continuous). It is speculated that an optimized ring design will be necessary to minimise wear via 1) additional cylinder lubrication to carry away char and ash contamination of the cylinder wear surface, 2) avoiding Brinelling by hard ash particles means that pressure equalisation across the ring pack will be more important which also increases the minimum oil film thickness, 3) ring porting/draining needs to be increased to allow for a step increase in particulates (ash and char) in the lubricant film, 4) ring shape may need to be changed to increase down scrap of contaminated lubricant to collection points. Piston ring rotation would also assist in evacuating contaminated oil grunge from behind the rings.

Materials

In general, the materials used for the critical components in the fuel system, piston rings and cylinder liner in conventional diesel engines are unsuitable for MRC. High hardness is essential to avoid abrasive wear from coal ash. Although ceramic coatings are available for piston rings and liners, conventional hard coatings are generally too thin to prevent the Brinelling effect of large hard fly ash particles – *ie* indenting through the hard coating into the softer substrate. Thicker, more monolithic coatings will be necessary with binders that are resistant to corrosion and grain plucking. The injector nozzle is particularly challenging. Although conventional polycrystalline diamond compacts have been shown to be effective in managing nozzle abrasive and cavitation wear of nozzles, the newer nano-particle compacts of polycrystalline diamond or cubic boron nitride are expected to give an even better performance – and are tougher. These materials should also be used for fuel system valve seats and needles/poppets. A redesign of the injector is required to utilize these ceramics, in particular, as the ceramic components require an increase in component cross-section to compensate for lower tensile strength.

MRC can be handled using conventional steels (as for coal water fuels); however, it is recommended that components downstream of the fuel strainer are constructed from rustless steels – especially the engine fuel delivery system and high-pressure injection system. This is to reduce scaling and erosion-corrosion. For pump and injector bodies, steels recently developed for biofuel should be considered (*eg* Duval TN15 or similar).

Exhaust ducting

Conventional horizontal ducting between the turbocharger turbine outlet and emissions control equipment will likely result in ash deposits on the lower surfaces of ducting – especially from shed ash deposits. Minimizing horizontal runs, live bottom ducts (*eg* equipped with drag chains), dropout boxes, soot blowers, and other measures will need to be used to prevent deposition from becoming an issue.

Dual injection

A dual injection system will be necessary to allow the engine to start and warm-up on diesel or lighter fuel oil, and to enable pilot injection to control ignition (depending on the MRC quality). For some engines, the fuel oil side of the existing dual-fuel system may be used - possibly downsized to match only starting and pilot rating.

Cylinder lubricant drains

To accommodate increased particulates contamination of the cylinder lubricant film, increased cylinder lubrication is required, with provision to collect contaminated down scrap of lubricant (eg using a spiral/circumferential oil collection groove(s) near the bottom of the stroke). This arrangement will enable dirty lubricant to be routed out of the engine for separate deep cleaning using a centrifuge, thereby reducing the filtration load on the crankcase lubricant system.

Turbocharger

Coarse particulate matter in the engine exhaust will cause inlet vane and turbine erosion, especially for particles larger than (say) 10 μ m. While the bulk of the flyash is likely to be finer than this value (larger cenospheres are unlikely to be an issue as they are spherical and being hollow have a small equivalent aerodynamic diameter), ash deposits shedding from inside the engine and exhaust ducting will be larger. For this reason, turbines and inlet vanes will require hard facing – as used for large low-speed 2-stroke marine engines using heavy and residual fuel oils.

Technology gaps

While it is believed that there are no technical limitations concerning adapting an engine for DICE (this is an engineering issue only), there are a number of technology gaps that continue to hamper development. As these involve both the fuel and the engine, these gaps are discussed under that of a new fuel cycle involving the production of new fuel, for adapted engines for new coal generation markets:

- For the fuel, this includes producing a suitable slurry fuel from coal for a new end use, for which little experience.
- For the engine, these involve designing and manufacturing new critical components for an engine with acceptable longevity and R&M requirements – and for economically viable fuel quality.
- Overall, there is a lack of logistics/infrastructure for a DICE fuel cycle.

While all issues were considered to some extent in the comprehensive USDOE program from 1978-92 (which focused on bituminous coal replacing diesel fuel) this data is only partially relevant to the present initiative, which targets a sub-bituminous coal and larger capacity stationary generation. Also, there has been a range of new technologies and business drivers over the last 25 years – for example, more efficient mills, new abrasion-resistant materials, manufacturing methods, electronic control, the rise of the reciprocating engine for both decentralized and baseload generation.

What is lacking is an understanding of the trade-offs between fuel quality and engine modifications, and this balance should be reassessed in the context of developments in ultra-hard materials and manufacturing techniques introduced over the last 25 years.

Table 5 below summarises the currently known technology gaps.

Table 5 Perceived technology gaps

Technology gap	Description	Importance
Processing and formulation of sub-bituminous coal	<p>Deashing by flotation or selective agglomeration may result in a higher product ash.</p> <p>Lower rank coals can make excellent MRC if the surface properties are altered and any porosity reduced, eg by hydrothermal treatment or low-temperature carbonization.</p> <p>Cost effective additive packs to provide optimal solids content and rheology.</p>	<p>High</p> <p>(trade-off between fuel cost and engine cost)</p>
Fuel logistics	<p>Fuel quality standards, including suitable performance tests need to be established (pf coal and fuel oil standards are not suitable for DICE).</p> <p>CSIRO has a number of DICE fuel tests which could be used as a starting point.</p>	<p>High</p>
Fuel-engine interactions	<p>Very little data for sub-bituminous coals.</p> <p>The occurrence of mineral matter in the processed coal will have a significant influence on the required engine adaptations (armoring), and R&M costs, however, it is likely that this will only cause a small increase in overall capital cost for an Nth installation.</p>	<p>High</p>
Engine design	<p>Current designs and materials of construction assume clean fuel. This limitation applies to the fuel supply system, the injection system, cylinder components, exhaust valve seats, exhaust system, turbocharger turbine, and heat recovery systems.</p> <p>Engine maker philosophy – the fuel needs to match the engine</p>	<p>High</p> <p>High – potential large new markets using lower cost fuel needs to be valued</p>
Next-generation DICE fuel systems	<p>Atomization and atomizer longevity is an essential requirement for DICE.</p> <p>The existing practice of pressure atomization is a likely to be a stop gap solution.</p> <p>Air blast atomization could solve nozzle and wear associated with high pressure MRC, and potentially allow firing of</p>	<p>Medium in the short term, but could eliminate the atomizer problem and result in relaxed fuel quality requirements</p> <p>High</p>

Technology gap	Description	Importance
	<p>paste fuel, but requires more adaptation to the engine systems</p> <p>The potential economic benefits of lower-cost fuel should warrant extra effort on the engine, MRC is a different fuel that requires a different engine.</p>	<p>Engine manufacturers mostly adopt the view that the fuel must match the engine. The opposite could be optimal for DICE.</p>
New coal philosophy – LCA based	<p>DICE is a higher value market for coal. A new philosophy around quality and optimizing the overall coal fuel cycle is required. For example 1) creaming operations to produce MRC for DICE with higher ash MRC being used for boilers, low load or light up fuel, 2) mining of tailings dams, 3) other higher value end-uses for MRC quality coals</p> <p>The highly flexible nature of DICE could directly underpin a high penetration of intermittent renewables – giving a cleaner overall grid.</p>	<p>High</p> <p>Potential to reinvigorate the industry</p> <p>High</p> <p>New system boundaries need to be established – coal with, not versus</p>

3.2 Technical risks and issues

The key technical risks and issues associated with developing DICE – based on recent CSIRO experiences, are as follows, in decreasing order of importance:

1. **Commitment:** Ensuring commitment of both the engine manufacture and fuel supplier/fuel chain as this involves producing and using a fuel that is new to the world – this requires industry backing and commitment to not only undertake the engineering RD&D, but also to establish new logistics (including tests for quality, OH&S, public perceptions). If a holistic development approach is not taken, development could stall due to a chicken-and-egg situation between fuel supply and availability of suitable engines.
2. **Tradeoffs:** Establishing at the outset nominal trade-offs between fuel quality and engine modifications. The engine manufacturer will likely insist that the fuel is produced to suit the engine and the fuel supplier that the engine is adapted to suit the fuel. Although a full-scale demonstration is required to quantify the optimum quality-engine adaptations, an early decision should be made on fuel quality targets to give an acceptable overall generation cost. Other changes are also required: For the coal supplier, MRC must be regarded as a premium fuel and prepared and handled accordingly; for the engine manufacturer it should be accepted that MRC is not a fuel oil, and that DICE will require substantial changes to engine manufacturers to incorporate new materials and changes to the base engine (*eg* a new fuel system, revised cylinder heads to accommodate a larger

injector, increased crankcase lubricant cleaning, revised exhaust ducting and turbine materials *etc*).

3. **Development philosophy:** Ensuring that both the engine manufacturer and fuel supply parties agree with the engine development program. There are two diametrically opposite pathways to achieving a commercial engine: 1) develop and test what is considered to be key components prior to undertaking the engine tests/demonstration, or 2) undertake engine tests early with adapted components to identify and prioritize component development needs and learn by doing. This single issue was the cause for termination of the recent CSIRO project with an engine manufacturer and the Australian coal industry: The coal industry disagreed with OEM's approach (which was a 3-5 year program based on early engine trials prior to component development) to develop a commercial engine for DICE. It is emphasized that the program was not terminated on technical grounds – only conflicting philosophies on how development should proceed.
4. **Supporting R&D:** Including a parallel program to develop and establish fuel cycle logistics. This should include identifying/developing suitable tests for the fuel – which will likely involve a hybrid of fuel oil and coal type tests. It is recommended that a high degree of importance is placed on understanding how the inorganics in the as mined coal report to the MRC fuel, the exhaust gases, and the wear implications – especially for the injector nozzles and cylinder components. For example, depending on the coal and the cleaning methods used, around one-third of the ash content (in, say a 2% ash coal) could be derived from organically bound or finely disseminated mineral matter which will have different wear implications than coarser extraneous quartz particles. Another key area is MRC rheology: If this is correct the relatively high viscosity fuel will inject as well as fuel oil and will be safe to store without agitation. If not, fuel system and injector nozzle blockages will result, and fuel tanks settle to form a compacted sludge. Rheology targets are detailed above in Section 2.1.3.
5. **Engine ready MRC:** Developing a cost effective, engine ready fuel. For bituminous coals fully commercial technologies are available to do this. For lower rank coals such as Powder River Basin coal, some development is required to ensure sufficiently low mineral content and to allow an MRC with over 50% coal to be produced with acceptable rheology.
6. **Engine modifications:** These have been detailed in Sections 2.1.2 and 3.1 above. The minimum modifications to enable an engine trial, for example, to obtain combustion and heat release data, and to identify other issues, is a seal oil protected injector and fuel pump. Using a standard tool steel nozzle should enable 5-10 hours of consistent operation to gain early engine performance data and to refine the component development program.

3.3 Key R&D requirements for development

The technical R&D requirements are discussed below in the context of developing an overall fuel cycle that is ready for commercialization by 2030:

- Fuel development
- Engine component development

- Logistics

3.3.1 Fuel R&D

Cost-effective fuel processing to meet a specification that is suitable for DICE is essential. For most coals, this will require producing a finer and lower ash product than for existing markets – but without the usual moisture constraints. Three steps are involved, and all require R&D and testing to optimize the processing for the specified feed coal.

1. Demineralising and densification
2. Micronising and slurry production
3. Blending

The steps and nominal targets for both R&D and test work is described below, based on our experience with 48 coals.

Demineralising and densification

The first step is to produce feed coal with sufficiently low ash, and without coarse, hard minerals such as quartz, pyrites or rutile. It is important to recognize that this requires low temperature plasma ashing (LTA), followed by quantitative X-ray diffraction (XRD), to determine the mineral species. This complements a standard coal ash analysis. From recent experience, this step will be challenging for the sub-bituminous PRB coal proposed, as deep cleaning by a highly selective process, such as flotation or selective agglomeration, is likely to be less effective than for bituminous coals –resulting in both higher product ash and lower recovery. Ideally, cleaning would be undertaken on densified material – eg after pretreatment by hydrothermal treatment. Hydrothermal treatment is also known to reduce hydrophilic surface groups and oxygen content (slightly), which further assist in both cleaning and by increasing calorific value of the fuel slurry.

Micronising and slurry production

The second step is to micronize the cleaned feed coal. Ideally, this is by higher efficiency wet milling with the required slurry water plus additives. For a 500 rpm engine, a conservative top size (d_{97}) is 65 μ m. The aim is to produce a size distribution that will have a good packing efficiency, which maximises the coal loading and therefore calorific value of the fuel.

Unless a cleaning step follows micronizing (as would be the case for bituminous coal), micronizing should be undertaken with steel mill media, as ceramic media can chip and cause unacceptable contamination. If steel media is used, the fuel will pickup some Fe, but as discussed below, this iron pickup can improve fuel rheology.

Blending and trimming

It is unlikely that a fuel freshly micronized and slurried in step 2 will have acceptable rheology. A significant improvement in fuel rheology requires a combination of further blending and aging. Blending is most efficiently undertaken using a combination of a high shear mixer (eg Eirich-type paddle mixer) followed by a longer period of low-intensity mixing (eg a Visco-jet or similar). Experience has shown that the energy required for the high-intensity mixing stage can be as high as 30-50% of that of micronizing. The low shear mixing could also be provided by

storage tank agitation. During the blending and trimming step, the rheology of the MRC should be measured for the shear rate range 0.1-3000/s (or higher) to ensure the shear thinning behavior outlined in Section 2.1.3. Additional trim additions of a surfactant or thickening agent may be required to achieve these properties.

Example additions for Australian bituminous and lignitic coals are shown in **Error! Reference source not found.**

Table 6 Nominal additives used to produce MRC

Purpose	Example	Range wt% ¹	Comment
Dispersant	Polystyrene sulfonate	0.1-0.5	Needs to be optimized for the coal. Other dispersants may be more economical
Stabiliser	Carboxymethylcellulose	0 0.1	Often not required, can interfere with the dispersant
Auxillary	Soluble Fe or Ca	0.01–0.1	Bridging agent. Most effective for bituminous coals. Not required for alkaline ash coals
Biocide	From vendors	0.0-0.1	Usually not required

¹ active ingredient, dry coal basis

As a general comment, processed lignite and sub-bituminous coal usually produce excellent fuel slurries from a stability and shear thinning perspective; however, porosity and residual surface groups reduce the coal content and, therefore, the calorific value of the fuel for a given viscosity. The other factor that affects the coal content of the slurry is the particle size distribution, which determines the packing efficiency (can be calculated).

Suggestions for research studies that would assist in de-risking the fuel technology for bituminous and sub-bituminous coals are given below. It should be noted that not all of these studies may be required – as work progresses, the research will be amended to achieve the goal cost effectively.

Mineral matter

- Identify the mineral species in the coal (LTA plus XRD, and the size distribution of the various minerals by SEM - very useful in considering beneficiation issues and options.
- Optimize mineral removal from micronized coal(with and without hydrothermal treatment), using flotation or other physical separation procedures- how much of which mineral species is removed?.This study will include the effect of flotation aids/chemicals on slurry rheology.Dewatering is required after flotation, which requires a dilute (~5%) slurry. Research is required to develop the most cost-effective dewatering technology and to optimize dewatering aids, prior to fuel slurry formulation.

Surface groups

- For lower rank coals, level level of carboxylic acid/carboxylate surface groups should be measured (*eg* by a titration procedure).
- If insufficient surface groups are present to achieve stability and shear thinning studies will be undertaken to determine how can they be generated at minimal cost for bituminous and sub-bituminous coals (*eg* by increasing surface oxidation using chemicals or electrolysis).
- Additives such as calcium ions have a very beneficial effect on bituminous coal slurries, with small additions (<0.02%) changing slurries from shear thickening to shear thinning. Is this effective for the target coal, and what is the effect when combined with a dispersant?
- What is the effect of hydrothermal treatment (and perhaps other treatments such as compression, or low temperature pyrolysis) on the coal properties such as surface groups and porosity may need to be assessed, as coal characterisation proceeds.

Milling/micronization

- It may be possible to wet micronize the coal to achieve the final slurry coal concentration. This would have the benefit of avoiding an additional trim dewatering step, especially if a dry beneficiation process was used.

Slurry generation

- Mixing conditions (time, intensity, dispersant, type of mixer) are known to affect the properties of the slurry, but this depends on the coal and additives used. Experimentation is required to optimize mixing for the particular coal.

Fuel stability

- Coal slurries can be adversely affected by bacteria and may need biocides to maintain stability. Work is required to determine if biocide, if required, and identify formulations that do not negatively affect slurry rheology. CSIRO has had a bacterial problem with only 2 coals to date (out of 48); however, other groups have experienced significant bacterial issues.
- Stability tests – many of the tests in the literature are focussed on comparatively short term stability (days to weeks). There is a need for tests that are relevant to commercial operations associated with storage and transport (months).

3.3.2 Engine component R&D

Engine component R&D is mostly for fuel delivery and injection systems, including materials selection. Key areas include:

- Wear coatings for the piston rings and cylinder walls
- Piston bowl shape
- Ring shape

- An MRC injection system with seal oil protected sliding surfaces and ceramic valves and atomiser nozzle.
- Exhaust ducting - reengineered to manage ash dropout
- Cylinder lubricant drains to remove contaminated oil
- Turbocharger armoring
- Reengineered fuel delivery system

These are described in more detail under development imperatives and the development pathway below.

3.3.3 Logistics R&D

DICE is a potential new market for both coal and reciprocating engines that requires the establishment of new fuel cycle logistics, especially fuel quality standards, and fuel supply logistics. These are described in more detail under development imperatives and the development pathway below.

3.4 Development pathway

A development pathway is proposed in the context of a revised positioning of the DICE fuel cycle, including:

- Energy security
- High thermal efficiency and lower CO₂/MWh at small unit size
- A new coal replacement for oil, coal and natural gas
- Nimble generation to support variable electricity demand
- Underpinning a high penetration of intermittent renewables (it is the CO₂ intensity of the overall system that is key – not that of the individual technologies)
- A first commercial DICE plant by 2030

Also, the program considers several development imperatives, derisking by staged development and scale-up risk – which are discussed below.

3.4.1 Development imperatives

Recent R&D has highlighted development imperatives, which have shaped the proposed development pathway:

1. Securing the commitment of an engine OEM and component manufacturer (*eg* fuel systems).
2. Development of a suitable large engine test facility (*ie* small scale demonstration engine), which is capable of firing MRC at near commercial scale conditions; for example, an inline 6-cylinder variant of a larger V18 cylinder engine suitable for commercial generation.
3. Small demonstration-scale engine tests to obtain key performance data on combustion, using tonnage lots of consistent and high quality MRC produced from larger fuel plants.

4. Detailed techno-economic assessment of DICE for different markets to assist with developing engine and fuel targets, and to increase the case for industry commitment.
5. Detailed risk and hazard review to further de-risk the new fuel cycle, identify key technology gaps/show stoppers, and to broaden stakeholder engagement.
6. Duration engine tests to investigate fouling. These tests could be performed using smaller engine tests and a range of adapted boiler test methods, to avoid the need for producing a larger tonnage amount of MRC and the costs of duration operation of the larger test engine.
7. R&D to obtain data for optimizing fuel handling logistics, and to enable engineered systems to be developed for a range of scenarios (local generation, distributed generation, export).
8. Developments in MRC standards, in particular, to take into account the wide differences and trade-off in MRC properties between different coals.
9. Developing an outreach program to ensure correct positioning and avoid negativities from coal's past image.

3.4.2 De-risking with staged development

While the previous DICE RD&D has provided promising findings for a range of technical issues around coal-engine interactions, this work can only provide a technology readiness level of 4 for most technical aspects. De-risking by increasing the technology readiness level or TRL from 4 to 8, to justify (say) a 20 MWe commercial demonstration project requires that appropriate small-scale demonstration tests are undertaken – taking full benefit of the many technical improvements over the last 30 years. DICE needs considerable development and demonstration to match the technological development of current power generation technologies. However, this can be cost-effectively fast-tracked: compared to the incumbent technologies, DICE has the ability to carry out a near-commercial scale demonstration at a relatively small size (say 5 MW). The 5 MW capacity engine-generator can be obtained in skid form, in a straight-6 configuration, giving a cylinder of approximately 40 cm bore and operating at 500 rpm. The simple in-line configuration with fewer cylinders ensure easier and faster incorporation of new componentry for testing - essential to shortening development time. For example, the option of only needing to make changes to one cylinder – which can also be swapped out as a complete power unit in a few hours to facilitate testing.

The data and experience gained from this engine would be directly applicable to a larger semi-commercial demonstration - for example, a V18 configuration producing 20 MW at 500 rpm. It is envisaged that successful demonstration at this scale would lead to larger commercial installations comprising multiple 20 MW engines, as is practiced for gas engine installations. This would not entail any scaleup of DICE – as discussed in more detail below. However, it is envisaged that the waste heat recovery system would be scaled up to reduce capital cost and to improve overall efficiency – this is existing commercial technology. In this event, the exhaust from several engines would be combined into a single waste heat recovery unit.

3.4.3 Scale up risk

The cylinder size, cylinder rating and power output for the proposed development steps, out to a full-size commercial engine are given in Table 7.

Table 7 Scaleup factors from demonstration through to large commercial installation

Development stage	Bore (cm)	Cylinder rating (kWe/cyl)	Cylinders Units	Plant output (MWe)	Scale up
Small scale demonstration	46	1000	6	5-6	1
Demonstration plant	46	1000	18	20	1
First commercial	46	1000	18 5 units	100	1
Large commercial 4-stroke	63	2000	18 5 units	200	2x
Large commercial 2-stroke	94	5000	12 6 units	360	5x

The scale-up factor (based on cylinder area) between the development stages is at most 2-5x, which are relatively small scale-up steps that have low technical risk:

- The scale-ups are considered very conservative by the engine manufacturers – especially if a National Test Facility is available to test the latest developments before deployment
- In contrast to many technologies, DICE has the advantage of being able to undertake near full-scale demonstration at small-scale.
- As cylinder size increases, many of the technical issues associated with firing MRC decrease (eg more time and space for combustion allows reduced atomization, and wear effects also decrease).

Overall, it is envisaged that a staged development program could be established with an engine manufacturer and OEMs (eg suppliers of injection and turbocharging components) to quickly undertake the demonstration program, to enable commercial deployment by 2030.

3.4.4 Staged development program

The recommended program involves 3 stages, which allows sequential de-risking and the development necessary to provide the experience and data required to develop the components to adapt an engine for a demonstration plant. In comparison to other new technologies, DICE has the advantage of being based entirely on relatively small adaptations of existing commercial technology, and at a small scale to drastically shorten the time required to progress from single-cylinder tests through to commercial deployment. The stages and timings are as follows:

Stage 1 (2020-22) Single-cylinder engine tests - component development, single-cylinder engine tests, logistics and business cases

Stage 2 (2023-26) DICE test facility and fuel plant (5 MW)

Stage 3 (2027-30) Semi-commercial DICE plant (20 MW units)

The program timeline is also shown in Figure 14, with additional details on the individual activities given below.

Stage 1 - Single-cylinder engine tests

These tests will provide both a focus and a framework for the entire fuel cycle, including:

- Processes and experience in the production of (say) 20 tonnes of suitable fuel
- Negotiation of a trade-off between fuel quality and engine modifications – both for short-term tests and future commercial operations.
- Hands-on experience with producing, handling and storage of bulk MRC fuel
- Fuel quality testing
- On-engine fuel handling experience, including both the low pressure fuel supply system and the high pressure injection system
- DICE operating strategy, including startup, operation at various load settings, and shut down with or without system flushing
- Optimizing pilot fuelling
- Exhaust emissions
- Duration testing of a new injector
- Preliminary data on ash fouling
- Preliminary techno-economics and risk assessment
- Business case for DICE facility – a shared national facility or consortia owned
- Broadening stakeholder engagement with real data

Stage 2 – DICE demonstration plant (5MW)

Development of a suitable engine test facility (*ie* demonstration engine), capable of firing MRC under near commercial scale conditions is essential to development – of both the engine and fuel production.

While all manufacturers are capable of undertaking engine tests in dedicated test cells, to avoid competition for test cell access, it is recommended that either a dedicated test cell is obtained, or a new host site is used close to supporting engineers. Also, while a brake dynamometer is normally used for engine testing, a standard alternator load (*ie* as a genset) can be used with sufficiently accurate information of combustion and engine performance being obtained from cylinder indicator readings. The use of a generator also allows power exports to offset test costs (important for the longer duration tests).




Figure 14 Proposed 3-stage development program

An engine-generator producing around 5-6 MWe is recommended to increase the validity of the test results by demonstrating the technology with a cylinder size suitable for commercial operation – for example, a 6-cylinder variant of the 18V 48/60 engine chosen as the basis for this present concept study.

An engine of this size will require around 6000 liters of fuel per day, equivalent to about 2 t/h of processed coal - which would also ensure MRC production at a reasonable scale.

Engine tests could determine the effects of the following on combustion/heat release, performance, thermal efficiency, lubricant contamination, wear *etc*:

- Engine load
- Cylinder air inlet temperature (by changing coolant flow to the aftercooler)
- MRC coal loading and rheology
- Pilot fuel timing and rate
- Development of operating strategies for starting, warmup, load changing, and shut down (short and long)
- Component durability tests – which could include using different materials and component designs for individual cylinders to provide a quicker and more cost effective comparison of component performance than using individual test campaigns.
- Emissions as a function of load and fuel properties
- Engine ash fouling
- Turbine abrasion

Additional fuel supply tanks should be available to enable fuel batching to ensure consistent fuel quality for each series of tests.

It is also recommended that a parallel R&D and logistics program be undertaken, including:

- Detailed risk and hazard assessment, to further de-risk the new fuel cycle, identify key technology gaps/showstoppers, and to broaden stakeholder engagement. MRC slurry fuels and new coal combustion equipment will be required to demonstrate no surprises. For example, MRC is finely divided coal, but it is not classified as flammable. Spills can be readily cleaned up with a shovel once the fuel loses a few percent moisture. While MRC looks like oil, spills are less detrimental (see Figure 15 below), and different handling and storage procedures are required.



Figure 15 MRC spill 24 hours later (from hydrothermally treated lignite)

- Detailed techno-economic assessment of DICE for different markets to assist with developing engine and fuel targets, and to increase the case for industry commitment. This assessment should include using DICE as both incremental or old replacement capacity at existing pf power plants, as well as for greenfield development.
- R&D to obtain data for optimizing fuel handling logistics, and to enable engineered systems to be developed for a range of scenarios (captive or mine-mouth generation, decentralized generation, centralized generation, export).
- Developing standards and certification to take into account the very different properties of MRC compared to fuel oil.
- Developing a detailed business case for commercialization.
- Broadening engagement/outreach. DICE is a potential new (and large) market for both coal suppliers and engine manufacturers and their componentry. However, recent experience has shown that engine manufacturers are generally reluctant to consider DICE due to coal's high CO₂ intensity (at the burner tip) – on top of their business-as-usual competing commercial priorities. It is therefore essential at the outset to establish and clearly articulate both the economic and environmental benefits of DICE to all stakeholders, for example:
 - Nomination as clean coal is no longer enough.
 - DICE allows the novel use of coal to provide the backbone for a nimble, secure, ultra-low emissions power system by underpinning a high penetration of renewables - including the direct use of biomass and renewable ammonia. **It's the performance of the overall system that is key, not the individual technologies, as neither would likely exist without the other.**

- Also, once DICE is installed it can utilize a wide range of alternative fuels including crude bio-oils, chars and other niche fuels etc – giving many other advantages (increased utilization, reduced processing costs and losses, and the use of bioenergy wastes). These should be quantified using life cycle analysis. Only a streamlined LCA will be required to show the overall benefits. The LCA should be supported by a corresponding techno-economic assessment of the integrated energy cycle.

Stage 3 First of a kind DICE plant – 20 MW

The smallest representative, first of a kind DICE power plant, is likely to be that of a single large 4-stroke engine (say) 20 MWe.

- An engine of this size can be broken down into manageable sections, to enable road transport to most locations.
- Although essentially a commercial operation, it is expected that only limited performance warranties would be provided by the engine manufacturer, but this would be offset via the initial pricing and by close supervision of operation and maintenance by the engine manufacturer (and other equipment suppliers).
- Suitable locations or host sites for the first of a kind DICE plant are envisaged as:
 - Alongside existing pf steam plants to enable sharing of coal supply, logistics, and transmission infrastructure – possibly with the long term aim of progressively replacing older pf units. This could have an additional benefit of training future operators and maintenance personnel. The MRC plant could also be used to supply light up and low load fuel to the pf plant.
 - A mine-mouth power plant. This location would provide additional economic benefits for the coal miner, and allow any lower quality MRC feed coals to be diverted to conventional markets.
 - Alongside a natural gas fired power plant with limited gas supply – with the possibility of switching out/retrofitting existing engines for MRC.

Commercialization approach

Following the successful demonstration, rapid commercialization is possible, and likely to be driven by a strong need for incremental coal generation capacity for:

- Replacing old, inefficient and uneconomic pf plants (say units smaller than 300 MW and/or older than 30 years).
- New load-following capacity to secure a higher penetration of renewables, and in direct competition with gas open-cycle plants with higher gas prices.
- Remote generation, especially for supplying large coal mines and surrounding regions.
- New capacity with CO₂ capture and storage, as DICE has the potential for a 30% reduction in the cost of capture over pf coal plants. The cost reduction is due to a combination of higher thermal efficiency (less CO₂/MWh) and the ability to use 130°C coolant and exhaust heat for stripping.

- Once an engine is adapted for DICE it will be capable of handling a wide range of other alternative fuels (*ie* difficult) fuels (for example coal-biochar or coal-ammonia blends, crude biooils) which would extend the facilities value past the proposed demonstration, and provide additional environmental incentives for the facility and commercialization of DICE.

MRC, including higher ash products, could be used to replace fuel oil for boiler lightup and low load operation.

CONTACT US

t 1300 363 400
+61 3 9545 2176
e enquiries@csiro.au
w www.csiro.au

Your CSIRO

Australia is founding its future on science and innovation. Its national science agency, CSIRO, is a powerhouse of ideas, technologies and skills for building prosperity, growth, health and sustainability. It serves governments, industries, business and communities across the nation.

For further information

Energy Technology

Louis Wibberley

t +61 2 4060 6050
m +61 419 512 218
e louis.wibberley@csiro.au