



NATIONAL ENERGY TECHNOLOGY LABORATORY

# Analysis of Solid Oxide Fuel Cell Plant Configurations with CCS

Dale Keairns

*Booz Allen Hamilton*

*12<sup>th</sup> Annual SECA Workshop  
Pittsburgh, PA  
July 26-28, 2011*



# Acknowledgements

- **DOE Contract DE-FE0004001**
  - Task 04001.410.01, 04001.341.01
- **Collaborators**
  - Richard Newby, Booz Allen Hamilton
  - DOE National Energy Technology Laboratory
    - Shailesh Vora
    - Travis Shultz
    - William Summers
    - Kristin Gerdes
    - Walter Shelton

# Objectives


- Develop technology pathways that project plant performance and cost of electricity for Integrated Gasification Fuel Cell (IGFC) and Natural Gas Fuel Cell (NGFC) Plant Configurations with carbon capture and storage (CCS)
- Select pathways that
  - ✓ Focus on SOFC power block technology advances and
  - ✓ Alternate pathway to include gasifier advances for high methane syngas for IGFC systems
- Utilize site, fuel and economic assumptions consistent with the NETL Bituminous Coal Baseline report
- Compare pathway results to 'Today's fossil plants' with and w/o CCS
  - ✓ Supercritical PC
  - ✓ IGCC
  - ✓ NGCC

# Design Basis Common to All Cases


- **Consistent with NETL Bituminous Coal Baseline Report**
- **Site: mid-western U.S.; ISO conditions**
- **Plant Boundary: total plant facility**
  - COE includes transport, storage and monitoring of CO<sub>2</sub>
- **Fuels: IL #6 Coal and Natural Gas**
- **Plant Capacity: 550 MWe with carbon capture & storage**
- **Conventional Cryogenic Air Separation**
- **Gas Cleaning for IGFC Plants: Dry Gas Cleaning**

# Design Basis: SOFC Power Island


- Planar SOFC technology
- Separate cathode and anode off-gas
- Cathode and anode gas recycle



# IGFC Gasification Process




# NGFC Natural Gas Supply



# SOFC Plant Concepts

*Pathways consider alternate fuel supply and SOFC operating pressure  
(NGFC with external and internal reforming; IGFC with conventional and catalytic gasifiers)*





# Design Basis: SOFC

- **Carbon deposition control: (atomic O / atomic C) > 2.0**
- **Operating voltage = stack inlet Nernst potential – overpotential**
- **Baseline Conditions (consistent with current test data and cost)**
  - 140 mV overpotential
  - 1.5%/1000 hrs degradation
  - 5.9% gasifier methane content
  - 97% inverter efficiency
  - \$296/kW Atm. Pressure SOFC stack unit installed cost
  - 80% plant capacity factor
- **Advancements**
  - 70 mV overpotential
  - 0.2%/1000 hrs degradation
  - 10.2% conventional gasifier methane content
  - 30% catalytic gasifier methane content
  - 98% inverter efficiency
  - \$268/kW Atm. Pressure SOFC stack unit installed cost
  - 85% and 90% plant capacity factors
  - 285 psia pressurized SOFC
  - Internal catalytic SOFC reforming (applicable for NGFC plants)

# Pathway Study Process Cases


- *Conventional Gasifier Pathway*
  - *Catalytic Gasifier Pathway*
  - *Natural Gas Pathway*
- 
- *Each pathway begins with the atm. pressure SOFC baseline conditions*
  - *30 cases used to show results from improvements in baseline conditions*

Parameter	Base	Improved
SOFC Degradation (%/1000 hrs)	1.5	0.2
Cell Overpotential (mv)	140	70
Gasifier CH <sub>4</sub> (conventional)	5.9%	10.2%
Gasifier CH <sub>4</sub> (catalytic)	30%	NA
SOFC Stack Cost (Atm.) (\$/kW)	296	268
SOFC Stack Cost (Pressure) (\$/kW)	442	414
Inverter Efficiency	97%	98%


# Results: Data Reported

- Process Block Flow Diagram and Stream Table
- Power Summary
- Mass Flow Diagram
- Energy Flow Diagram
- HP and LP-Steam Balances
- Water Balance
- Carbon Balance
- Sulfur Balance
- Air Emissions
- Capital Cost Breakdown
- Owner's Cost Breakdown
- First-year COE Breakdown

# IGFC Mass Flow Balance Example




\*Coal feed: ILL #6 as received



Design Basis (Case 1)	
SOFC	Planar, Atm Press.
Overpotential	140 mV
Degradation	1.5%/1000 hrs
Inverter Eff.	97%
Gasifier	6% methane

# IGFC Energy Flow Diagram Example




Design Basis (Case 1)	
SOFC	Planar, Atm Press.
Overpotential	140 mV
Degradation	1.5%/1000 hrs
Inverter Eff.	97%
Gasifier	6% methane

# Cost Estimation

- **Consistent with Bituminous Coal Baseline Study: June 2007 \$**
- **Capital Costs (total overnight cost):** equipment, materials, labor, indirect construction costs, engineering, owner's costs, and contingencies
- **Operating Costs:** operating, maintenance, administrative labor; consumables; fuel; waste disposal; stack replacement cost
- **Contingencies and Capital Charge Factor**
  - Consistent with Baseline Study
- **SOFC Stack Module Cost (Stack, enclosure, inverter)**
  - Assumes NETL Cost Target (consistent with technology developers cost estimates)
  - Cost reduction consistent with 20% reduction in stack cost
- **CO<sub>2</sub> transport, storage and monitoring consistent with Baseline study**
- **Natural Gas Price, \$/MMBtu: 4.0, 6.55, 12.0**

# Conventional Gasifier Pathway: Efficiency and Capital Cost




Parameter	Baseline	With R&D
SOFC Degradation (%/1000 hrs)	1.5	0.2
Cell Overpotential (mv)	140	70
Gasifier CH <sub>4</sub>	5.9%	10.2%
SOFC Stack Cost (Atm.) (\$/kW)	296	268
SOFC Stack Cost (Pressure) (\$/kW)	442	414
Inverter Efficiency	97%	98%

## Comparison with Today's IGCC and PC


IGCC (CoP gasifier) CCS: 31.0 %, \$3466/kW  
 SCPC CCS: 28.4 %, \$3570/kW  
 SCPC w/o CCS: 39.3 %, \$2024/kW

# Conventional Gasifier Pathway: FY COE





# IGFC Catalytic Gasifier Pathway: FY COE




Today's SCPC or IGCC w/ CCS

Today's SCPC or NGCC w/o CCS


Parameter	Base	Improved
SOFC Degradation (%/1000 hrs)	1.5	0.2
Cell Overpotential (mv)	140	70
Gasifier CH <sub>4</sub> (conventional)	5.9%	10.2%
Gasifier CH <sub>4</sub> (catalytic)	30%	NA
SOFC Stack Cost (Atm.) (\$/kW)	296	268
SOFC Stack Cost (Pressure) (\$/kW)	442	414
Inverter Efficiency	97%	98%

# NGFC Pathway FY COE

## Atmospheric Pressure SOFC



# Water Consumption (with CCS)



# Conclusions

- **IGFC and NGFC have significant environmental advantage over all other fossil fuel power plants**
  - Near-zero emissions including > 99% carbon capture (97% for pressurized SOFC)
- **IGFC with commercial gasifier and enhanced-commercial gasifier technology**
  - Significant performance and cost advantage over today's IGCC and PC with CCS
  - Cost comparable to today's IGCC without CCS
- **IGFC with catalytic coal gasifier and atmospheric-pressure SOFC**
  - Greatest cost benefit
  - Costs comparable to today's PC and NGCC without CCS
- **IGFC with catalytic coal gasifier and pressurized-SOFC**
  - Performance benefits over IGFC with atmospheric-pressure SOFC, but no COE benefit

# Conclusions

- **Systems analysis shows benefit of**
  - Reducing cell overpotential (capital and efficiency benefit)
  - Reducing degradation (capital benefit)
  - Improving system reliability (COE benefit)
  - Internal catalytic SOFC reforming: beneficial if achieved w/o significant stack cost increase
- **Pathway study informs technology development**
  - Basis for prioritizing technology development
  - Basis for selecting test conditions (e.g. syngas composition)
- **Additional integrated system opportunities**
  - Humid gas cleaning with atmospheric-pressure SOFC
  - Advance CO<sub>2</sub> compression