



## **Sensors and Controls - Techno-Economic Analysis for Existing Generating Units**

Presented by: Katrina Krulla

Contributors: Bill Babiuch, Jeff Withum, Paul Myles, Peter Kabatec





# NETL – Program Planning and Analysis

**Conduct analyses for multiple programs at NETL to assess:**

- **Market potential**
- **Cost and performance**
- **Barriers to entry**
- **Benefits to Society**


# Top 10% of Coal Fired Generating Fleet is Over 5pp More Efficient than the Average

	2008 Top 10%		2008 Rest of Fleet	
	Average	Range	Average	Range
Generation Weighted Efficiency	<b>37.6%</b>	36.3% - 43.7%	32.0%	19.5% - 36.2%
Capacity (MW)	580	114 - 1426	329	27 - 1300
% of units that are Super Critical	55%	-	10%	-
Steam Pressure (psig)	2935	1800 - 3500	2088	600 - 5000
Age (yrs)	40	1 - 54	42	1 - 69
Load Factor*	83%	67% - 99%	75%	24% - 105%
% of units burning Bituminous Coal	66%	-	56%	-
% of units with SO2 Controls	36%	-	35%	-

**Significant overlap in characteristics of the top 10% called into questions the General “rules of thumb” regarding efficiency**

# Availability


## 2005-2009 Average Annual Plant Revenue Loss Due to Equipment Forced Outages and Derates (2011 \$)





# Availability

## Potential Revenue Increase and Avoided Maintenance Costs per based on 10% Decrease in Forced and Unplanned Maintenance Outages



# Cost and Performance of Previous Sensors and Controls Projects

MWs	Capital Cost (Thousand \$)	O&M Cost (Thousand \$/yr)	Reduction in Operator Cost (Thousand \$/yr/unit)	Reduction in HR (Btu/KWh)	Nox Reduction (%)	Availability Improvements		
						Increased Operation Hours (Hr/Yr)	Net Generation Increase (MWh)	Contract Maint. Savings (Thousand \$/Yr)
0-99	\$500 - \$600	\$50 - \$60	\$120	175 - 225	5 - 8	75	4,500	\$450
100-199	\$500 - \$600	\$50 - \$60	\$120	175 - 225	5 - 8	79	10,700	\$470
200-299	\$600 - \$700	\$60 - \$70	\$120	125 - 175	5 - 8	77	17,500	\$460
300-399	\$600 - \$700	\$60 - \$70	\$120	125 - 175	5 - 8	78	25,500	\$465
400-599	\$800 - \$900	\$70 - \$80	\$120	75 - 125	5 - 8	100	52,000	\$600
600-799	\$800 - \$900	\$70 - \$80	\$120	75 - 125	5 - 8	85	56,500	\$510
800-999	\$900- \$1,000	\$80 - \$90	\$120	25 - 75	5 - 8	55	46,000	\$325
1000+	\$900 - \$1,000	\$80 - \$90	\$120	25 - 75	5 - 8	100	125,000	\$600




# Business Case Tool - Net Present Value Analysis (NPV)


- **Previous table established input ranges to determine which plants would benefit economically from a Sensors and Controls refurbishment project.**
- **Obtained Unit level data from the Energy Velocity database**
  - **Electric price**
  - **Fuel price**
  - **Current heat rate**
  - **Emissions**
  - **Capacity Factor**
- **Built an NPV tool to model the business case decision of each unit**
- **Assumed units would only refurbish if they could payback in 2 years**

# Net Present Value Analysis - Sensitivities


Change in Total U.S. 5-Year NPV, Million \$



# Net Present Value Analysis - Results



# Net Present Value Analysis - Results




# Conclusion

- **Advanced Sensors and Controls have the potential to be economically installed on 150GW to 300GW of the existing coal power generation fleet.**
- **Availability is the key driver in determining the economics of refurbishment projects. Reducing forced outages by 10% alone would make it economical for most of the coal fleet to refurbish at capital costs under \$1 million.**
- **Coal fired power plant CO<sub>2</sub> emissions could be reduced around 1% or 20 million metric tons per year from Advanced Sensors and Controls refurbishment. Cost \$2-\$10/mt CO<sub>2</sub> avoided.**

# Future Work

- **Add NG-fired mid and baseload units**
- **Conduct similar analysis for advanced materials**

# Homework Question



What do we need to move Fossil Energy's Innovation index from -0.7 to +0.7?

# Backup

---

# Individual Unit Best Year Efficiency

Decile	2008 Efficiency	1998 - 2008 Best Year Efficiency
1	27.6%	29.9%
2	29.9%	31.7%
3	30.8%	32.5%
4	31.6%	33.3%
5	32.2%	34.1%
6	32.9%	35.0%
7	33.8%	35.8%
8	34.7%	36.9%
9	35.7%	37.7%
10	37.6%	39.7%
<b>Average</b>	<b>32.5%</b>	<b>34.5%</b>

- An individual unit had varied efficiency over the 10 year period in EV
- Setting each unit to the highest achieved efficiency (1998-2008), yields overall fleet efficiency that is 2pp higher than 2008.
- Best year efficiency did not occur in years with highest load factors and seemed unrelated to changes in coal type.
- In most cases increase was not due to major refurbishment. Increase may be due to better operation or maintenance cycle.

# Summary of NEMS Run Results 2035

	Refurbish Capacity (GW)	Coal Generation (BkWh)	Average US COE (¢/kWh)	Total Electric Sales (BkWh)	US Total Electric Bill
AEO2011 Reference	0	2197	9.2	4474	412
No NSR	255	2225	9.1	4491	410
With NSR	133	2204	9.2	4477	411

- **Program benefits from reductions in cost of electricity** (assuming plant optimization program continues to be funded at current levels)
  - **IRR of 22% to 30%**
  - **ROI at 8% discount rate of 5:1 – 15:1.**

# Sensors and Controls Expansion to Other Plant Types

## Breakdown of Existing Generation Fleet

Fuel Type	# Units	Capacity (GW)	Percentage of Total Capacity	2010 Generation (BkWh)	Percentage of 2010 Generation
Coal	863	318.3	29%	1917	44%
NG - Mid and Baseload	789	269.1	24%	630	14%
NG Peaking	1823	205.2	19%	283	7%
Nuclear	103	110.5	10%	899	21%
Hydro - Mid and Baseload	49	2.7	0.2%	290	7%
Hydro - Peaking Units	849	60.9	6%		
Wind	491	51.9	5%	97	2%
Petroleum	385	37.6	3%	24	1%
Renewables excl. Hydro and Wind	303	16.3	1%	80	2%
Others	202	26.5	2%	129	3%