

# **Evaluation of Carbon Dioxide Capture From Existing Coal Fired Plants by Hybrid Sorption Using Solid Sorbents (CACHYS™)**

**NETL CO<sub>2</sub> Capture Technology Meeting**  
**Pittsburgh, Pennsylvania**  
**July 8-11, 2013**

**Steve Benson, Dan Laudal, Nicholas Lentz, Kirtipal Barse & Harry Feilen**  
**University of North Dakota – Institute for Energy Studies**

**Srivats Srinivasachar**  
**Envergex LLC**

# Project Overview

---

- Project Overview
- Technology Fundamentals
- Progress and Current Status
- Significant Accomplishments
- Plans for Future Testing

# Presentation Overview

---

- Project Funding
  - U.S. Department of Energy Carbon Dioxide Capture RD&D program
  - Bench-scale testing
  - October 2011 to September 2014
  - Initial concept testing conducted by Envergen and UND under DOE STTR program
- Total Project Funding: \$3,690,000
  - DOE Share: \$2,952,000
  - Cost Share: \$738,000

# Project Participants

---

- US Department of Energy - NETL
- UND Institute for Energy Studies
- Envergex LLC
- Lignite Energy Council/NDIC
- ALLETE Group
  - Minnesota Power
  - BNI Coal
- SaskPower
- Barr Engineering
- Solex Thermal Science




# Project Objectives

---

- Overall Project Objectives
  - Improve current state-of-the-art (amine scrubbing) by developing a novel sorbent-based, post-combustion CO<sub>2</sub> capture technology
  - Achieve at least 90% CO<sub>2</sub> removal from coal combustion flue gas
  - Demonstrate progress toward DOE target of less than 35% increase in levelized cost of electricity (LCOE) for plant with CO<sub>2</sub> capture
  - Demonstrate at bench-scale level a sorbent-based technology for capture of CO<sub>2</sub> by hybrid sorption (CACHYS™) from coal combustion flue gas
  - Develop key information on sorbent and technology effectiveness
    - Energy Requirements
    - Physical Properties
    - Process Integration
    - Equipment sizing, capital and operating costs

# **Technology Background and Fundamentals**

# CACHYS™ Hybrid Sorption Process




- Key component – metal carbonate salt
- Reacts with  $\text{CO}_2$  to form adduct. Reversible with heat addition
- Additive/process conditions - enhance adsorption kinetics + reduce adsorption/regeneration energy

# CACHYS™ Process Advantages

## Advantages

- ✓ Low reaction heat ~ 40-80 kJ/mol CO<sub>2</sub> (novel chemistry and process conditions)
- ✓ High sorbent capacity (> 7 g CO<sub>2</sub>/100 gm sorbent)
- ✓ Increased sorption kinetics (smaller-sized equipment)
- ✓ Use of low cost, abundantly available materials for sorbent
- ✓ Use of commercially-demonstrated equipment design/configuration
- ✓ Reduced capital and operating costs



# CACHYS™ Process Challenges

---

- Challenges
  - Confirmation of energetics
  - Confirmation of sorbent capacity
  - Confirmation of reaction kinetics
  - Sorbent integrity
  - Sorbent handling

# **Progress and Current Status**

# Technical Approach and Project Scope

---

- Scope of work includes eight main tasks
  - Task 1: Project Management and Planning
  - Task 2: Initial Technology and Economic Feasibility Study
  - Task 3: Determination of Hybrid Sorbent Performance Metrics
  - Task 4: Bench-Scale Process Design
  - Task 5: Bench-Scale Process Procurement and Construction
  - Task 6: Initial Operation of the Bench-Scale Unit
  - Task 7: Bench-Scale Process Testing
  - Task 8: Final Process Assessment

# Milestone Log – Budget Period 1

ID	Task	Title/Description	Planned Completion Date	Actual Completion Date	Verification Method
a	1	Submit Project Management Plan	10/31/2011	10/28/2011	Project Management Plan file
b	1	Complete Kick-off Meeting	11/21/2011	11/21/2011	Briefing Document & Meeting Results
c	2	Complete Preliminary Technical and Economic Feasibility Study	8/15/2012	8/15/2012	Topical Report file
d	3	Complete thermogravimetric analysis (TGA) and differential scanning calorimetry (DSC) testing of 5 sorbent formulations	7/31/2012	7/31/2012	Results reported in the quarterly report
e	3	Down-select to two optimal sorbent formulations for fixed-bed testing	8/15/2012	8/15/2012	Results reported in the quarterly report
f	3	Complete fixed-bed testing of the CACHYS™ process with two optimal sorbent formulations	9/30/2012	9/30/2012	Results reported in the quarterly report
g	3	Determine the optimal process operating conditions of the adsorber and regenerator units, for low energy operation	9/30/2012	9/30/2012	Results reported in the quarterly report

# Milestone Log – Budget Period 2

ID	Task	Title/Description	Planned Completion Date	Actual Completion Date	Verification Method
h	4	Complete bench-scale unit column design utilizing a refined mass and energy balance of the CACHYS™ process	12/31/2012	12/17/2012	Results reported in the quarterly report
i	5	Bench-scale unit engineering design package released for bid	1/15/2013	12/31/2012	Bid package is submitted to system integrator/fabricator and submitted to NETL for record
j	5	Complete bench-scale unit construction	7/30/2013		Results reported in the quarterly report
k	6	Complete shakedown testing of the flue gas sampling and conditioning system, as well as the adsorber and regenerator	9/15/2013		Results reported in the quarterly report
l	6	Submit a test matrix for the bench-scale parametric test campaign	9/30/2013		Results reported in the quarterly report

# Decision Points & Success Criteria

---

Decision Point	Basis for Decision/Success Criteria
Completion Budget Period 1 Year 1	<ol style="list-style-type: none"><li data-bbox="396 475 1819 532">1. Successful completion of all work proposed in Budget Period 1</li><li data-bbox="396 561 1819 753">2. Demonstrate sorbent CO<sub>2</sub> equilibrium capacity of greater than 70 g of CO<sub>2</sub>/kg of sorbent - <b>CACHYS™ sorbents have capacities that range from 70 to 100 g CO<sub>2</sub>/kg sorbent.</b></li><li data-bbox="396 782 1819 911">3. Demonstrate a heat of sorption of 80 kJ/mole of CO<sub>2</sub> or less - <b>Sorption energies ranged from 30 to 80 kJ/mole of CO<sub>2</sub></b></li><li data-bbox="396 939 1819 1068">4. Submission of a Topical Report – Preliminary Technical and Economic Feasibility Study - <b>Completed; Revised report uploaded</b></li><li data-bbox="396 1096 1819 1218">5. Submission/approval of a Continuation Application to DOE – <b>Continuing application approved</b></li></ol>

# Decision Points & Success Criteria

---

Decision Point	Basis for Decision/Success Criteria
<b>Completion Budget Period 2 Year 2</b>	1. Successful completion of all work proposed in Budget Period 2.
	2. Submission of a bench-scale engineering design package - <b>CACHYS™ bench-scale system design submitted and approved</b>
	3. Complete construction of a bench-scale CACHYS™ system
	4. Submission of a test matrix for the bench-scale testing campaign
	5. Submission/approval of a Continuation Application to DOE

# Decision Points & Success Criteria

---

Decision Point	Basis for Decision/Success Criteria
End of Project Year 3	1. Successful completion of all work proposed
	2. Complete continuous testing of integrated bench-scale CACHYS™ process for 1 month
	3. Submission of a Topical Report - Final Technical and Economic Feasibility Study
	4. Submission of a Topical Report – Preliminary EH&S Assessment
	5. Submission of a Final Report

# **Significant Accomplishments**


# Sorbent Screening and Energetics Determination

---




- Sorbent formulation and selection
- Thermogravimetric analyzer/differential scanning calorimeter (TGA/DSC) used to determine sorbent capacity, kinetics and sorption energetics

# Adsorption Energy Data: TGA/DSC




- Adsorption energy ~ 40-80 kJ/mol CO<sub>2</sub>
- Below target of 80kJ/mol CO<sub>2</sub> and significantly lower than standard carbonate process (130 kJ/mol CO<sub>2</sub>)

# TGA/DSC Desorption Energy Data



- Desorption energy ~ 30-80 kJ/mol CO<sub>2</sub>
- Below target of 80kJ/mol CO<sub>2</sub> and significantly lower than standard carbonate process (130 kJ/mol CO<sub>2</sub>)


# Fixed/Bubbling Bed Reactor Testing




## Components

A	Mass Flow Controllers
B	Bubbler
C	Air Preheater
D	Steam Generator
E	Reactor
F	Condenser
G	Water Knockout Drum
H	5 Gas Analyzer
I	Manual Steam Control #1
J	Manual Steam Control #2
T1	Thermocouple – Air In
T2	Thermocouple – Reactor Wall
T3	Thermocouple – Air Out
P1	Pressure Transducer (Bottom)
P2	Pressure Transducer (Top)

# Fixed/Bubbling Bed Testing: Typical Adsorption Cycle



# Fixed/Bubbling Bed Testing: Typical Desorption Cycle



# Adsorption Loadings for Sorbents Tested

Number	Sorbent	Total Cycles	Average Adsorption (g CO <sub>2</sub> )*	Normalized Average Adsorption** (g CO <sub>2</sub> / 100 g pure sorbent)
1	HCK-1	4	5.5	7.1
2	HCK-2	5	6.5	7.1
3	Used HCK-1	5	8.0	9.0
4	HCK-4	5	6.7	7.1
5	HCK-5	6	7.6	9.2
6	HCK-7	7	7.7	9.1
7	HCK-16	7	7.0	8.2
8	HCK-25	11	5.8	7.2
9	HCK-31	6	7.4	8.8
* Does not include the first cycle				
** Calculated using TGA/DSC analyses				

# Sorbent Selection For Multi-Cycle Evaluation

---

- HCK-4 sorbent averaged 7.1 g CO<sub>2</sub> and was consistently in the range of 6.8-7.4 g CO<sub>2</sub> per 100 grams of sorbent.
- HCK-7 sorbent averaged 9.1 g CO<sub>2</sub> (capacities as high as 10.0 g CO<sub>2</sub>) per 100 grams of sorbent.
- Exceeds project goal of capacity of 7.0 g CO<sub>2</sub> per 100 grams of sorbent.

# Fixed/Bubbling Bed Reactor: Multi-cycle Sorbent Testing

---

- 100 cycles with down-selected sorbents, HCK-4 & HCK-7
- Gather key information on sorbent performance
  - Attrition resistance
  - Determine capacity with continuous cycling
  - Determine optimal operating conditions


# Fixed/Bubbling Bed Reactor: Multi-cycle Sorbent Testing

---


- HCK-4 Results
  - Capacity at optimal process conditions: 8.3 g CO<sub>2</sub>/100 g Sorbent
  - No apparent loss in sorbent capacity
  - Little attrition to 75 cycles. Measurable attrition between 75 - 100 cycles
- HCK-7 Results
  - Average capacity: 8.9 g CO<sub>2</sub>/100 g Sorbent
  - No apparent loss in sorbent capacity
  - Little attrition through 100 cycles
- HCK-31 Results
  - Average capacity: 8.8 g CO<sub>2</sub>/100 g Sorbent
  - Candidate for slipstream bench-scale testing

# Fixed/Bubbling Bed Reactor: Multi-cycle Sorbent Testing

HCK-4



HCK-7



- Selected sorbents exceeded goal of 7.0 g CO<sub>2</sub>/100g of sorbent and maintained capacity over the 100 cycle tests

# Task 2: Initial Technology and Feasibility Study

---

- Developed detailed process scheme
- Used ASPEN Plus software for CACHYS™ process model
- Identified all process equipment
- Designed, sized, and specified equipment
- Developed detailed plant design and plant arrangement
- Obtained plant component costs
- Determined capital costs for plant installation
- Estimated startup and ongoing operating costs
- Compared performance and costs to benchmarks

# Technical and Economic Feasibility Study (550 MW<sub>e</sub> Net Output)

---


- Initial Technical and Economic Feasibility (550MW<sub>e</sub>)
  - Total O&M \$28,290,000
  - Capital Charge \$130,794,000
  - Total Cost \$118,577,000
  - CO<sub>2</sub> Captured 3,614,000 Tons
  - Cost of CO<sub>2</sub> Capture \$36.19/ton
  - Cost of Electricity Increase 40%

# Task 4: Bench-Scale System Design

---


- Capture CO<sub>2</sub> from UND's Steam Plant
  - 30 acfm slip stream of flue gas from coal-fired boiler
- Gas Conditioning System
  - Fabric filter
  - Wet packed bed SO<sub>2</sub> scrubber
- Adsorber System
  - FD/ID fans
  - Circulating fluidized bed
  - Cyclone for bulk solids separation
  - Fabric filters for fines separation
- Regenerator System
  - Pre-heater unit
  - Regenerator unit
  - Cooler unit
- Regenerator Off-Gas System
  - Particulate filter
  - Steam condensers

# Bench-Scale Design for Slipstream Testing: Block Flow Diagram




- Use of real flue gas - coal-fired boiler at the UND steam plant

# Task 5: Bench-Scale Facility



- Two 20 ft. shipping containers
- 30 ft. tall process tower fabricated by UND
- Flue gas sampled from either of two coal-fired boilers

# Bench-Scale Facility



- Gas conditioning system completed
- Installation of adsorber and regenerator systems continuing
- Target completion of shakedown testing - September 2013

# Future Plans

---

- Year 2
  - Complete construction bench-scale CACHYS™ system
  - Complete sorbent substrate optimization
- Year 3
  - Bench-scale testing – Operate bench-scale adsorption and desorption facility (parametric and continuous). Collect data to determine technical feasibility at this scale (30 acfm flue gas).
    - Sorbent and process performance
    - Adsorbent and regenerator multi-cycle testing
    - Data for updating process design and economics
    - Determination of environmental health and safety concerns

# Acknowledgements

---

- Project Funding and Cost Share
  - U.S. Department of Energy (DOE-NETL)
  - Lignite Energy Council/NDIC
  - ALLETE (Minnesota Power and BNI Coal)
  - SaskPower
  - Solex
  - UND
  
- DOE-NETL Project Manager – Andrew Jones

# Contact Information

**Steven A. Benson**

**Institute for Energy Studies, University of North Dakota**

**(701) 777-5177; Mobile: (701) 213-7070**

**steve.benson@engr.und.edu**

**Dan Laudal**

**Institute for Energy Studies, University of North Dakota**

**(701) 777-3456; Mobile: (701) 330-3241**

**daniel.laudal@engr.und.edu**

**Srivats Srinivasachar**

**Envergex LLC**

**(508) 347-2933; Mobile: (508) 479-3784**

**srivats.srinivasachar@envergex.com**