


Post-Combustion CO₂ Capture System for Existing Coal-fired Power Plant

Contract No. DE-FE-0007580



**Gökhan Alptekin, PhD
Ambal Jayaraman, PhD
Robert Copeland, PhD**

**DOE/NETL Carbon Capture
Meeting**

**Pittsburgh, PA
July 29, 2014**

TDA Research Inc. • Wheat Ridge, CO 80033 • www.tda.com

TDA Research, Inc.

- Privately Owned/Began operations in 1987
- 78 full-time technical staff
 - Primarily chemists and engineers, more than half with advanced degrees (26 PhDs)
- 50,000 ft² office and lab spaces
- Core competency in advanced material development
- Successful commercialization of several technologies in a wide range of applications



Direct H₂S Oxidation



Synthesis of Advanced Carbons



SulfaTrap™ Purifiers



Project Summary

- **The objective is to develop a post-combustion carbon capture process for existing coal-fired power plants**
 - **Demonstrate techno-economic viability of the new concept at the bench-scale and via small slipstream evaluation**
- **A new carbon adsorbent is used to selectively remove CO₂ from the flue gas**

Budget Period 1

- **Sorbent Optimization/scale-up and Laboratory Evaluations**
- **Process Design and System Analysis**

Budget Period 2

- **Long-term Sorbent Cycling**
- **Design of a Breadboard Prototype Test Unit**

Budget Period 3

- **Fabrication of the Prototype Test Unit**
- **Proof-of concept Evaluation with Actual Flue Gas**
- **High Fidelity Process Optimization/Design and Economic Analysis**

Project Partners



Project Duration


- Start Date = October 1, 2011
- End Date = December 31, 2014

Budget

- Project Budget = \$3,375,000
- DOE Share = \$2,700,000
- TDA/Partners Share = \$675,000

TDA's Approach


- The sorbent consists of a carbon material modified with surface functional groups that remove CO₂ via physical adsorption
 - CO₂-surface interaction is strong enough to allow operation at target temperature range (60-80°C)
 - Because CO₂ does not covalently bond to the surface, the energy input for the regeneration process is low
- Heat of adsorption of CO₂ is **3.9-4.8 kcal/mol** for TDA sorbent
 - The net energy loss in sorbent regeneration is expected to be much lower than amine scrubbers



- Sorbent Features


- Mesopores eliminate diffusion limitations and allow rapid cycling/short cycle times
- Moderately high surface area for high CO₂ capacity
- Thermal stability already demonstrated

Integrated CO₂ Capture System





- Design operating temperature = 58-80°C
- High tolerance to SO₂ and NO_x reduces flue gas purification needs
 - Stable performance in presence of up to 70 ppmv SO₂ and 300 ppmv NO_x
 - Single-stage FGD

TDA's CO₂ Capture System




CO₂ Breakthrough Profile/Capacity




T=68°C, P=16 psia, GHSV= 2,000h⁻¹, 16% CO₂, 12-18% H₂O, simulated flue gas


- **CO₂ capacity = 1.5% wt. at breakthrough (2.0% vol. CO₂ at the exit)**
- **CO₂ capacity = 5.3% wt. at saturation (15.8% vol. CO₂ at the exit)**



Control of Water Adsorption



- The carbon surface is modified to reduce water adsorption
 - Surface functionality, surface area and pore size are also optimized to reduce the water uptake



- Surface area has been increased while maintaining mesoporosity
 - Higher capacity due to increased number of active surface sites

Sorbent Production Scale-up



Feeder

Continuous rotary kiln

- A continuous rotary kiln was setup to carry out carburization and activation processes
 - 12 lb/hr production capacity (continuous)

Exhaust gas treatment

High Mechanical Integrity

- The crush strength of the pellets are improved to 1.5-2.5 lb_f/mm (in the range of commercial samples)


2" screw extruder



Pellets before treatment





Pellets after treatment



- Forming the pellets prior to carburization provided the highest strength pellets
 - Pre-forming pellets also improved yields


Multiple VSA Cycles

$T = 58-70^{\circ}\text{C}$, $P_{\text{ads}} = 14-18 \text{ psia}$, $P_{\text{des}} = 3 \text{ psia}$, $\text{GHSV} = 250/2,000 \text{ h}^{-1}$
 $\text{CO}_2 = 15\%$, $\text{H}_2\text{O} = 12-18\%$ by vol. in simulated flue gas




- Sorbent capacity and removal efficiency recovered following a major upset (stable capacity over 34,000+ cycles)


Design of the Moving-Bed System



Design of the Fixed-Bed System




System Design/Packed Beds



Total Plant Cost

- **B&W estimated the total plant cost for the moving-bed system as ~\$424 million (2011 basis)**
 - The use of off-the-shelf components increased redundancy and cost
 - The solid movers/vacuum pump constituted ~35% of the cost



- **The total plant cost for fixed-bed system was estimated as \$372 MM based on 1.4% wt. CO₂ working capacity**
 - B&W is analyzing a design with 4% wt. CO₂ working capacity (initial estimates shows that the plant cost will be reduced to \$276 MM)

Quality Guidelines for Energy System Studies, Cost Estimation Methodology for NETL Assessments of Power Plant Performance, DOE/NETL_2011/1455, April 2011.

Cost Performance Baseline for Fossil Energy Plants Volume 1: Bituminous Coal and Natural Gas to Electricity, DOE/NETL_2010/1397, Revision 2, November 2010.

Carbon Capture and Sequestration System Analysis Guidelines, DOE/NETL, April 2005.

System Analysis

CO ₂ CAPTURE TECHNOLOGY		Amine	VSA-Moving Bed	VSA-Fixed Bed	VSA-Fixed Bed
CASE DESCRIPTION	UNITS	Booster fan to meet higher ΔP	LP purge Steam generated	LP Purge Steam generated	LP Purge Steam from ST cycle
CARBON CAPTURED	%	90.0	90.0	90.0	90.0
GROSS POWER GENERATED (AT GENERATOR TERMINALS), kWe					
STEAM TURBINE POWER	kWe	669,880	806,985	806,985	798,903
TOTAL AUXILIARY CONSUMPTION	kWe	140,501	195,637	189,759	178,065
AUXILIARY LOAD SUMMARY					
FLUE GAS BOOSTER	kWe	11,690	9,647	10,677	10,677
CO ₂ REMOVAL UNIT	kWe	22,084	18,596	11,661	-
CO ₂ COMPRESSION	kWe	54,882	115,675	115,675	115,675
PUMPING & COOLING TOWER	kWe	19,041	18,354	18,380	18,382
OTHER LOADS	kWe	32,804	33,365	33,365	33,332
NET POWER OUTPUT	kWe	529,379	611,348	617,226	620,837
% NET PLANT EFFICIENCY, HHV	%	25.18	29.08	29.36	29.53
CONSUMABLES					
AS-RECEIVED FEED	KG/H	278,957	278,957	278,957	278,957
RAW WATER USAGE	GPM	10,759	10,027	10,036	10,037



- TDA's CO₂ capture system achieves 29.5% efficiency in comparison to 25.2% with amine scrubbers (17.3% higher efficiency)

Cost of CO₂ Capture

CO ₂ CAPTURE TECHNOLOGY	Amine	VSA-Moving Bed	VSA-Fixed Bed	VSA-Fixed Bed
CASE DESCRIPTION	Booster fan to meet higher ΔP	LP purge Steam generated	LP Purge Steam generated	LP Purge Steam from ST cycle
Net power, MW	529.38	611.35	617.23	620.84
Capacity factor (CF), %	85	85	85	85
Total plant cost (TPC), \$	1,653,521,816	1,732,257,957	1,654,271,376	1,654,165,943
Total plant cost (TPC), \$/kWe	3,124	2,834	2,680	2,641
Initial catalyst & chemicals cost, \$	2,673,187	17,961,441	8,638,361	8,586,597
Total overnight cost (TOC), \$	2,029,584,945	2,143,947,190	2,038,150,311	2,020,608,218
Cost of electricity (COE) w/o CO₂ TS&M, \$/MWh	111.1	103.0	96.8	95.6
Cost of electricity (COE), \$/MWh	117.9	108.9	102.6	101.4
CO ₂ in Fluegas, ST/h	730.0	730.0	730.0	730.0
Cost of CO₂ Capture				
\$/ST	47.14	46.06	40.59	39.69
\$/tonne	51.96	50.77	44.74	43.75
Cost of CO₂ Avoided				
\$/ton	61.98	52.44	45.77	44.50
\$/tonne	68.32	57.81	50.45	49.05



- **TDA's VSA Fixed-bed/LP steam purge (withdrawn from ST cycle) provided the lowest 1st year COE of \$101.4/MWh (vs. \$117.9/MWh for amine scrubbers)**
- **Cost of CO₂ avoided is \$49.05/tonne (28.2% improvement over amines)**

Prototype Unit Design



Gas-Solid Contactors

Prototype Adsorber Reactor



Solids Out

2-5 CFM flue gas flow
7-8 ft³/h of sorbent circulation

20


Wheat Ridge Facility





Golden Facility



Circulating Bed System




Sorbent Performance in Moving-Bed Unit



- Flue gas flow rate 40 SLPM (1.4 SCFM)
- Inlet CO₂ Concentration = 13.2% vol.
- Adsorption pressure = 12.2 psia
- Regeneration pressure = 3.5 to 4 psia
- Sorbent circulation rate of 98.3 g/min
- CO₂ Removal Efficiency = 94+%

4-Bed VSA System



4-Bed VSA System




Dimensions
72" x 24" x 72"

Feed rate
2 SCFM flue gas


Baseline Operating Conditions
70°C, 3 – 17 psia

4-bed VSA Fixed Bed Cycles




	Stage 1			Stage 2			Stage 3			Stage 4		
Time (min)	3			1	1	1	3			1	1	1
Bed 1	ADS			EQ1	CoBD	CnBD	PURGE			EQ2	Hold	PRESS
Bed 2	EQ2	Hold	PRESS	ADS			EQ1	CoBD	CnBD	PURGE		
Bed 3	PURGE			EQ2	Hold	PRESS	ADS			EQ1	CoBD	CnBD
Bed 4	EQ1	CoBD	CnBD	PURGE			EQ2	Hold	PRESS	ADS		


Slipstream Testing with the Unit



- A slipstream test will be carried out at GTI
- All facility modifications are complete





Site Preparation Work



- The test system will provide 4 CFM flue gas slipstream at the desired gas composition/purity
- GTI completed all site modifications, including installation of a coal feeder, modifications to an existing boiler, installation of flue gas purification system

Removal of Contaminants



- **NO_x and SO₂ control will be accomplished by materials provided by TDA**
 - SulfaTrap™-SO for SO₂ scrubbing to sub ppmv concentration
 - NO Oxidation catalyst/NO₂ scrubbing sorbent for NO_x control at sub ppmv concentration

Acknowledgements

- **The funding from DOE/NETL under Contract No. DE-FE-0007580 is greatly acknowledged**
- **Technical Monitor, Andrew O’Palko, NETL**
- **Dr. Bartevo Sakadjian, Doug Devault, Ruyu Zhang, B&W**
- **Dr. Ashok Rao, UCI**
- **Dr. Chuck Shistla and Andy Hill, GTI**
- **Dr. Francois Botha and Dr. Debalina Dasgupta, ICCI**