An Update of Effluent Limitation Guideline Treatment Options for Coal-Fired Power Plants

2018 Review Meeting for Crosscutting Technologies

Eric Grol April 11, 2018





- 1. Coal regulatory overview
- 2. Existing sources ELG overview
- 3. Recent regulatory developments/technology needs
- 4. New sources ELG overview
- 5. Spray dryer evaporator for zero liquid discharge



Total Emissions from Coal-Fired Generation Dramatic Reduction Despite Increase in Usage





Sources: EPA National Air Pollutant Emission Trends, EIA Annual Energy Review





Air Quality Regulations: Water Impacts





TABLE VIII-1-FINAL RULE: STEAM ELECTRIC MAIN REGULATORY OPTIONS

Wastestreams -	Technology basis for the main BAT/NSPS/PSES/PSNS regulatory options							
	A	в	С	D	E	F		
FGD Wastewater	Chemical Precipi- tation	Chemical Precipi- tation + Bio- logical Treat- ment	Chemical Precipi- tation + Bio- logical Treat- ment	Chemical Precipi- tation + Bio- logical Treat- ment	Chemical Precipi- tation + Bio- logical Treat- ment	Evaporation.		
Fly Ash Transport Water	Dry handling	Dry handling	Dry handling	Dry handling	Dry handling	Dry handling.		
Bottom Ash Transport Water.	Impoundment (Equal to BPT)	Impoundment (Equal to BPT)	Dry handling/ Closed loop (for units >400 MW); Im- poundment (Equal to BPT)(for units ≤400 MW)	Dry handling/ Closed loop	Dry handling/ Closed loop	Dry handling/ Closed loop.		
FGMC Wastewater Gasification Wastewater Combustion Residual Leachate. Nonchemical Metal Cleaning Wastes.	Dry handling Evaporation Impoundment (Equal to BPT). [Reserved]	Dry handling Evaporation Impoundment (Equal to BPT). [Reserved]	Dry handling Evaporation Impoundment (Equal to BPT). [Reserved]	Dry handling Evaporation Impoundment (Equal to BPT). [Reserved]	Dry handling Evaporation Chemical Precipi- tation. [Reserved]	Dry handling. Evaporation. Chemical Precipi- tation. [Reserved].		

Existing Source Standard

New Source Standard





- FGD Wastewater: Chemical precipitation followed by biological treatment
 - BAT is chemical precipitation systems that employs hydroxide precipitation, sulfide precipitation, and iron coprecipitation, followed by anoxic/anaeorbic fixed film biological treatment
- Fly ash transport water: Dry handling
 - BAT is dry vacuum system using mechanical exhauster to pneumatically convey fly ash from hoppers to a silo



Existing Sources (Direct & POTW)



- Bottom ash transport water: Dry handling
 - Water quench/mechanical drag conveyor (incline dewatering)
 - Recovered water reused in quench
- Flue gas Hg control wastewater: Dry handling
 - BAT is dry vacuum system using mechanical exhauster to pneumatically convey fly ash from hoppers to a silo (same as fly ash)





- Combustion residual leachate
 - Combustion residuals: wastes generated from combustion, generally collected by pollution control technologies, stored at the plant in landfills or surface impoundments. Leachate includes liquid, including suspended or dissolved solids, that has drained from landfill materials or that has passed through a containment structure (example: water leaking from an ash pond)
 - BAT: surface impoundments



Compliance timeline for existing sources



- Specific deadline for compliance is at the discretion of the permitting authority, but should be as soon as possible beginning November 1, 2018, but no later than December 31, 2023
- Voluntary incentive option for FGD wastewater from existing sources
 - Adopting the more stringent FGD wastewater standard based on evaporation (i.e., the new source FGD wastewater standard) allows more compliance time



ELG Rule Update





43494 Federal Register/Vol. 82, No. 179/Monday, September 18, 2017/Rules and Regulations

SUMMARY: Under the Clean Water Act ("CWA"), The Environmental Protection Agency (EPA) intends to conduct a rulemaking to potentially revise certain best available technology economically achievable ("BAT") effluent limitations and pretreatment standards for existing sources ("PSES") for the steam electric power generating point source category, which were published in the Federal Register on November 3, 2015. EPA is, accordingly, postponing the associated compliance dates in the 2015 Rule. In particular, EPA is postponing the earliest compliance dates for the new, more stringent, BAT effluent limitations and PSES for flue gas desulfurization ("FGD") wastewater and bottom ash transport water in the 2015 Rule for a period of two years. At this time, EPA





- Regulatory reform agenda places a premium on existence of sufficient data on which to base regulations
- Utility Water Act Group (UWAG) comments in petition for reconsideration:
 - Demonstration of biological treatment for plants burning subbituminous & lignite
 - Impact of FGD wastewater variability on compliance



Technology Needs: Assessing Biological Treatment for Subbit, Lignite Plants



Comparison of 4-Day Average FGDW Treatment After Chemical Precipitation at Allen, Belews Creek, and Pleasant Prairie⁹⁹

Analyte	Unit	4-Day Average Dissolved Effluent, Allen (E. Bituminous)	4-Day Average Dissolved Effluent, Belews Creek (E. Bituminous)	4-Day Average Dissolved Effluent, Pleasant Prairie (PRB)
Aluminum	(ug/l)	NQ ¹⁰⁰	ND	NQ
Arsenic*	(ug/l)	NQ	NQ	<mark>4.85</mark>
Boron	(ug/l)	58,600	150,000	9,930
Calcium	(ug/l)	1,750,000	3,490,000	639,000
Chloride	(mg/l)	3,300	7,780	1,950
Magnesium	(ug/l)	396,000	738,000	3,560,000
Manganese	(ug/l)	393	NQ	10,800
Mercury	(ng/l)	<mark>342</mark>	<mark>46,200</mark>	<mark>22.3</mark>
Nitrate/Nitrite	(mg/l)	<mark>13.3</mark>	<mark>19.8</mark>	<mark>160</mark>
<u>Selenium</u>	(ug/l)	<mark>91.1</mark>	<mark>1,210</mark>	<mark>2,080</mark>
Sodium	(ug/l)	31,300	48,900	518,000
Sulfate	(mg/l)	1,400	1,380	15,500
TDS	(mg/l)	7,560	20,100	22,400
*The pollutants h	ighlighte	d are those for whi	ch EPA set new BA	AT limits.

Wide variability in FGD wastewater composition based on coal type

UWAG: biological treatment cost, effectiveness depends on full pollutant "matrix" Technology Needs: Assessing Impact of FGD Wastewater Variability on Biological Treatment



- Technology need during reconsideration: ability of biological treatment to demonstrate consistent performance with changing FGD wastewater quality
- Factors that impact FGD wastewater quality:
 - Coal quality
 - FGD cycles of concentration that affect Cl, TDS
 - Cl, Mg levels in limestone reagent
 - Various forms of Se in FGD wastewater
 - Coal plant cycling
 - FGD wastewater temperature swings



Technology Needs: Determining Speciation of Heavy Metals in Coal Plant Wastewater



- "EPA intends to fully evaluate all of the issues raised in the petitions, including concerns about: cost and impacts to steam electric facilities, public availability of information on which the rule is based, <u>lack of data for plants that burn</u> <u>certain types of coal</u>, and validity of certain pollutant data used in EPA's 2015 Rule analysis."*
- Similar to Hg air emissions, need to characterize speciation of heavy metals in wastewater streams as functions of coal type, pollution controls
- Understanding coal plant early retirement drivers, and necessary lifespans for FGD wastewater treatment systems

^{*} https://www.epa.gov/sites/production/files/2017-09/documents/steam-electric-elg_final_postpone-compliance-dates_fr-prepub_09-12-2017.pdf





• FGD Wastewater:

- BADCT/NSPS (Direct discharge): Limits on As, Hg, Se, TDS based on evaporation
- Pretreatment Standards for New Sources (PSNS): Applies to units discharging to POTW, standard is limits on As, Hg, Se, TDS based on evaporation
- Fly ash transport water: Dry handling
 - Dry vacuum system using mechanical exhauster to pneumatically convey fly ash from hoppers to a silo
 - BADCT/NSPS for direct discharge units, PSNS for units that discharge to POTW





- Bottom ash transport water: Dry handling BADCT/NSPS (direct discharge) and PSNS (POTW discharge)
 - Water quench/mechanical drag conveyor (incline dewatering)
 - Recovered water reused in quench
- Flue gas Hg control wastewater: Dry handling BADCT/NSPS (direct discharge) and PSNS (POTW discharge)
 - Dry vacuum system using mechanical exhauster to pneumatically convey fly ash from hoppers to a silo (same as fly ash)



ALSTOM Cliffside - Integrated AQCS







Spray Dryer Evaporator – FGD Wastewater ZLD

- Controlling chloride levels in wet FGD blowdown a driving force in spray dryer evaporator design
 - Wet FGD & spray dryer materials of construction
- Evaporation heat source is flue gas "robbed" from air preheater in boiler; spray dryer evaporation degrades plant heat rate
 - 900 MW low-Cl PRB unit $\approx 30 50$ gpm blowdown, 2-3% flue gas bypass¹
 - 900 MW eastern coal unit ≈ 170 200 gpm blowdown, 10-12% flue gas bypass¹
- Baghouse will see 5 10% increase in solids loading



- Co-author Marc Turner (NETL/Leidos)
- Fellow analysts at NETL
- NETL support contractor Black and Veatch for help with spray dryer evaporator, regulatory insights

