




**Modular Gasification for
Syngas/Engine Combine Heat and Power Applications in
Challenging Environments**
(Funding by DOE/NETL Contract DE-FE0031446)

MAKING COAL RELEVANT FOR SMALL SCALE APPLICATIONS

UAF is an AA/EO employer and educational institution and prohibits illegal discrimination against any individual: www.alaska.edu/nondiscrimination/.

WHERE IS FAIRBANKS?






PROJECT PARTNERS



SLR & PDC:
Permitting and Environmental Assessments



HMI:
Intellectual Property
Decades Experience



WorleyParsons:
Detailed Engineering
Cost Estimating Service



Cost Share: Chena Power, Aurora Energy,
UAF, Sotacarbo, HMI, GVEA, Innio, Western
Energy Services



PROJECT DESCRIPTION AND OBJECTIVE

Demonstrate small scale coal gasification to fuel reciprocating engine generators

- Cost effective coal generating capacity for small applications
- Provides load following services
- Ideal for islanding systems
- Local jobs







ALIGNMENT WITH DOE GOALS

- ✓ Small—50-350 MW
 - ✓ This project: 18 MWe
 - ✓ First step toward “modularizing”
 - ✓ Near Zero Emissions
 - ✓ Built in a “Serious non-Attainment area for PM2.5”
 - ✓ Minimize water usage
 - ✓ Water cleaned up for greenhouse use
 - ✓ Capable of natural gas co-firing
 - ✓ Engines are easily convertible to firing natural gas or propane
 - ✓ Capable of high ramp rates
 - ✓ Designed for wind regulation
- Not specifically part of DOE’s stated goals, but noteworthy:
- ✓ Pyrolysis tars/oils can be used in diesel engines
 - ✓ Deigned to co-fire biomass



UAF'S MODIFIED DESIGN



UAF'S MODIFIED DESIGN



THE EQUIPMENT





FOUND A HOME!





WHY COAL GASIFICATION?

COSTS FOR REGULATING 10 MWe OF WIND POWER

	Syngas Project (UAF)	Diesel (GVEA)	Natural Gas (not an option)
Capital Cost (option 3)	\$85 million	--	--
Fuel Costs + other O&M	\$76.6/MWh (\$10/mmbtu)	\$147.2/MWh (\$15/mmbtu)	\$200/MWh (\$20/mmbtu)
Wind Regulation Costs (10 MWe regulating capacity)	\$3.1 M/yr (GVEA's cost to regulate wind with syngas)	\$6.5 M/yr (avoidable costs)	--
Total Generation (syngas and liquid fuels)	18 MW 10.0 MW avg 5 to 18 MW swing	240 MW 43.2 MW avg 35 to 48 MW swing	--
Efficiency, HHV	39%	<15% (turbines)	--

THE PROBLEM: INTERMITTENT GENERATION

Eva Creek



“Free”
Energy

Combustion
Turbine



Expensive
Energy



Coal



Cheapest
Energy

THE SOLUTION: COAL ENABLING WIND

Eva Creek



“Free”
Energy



Recip.
Generator



Cheapest
Energy




Coal



Cheapest
Energy




Combustion
Turbine



Expensive
Energy


EFFICIENCY vs. LOAD

COMBINED CYCLE LM6000 GAS TURBINE PLANT – NPEP
EFFICIENCY CURVE – COMPARED TO DIESEL RECIP UNITS
IN WIND LOAD FOLLOWING APPLICATION



EFFICIENCY vs. LOAD

COMBINED CYCLE LM6000 GAS TURBINE PLANT – NPEP
EFFICIENCY CURVE – COMPARED TO DIESEL RECIP UNITS
IN WIND LOAD FOLLOWING APPLICATION






REGULATORY/PERMITTING

The EPA designated the Fairbanks vicinity as a “serious nonattainment area for PM_{2.5}”

- PM_{2.5} and precursors (NO_x, SO₂, volatile organic compounds, and ammonia) will be regulated under the nonattainment New Source Performance Standard
- Even with Best Available Control Technology, this project is economical




MODULARITY and SCALING




Gasifier/Engine
System is Modular and
Scalable

Multiple gasifier trains
and engines can create
powerplants from 1
MWe to 30 MWe+



AK-DGGS IDENTIFIED 37 VILLAGES WITH COAL NEARBY



RADICALLY ENGINEERED SYSTEM



- Make it work at 10 to 18 MWe
 - Economies of Scale working against us
- Make it work at village scale <2MWe
- Integrate with diesel infrastructure
- Make it work with biomass and waste products

USEFUL IN LOWER-48, TOO!



- Coal plants are best suited for baseload operation because it requires a long period to ramp up and to ramp down
- Syngas/Engine combinations has the potential for making coal a cost competitive resource meeting flexible energy demand and fluctuating generation



BUT MOST IMPORTANTLY ...POWER ALASKA'S INTERIOR





RISK FACTORS

- Except for the HMI Gasifier, all components are available commercially
 - HMI gasifier components are well understood and documented
- Emission controls could be *the* key factor to be addressed
 - Fairbanks is in an EPA designated “Serious non-attainment area for PM 2.5”

MEET THE TEAM

- Diane Revay Madden, NETL
- Brent J Sheets, UAF
- Rolf Maurer & Team, HMI
- Harvey Goldstein & Team, WorleyParsons
- Chilkoot Ward & David Fish, Aurora Energy
- Randy Hobbs, Hobbs Industries
- Alberto Pettinau, Sotacarbo
- Isaac Bertschi & Courtney Kimball, SLR
- Erica Betts, PDC





QUESTIONS?



Brent J Sheets

907-750-0650

bjsheets2@alaska.edu

<http://pdl.uaf.edu/>