
# Natural Gas-Based Coproduction of Power and H<sub>2</sub> with CCS

Chuck White<sup>1</sup> and Jess VanWagoner<sup>1</sup>

<sup>1</sup>KeyLogic Systems, LLC



INTERNAL USE ONLY – NOT APPROVED FOR PUBLIC RELEASE





## **Disclaimer and Acknowledgement**



### DISCLAIMER

"This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency."

### ACKNOWLEDGEMENT

Team KeyLogic's contributions to this work were funded by the National Energy Technology Laboratory under the Mission Execution and Strategic Analysis contract (DE-FE0025912) for support services. The authors would like to thank Walter Shelton (NETL), Travis Shultz (NETL), and Mark Woods (KeyLogic) for their support and assistance in performing this work.



## Agenda

NATIONAL ENERGY TECHNOLOGY LABORATORY

- Project Summary
- Process Descriptions
  - Baseline Steam Methane Reforming Case
  - Direct-fired Reformer

## • Design Basis

- Assumptions
- Methodology
- Uncertainty Analysis and Data Gaps
- Performance Results
- Economic Analysis Results
- Additional Sensitivity Analyses





#### Justification

- Hydrogen is an important chemical raw material and gaining growing attention for energy storage and low/zero carbon power applications
- Coproduction of hydrogen and power may allow fossil fuels to continue to play a critical role in a carbon constrained world


### Highlights

- Coproduction of hydrogen and power is potentially economically viable
- Steam methane reforming (SMR) is the low-cost technology of choice for coproduction of hydrogen and power with 90% CCS
- Oxygen-blown autothermal reforming (ATR) appears competitive with SMR for hydrogen production at small scale but is not a superior process for hydrogen and power coproduction

### Outcomes

- Update to accuracy and understanding of SMR technology
- Sensitivity analyses identifying possible optimization paths for ATR

### BFD for SMR w/ CT and CCS








#### Approach

- Extensive literature survey performed
- Brainstorming sessions to identify potential co-production concepts of interest and proposed scale
- Spreadsheet level screening analysis used to down select most promising concepts
- Techno-economic analyses for 2 processes using Aspen Plus models
  **Results**

Gross Plant Output, kWe		
	SMR	ATR
Gas Turbine Power	21,900	21,540
Steam Turbine Power	0	0
Total	21,900	21,540
Auxiliary Load, kWe		
Primary Air Fans / O <sub>2</sub> Compressor	210	2,600
CO <sub>2</sub> Compressor	2,420	3,120
Fuel Gas Recycle Compressor		1,520
Air Separation Unit		5,374
BFW and Ground Water Pumps	90	110
Circulating Water Pump	240	460
Cooling Tower Fans	120	230
CO <sub>2</sub> Capture/Removal Auxiliaries	1,030	1,060
Gas Turbine Auxiliaries <sup>1</sup>	0	0
Miscellaneous Balance of Plant <sup>2</sup>	20	20
Transformer Losses	80	110
Total	4,210	14,604

Sensitivity of H<sub>2</sub> RSP to electricity purchase price








#### Results

Plant Performance Summary		
	SMR	ATR
Auxiliary Load, kW <sub>e</sub>	4,210	14,604
Net Plant Power, kW <sub>e</sub>	17,690	6,936
Natural Gas SMR Feed Flowrate, kg/hr (lb/hr)	11,706 (25,807)	15,268 (33,661)
Natural Gas SMR Thermal Input (HHV) <sup>1</sup> , kW <sub>th</sub>	172,381	224,845
Total Hydrogen Production, kg/hr (lb/hr)	3,583 (7,899)	2,416 (5,326)
Total Hydrogen Production (HHV) <sup>2</sup> , kW <sub>th</sub>	141,218	95,227
Hydrogen Production Efficiency (HHV)	79%	42%
Excess Hydrogen (Storage or Sale), kg/hr (lb/hr)	1,906 (4,203)	2,416 (5,326)
Hydrogen Fuel to Combustion Turbine, kg/hr (lb/hr)	1,676 (3,695)	1,659 (3,658)
Combustion Turbine Thermal Input (HHV), kW <sub>th</sub>	66,071	65,400
Combustion Turbine Efficiency (HHV) <sup>3</sup>	33.1%	32.9%
Net Plant Efficiency (HHV)	54%	16%
CO2 Recovered, ton/day	739	962
CO2 Emissions, ton/day	82	57
Hydrogen Yield⁴	0.71	0.37
Raw Water Withdrawal, gpm	441	454

Sensitivity to feed ratio of air to oxidant in ATR







#### Limitations

- Kinetic data for reformers not available
- TEAs limited to thermodynamic (equilibrium) analysis
- Cost algorithms extrapolated to a large degree
- Non-predictive models for AGR

### Suggested Follow-On Work

- Vendor RFIs for cost quotes for small scale SMR, ATR, AGR units
- Enhance granularity of AGR models to allow process optimization
- Screening level TEAs for more advanced technologies (syngas chemical looping)
- Explore more use cases for hydrogen storage


#### **Data Resources and Project Coordination**


- 2010 NETL/ESPA study on coal to H<sub>2</sub> with SMR reference case
- Cost data from prior studies (Baseline DPE, NG direct fired sCO<sub>2</sub>)

### Authors

- Jessica VanWagoner, KeyLogic
- Chuck White, KeyLogic










Baseline Steam Methane Reforming

U.S. DEPARTMENT OF Solutions for Today | Options for Tomorrow

INTERNAL USE ONLY - NOT APPROVED FOR PUBLIC RELEASE






INTERNAL USE ONLY - NOT APPROVED FOR PUBLIC RELEASE

Autothermal Reformer Technology

U.S. DEPARTMENT OF Solutions for Today | Options for Tomorrow








Design Basis

INTERNAL USE ONLY – NOT APPROVED FOR PUBLIC RELEASE



# Site, Fuel and Hydrogen Characteristics



#### Site Characteristics<sup>1</sup>

Parameter	Value		
Location	Greenfield, Midwestern U.S.		
Water	50 % Municipal and 50% Ground Water		
Elevation, ft	0		
Barometric Pressure, MPa (psia)	0.101 (14.696)		
Average Ambient Dry Bulb Temperature, °C (°F)	15 (59)		
Average Ambient Wet Bulb Temperature, °C (°F)	10.8 (51.5)		
Design Ambient Relative Humidity, %	60		
Cooling Water Temperature, °C (°F) <sup>A</sup>	15.6 (60)		
Air composition based on published psychrometric data, mass %			
N <sub>2</sub>	74.97		
0 <sub>2</sub>	23.03		
Ar	1.30		
H <sub>2</sub> O	0.65		
CO <sub>2</sub>	0.05		
Total	100.00		

INTERNAL USE ONLY -

#### **Fuel Characteristics<sup>1</sup>**

Component		Volume Percentage
Methane	CH <sub>4</sub>	93.1
Ethane	C <sub>2</sub> H <sub>6</sub>	3.2
Propane	C <sub>3</sub> H <sub>8</sub>	0.7
<i>n</i> -Butane	C <sub>4</sub> H <sub>10</sub>	0.4
Carbon Dioxide	CO <sub>2</sub>	1.0
Nitrogen	N <sub>2</sub>	1.6
Methanethiol <sup>A</sup>	CH <sub>4</sub> S	5.75x10 <sup>-6</sup>
	Total	100.00
	LHV	HHV
kJ/kg (Btu/lb)	47,454 (20,410)	52,581 (22,600)

<sup>A</sup>The sulfur content of natural gas is primarily composed of added Mercaptan (methanethiol,  $CH_4S$ ) with trace levels of  $H_2S$  (11). Note: Fuel composition is normalized and heating values are calculated

#### Hydrogen Characteristics<sup>2</sup>

Product Specification		Product Purity	
Hydrogen	H <sub>2</sub>	99.9	
	LHV	HHV	
kJ/kg (Btu/lb)	120,017(51,585)	141,936 (61,006)	



Source: 1NETL, "Cost and Performance Baseline for Fossil Energy Plants, Volume 1a: Bituminous Coal (PC) and Natural Gas to Electricity, Revision 3," NOT APPROVED FOR PUBLIC RELEASE July 2015.

<sup>2</sup> NETL, "Assessment of Hydrogen Production with CO2 Capture, Volume 1: Baseline State-of-the-Art Plants, Revision 1," November 2011.

## **Design Basis**



### Environmental targets

- 90% CO<sub>2</sub> capture for all cases
- Sulfur Oxides (SO<sub>2</sub>) controlled by zinc oxide guard bed
- Nitrogen Oxides (NO<sub>x</sub>) controlled with low NO<sub>x</sub> burners to meet the emission standard of 2.5 ppmv (dry) @ 15% O<sub>2</sub>

## SMR plant basis

- SMR case based on Case 1-2 from the Assessment of Hydrogen Production with CO<sub>2</sub> Capture Volume 1: Baseline State-of-the-Art Plants (NETL, 2011)
- Scaled down to provide approximately equal amounts of hydrogen for sale and turbine fuel

## • ATR plant basis

• Similar to SMR scale but limited by desire to have export power



# **Cost Estimating Methodology**



- Capital costs were scaled from NETL reference cases found in NETL's Bituminous Baseline (Revision 3) (BBR3)<sup>1</sup>, legacy SMR cost models<sup>2</sup>, and DPE TEA Report in preparation
- Costs based on the BBR3 were scaled according to methodology outlined in the Cost Scaling Quality Guidelines for Energy System Studies
- Costs were escalated to 2018\$
- Cost of electricity (COE) and the required selling price (RSP) of hydrogen were calculated using the methodology outlined in Revision 3 of the Bituminous Baseline
  - Financial parameter assumptions match those of Case B31B from Revision 3



Source: INETL, "Cost and Performance Baseline for Fossil Energy Plants, Volume 1a: Bituminous Coal (PC) and Natural Gas to Electricity, Revision 3," July 2015.

# Uncertainty Analysis and Data Gaps



- Capital costs associated with unit operations unique to the SMR process (reformer, PSA) were scaled using generic scaling factors, since scaling methodology for these accounts were not available
- Capital costs unique to the SMR process were scaled from costs in the legacy SMR cost models<sup>1</sup>

• These include capital costs for the reformer, PSA, and the MDEA system<sup>2</sup>

- These capital costs may be outdated (2007\$), and the original quote is not available
- The SMR scale in this study is ~7.2x smaller than the scale in the legacy SMR work
- Future work could aim to obtain updated SMR quotes and also quotes specific to the scale considered in this study



# **Uncertainty Analysis and Data Gaps**



ATR Case

## Largest areas on uncertainty


- ATR capital cost
- ATR temperature at which catalyst is no longer necessary
- MDEA capital cost

# • Vendor quotes at target scale needed for:

- ATR
- ASU
- AGR

### Reduction in uncertainty unlikely to impact relative ranking of technologies








## Performance Results

INTERNAL USE ONLY – NOT APPROVED FOR PUBLIC RELEASE



## Plant Performance Results



Plant Performance Summary		
	SMR	ATR
Auxiliary Load, kW <sub>e</sub>	4,210	14,604
Net Plant Power, kW <sub>e</sub>	17,690	6,936
Natural Gas SMR Feed Flowrate, kg/hr (lb/hr)	11,706 (25,807)	15,268 (33,661)
Natural Gas SMR Thermal Input (HHV) <sup>1</sup> , kW <sub>th</sub>	172,381	224,845
Total Hydrogen Production, kg/hr (lb/hr)	3,583 (7,899)	2,416 (5,326)
Total Hydrogen Production (HHV) <sup>2</sup> , kW <sub>th</sub>	141,218	95,227
Hydrogen Production Efficiency (HHV)	79%	42%
Excess Hydrogen (Storage or Sale), kg/hr (lb/hr)	1,906 (4,203)	2,416 (5,326)
Hydrogen Fuel to Combustion Turbine, kg/hr (lb/hr)	1,676 (3,695)	1,659 (3,658)
Combustion Turbine Thermal Input (HHV), kW <sub>th</sub>	66,071	65,400
Combustion Turbine Efficiency (HHV) <sup>3</sup>	33.1%	32.9%
Net Plant Efficiency (HHV)	54%	16%
CO2 Recovered, ton/day	739	962
CO2 Emissions, ton/day	82	57
Hydrogen Yield⁴	0.71	0.37
Raw Water Withdrawal, gpm	441	454

<sup>1</sup>HHV of Natural Gas is 53,014 kJ/kg (22,792 Btu/lb)

<sup>2</sup>HHV of Hydrogen is 141,900 kJ/kg (61,006 Btu/lb)

<sup>3</sup>Not including fuel dilution steam



## **Power Performance Summary**



Gross Plant Output, kWe		
	SMR	ATR
Gas Turbine Power	21,900	21,540
Steam Turbine Power	0	0
Total	21,900	21,540
Auxiliary Load, kWe		
Primary Air Fans / O <sub>2</sub> Compressor	210	2,600
CO <sub>2</sub> Compressor	2,420	3,120
Fuel Gas Recycle Compressor		1,520
Air Separation Unit		5,374
BFW and Ground Water Pumps	90	110
Circulating Water Pump	240	460
Cooling Tower Fans	120	230
CO <sub>2</sub> Capture/Removal Auxiliaries	1,030	1,060
Gas Turbine Auxiliaries <sup>1</sup>	0	0
Miscellaneous Balance of Plant <sup>2</sup>	20	20
Transformer Losses	80	110
Total	4,210	14,604

<sup>1</sup>Gas turbine auxiliary loads are accounted for in the gas turbine output power.


<sup>2</sup>Includes plant control systems, lighting, HVAC, and miscellaneous low voltage loads.





## Economic Analysis Results

INTERNAL USE ONLY - NOT APPROVED FOR PUBLIC RELEASE



## **Cost Results Summary**




Capital Costs

	Case 1 - SMR	Case 2 – ATR
Account	Total Plant Cost	(\$/1,000) (2018)
Account 3: Feedwater and Miscellaneous BOP Systems	30,483	29,734
Account 5A: Gas Cleanup and Piping	4,899	6,190
Account 5B: CO <sub>2</sub> Removal and Compression	97,596	69,491
Account 6: Combustion Turbine and Accessories	11,691	11,691
Account 7: HRSG, Ductwork and Stack	7,070	8,476
Account 9: Cooling Water System	4,306	6,392
Account 11: Accessory Electric Plant	14,754	21,695
Account 12: Instrumentation and Control	4,026	8,492
Account 13: Improvements to Site	3,901	3,889
Account 14: Buildings and Structures	1,891	1,922
Account 15: Methane Reformer	29,893	74,445
Account 16: Pressure Swing Adsorber	10,301	7,516
Total	220,811	249,933




## **Cost Results Summary**

Owner's Costs










• H<sub>2</sub> T&S not included in RSP



# **RSP Sensitivity to Electricity Purchase Price**






NATIONAL

NOLOGY

## Cost of Electricity (COE)






• H<sub>2</sub> T&S not included in RSP



## **Direct-fired Reformer Coproduction Case**



COE Sensitivity to Hydrogen Purchase Price









## Additional Sensitivity Analyses

INTERNAL USE ONLY – NOT APPROVED FOR PUBLIC RELEASE



# **Additional Sensitivity Analyses**

- Sensitivity analyses performed to assess performance and economic impacts of:
  - ATR temperature
  - ATR pressure
  - Oxygen purity (Oxygen:air ratio)
  - Hydrogen production rate
  - Assumed natural gas price








## **Range Sensitivity Analysis to ATR Temperature**

- Plot shows estimated COE and H<sub>2</sub> RSP as a function of ATR exit temperature
- Temperature ranged from 1800 °F to 2000 °F (baseline)
- Assumed no catalyst required
- H<sub>2</sub> RSP decreases with increasing temperature whereas COE increases








## Perturbation Sensitivity Analysis to ATR Pressure


- Plot shows estimated COE and H<sub>2</sub> RSP as a function of ATR inlet pressure
- Single pressure evaluated (430 psia) compared to baseline (480 psia)
- Process and computation constraints limited range
- H<sub>2</sub> RSP decreases slightly with increasing pressure whereas COE increases moderately





### Small Range Sensitivity Analysis to Oxygen: Air Ratio

- Plot shows estimated COE and H<sub>2</sub> RSP as a function of fraction of oxidant as air
- Air oxidant fraction ranged from 0.0 to 0.03
- Model computation constraints limited range
- H<sub>2</sub> RSP decreases slightly with increasing air whereas COE passes through a minimum and then rises rapidly








NATIONAL

### Small Range Sensitivity Analysis to Hydrogen Production


- Plot shows estimated COE and H<sub>2</sub> RSP as a function of WGS cooler temperature
- As WGS cooler temperature decreases, more H<sub>2</sub> produced
- Requirement to have excess power limited range
- As WGS cooler temperature decreases, H<sub>2</sub> RSP decreases whereas COE passes through a minimum and then rises rapidly





### **Range Sensitivity Analysis to Assumed Price of Natural Gas**

- Plot shows estimated COE and H<sub>2</sub> RSP as a function of the assumed NG price
- NG price range 2-5 \$/MMBtu
- As NG price increases, both COE and H2 RSP increase monotonically
- Every \$1/MMBtu increase in NG price increases:
  - COE by 110 \$/MWh
  - $\circ~{\rm H_2}$  RSP by 0.315 \$/kg









INTERNAL USE ONLY - NOT APPROVED FOR PUBLIC RELEASE

