


# Techno-Economic Analyses for Direct Air Capture (DAC)

*Overview*

**Tim Fout, Strategic Systems Analysis and Engineering (SSAE)**



February 24, 2021



Solutions for Today | Options for Tomorrow



# Presentation Outline

---



- **Techno-Economic Analysis (TEA) Process**
- **QGESS Description/Location**
- **Bituminous Baseline Study Overview/Example**

# Presentation Outline

---



- **Techno-Economic Analysis (TEA) Process**
- QGESS Description/Location
- Bituminous Baseline Study Overview/Example

# Tecno-Economic Analysis Tools

Right tool for TRL level




- **Low TRL Analysis**

- Mass and Energy Balances
- Preliminary Spreadsheet Models – Post Combustion Tool, Compression Tool
- Cost correlations

- **Mid to High TRL (for NETL projects)**

- Process Simulation Software
  - Aspen Plus
  - CHEMCAD
  - Thermoflow
  - Others

# Steps to Performing TEA




1. Form a Technology Analysis Plan
2. Create a Performance Model
3. Cost Estimating – BSP
4. Reporting Requirements

# Technology Analysis Plan (TAP)

What is a TAP?




- A TAP discusses the approach and methodology required to conduct the TEA
- Presented to stakeholders prior to starting the TEA
  - Document assumptions
  - Ensure valuable product
- Updated as the TEA is performed - changes should be noted in a final document



| Case                         | Baseline<br>(Reference) | Case Study          |               |         |
|------------------------------|-------------------------|---------------------|---------------|---------|
|                              |                         | Case 1              | Case 2        | Case 2A |
| Technology Combinations      |                         |                     |               |         |
| CO <sub>2</sub> Removal      | Selexol                 | Novel Capture Tech. |               |         |
| Enabling Tech.               | Std. Tech.              |                     | Enabled Tech. |         |
| CO <sub>2</sub> Purification | No                      |                     |               | Yes     |

# Steps to Performing a TEA



1. Form a Technology Analysis Plan
- 2. Create a Performance Model**
3. Cost Estimating – BSP
4. Reporting Requirements




# Performance Model Results for Reporting

- **Build a performance model**

- Frequently completed in ASPEN, CHEMCAD, Thermoflow, etc.
- When applying novel technology:
  - Balance of plant equipment NOT affected by research area will be scaled (RR)
  - Changes in operating parameters and other assumptions that are different than those QGESS must be justified in the TEA document (RR)

- **Detailed Process Flow Diagram (RR)**



Note: Block Flow Diagram is not intended to represent a complete material balance. Only major process streams and equipment are shown.



# Performance Modeling Inconsistencies

- Items that are often varied between the reference and novel cases without justification:

- Condenser pressure
- Steam cycle conditions (e.g. reheat temperature)
- Combustion turbine conditions (e.g. turbine inlet temperature)
- Cooling water temperature
- ASU performance and oxygen quality
- Emissions levels
- Equipment selection

These variations without justification may require further communication or resubmission of report

Performance variations NOT related to the novel technology between the reference and novel cases should thoroughly explained

# Performance Model Results for Reporting



- **Material and Energy Balances (RR)**
  - Consistent with the level of detail found in the Baseline reports. Material balance should include
    - All inputs feedstock, catalyst, limestone, etc.
    - All outputs such as stack gas, waste water, solid waste disposal
    - Stream compositions
  - Energy Balance should include
    - Thermal energy input from fuel
    - Major auxiliary loads
    - Detailed loads for new technology

# Model Results

B5B (GEE Radiant Capture)



- **Total power from turbines (RR)**
- **New auxiliary loads (RR)**
- **Net Power (RR)**
- **Heat rate, efficiencies, etc. (RR)**  
HHV Commonly used for NETL reporting purposes
- **Water withdraw, consumption, and discharge (RR)**  
If new technology creates impurities in water discharge, this must be documented
- **CO<sub>2</sub> product composition (RR)**
- **Air emissions**
- **Equipment and auxiliary loads NOT affected by novel technology will be scaled appropriately**

| Power Summary                                     | Rev4-PO    | Rev4       |
|---|------------|------------|
| Combustion Turbine Power, MWe                     | 464        | 464        |
| Sweet Gas Expander Power, MWe                     | 3          | 3          |
| Steam Turbine Power, MWe                          | 276        | 274        |
| <b>Total Gross Power, kWe</b>                     | <b>743</b> | <b>741</b> |
| Auxiliary Load Summary                            |            |            |
| Acid Gas Removal, kWe                             | 11,490     | 11,550     |
| Air Separation Unit Auxiliaries, kWe              | 1,000      | 1,000      |
| Air Separation Unit Main Air Compressor, kWe      | 70,920     | 71,280     |
| Air Separation Unit Booster Compressor, kWe       | 5,580      | 5,610      |
| Ammonia Wash Pumps, kWe                           | 90         | 90         |
| Circulating Water Pumps, kWe                      | 4,740      | 4,850      |
| Claus Plant TG Recycle Compressor, kWe            | 60         | 1,080      |
| Claus Plant/TGTU Auxiliaries, kWe                 | 250        | 250        |
| CO <sub>2</sub> Compression, kWe                  | 29,000     | 31,670     |
| Coal Dryer Air Compressor, kWe                    | 0          | 0          |
| Coal Handling, kWe                                | 470        | 470        |
| Coal Milling, kWe                                 | 2,240      | 2,250      |
| Combustion Turbine Auxiliaries, kWe               | 1,000      | 1,000      |
| Condensate Pumps, kWe                             | 260        | 270        |
| Cooling Tower Fans, kWe                           | 2,450      | 2,510      |
| Feedwater Pumps, kWe                              | 3,810      | 3,840      |
| Gasifier Water Pump, kWe                          | 0          | 0          |
| Ground Water Pumps, kWe                           | 490        | 500        |
| Miscellaneous Balance of Plant <sup>A</sup> , kWe | 3,000      | 3,000      |
| Nitrogen Compressors, kWe                         | 35,460     | 36,580     |
| Nitrogen Humidification Pump, kWe                 | 0          | 0          |
| Oxygen Pump, kWe                                  | 480        | 480        |


| Auxiliary Load Summary                   |            |            |
|--|------------|------------|
| Quench Water Pump, kWe                   | 400        | 400        |
| Shift Steam Pump, kWe                    | 210        | 210        |
| Slag Handling, kWe                       | 1,150      | 1,150      |
| Slag Reclaim Water Recycle Pump, kWe     | 0          | 0          |
| Slurry Water Pump, kWe                   | 190        | 190        |
| Sour Gas Compressors, kWe                | 0          | 0          |
| Sour Water Recycle Pumps, kWe            | 10         | 10         |
| Steam Turbine Auxiliaries, kWe           | 100        | 200        |
| Syngas Recycle Compressor, kWe           | 0          | 0          |
| Syngas Scrubber Pumps, kWe               | 140        | 140        |
| Process Water Treatment Auxiliaries, kWe | 1,670      | 1,320      |
| Transformer Losses, kWe                  | 2,860      | 2,870      |
| <b>Total Auxiliaries, MWe</b>            | <b>180</b> | <b>185</b> |
| <b>Net Power, MWe</b>                    | <b>564</b> | <b>556</b> |

# Reporting Novel Equipment




- Novel equipment should be reported at a greater level of detail than found in the Baseline study
- Items to include (RR):
  - Design equations (if developed)
  - Scaling methodology and equations
  - Design basis (kinetics, volumetric throughput, etc.)
  - How was the data for the above collected (TGA, lab scale bubbling bed, etc.)

# Steps to Performing TEA



1. Form a Technology Analysis Plan
2. Create a Performance Model
3. Cost Estimating – BSP
4. Reporting Requirements

# Classes of NETL Cost Estimates



Process flow diagrams (PFDs) and piping and instrument diagrams (P&IDs) are the primary documents that define project scope. **Association for the Advancement of Cost Engineering** International (AACE) Recommended Practice No. 18R-97 describes the AACE cost estimate classification system.

# QGESS: Cost Estimation Methodology

## • Capital Cost Breakdown


- Estimate Class
- Contingency Guidelines
- Owner's Cost Recommendations
- Estimate Scope
- Project Scope

## • Economic Analysis

- Global Economic Assumptions
- Recommended Financing Structures
- Estimation of BSP

### QUALITY GUIDELINES FOR ENERGY SYSTEM STUDIES

### Cost Estimation Methodology for NETL Assessments of Power Plant Performance





# Economic Analysis – Breakeven CO<sub>2</sub> Sales Price

## Cost of Capture



- **Breakeven CO<sub>2</sub> Sales Price (BSP)** is the minimum revenue a power plant must receive for the CO<sub>2</sub> captured and sent to storage in order to cover cost and stated IRROE
  - Determining involves a complex set of financial assumptions
  - To simplify the calculation, a Fixed Charge Rate (for capital) has been developed.
    - Simplifies and unifies common financial terms and assumptions
    - Annualizes the capital cost over the life of the plant
- A simplified equation can be utilized to determine the BSP to unify assumptions

$$\text{BSP} = \frac{\text{Annualized capital charge} + \frac{\text{Annual fixed operating costs} + \text{Annual variable operating costs}}{\text{annual CO}_2 \text{ captured and sent to storage}}}{\text{annual CO}_2 \text{ captured and sent to storage}}$$

# Economic Analysis - BSP

(RR)



$$\text{BSP} = \frac{\text{FCR} \cdot \text{TASC} + \text{OC}_{\text{FIX}} + \text{CF} \cdot \text{OC}_{\text{VAR}} + \text{CF} \cdot \text{FP}}{\text{CF} \cdot \text{FCO}_2}$$

- The **FCR** takes into account the financial aspects of the plant and represents them in a single factor that can then be used to annualize the capital over the life of the plant. Greater detail can be found in the QGESS documents.
- The **FCO<sub>2</sub>** parameter is the annual flow of CO<sub>2</sub> from the plant (at 100% CF);
  - NET removal = is the net CO<sub>2</sub> removed from the atmosphere
  - GROSS = is the gross CO<sub>2</sub> removed from the atmosphere by the DAC system
  - PLANT GROSS = gross DAC removal plus and other CO<sub>2</sub> product flow from the overall plant including power generation
- The **CF** parameter Capacity Factor, which is assumed to be equal to the availability
- The **FP** is the sum of annual fuel costs (if in plant boundary)

| Fixed Operating Costs (OC <sub>FIX</sub> )      | Variable Operating Costs (OC <sub>VAR</sub> )   |
|---|---|
| Annual Operating Labor Cost                     | Maintenance Material Cost                       |
| Maintenance Labor Cost                          | Other Consumables                               |
| Administrative & Support Labor                  | Waste Disposal                                  |
| Property Taxes and Insurance                    | Emission Costs                                  |
| Additional OC <sub>FIX</sub> for new technology | Byproduct Revenues                              |
|   | Additional OC <sub>VAR</sub> for new technology |
|   | *Energy Costs, if outside plant                 |

# Economic Analysis – Capital Costs

(RR)

$$BSP = \frac{FCR \cdot \text{TASC} + OC_{FIX} + CF \cdot OC_{VAR} + CF \cdot FP}{CF \cdot FCO_2}$$

Diagram illustrating the components of the Bare Elected Cost (BEC) and Total As-Spent Cost (TASC) in the context of the Bare Elected Cost (BEC) equation.

**BEC Components:**

- process equipment
- supporting facilities
- direct and indirect labor
- EPC contractor services

**EPCC Components:**

- process contingency
- project contingency

**TPC Components:**

- pre-production costs
- inventory capital
- financing costs
- other owner's costs

**TOC Components:**

- escalation during capital expenditure period
- interest on debt during capital expenditure period

**TASC Components:**

- Bare Elected Cost
- Engineering, Procurement and Construction Cost
- Total Plant Cost
- Total Overnight Cost
- Total As-Spent Cost

**Notes:**

- BEC, EPCC, TPC, TOC and TCR are all "overnight" costs expressed in base-year dollars.
- TASC is expressed in mixed-year current dollars, spread over the capital expenditure period.

# Capital Cost Basis of Novel Equipment



- **Capital costs (projected commercial costs) for unique equipment may be calculated by several methods: (RR)**
  - Scaled: The equipment can be scaled if analogous equipment is available either in an NETL baseline study or otherwise
  - Bottom-up: Build cost from metal and manufacturing cost estimates
  - If neither a scaled approach or a bottom-up estimate can be produced - research goals or bearable costs can be estimated
    - This approach is occasionally used at laboratory scale projects
  - Report what the basis is for cost (experimental scale)
- **The methodology, reference equipment, and sources of data should be documented in detail within the TEA**
- **Balance of plant will be directly used or scaled from the Baseline reports**

# Contingency Estimation



- Contingency is to cover the known-unknowns or costs that will likely occur based on past experience due to incomplete engineering design
  - Example: early in the design phase, the plant will have high contingencies, future plants should have lower contingencies, but more known costs
- Two types of contingencies are used:
  - Project Contingency: AACE 16R-90 states that project contingency for a “budget-type” estimate (AACE Class 4 or 5) should be 15 percent to 30 percent of the sum of BEC, EPC fees and process contingency.
  - Process Contingency: intended to compensate for uncertainty in cost estimates caused by performance uncertainties associated with the development status of a technology.

- Each “process” in the TEA is assigned a contingency

| Technology Status             | Process Contingency |
|-------------------------------|---------------------|
| New Concept – limited data    | 40+%                |
| Concept with bench scale data | 30-70%              |
| Small Pilot scale data        | 20-35%              |
| Full sized modules tested     | 5-20%               |
| Commercial process            | 0-10%               |

# Contingency Estimation

- Generally, novel technology should have a higher contingency than those in the Baseline studies
- Level of Contingency used should be relative to the development level and engineering completeness of the cost estimate for the novel technology.
- If R&D cost targets, if applicable, contingency might be inclusive
  - When assessing progress towards R&D targets, appropriate contingencies should be included

- Contingency is not:

- To cover poor engineering or poor estimates
- Accuracy
- Cover a scope change
- Account for delays
- Unexpected cost escalation
- Plant performance after startup


Process contingencies range between 2-5% of overall TPC

| Process Contingency                 |     |
|-------------------------------------|-----|
| Slurry prep and Feed pump           | 5%  |
| Gasifier and syngas cooler          | 15% |
| Two stage Selexol                   | 20% |
| Mercury Removal                     | 5%  |
| CO <sub>2</sub> removal (PC & NGCC) | 20% |
| Combustion Turbine                  | 5%  |
| AHT in IGCC                         | 10% |
| Instrumentation and controls        | 5%  |

# Economic Analysis - BSP


Once BSP has been calculated:

- Compared to reference to novel cases(RR)
- Sensitivity analysis can be conducted to guide research or suggest future goals (RR)
  - Examples include:
    - Capital cost,
    - changes in kinetics
    - reduced pressure drop,
    - reduced heat of reaction to reduce regeneration duties
- This information can be utilized to determine if a parameter is critical.
- **Warning: Do not compare BSP from different developer TEA's. BSP's should only be compared when from the same TEA with the same assumptions and basis**





# Steps to Performing TEA



1. Form a Technology Analysis Plan
2. Create a Performance Model
3. Cost Estimating – BSP
4. Reporting Requirements

# Reporting Requirements

- **TAP – share with stakeholders**

- State Design and Cost Assumptions and Basis



- **Updated TAP**

- **Performance Modeling**

- Block Flow diagram
- Detailed Simulation Model
- Material and Energy Balance

- **Cost Estimating – Capital Cost and Breakeven CO<sub>2</sub> Sales Price (\$/tonne)**

- Detailed TOC cost estimates
- Sensitivity Studies
- Breakeven Sales Price
  - Focus on \$/tonne NET
  - May also calculate on GROSS or PLANT GROSS basis

- **The TEA report should:**

- Provide reasoning for new equipment design basis – experimental data is preferred
- Have a level a detail equal or greater than that outlined in the Bituminous Baseline (particularly for novel equipment)
- Provide a basis for both design and costing of novel equipment

- **Remember to:**

- Justify any variations from the QGESS/Baseline outside of the new technology
- Provide enough detail to reproduce stated number
- Once complete, use the information to guide research

# Presentation Outline

---



- TEA Process
- **QGESS Description/Location**
- Bituminous Baseline Study Overview/Example

# NETL Quality Guidelines for Energy System Studies

QGESS



| Title  | Description  |
|--|--|
| <b>Detailed Coal Specifications</b>                          | Provides detailed specifications for seven coals commonly used with detailed production information  |
| <b>Specifications for Selected Feedstocks</b>                | Provides recommended specifications for natural gas and coal that are commonly found in NETL energy system studies.  |
| <b>Process Modeling Design Parameters</b>                    | Documents the process modeling assumptions most commonly used in systems analysis studies and the basis for those assumptions. The large number of assumptions required for a systems analysis makes it impractical to document the entire set in each report. This document serves as a comprehensive reference for these assumptions as well as their justification. |
| <b>CO<sub>2</sub> Impurity Design Parameters</b>             | Summarizes the impurity limits for CO <sub>2</sub> stream components for use in carbon steel pipelines, enhanced oil recovery (EOR), saline formation sequestration, and co-sequestration of CO <sub>2</sub> and H <sub>2</sub> S in saline formations.  |
| <b>Capital Cost Scaling Methodology</b>                      | Provides a standard basis for scaling capital costs, with specific emphasis on scaling exponents. This document contains a listing of frequently used pieces of equipment and their corresponding scaling exponent for various plant types, along with their ranges of applicability.  |
| <b>Cost Estimation Methodology</b>                           | Summarizes the cost estimation methodology employed by NETL in its assessment of power plant performance.  |
| <b>Estimating Carbon Dioxide Transport and Storage Costs</b> | Addresses the cost of CO <sub>2</sub> transport and storage (T&S) in a deep saline formation with respect to plant location and region-specific aquifers.  |
| <b>Fuel Prices for Selected Feedstocks</b>                   | Provides an estimate of the market price delivered to specific end-use areas of four coals that are commonly used as feedstocks in the energy system studies sponsored by NETL. Also includes the estimated market price for natural gas delivered to three different regions.   |

# Examples of Information Used in TEA

QGESS Documents Frequently Referenced



## • QGESS on Process Modeling Design

- Site Conditions
- Steam Cycle Conditions
- Coal Combustion Parameters
- Gasifier Performance
- Syngas Processing
- Sulfur Processing
- Equations of State
- Cooling Water Parameters

## • Feedstock Specification QGESS

- Natural Gas Composition
- Coal Compositions – by type
- Limestone Analysis
- Lime Analysis
- LHV and HHV

## • QGESS on CO<sub>2</sub> Impurities

- CO<sub>2</sub> Delivery Pressure
- Individual Contaminate Concentration Limits
- CO<sub>2</sub> minimum concentration
- Specifications for intended use (Saline, EOR, etc.)
- Venting concerns

# Energy Analysis Website

## NETL Webpage: Library: Energy Analysis



### ABOUT ENERGY ANALYSIS

NETL conducts a variety of energy analyses to identify and evaluate promising research and development (R&D) opportunities in order to provide balanced solutions in support of economic sustainability, energy supply security, mitigation of global climate change, and improved environmental performance.

NETL-conducted studies require a multi-disciplinary approach to the assessment of large, complex energy systems encompassing energy production, distribution, and use. Strategic assessments and planning efforts also incorporate the evaluation of current status, near-term trends, and futuristic scenarios.

#### KEY ANALYSIS AREAS

##### TECHNOLOGY ANALYSIS

Technology analyses estimate and assess the performance and cost of current, state-of-the-art as well as future energy technologies and systems that result from successful NETL RD&D. Example energy technologies and systems include advanced carbon capture technologies and systems that store captured carbon dioxide in deep geologic formations. The outputs from technology analyses are used to inform larger scale energy-economic models that place these technologies in context within the larger energy portfolio. The analyses also provide insights into the anticipated competitiveness of these technologies, as well as the potential economic, environmental, and energy security impacts and benefits that result from successful NETL RD&D under a variety of possible future scenarios.

##### BENEFITS ANALYSIS

Focuses on quantifying both prospective and retrospective benefits of energy R&D programs using economic models. These studies deliver an understanding of the potential economic competitiveness of advanced energy technologies being developed at NETL, both in the near term and over the next several decades.

The extent to which benefits are realized is a function of several factors, including:

- Success at meeting R&D goals
- Competition with other technologies
- Future energy prices
- Future regulatory actions

Since the future of markets and regulations is uncertain, alternative scenarios must be considered. NETL analysts use economic models to forecast the market penetration of advanced energy systems for a variety of possible futures. Impacts are evaluated and associated benefits quantified across three areas: economic, environmental, and energy security.

##### INTEGRATED ELECTRIC POWER SYSTEMS INFRASTRUCTURE EVALUATION

Studies involve analyzing the interdependencies of electric power systems with other critical infrastructures, such as transportation networks and water infrastructure. Analyses evaluate options for generation, transmission, distribution, and consumption of electricity considering the value of electric power to industry, consumers, and society.

##### ENERGY DATA AND TRENDS ANALYSIS

Energy analyses include assessments of near- and long-term trends within the U.S. and world energy industries that may impact energy price, availability, and security while influencing the choice of fuels and energy production technologies.

##### LIFE CYCLE ASSESSMENT

Life Cycle Analysis (LCA) is a comprehensive form of analysis that utilizes the principles of Life Cycle Assessment, Life Cycle Cost Analysis, and various other methods to evaluate the environmental, economic, and social attributes of energy systems ranging from the extraction of raw materials from the ground to the use of the energy carrier to perform work (commonly referred to as the "life cycle" of a product). Results are used to inform research at NETL and evaluate energy options from a National perspective.



Search Publications



Analytical Tools & Data



Baseline Studies



Life Cycle Analysis



Quality Guidelines



Technology Focus Areas



Analysis Focus Areas

<https://netl.doe.gov/ea/about>

# Energy Analysis Website

## Search Energy Analysis



[About](#) [Research and Programs](#) [Business](#) [Education](#) [Library](#) [News and Events](#)

### SEARCH ENERGY ANALYSIS

|                         |  |                        |  |
|-------------------------|--|------------------------|--|
| Technology Focus:       | <input type="button" value="None selected"/> | Analysis Focus:        | <input type="button" value="None selected"/> |
| Document Kind:          | <input type="button" value="None selected"/> | Collection Name:       | <input type="button" value="None selected"/> |
| Release Year:           | <input type="button" value="None selected"/> | Group:                 | <input type="button" value="None selected"/> |
| Life Cycle Analysis:    | <input type="button" value="None selected"/> | Author:                | <input type="button" value="None selected"/> |
| Authoring Organization: | <input type="button" value="None selected"/> | NETL Point Of Contact: | <input type="button" value="None selected"/> |

Sort Preference: ☒ Recent ☐ Relevance

<https://netl.doe.gov/energy-analysis/search>



# QGESS Examples

## Site Characteristics



### Site Characteristics

| Parameter          | Value                              |
|--------------------|------------------------------------|
| Location           | Greenfield, Midwestern U.S.        |
| Topography         | Level                              |
| Size (PC), acres   | 300                                |
| Size (NGCC), acres | 100                                |
| Transportation     | Rail or Highway                    |
| Ash Disposal       | Off-Site                           |
| Water              | 50% Municipal and 50% Ground Water |

### Site Ambient Conditions

| Parameter   | Value          |
|---|----------------|
| Elevation, m (ft)   | 0 (0)          |
| Barometric Pressure, MPa (psia)                               | 0.101 (14.696) |
| Average Ambient Dry Bulb Temperature, °C (°F)                 | 15 (59)        |
| Average Ambient Wet Bulb Temperature, °C (°F)                 | 10.8 (51.5)    |
| Design Ambient Relative Humidity, %                           | 60             |
| Cooling Water Temperature, °C (°F) <sup>A</sup>               | 15.6 (60)      |
| Air composition based on published psychrometric data, mass % |                |
| N <sub>2</sub>  | 75.055         |
| O <sub>2</sub>  | 22.998         |
| Ar  | 1.280          |
| H <sub>2</sub> O  | 0.616          |
| CO <sub>2</sub>   | 0.050          |
| Total   | 100.00         |

# QGESS Examples

## Fuel Specification

### Coal Specifications

|  | Volume 1a and Volume 1b Rev3 |                 | Volume 1 Rev4   |                 |
|--|------------------------------|-----------------|-----------------|-----------------|
| Rank                                       | Bituminous                   |                 | Bituminous      |                 |
| Seam                                       | Illinois No. 6 (Herrin)      |                 | Illinois No. 6  |                 |
| Source                                     | Old Ben Mine                 |                 | -               |                 |
| Proximate Analysis (weight %) <sup>A</sup> |                              |                 |                 |                 |
|  | As Received                  | Dry             | As Received     | Dry             |
| Moisture                                   | 11.12                        | 0.00            | 11.12           | 0.00            |
| Ash  | 9.70                         | 10.91           | 9.70            | 10.91           |
| Volatile Matter                            | 34.99                        | 39.37           | 34.99           | 39.37           |
| Fixed Carbon                               | 44.19                        | 49.72           | 44.19           | 49.72           |
| Total                                      | 100.00                       | 100.00          | 100.00          | 100.00          |
| Sulfur                                     | 2.51                         | 2.82            | 2.51            | 2.82            |
| HHV, kJ/kg (Btu/lb)                        | 27,113 (11,666)              | 30,506 (13,126) | 27,113 (11,666) | 30,506 (13,126) |
| LHV, Btu/lb (Btu/lb)                       | 26,151 (11,252)              | 29,544 (12,712) | 26,151 (11,252) | 29,544 (12,712) |
| Ultimate Analysis (weight %)               |                              |                 |                 |                 |
|  | As Received                  | Dry             | As Received     | Dry             |
| Moisture                                   | 11.12                        | 0.00            | 11.12           | 0.00            |
| Carbon                                     | 63.75                        | 71.72           | 63.75           | 71.72           |
| Hydrogen                                   | 4.50                         | 5.06            | 4.50            | 5.06            |
| Nitrogen                                   | 1.25                         | 1.41            | 1.25            | 1.41            |
| Chlorine                                   | 0.29                         | 0.33            | 0.15            | 0.17            |
| Sulfur                                     | 2.51                         | 2.82            | 2.51            | 2.82            |
| Ash  | 9.70                         | 10.91           | 9.70            | 10.91           |
| Oxygen <sup>B</sup>                        | 6.88                         | 7.75            | 7.02            | 7.91            |
| Total                                      | 100.00                       | 100.00          | 100.00          | 100.00          |



### Natural Gas Specification

|                           | Volume 1a Rev3        |                    | Volume 1 Rev4             |                    |
|---------------------------|-----------------------|--------------------|---------------------------|--------------------|
| Component                 | Volume Percentage     |                    | Volume Percentage         |                    |
| Basis                     | QGESS                 |                    | Aspen: QVAL GRS/NET @ 25C |                    |
| Methane                   | 93.1                  |                    | 93.1                      |                    |
| Ethane                    | 3.2                   |                    | 3.2                       |                    |
| Propane                   | 0.7                   |                    | 0.7                       |                    |
| n-Butane                  | 0.4                   |                    | 0.4                       |                    |
| Carbon Dioxide            | 1.0                   |                    | 1.0                       |                    |
| Nitrogen                  | 1.6                   |                    | 1.6                       |                    |
| Methanethiol <sup>A</sup> | 5.75x10 <sup>-6</sup> |                    | 5.75x10 <sup>-6</sup>     |                    |
| Total                     | 100.00                |                    | 100.00                    |                    |
|                           | LHV                   | HHV                | LHV                       | HHV                |
| kJ/kg (Btu/lb)            | 47,454<br>(20,410)    | 52,581<br>(22,600) | 47,201<br>(20,293)        | 52,295<br>(22,483) |
| MI/scm (Btu/scf)          | 34.71 (932)           | 38.46 (1,032)      | 34.52 (927)               | 38.25 (1,027)      |


# Presentation Outline

---



- TEA Process
- QGESS Description/Location
- **Bituminous Baseline Study Overview/Example**
  - Type of content to include
  - DAC baseline not available yet

# Final Block Flow Diagram – B12B



# B31B NGCC Stream Tables



|  | 1          | 2         | 3          | 4         | 5          | 6  | 7          | 8         | 9          | 10        | 11         | 12         |
|--|------------|-----------|------------|-----------|------------|--|------------|-----------|------------|-----------|------------|------------|
| V-L Mole Fraction                          |            |           |            |           |            |  |            |           |            |           |            |            |
| Ar   | 0.0092     | 0.0000    | 0.0089     | 0.0089    | 0.0000     | 0.0000                                     | 0.0000     | 0.0098    | 0.0000     | 0.0000    | 0.0000     | 0.0000     |
| CH <sub>4</sub>                            | 0.0000     | 0.9310    | 0.0000     | 0.0000    | 0.0000     | 0.0000                                     | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     |
| CH <sub>4</sub> S                          | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000                                     | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     |
| C <sub>2</sub> H <sub>6</sub>              | 0.0000     | 0.0320    | 0.0000     | 0.0000    | 0.0000     | 0.0000                                     | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     |
| C <sub>3</sub> H <sub>8</sub>              | 0.0000     | 0.0070    | 0.0000     | 0.0000    | 0.0000     | 0.0000                                     | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     |
| C <sub>4</sub> H <sub>10</sub>             | 0.0000     | 0.0040    | 0.0000     | 0.0000    | 0.0000     | 0.0000                                     | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     |
| CO <sub>2</sub>                            | 0.0003     | 0.0100    | 0.0408     | 0.0408    | 0.0000     | 0.0000                                     | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     |
| H <sub>2</sub> O                           | 0.0099     | 0.0000    | 0.0875     | 0.0875    | 1.0000     | 0.0000                                     | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     |
| N <sub>2</sub>                             | 0.7732     | 0.0160    | 0.7428     | 0.7428    | 0.0000     | 0.0000                                     | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     |
| O <sub>2</sub>                             | 0.2074     | 0.0000    | 0.1200     | 0.1200    | 0.0000     | 0.0000                                     | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     |
| SO <sub>2</sub>                            | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000                                     | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     |
| Total                                      | 1.0000     | 1.0000    | 1.0000     | 1.0000    | 1.0000     | 1.0000                                     | 1.0000     | 1.0000    | 1.0000     | 1.0000    | 1.0000     | 1.0000     |
| V-L Flowrate (kg/mol/hr)                   | 132,867    | 5,383     | 138,406    | 138,406   | 14,300     | 0.0000                                     | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     |
| V-L Flowrate (kg/hr)                       | 3,834,126  | 93,272    | 3,927,398  | 3,927,398 | 259,200    | 0.0000                                     | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     |
| Solids Flowrate (kg/hr)                    | 0          | 0         | 0          | 0         | 0          | 0.0000                                     | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     |
| Temperature (°C)                           | 15         | 27        | 625        | 111       | 308        | 0.10                                       | 2.96       | 0.11      | 0.10       | 0.5       | 0.10       | 0.5        |
| Pressure (MPa, abs)                        | 0.10       | 2.96      | 0.11       | 0.10      | 0.5        | 30.23                                      | 22.04      | 832.66    | 255.52     | 3,080     | -97.58     | -4,487.18  |
| Steam Table Enthalpy (kJ/kg) <sup>A</sup>  | 30.23      | 22.04     | 832.66     | 255.52    | 3,080      | AspenPlus Enthalpy (kJ/kg) <sup>B</sup>    | -97.58     | -4,487.18 | -644.47    | -1,221.61 | -12,900    | -12,900    |
| AspenPlus Enthalpy (kJ/kg) <sup>B</sup>    | -97.58     | -4,487.18 | -644.47    | -1,221.61 | -12,900    | Density (kg/m <sup>3</sup> )               | 1.2        | 22.1      | 0.4        | 0.9       | 1.9        | 1.9        |
| Density (kg/m <sup>3</sup> )               | 1.2        | 22.1      | 0.4        | 0.9       | 1.9        | V-L Molecular Weight                       | 28.857     | 17.328    | 28.376     | 28.376    | 18.0       | 18.0       |
| V-L Molecular Weight                       | 28.857     | 17.328    | 28.376     | 28.376    | 18.0       | V-L Flowrate (kg/mol/hr)                   | 292,921    | 11,867    | 305,132    | 305,132   | 31,700     | 31,700     |
| V-L Flowrate (kg/mol/hr)                   | 292,921    | 11,867    | 305,132    | 305,132   | 31,700     | V-L Flowrate (lb/hr)                       | 8,452,800  | 205,630   | 8,658,430  | 8,658,430 | 571,500    | 571,500    |
| V-L Flowrate (lb/hr)                       | 8,452,800  | 205,630   | 8,658,430  | 8,658,430 | 571,500    | Solids Flowrate (lb/hr)                    | 0          | 0         | 0          | 0         | 0          | 0          |
| Solids Flowrate (lb/hr)                    | 0          | 0         | 0          | 0         | 0          | Temperature (°C)                           | 203        | 29        | 29         | 30        | 585        | 356        |
| Temperature (°C)                           | 203        | 29        | 29         | 30        | 585        | Pressure (MPa, abs)                        | 1.64       | 2.90      | 3.04       | 15.27     | 16.50      | 3.74       |
| Pressure (MPa, abs)                        | 1.64       | 2.90      | 3.04       | 15.27     | 16.50      | Steam Table Enthalpy (kJ/kg) <sup>A</sup>  | 863.65     | -6.32     | 137.79     | -231.09   | 3,528.08   | 3,112.11   |
| Steam Table Enthalpy (kJ/kg) <sup>A</sup>  | 863.65     | -6.32     | 137.79     | -231.09   | 3,528.08   | AspenPlus Enthalpy (kJ/kg) <sup>B</sup>    | -15,116.65 | -8,969.87 | -15,225.37 | -9,194.65 | -12,452.22 | -12,868.18 |
| AspenPlus Enthalpy (kJ/kg) <sup>B</sup>    | -15,116.65 | -8,969.87 | -15,225.37 | -9,194.65 | -12,452.22 | Density (kg/m <sup>3</sup> )               | 861.8      | 60.1      | 375.2      | 630.1     | 45.6       | 13.8       |
| Density (kg/m <sup>3</sup> )               | 861.8      | 60.1      | 375.2      | 630.1     | 45.6       | V-L Molecular Weight                       | 18.015     | 43.997    | 19.315     | 43.997    | 18.015     | 18.015     |
| V-L Molecular Weight                       | 18.015     | 43.997    | 19.315     | 43.997    | 18.015     | V-L Flowrate (lbmol/hr)                    | 16         | 11,219    | 40         | 11,219    | 59,504     | 59,504     |
| V-L Flowrate (lbmol/hr)                    | 16         | 11,219    | 40         | 11,219    | 59,504     | V-L Flowrate (lb/hr)                       | 294        | 493,588   | 777        | 493,588   | 1,071,980  | 1,071,980  |
| V-L Flowrate (lb/hr)                       | 294        | 493,588   | 777        | 493,588   | 1,071,980  | Solids Flowrate (lb/hr)                    | 0          | 0         | 0          | 0         | 0          | 0          |
| Solids Flowrate (lb/hr)                    | 0          | 0         | 0          | 0         | 0          | Temperature (°F)                           | 397        | 85        | 85         | 86        | 1,085      | 672        |
| Temperature (°F)                           | 397        | 85        | 85         | 86        | 1,085      | Pressure (psia)                            | 237.4      | 421.1     | 441.1      | 2,214.7   | 2,393.1    | 542.3      |
| Pressure (psia)                            | 237.4      | 421.1     | 441.1      | 2,214.7   | 2,393.1    | Steam Table Enthalpy (Btu/lb) <sup>A</sup> | 371.3      | -2.7      | 59.2       | -99.4     | 1,516.8    | 1,338.0    |
| Steam Table Enthalpy (Btu/lb) <sup>A</sup> | 371.3      | -2.7      | 59.2       | -99.4     | 1,516.8    | AspenPlus Enthalpy (Btu/lb) <sup>B</sup>   | -6,499.0   | -3,856.4  | -6,545.7   | -3,953.0  | -5,353.5   | -5,532.3   |
| AspenPlus Enthalpy (Btu/lb) <sup>B</sup>   | -6,499.0   | -3,856.4  | -6,545.7   | -3,953.0  | -5,353.5   | Density (lb/ft <sup>3</sup> )              | 53.801     | 3.755     | 23.421     | 39.338    | 2.849      | 0.863      |
| Density (lb/ft <sup>3</sup> )              | 53.801     | 3.755     | 23.421     | 39.338    | 2.849      |  |            |           |            |           |            |            |


|  | 13         | 14        | 15         | 16        | 17         | 18         | 19         | 20         | 21         | 22         | 23         |
|--|------------|-----------|------------|-----------|------------|------------|------------|------------|------------|------------|------------|
| V-L Mole Fraction                          |            |           |            |           |            |            |            |            |            |            |            |
| Ar   | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     |
| CH <sub>4</sub>                            | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     |
| CH <sub>4</sub> S                          | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     |
| C <sub>2</sub> H <sub>6</sub>              | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     |
| C <sub>3</sub> H <sub>8</sub>              | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     |
| C <sub>4</sub> H <sub>10</sub>             | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     |
| CO <sub>2</sub>                            | 0.0000     | 0.9995    | 0.0500     | 0.9995    | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     |
| H <sub>2</sub> O                           | 1.0000     | 0.0005    | 0.9500     | 0.0005    | 1.0000     | 1.0000     | 1.0000     | 1.0000     | 1.0000     | 1.0000     | 1.0000     |
| N <sub>2</sub>                             | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     |
| O <sub>2</sub>                             | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     |
| SO <sub>2</sub>                            | 0.0000     | 0.0000    | 0.0000     | 0.0000    | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     | 0.0000     |
| Total                                      | 1.0000     | 1.0000    | 1.0000     | 1.0000    | 1.0000     | 1.0000     | 1.0000     | 1.0000     | 1.0000     | 1.0000     | 1.0000     |
| V-L Flowrate (kg/mol/hr)                   | 7          | 5,089     | 18         | 5,089     | 26,991     | 26,991     | 31,036     | 31,036     | 4,030      | 20,674     | 35,246     |
| V-L Flowrate (kg/hr)                       | 133        | 223,888   | 353        | 223,888   | 486,242    | 486,242    | 559,118    | 559,118    | 72,598     | 372,443    | 634,975    |
| Solids Flowrate (kg/hr)                    | 0          | 0         | 0          | 0         | 0          | 0          | 0          | 0          | 0          | 0          | 0          |
| Temperature (°C)                           | 203        | 29        | 29         | 30        | 585        | 356        | 584        | 308        | 281        | 38         | 38         |
| Pressure (MPa, abs)                        | 1.64       | 2.90      | 3.04       | 15.27     | 16.50      | 3.74       | 3.51       | 0.52       | 0.51       | 0.01       | 0.01       |
| Steam Table Enthalpy (kJ/kg) <sup>A</sup>  | 863.65     | -6.32     | 137.79     | -231.09   | 3,528.08   | 3,112.11   | 3,642.67   | 3,080.20   | 3,024.62   | 2,376.09   | 160.78     |
| AspenPlus Enthalpy (kJ/kg) <sup>B</sup>    | -15,116.65 | -8,969.87 | -15,225.37 | -9,194.65 | -12,452.22 | -12,868.18 | -12,337.62 | -12,900.10 | -12,955.67 | -13,604.20 | -15,819.51 |
| Density (kg/m <sup>3</sup> )               | 861.8      | 60.1      | 375.2      | 630.1     | 45.6       | 13.8       | 9.0        | 2.0        | 2.0        | 0.1        | 992.8      |
| V-L Molecular Weight                       | 18.015     | 43.997    | 19.315     | 43.997    | 18.015     | 18.015     | 18.015     | 18.015     | 18.015     | 18.015     | 18.015     |
| V-L Flowrate (lbmol/hr)                    | 16         | 11,219    | 40         | 11,219    | 59,504     | 59,504     | 68,422     | 68,422     | 8,884      | 45,578     | 77,705     |
| V-L Flowrate (lb/hr)                       | 294        | 493,588   | 777        | 493,588   | 1,071,980  | 1,071,980  | 1,232,645  | 1,232,645  | 160,051    | 821,097    | 1,399,880  |
| Solids Flowrate (lb/hr)                    | 0          | 0         | 0          | 0         | 0          | 0          | 0          | 0          | 0          | 0          | 0          |
| Temperature (°F)                           | 397        | 85        | 85         | 86        | 1,085      | 672        | 1,084      | 587        | 538        | 101        | 101        |
| Pressure (psia)                            | 237.4      | 421.1     | 441.1      | 2,214.7   | 2,393.1    | 542.3      | 508.6      | 75.0       | 73.5       | 1.0        | 1.0        |
| Steam Table Enthalpy (Btu/lb) <sup>A</sup> | 371.3      | -2.7      | 59.2       | -99.4     | 1,516.8    | 1,338.0    | 1,566.1    | 1,324.2    | 1,300.4    | 1,021.5    | 69.1       |
| AspenPlus Enthalpy (Btu/lb) <sup>B</sup>   | -6,499.0   | -3,856.4  | -6,545.7   | -3,953.0  | -5,353.5   | -5,532.3   | -5,304.2   | -5,546.0   | -5,569.9   | -5,848.8   | -6,801.2   |
| Density (lb/ft <sup>3</sup> )              | 53.801     | 3.755     | 23.421     | 39.338    | 2.849      | 0.863      | 0.563      | 0.122      | 0.125      | 0.003      | 61.977     |

<sup>A</sup>Steam table reference conditions are 32.02°F & 0.089 psia

<sup>B</sup>Aspen thermodynamic reference state is the component's constituent elements in an ideal gas state at 25°C and 1 atm

# B31B (NGCC Capture)

## Heat & Mass Balance



# B12B (SC PC Capture)

## Performance Summary



| Power Summary                                       | Rev4 – 650 MW |
|---|---------------|
| Steam Turbine Power, MWe                            | 770           |
| <b>Total Gross Power, MWe</b>                       | <b>770</b>    |
| <b>Auxiliary Load Summary</b>                       |               |
| Activated Carbon Injection, kWe                     | 40            |
| Ash Handling, kWe                                   | 880           |
| Baghouse, kWe                                       | 120           |
| Circulating Water Pumps, kWe                        | 9,610         |
| CO <sub>2</sub> Capture/Removal Auxiliaries, kWe    | 27,300        |
| CO <sub>2</sub> Compression, kWe                    | 44,380        |
| Coal Handling and Conveying, kWe                    | 530           |
| Condensate Pumps, kWe                               | 790           |
| Cooling Tower Fans, kWe                             | 4,970         |
| Dry Sorbent Injection, kWe                          | 80            |
| Flue Gas Desulfurizer, kWe                          | 4,230         |
| Forced Draft Fans, kWe                              | 2,560         |
| Ground Water Pumps, kWe                             | 900           |
| Induced Draft Fans, kWe                             | 10,440        |
| Miscellaneous Balance of Plant <sup>A,B</sup> , kWe | 2,250         |
| Primary Air Fans, kWe                               | 2,010         |
| Pulverizers, kWe                                    | 4,100         |
| SCR, kWe  | 50            |
| Sorbent Handling & Reagent Preparation, kWe         | 1,280         |
| Spray Dryer Evaporator, kWe                         | 300           |
| Steam Turbine Auxiliaries, kWe                      | 500           |
| Transformer Losses, kWe                             | 2,680         |
| <b>Total Auxiliaries, MWe</b>                       | <b>120</b>    |
| <b>Net Power, MWe</b>                               | <b>650</b>    |

| Performance Summary   | Rev4 – 650 MW     |
|---|-------------------|
| <b>Total Gross Power, MWe</b>   | <b>770</b>        |
| CO <sub>2</sub> Capture/Removal Auxiliaries, kWe  | 27,300            |
| CO <sub>2</sub> Compression, kWe  | 44,380            |
| Balance of Plant, kWe   | 48,320            |
| <b>Total Auxiliaries, MWe</b>   | <b>120</b>        |
| <b>Net Power, MWe</b>   | <b>650</b>        |
| HHV Net Plant Efficiency, %   | 31.5%             |
| HHV Net Plant Heat Rate, kJ/kWh (Btu/kWh)   | 11,430 (10,834)   |
| LHV Net Plant Efficiency, %   | 32.7%             |
| LHV Net Plant Heat Rate, kJ/kWh (Btu/kWh)   | 11,024 (10,449)   |
| HHV Boiler Efficiency, %  | 88.1%             |
| LHV Boiler Efficiency, %  | 91.3%             |
| Steam Turbine Cycle Efficiency, %   | 57.5%             |
| Steam Turbine Heat Rate, kJ/kWh (Btu/kWh)   | 6,256 (5,930)     |
| Condenser Duty, GJ/hr (MMBtu/hr)  | 2,127 (2,016)     |
| AGR Duty, GJ/hr (MMBtu/hr)  | 2,344 (2,222)     |
| As-Received Coal Feed, kg/hr (lb/hr)  | 273,628 (603,246) |
| Limestone Sorbent Feed, kg/hr (lb/hr)   | 26,469 (58,354)   |
| HHV Thermal Input, kWt  | 2,062,478         |
| LHV Thermal Input, kWt  | 1,989,286         |
| Raw Water Withdrawal, (m <sup>3</sup> /min)/MW <sub>net</sub> (gpm/MW <sub>net</sub> )  | 0.058 (15.3)      |
| Raw Water Consumption, (m <sup>3</sup> /min)/MW <sub>net</sub> (gpm/MW <sub>net</sub> ) | 0.041 (10.8)      |
| Excess Air, %   | 20.3%             |

### Rev4 Footnotes:

<sup>A</sup>Boiler feed pumps are turbine driven

<sup>B</sup>Includes plant control systems, lighting, HVAC, and miscellaneous low voltage loads



# B12B Equipment Summaries

| Equipment No. | Description                        | Type   | Design Condition   | Operating Qty. | Spares |
|---------------|------------------------------------|--|--|----------------|--------|
| 8             | Vacuum Filter Belt                 | Horizontal belt                                | 44 tonne/hr (49 tph) of 50 wt% slurry  | 2              | 1      |
| 9             | Filtrate Water Return Pumps        | Horizontal centrifugal                         | 850 lpm @ 13 m H <sub>2</sub> O (220 gpm @ 40 ft H <sub>2</sub> O)   | 1              | 1      |
| 10            | Filtrate Water Return Storage Tank | Vertical, lined                                | 560,000 lpm (150,000 gal)  | 1              | 0      |
| 11            | Process Makeup Water Pumps         | Horizontal centrifugal                         | 1,990 lpm @ 21 m H <sub>2</sub> O (530 gpm @ 70 ft H <sub>2</sub> O)   | 1              | 1      |
| 12            | Activated Carbon Injectors         | ---  | 60 kg/hr (140 lb/hr)   | 1              | 0      |
| 13            | Hydrated Lime Injectors            | ---  | 1,660 kg/hr (3,650 lb/hr)  | 1              | 0      |
| 14            | Cansolv                            | Amine-based CO <sub>2</sub> capture technology | 3,724,000 kg/hr (8,211,000 lb/hr) 19.1 wt% CO <sub>2</sub> concentration   | 1              | 0      |
| 15            | Cansolv LP Condensate Pump         | Centrifugal                                    | 1,287 lpm @ 1 m H <sub>2</sub> O (340 gpm @ 4 ft H <sub>2</sub> O)   | 1              | 1      |
| 16            | Cansolv IP Condensate Pump         | Centrifugal                                    | 6 lpm @ 4.6 m H <sub>2</sub> O (2 gpm @ 15 ft H <sub>2</sub> O)  | 1              | 1      |
| 17            | CO <sub>2</sub> Dryer              | Triethylene glycol                             | Inlet: 152 m <sup>3</sup> /min @ 3.0 MPa (5,381 acfm @ 441 psia)<br>Outlet: 2.9 MPa (421 psia)<br>Water Recovered: 487 kg/hr (1,074 lb/hr) | 1              | 0      |
| 18            | CO <sub>2</sub> Compressor         | Integrally geared, multi-stage centrifugal     | 8.0 m <sup>3</sup> /min @ 15.3 MPa, 80°C (299 acfm @ 2,217 psia, 176°F)  | 2              | 0      |
| 19            | CO <sub>2</sub> Aftercooler        | Shell and tube heat exchanger                  | Outlet: 15.3 MPa, 30°C (2,215 psia, 86°F) Duty: 88 MMkJ/hr (84 MMBtu/hr)   | 1              | 0      |

## Case B12B – Account 7: Ductwork and Stack

| Equipment No. | Description | Type                               | Design Condition                             | Operating Qty. | Spares |
|---------------|-------------|------------------------------------|--|----------------|--------|
| 1             | Stack       | Reinforced concrete with FRP liner | 152 m (500 ft) high x 6.0 m (20 ft) diameter | 1              | 0      |

## Case B12B – Account 8: Steam Turbine and Accessories

| Equipment No. | Description             | Type   | Design Condition  | Operating Qty. | Spares |
|---------------|-------------------------|--|---|----------------|--------|
| 1             | Steam Turbine           | Commercially available advanced steam turbine        | 798 MW<br>24.1 MPa/593°C/593°C (3500 psig/1100°F/1100°F)  | 1              | 0      |
| 2             | Steam Turbine Generator | Hydrogen cooled, static excitation                   | 890 MVA @ 0.9 p.f., 24 kV, 60 Hz, 3-phase   | 1              | 0      |
| 3             | Surface Condenser       | Single pass, divided waterbox including vacuum pumps | 1,170 GJ/hr (2,220 MMBtu/hr),<br>Inlet water temperature 16°C (60°F),<br>Water temperature rise 11°C (20°F) | 1              | 0      |

# B12B Capital Cost Summary



| Case:                 |   | B31B           | – 2x1 CT NGCC w/ CO <sub>2</sub>      |           |          |                   | Estimate Type:     |               |           | Conceptual       |         |
|-----------------------|---|----------------|---------------------------------------|-----------|----------|-------------------|--------------------|---------------|-----------|------------------|---------|
| Plant Size (MW, net): |   | 646            |                                       |           |          |                   | Cost Base:         |               |           | Dec 2018         |         |
| Item No.              | Description   | Equipment Cost | Material Cost                         | Labor     |          | Bare Erected Cost | Eng'g CM H.O.& Fee | Contingencies |           | Total Plant Cost |         |
|                       |   |                |                                       | Direct    | Indirect |                   |                    | Process       | Project   | \$/1,000         | \$/kW   |
| 3                     |   |                | Feedwater & Miscellaneous BOP Systems |           |          |                   |                    |               |           |                  |         |
| 3.1                   | Feedwater System  | \$1,698        | \$2,910                               | \$1,455   | \$0      | \$6,063           | \$1,213            | \$0           | \$1,091   | \$8,367          | \$13    |
| 3.2                   | Water Makeup & Pretreating                                  | \$5,347        | \$535                                 | \$3,030   | \$0      | \$8,912           | \$1,782            | \$0           | \$2,139   | \$12,834         | \$20    |
| 3.3                   | Other Feedwater Subsystems                                  | \$966          | \$317                                 | \$301     | \$0      | \$1,583           | \$317              | \$0           | \$285     | \$2,185          | \$3     |
| 3.4                   | Service Water Systems                                       | \$1,623        | \$3,098                               | \$10,031  | \$0      | \$14,752          | \$2,950            | \$0           | \$3,540   | \$21,243         | \$33    |
| 3.5                   | Other Boiler Plant Systems                                  | \$230          | \$84                                  | \$209     | \$0      | \$523             | \$105              | \$0           | \$94      | \$722            | \$1     |
| 3.6                   | Natural Gas Pipeline and Start-Up System                    | \$9,304        | \$400                                 | \$300     | \$0      | \$10,005          | \$2,001            | \$0           | \$1,801   | \$13,807         | \$21    |
| 3.7                   | Waste Water Treatment Equipment                             | \$9,693        | \$0                                   | \$5,941   | \$0      | \$15,634          | \$3,127            | \$0           | \$3,752   | \$22,512         | \$35    |
| 3.9                   | Miscellaneous Plant Equipment                               | \$14,217       | \$1,865                               | \$7,225   | \$0      | \$23,306          | \$4,661            | \$0           | \$5,594   | \$33,561         | \$52    |
|                       | Subtotal  | \$43,078       | \$9,208                               | \$28,493  | \$0      | \$80,778          | \$16,156           | \$0           | \$18,296  | \$115,230        | \$178   |
| 5                     |   |                | Flue Gas Cleanup                      |           |          |                   |                    |               |           |                  |         |
| 5.1                   | Cansolv Carbon Dioxide (CO <sub>2</sub> ) Removal System    | \$148,215      | \$72,722                              | \$152,716 | \$0      | \$373,652         | 74,730             | 67,257        | 103,128   | \$618,768        | \$958   |
| 5.4                   | Carbon Dioxide (CO <sub>2</sub> ) Compression & Drying      | \$26,481       | \$3,972                               | \$10,986  | \$0      | \$41,440          | \$8,288            | \$0           | \$9,946   | \$59,674         | \$92    |
| 5.5                   | Carbon Dioxide (CO <sub>2</sub> ) Compressor Aftercooler    | \$218          | \$35                                  | \$93      | \$0      | \$346             | \$69               | \$0           | \$83      | \$498            | \$1     |
| 5.12                  | Gas Cleanup Foundations                                     | \$0            | \$382                                 | \$413     | \$0      | \$795             | \$159              | \$0           | \$191     | \$1,145          | \$2     |
|                       | Subtotal  | \$174,914      | \$77,111                              | \$164,208 | \$0      | \$416,233         | \$83,247           | \$67,257      | \$113,347 | \$680,085        | \$1,053 |
| 6                     |   |                | Combustion Turbine & Accessories      |           |          |                   |                    |               |           |                  |         |
| 6.1                   | Combustion Turbine Generator                                | \$72,224       | \$0                                   | \$4,395   | \$0      | \$76,619          | \$15,324           | \$0           | \$13,791  | \$105,735        | \$164   |
| 6.3                   | Combustion Turbine Accessories                              | \$2,626        | \$0                                   | \$160     | \$0      | \$2,786           | \$557              | \$0           | \$501     | \$3,845          | \$6     |
| 6.4                   | Compressed Air Piping                                       | \$0            | \$867                                 | \$196     | \$0      | \$1,063           | \$213              | \$0           | \$191     | \$1,467          | \$2     |
| 6.5                   | Combustion Turbine Foundations                              | \$0            | \$906                                 | \$979     | \$0      | \$1,885           | \$377              | \$0           | \$452     | \$2,714          | \$4     |
|                       | Subtotal  | \$74,850       | \$1,773                               | \$5,730   | \$0      | \$82,353          | \$16,471           | \$0           | \$14,937  | \$113,760        | \$176   |
| 7                     |   |                | HRS, Ductwork, & Stack                |           |          |                   |                    |               |           |                  |         |
| 7.1                   | Heat Recovery Steam Generator                               | \$34,545       | \$0                                   | \$8,636   | \$0      | \$43,181          | \$8,636            | \$0           | \$7,773   | \$59,590         | \$92    |
| 7.2                   | Heat Recovery Steam Generator Accessories                   | \$12,307       | \$0                                   | \$2,283   | \$0      | \$14,590          | \$2,918            | \$0           | \$2,626   | \$20,134         | \$31    |
| 7.3                   | Ductwork  | \$0            | \$852                                 | \$592     | \$0      | \$1,445           | \$289              | \$0           | \$260     | \$1,994          | \$3     |
| 7.4                   | Stack   | \$8,150        | \$0                                   | \$1,512   | \$0      | \$9,662           | \$1,932            | \$0           | \$1,739   | \$13,333         | \$21    |
| 7.5                   | Heat Recovery Steam Generator, Ductwork & Stack Foundations | \$0            | \$635                                 | \$597     | \$0      | \$1,232           | \$246              | \$0           | \$296     | \$1,774          | \$3     |
| 7.6                   | Selective Catalytic Reduction System                        | \$1,465        | \$616                                 | \$859     | \$0      | \$2,940           | \$588              | \$0           | \$529     | \$4,057          | \$6     |
|                       | Subtotal  | \$56,467       | \$2,104                               | \$14,479  | \$0      | \$73,049          | \$14,610           | \$0           | \$13,223  | \$100,882        | \$156   |

Report Capital by Account and Sub Account

Additional Accounts in Baseline include:

- 8 – Steam Turbine & Accessories
- 9 – Cooling Water System
- 11 – Accessory Electric Plant
- 12 – Instrumentation & Controls
- 13 – Improvements to Site
- 14 – Buildings & Structures

# Build up of Capital Costs

B31B Example



| Description                                      | \$/1,000           | \$/kW          |
|--|--------------------|----------------|
| <b>Pre-Production Costs</b>                      |                    |                |
| 6 Months All Labor                               | \$7,822            | \$12           |
| 1 Month Maintenance Materials                    | \$1,432            | \$2            |
| 1 Month Non-Fuel Consumables                     | \$1,211            | \$2            |
| 1 Month Waste Disposal                           | \$12               | \$0            |
| 25% of 1 Months Fuel Cost at 100% CF             | \$3,729            | \$6            |
| 2% of TPC  | \$25,626           | \$40           |
| <b>Total</b>                                     | <b>\$39,833</b>    | <b>\$62</b>    |
| <b>Inventory Capital</b>                         |                    |                |
| 60-day supply of fuel and consumables at 100% CF | \$2,026            | \$3            |
| 0.5% of TPC (spare parts)                        | \$6,407            | \$10           |
| <b>Total</b>                                     | <b>\$8,432</b>     | <b>\$13</b>    |
| <b>Other Costs</b>                               |                    |                |
| Initial Cost for Catalyst and Chemicals          | \$847              | \$1            |
| Land   | \$300              | \$0            |
| Other Owner's Costs                              | \$192,199          | \$298          |
| Financing Costs                                  | \$34,596           | \$54           |
| <b>Total Overnight Costs (TOC)</b>               | <b>\$1,557,531</b> | <b>\$2,412</b> |
| TASC Multiplier (IOU, 33 year)                   | 1.093              |                |
| <b>Total As-Spent Cost (TASC)</b>                | <b>\$1,701,831</b> | <b>\$2,635</b> |

# Fixed and Variable Operating Costs

B12B Example

|   |              |                            |  |                      |                          |
|---|--------------|----------------------------|--|----------------------|--------------------------|
| Case:   | B12B         | - SC PC w/ CO <sub>2</sub> |  | Cost Base:           | Dec 2018                 |
| Plant Size (MW, net):                                 | 650          | Heat Rate-net (Btu/kWh):   | 10,834                                 | Capacity Factor (%): | 85                       |
| Operating & Maintenance Labor                         |              |                            |  |                      |                          |
| Operating Labor                                       |              |                            | Operating Labor Requirements per Shift |                      |                          |
| Operating Labor Rate (base):                          |              | 38.50                      | \$/hour                                | Skilled Operator:    | 2.0                      |
| Operating Labor Burden:                               |              | 30.00                      | % of base                              | Operator:            | 11.3                     |
| Labor O-H Charge Rate:                                |              | 25.00                      | % of labor                             | Foreman:             | 1.0                      |
|   |              |                            |  | Lab Techs, etc.:     | 2.0                      |
|   |              |                            |  | Total:               | 16.3                     |
| Fixed Operating Costs                                 |              |                            |  |                      |                          |
|   |              |                            |  | Annual Cost          |                          |
|   |              |                            |  | (\$)                 | (\$/kW-net)              |
| Annual Operating Labor:                               |              |                            |  | \$7,161,008          | \$11.024                 |
| Maintenance Labor:                                    |              |                            |  | \$15,797,590         | \$24.319                 |
| Administrative & Support Labor:                       |              |                            |  | \$5,739,649          | \$8.836                  |
| Property Taxes and Insurance:                         |              |                            |  | \$49,367,468         | \$75.997                 |
| Total:  |              |                            |  | \$78,065,715         | \$120.175                |
| Variable Operating Costs                              |              |                            |  |                      |                          |
|   |              |                            |  | (\$)                 | (\$/MWh-net)             |
| Maintenance Material:                                 |              |                            |  | \$23,696,385         | \$4.89906                |
| Consumables   |              |                            |  |                      |                          |
|   | Initial Fill | Per Day                    | Per Unit                               | Initial Fill         |                          |
| Water (/1000 gallons):                                | 0            | 7,136                      | \$1.90                                 | \$0                  | \$4,206,523 \$0.86967    |
| Makeup and Waste Water Treatment Chemicals (ton):     | 0            | 21.3                       | \$550.00                               | \$0                  | \$3,627,291 \$0.74992    |
| Brominated Activated Carbon (ton):                    | 0            | 1.56                       | \$1,600.00                             | \$0                  | \$772,686 \$0.15975      |
| Enhanced Hydrated Lime (ton):                         | 0            | 39.9                       | \$240.00                               | \$0                  | \$2,967,412 \$0.61349    |
| Limestone (ton):                                      | 0            | 700                        | \$22.00                                | \$0                  | \$4,779,570 \$0.98814    |
| Ammonia (19 wt%, ton):                                | 0.00         | 69.0                       | \$300.00                               | 0.00                 | \$6,420,577 \$1.32741    |
| SCR Catalyst (ft³):                                   | 17,414       | 15.9                       | \$150.00                               | \$2,612,120          | \$740,101 \$0.15301      |
| CO <sub>2</sub> Capture System Chemicals <sup>a</sup> |              |                            | Proprietary                            |                      | \$9,225,455 \$1.90730    |
| Triethylene Glycol (gal):                             | w/equip.     | 544                        | \$6.80                                 | \$0                  | \$1,147,315 \$0.23720    |
| Subtotal:   |              |                            |  | \$2,612,120          | \$33,886,930 \$7.00589   |
| Waste Disposal  |              |                            |  |                      |                          |
| Fly Ash (ton)   | 0            | 657                        | \$38.00                                | \$0                  | \$7,744,619 \$1.60115    |
| Bottom Ash (ton)                                      | 0            | 146                        | \$38.00                                | \$0                  | \$1,720,404 \$0.35568    |
| SCR Catalyst (ft³):                                   | 0            | 16                         | \$2.50                                 | \$0                  | \$12,335 \$0.00255       |
| Triethylene Glycol (gal):                             |              | 544                        | \$0.35                                 | \$0                  | \$59,053 \$0.01221       |
| Thermal Reclaimer Unit Waste (ton)                    | 0            | 3.51                       | \$38.00                                | \$0                  | \$41,395 \$0.00856       |
| Prescrubber Blowdown Waste (ton)                      | 0            | 52.1                       | \$38.00                                | \$0                  | \$614,467 \$0.12704      |
| Subtotal:   |              |                            |  | \$0                  | \$10,192,273 \$2.10718   |
| By-Products   |              |                            |  |                      |                          |
| Gypsum (ton)  | 0            | 1064                       | \$0.00                                 | \$0                  | \$0 \$0.00000            |
| Subtotal:   |              |                            |  | \$0                  | \$0 \$0.00000            |
| Variable Operating Costs Total:                       |              |                            |  | \$2,612,120          | \$67,775,588 \$14.01213  |
| Fuel Cost   |              |                            |  |                      |                          |
| Illinois Number 6 (ton):                              | 0            | 7,239                      | \$51.96                                | \$0                  | \$116,691,765 \$24.12521 |
| Total:  |              |                            |  | \$0                  | \$116,691,765 \$24.12521 |

# Revision 4 Cost Estimate Results

PC and NGCC Cases




| Case Name   | PC             |       |                  |       | NGCC                          |       |
|---|----------------|-------|------------------|-------|-------------------------------|-------|
|   | PC Subcritical |       | PC Supercritical |       | State-of-the-art 2017 F-Class |       |
|   | B11A           | B11B  | B12A             | B12B  | B31A                          | B31B  |
| COST  |                |       |                  |       |                               |       |
| <b>Total Plant Cost (2018\$/kW)</b>   | 2,011          | 3,756 | 2,099            | 3,800 | 780                           | 1,984 |
| <i>Bare Erected Cost</i>  | 1,482          | 2,641 | 1,548            | 2,677 | 561                           | 1,312 |
| <i>Home Office Expenses</i>   | 259            | 462   | 271              | 469   | 112                           | 262   |
| <i>Project Contingency</i>  | 269            | 526   | 280              | 531   | 107                           | 304   |
| <i>Process Contingency</i>  | 0              | 127   | 0                | 123   | 0                             | 105   |
| <b>Total Overnight Cost (2018\$M)</b>   | 1,611          | 2,991 | 1,678            | 3,023 | 692                           | 1,558 |
| <b>Total Overnight Cost (2018\$/kW)</b>   | 2,478          | 4,604 | 2,582            | 4,654 | 952                           | 2,412 |
| <i>Owner's Costs</i>  | 467            | 848   | 484              | 854   | 172                           | 428   |
| <b>Total As-Spent Cost (2018\$/kW)</b>  | 2,860          | 5,314 | 2,980            | 5,371 | 1,040                         | 2,635 |
| <b>LCOE (\$/MWh) (excluding T&amp;S)</b>  | 60.9           | 100.8 | 61.3             | 99.7  | 42.2                          | 68.2  |
| <i>Capital Costs</i>  | 24.2           | 45.0  | 25.2             | 45.4  | 8.8                           | 22.3  |
| <i>Fixed Costs</i>  | 9.1            | 16.0  | 9.5              | 16.1  | 3.6                           | 8.6   |
| <i>Variable Costs</i>   | 7.9            | 14.5  | 7.7              | 14.0  | 1.7                           | 5.6   |
| <i>Fuel Costs</i>   | 19.7           | 25.4  | 18.9             | 24.1  | 28.1                          | 31.6  |
| <b>LCOE (\$/MWh) (including T&amp;S)</b>  | 60.9           | 110.2 | 61.3             | 108.7 | 42.2                          | 71.6  |
| <i>CO<sub>2</sub> T&amp;S Costs</i>   | 0.0            | 9.4   | 0.0              | 8.9   | 0.0                           | 3.5   |
| <b>Breakeven CO<sub>2</sub> Sales Price (ex. T&amp;S), \$/tonne<sup>A</sup></b>         | N/A            | 42.0  | N/A              | 42.9  | N/A                           | 74.8  |
| <b>Breakeven CO<sub>2</sub> Emissions Penalty (incl. T&amp;S), \$/tonne<sup>A</sup></b> | N/A            | 72.7  | N/A              | 69.9  | N/A                           | 96.7  |

<sup>A</sup> Both the breakeven CO<sub>2</sub> sales price and emissions penalty were calculated based on the non-capture SC PC Case B12A for all coal cases, and the non-capture NGCC Case B31A for natural gas cases


# Revision 4 Cost Estimate Results

Breakeven CO<sub>2</sub> Sales Price/Emissions Penalty



# Revision 4 Cost Estimate Results

Sensitivities – Capacity Factor







Questions ?

Tim Fout

Strategic Systems Analysis and Engineering

[Timothy.Fout@netl.doe.gov](mailto:Timothy.Fout@netl.doe.gov)

304-285-1341