# A Lizard-inspired Tube Inspector (LTI) Robot

Ehsan Dehghan-Niri (PI), Assistant Professor, Intelligent Structures and Nondestructive Evaluation (ISNDE) Laboratory, Civil Engineering, New Mexico State University Hamidreza Marvi (Co-Pi), Assistant Professor, Mechanical and Aerospace Engineering, Arizona State University







#### **Project Description and Objectives**

#### Problem statement









Thinning

Deposit corrosion

Pitting corrosion Stress corrosion cracking

- Tubes and pipelines are the main component of several units in power plants and oil, gas and water transmission.
- Aging power plants and pipelines is a major concern in the US.
- regular inspection is time consuming and costly (e.g. limited accessibility in power plants' units requires overhaul of units for routine inspection)

A Promising Solution is Robotic Inspection



#### **Project Description and Objectives**

#### **Current Robotic Systems and Limitations**

#### Technology benchmarking



Tube inspection robots. (a) Vertiscan system, (b) ICM climbing robot, (c) boiler wall cleaning and inspection robot, (d) inspection robotics system, (e) FAST UT system, and (f) PALM scanner.

#### Limitations:

- Cannot be used on complex geometries
- Require smooth surfaces
- Mostly require ferromagnetic materials
- Scanning has to be performed pointby-point
- Testing requires couplant





#### **Project Description and Objectives**

#### What do we propose?

- **Objective 1:** to integrate automation with *couplant-free* ultrasound transmission technology and develop an *advanced Lamb wave based imaging algorithm* to detect and evaluate crack and corrosion defects in tubes/pipes using a network of couplant-free ultrasound sensors placed at the location of the robot's grippers.
- Objective 2: to develop a robot with <u>friction-based mobility capabilities</u> to move on tubes with complex geometries, obstacles, and rough surfaces such as a U-bend corroded tubular structures.



# Lizard-inspired Tube Inspector (LTI) Robot

## Original concept vs. Current design

Original concept



Current design





#### Electromagnetic acoustic transducer (EMAT) integration





#### EMAT Lift-off and curvature effects





#### Integrated gripper and EMATs in motion



**NM** STATE New Mexico State University



#### Simulated Corrosion and Crack







Amplitude and wave velocity are two effective damage sensitive features for the current design and the simulated defects



**NM** STATE New Mexico State University

## Lamb wave imaging

BE BOLD. Shape the Future. New Mexico State University







**E. Dehghan-Niri**, S. Salamone, "A Multi-helical ultrasonic imaging approach for the structural health monitoring of cylindrical structures", *Structural Health Monitoring: International Journal, vol. 14 no. 1, pp. 73-85, 2015.* 

**E. Dehghan-Niri**, S. Salamone, "*Quantitative Corrosion Imaging of Pipelines using Multi-Helical Guided Ultrasonic Waves*", Structural Monitoring and Maintenance, An international Journal, Vol. 3, No. 3, pp. 215-232, 2016.

Lamb wave based imaging is in progress



#### Friction based Lamb waves



Friction based Lamb waves next step





#### **LTI Robot**



NM BE BOLD. Shape the Future. STATE New Mexico State University

13

## **Multifunctional Gripper**

## Original Design (v1)

BE BOLD. Shape the Future.



• This design was an upgrade to the Yale openended gripper design (Kevlar strings and pulleys).

• The kevlar strings tend to snap or lose their tension after multiple actuations of the gripper.







## **Multifunctional Gripper**

## New Design (v2)



Video sped up 4 times

Video sped up 8 times

- The actuation mechanism of kevlar strings was replaced by a worm gear pair with a gear ratio of 1:10 to ensure a robust and stable actuation of the gripper.
- The normal load was increased by two orders of magnitude compared to v1



#### **Normal Load and Friction characterization**





NM BE BOLD. Shape the Future. STATE New Mexico State University







#### Main body of the LTI robot





#### **Finite Element Analysis of the LTI Robot**







#### LTI robot in action



Video sped up 4 times



## **Outcomes, publications, patents**

#### Journals

H. Nematia, F. Alvidrez, A. Das, N. Masurkar, M. Rudraboina, H. Marvi, and E. Dehghan-Niri, "Integrating electromagnetic acoustic transducers in a modular robotic gripper for inspecting tubular components" Materials Evaluation, 2021, In press
 M. Ghyabi, H. Nemati and E. Dehghan-Niri, "A simplified framework for prediction of sensor network coverage in real-time structural health monitoring of plate-like structures," Structural Health Monitoring: and International Journal, under review
 S. Zamen, E. Dehghan-Niri, M. Ilami, V. Anand Senthilkumar, and H. Marvi, "Recurrence analysis of friction based dry-couplant ultrasonic Lamb waves in plate-like structures", Mechanical Systems and Signal Processing journal, under review

#### Patents

H. Marvi, E. Dehghan-Niri, and M. Ilami, "*Systems and methods for a Lizard-Inspired Tube Inspector (LTI) robot"*, US patent pending, 2019.

#### Conferences

- 1. Ghyabi and E. Dehghan-Niri, "*Structural health monitoring of metallic plate-like structures for partial crack detection"*, ASNT 28th Research Symposium, Hyatt Regency Orange County Garden Grove, CA, April 1-4, 2019.
- 2. Ghyabi and E. Dehghan-Niri, <u>"Comparison of Coverage Areas of Two Different Sensor Network Arrangements for Structural Health</u> <u>Monitoring of Plate-Like Structures"</u>, SPIE Smart Structures + Nondestructive Evaluation, Denver, CO, 3-7 March, 2019.
- 3. S. Zamen, M. Ilami, V. Senthilkumar, H. Marvi, and E. Dehghan-Niri, <u>"Experimental Evaluation of Friction Effects on Lamb Waves</u> <u>Generation"</u>, ASNT Annual Conference, Virtual, Nov. 2020.
- 4. H. Nemati, M. Ilami, J. Bhadra, H. Marvi, and E. Dehghan-Niri, <u>"Evaluation of curvature effects on the performance of an integrated</u> robotic gripper equipped with electromagnetic acoustic transducers", ASNT Annual Conference, Virtual, Nov. 2020.
- 5. H. Nemati, F. Alvidrez, A. Das, N. Masurkar, M. Rudraboina, H. Marvi and E. Dehghan-Niri, <u>"Toward Automated Ultrasonic Inspection of Pipelines and Tubular Components"</u> ASNT Research Symposium, Virtual, March 2021





#### FE's future workforce







## **Concluding Remarks**

# Review how results apply directly to strategic goals U.S. Department of Energy Office of Fossil Energy 2018–2022 STRATEGIC VISION

FE Strategic Goal 1. Develop secur	e and affordable fossil energy technologies to realize the full value of domestic								
energy resources.		FE Strategic Goal 4. Develop and maintain world-class organizational excellence.							
		Objectives	Sub-Objectives						
1.4 – Create smart infrastructure technologies for fossil energy	<ol> <li>1.4.1 – Develop advanced, integrated tools for transmission, delivery, and underground storage systems</li> </ol>	4.1 – Drive enterprise-wide culture	<ul> <li>4.1.1 - Develop and implement performance-reporting processes and tools that enable effective organizational decision making</li> <li>4.1.2 - Align human capital strategies and practices to the FE 2018–2022 Strategic Vision, ensuring employees are well positioned to succeed in delivering the mission</li> <li>4.1.3 - Promote employee engagement and partnerships within the FE workforce that drive success</li> </ul>						
	1.4.2 – Develop technologies to reduce losses of natural gas in transmission and distribution infrastructure	of high performance, innovation, empowerment, and scientific							
	1.4.3 – Create new multi-purpose pipeline technology that will enable the reliable transport of hydrocarbons, hydrogen, CO,, and other high-value	integrity							
	materials	_							
<b>FE Strategic Goal 2.</b> Enhance U.S. e technology, and the use of strateg	economic and energy security through prudent policy, advanced jic reserves.		4.1.4 – Cultivate and maintain a highly qualified, diverse, and well-trained workforce capable of achieving the FE mission and objectives						
Objectives	Sub-Objectives	4.2 – Promote knowledge sharing	4.2.1 – Develop and implement an Information Management Strategy						
2.1 – Protect the U.S. economy from severe petroleum supply interruptions	<ul> <li>2.1.1 – Maintain operational readiness to release petroleum products from the Strategic Petroleum Reserve (SPR), the Northeast Gasoline Supply Reserve, and the Northeast Home Heating Oil Reserve</li> <li>2.1.2 – Conduct legislatively directed sales from the SPR efficiently and effectively</li> <li>2.1.3 – Share technical expertise, best practices, and lessons learned from</li> </ul>	and transparent communication	defining the roadmap of goals, strategies, and objectives to implement technology-enabled business management and knowledge management systems 4.2.2 – Develop, execute, and monitor a strategic communications plan fr internal and external stakeholder engagement						
	SPR operations with international partners in support of global petroleum stockpiling 2.1.4 – Carry out the SPR Life Extension Phase II Project 2.1.5 – Make efficient use of excess storage capacity resulting from legislatively directed oil sales	4.3 – Foster responsible stewardship of resources, facilities, a safe work environment, and the communities FE serves	<ul> <li>4.3.1 – Strengthen values-based safety culture and maintain the highest standards of workplace safety, health, and security for all employees, facilities, and information</li> <li>4.3.2 – Maintain environmental stewardship</li> <li>4.3.3 – Align financial and infrastructure resources to the FE 2018–2022</li> </ul>						
2.2 – Advance technologies	2.2.1 - Improve the efficiency of existing coal-fired power plants		Strategic Vision						
to improve the efficiency, reliability, emissions, and	2.2.2 – Improve the reliability, emissions, and performance of existing coal- fired power plants								



performance of existing fossilbased power generation



## Strategic alignment of project to Fossil Energy (FE) objectives

The current project is inline with three of the strategic goals identified by Assistant Secretary for Fossil Energy

#### **Current Status of project:**

Currently the LTI robot is in TRL 3-4 level	
---	--

TRL 4	Has laboratory-scale testing of similar equipment systems been completed in a simulated environment?
TRL 3	Has equipment and process analysis and proof of concept been demonstrated in a simulated environment?

#### Industry/input or validation:

The PI is regularly seeking feedbacks from scientist and engineers in **GE power**. The final LTI robot will be demonstrated at the end of the project to robotic and NDT section at GE Power.

#### 2018–2022 STRATEGIC GOALS

FE's four Strategic Goals are:

1. Develop secure and affordable fossil energy technologies to realize the full value of domestic energy resources.

2. Enhance U.S. economic and energy security through prudent policy, advanced technology, and the use of strategic reserves.

3. Promote exports of domestically produced hydrocarbons and fossil energy technologies.

4. Develop and maintain world-class organizational excellence.





## Challenges, current status and next steps

Task serve	Assisted Deserves	Veer 1				1	Var	- 2		X2					
lask name	Assigned Resources	Otr 4	Otr 1	Otr 2	0tr 3	Otr A	Otr 1	Otr 2	Otr 3	Otr 4	Otr 1	Otr 2	dr 3 Otr 3	Otr 4	Otr 1
Task 1.0 - Project Management and Planning		Quit	QUII	QU 2	QLI 5	Qu +	Q(I) I	Q(i Z	Q <sub>1</sub> 5	QU 4	QU I	Q(i Z	Quis	Quit	QUII
Task 2.0 -															
Subtask 2.1 - Robot Leg Analysis and Design									On	track	ξ.				
Subtask 2.2 - Ultrasound and Leg technology in	:								Imn	acto	dhu	cov	10	<b>`</b>	
Milestone 1		ĺ							mμ	acte	uby	COV	IDIS	,	
Decision Point-1							•								
Subtask 2.3 - Leg Fabrication															
Subtask - 2.4 - Experimental Leg Technology Va															
Milestone 2		ĺ								•					
Decision Point-2		1									•				
Task 3.0 -															
Subtask 3.1 - Robot Design															
Subtask 3.2 - LTI Robot Fabrication													]		
Milestone 3													•		
Task 4.0 -		ĺ													
Subtask 4.1 - Lamb Wave Integration Evaluation															
Subtask 4.2 - Lamb Wave Integration Evaluation								I					]		
Milestone 4		1											•		
Task 5.0 - Final Validation															
Milestone 5															
		4													



The main challenge both teams are facing is the effect of COVID19 on operation of laboratories at NMSU and ASU and the new amendment related to foreign students imposed by DOE

**Next steps:** 1. Complete manufacturing 2 LTI robots (one at NMSU and one at ASU), and 3. Continue performing the fundamental research on friction based Lamb wave excitation, 4. finalize ultrasound imaging and perform experimental tests on the test beds developed at NMSU and ASU



#### **Materials Evaluation special issue**

#### **Robotic Inspection special issue**

Materials Evaluation, Technical Focus Issue on Robotic Inspection, to be published in July 2021.

H. Nematia, F. Alvidrez, A. Das, N. Masurkar, M. Rudraboina, H. Marvi, and E. Dehghan-Niri, "Integrating electromagnetic acoustic transducers in a modular robotic gripper for inspecting tubular components" Materials Evaluation, July 2021, In press

C. Lara, J. Villamil, A. Abrahao, A. Aravelli, G. Daldegan, S. Sarker, D. Martinez, **D. McDaniel**, "Development of an Innovative Inspection Tool for Superheater Tubes in Fossil Energy Power Plants" Materials Evaluation, July 2021, In press

X. Shi1, A. Olvera, C. Hamilton, J. Li, L. Utke, **A. Petruska**, Z. Yu, **Y. Deng** and **H. Zhang**, "Al-enabled Robotic NDE for Structural Damage Assessment and Repair" under review

ME is mailed out to approximately 16,000 ASNT members each month. Approximately half are US based and the rest are worldwide. Each paper is assigned a DOI number and added to the ASNT Library to be accessed by future researchers. Our last Technical Focus Issue was open-access and was accessed by approximately 12,000 readers.





# **Acknowledgment:** "This material is based upon work supported by the Department of Energy Award Number DE-FE0031649."

**Disclaimer:** "This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof."



#### Q&A



Ehsan Dehghan-Niri, Ph.D. Assistant Professor Civil Engineering Department Affiliated faculty member of Mechanical and Aerospace Engineering Department Director of Intelligent Structures and Nondestructive Evaluation (ISNDE) Laboratory New Mexico State University 210 Hernandez Hall, 3035 South Espina Street, Las Cruces, NM, 88003 Email: <u>niri@nmsu.edu</u> Office Phone: (575) 646 3514 Fax: (575) 646 6049 Website: <u>https://wordpress.nmsu.edu/niri/</u>



Hamid Marvi, Ph.D. Associate Professor Mechanical and Aerospace Engineering Director of the Bio-Inspired Robotics, Technology, and Healthcare (BIRTH) Laboratory Arizona State University 551 E Tyler Mall, Room ERC 365, PO Box 876106, Tempe, AZ 85287-6106 Email: hmarvi@asu.edu Office Phone: (480) 727 4853 Fax: (480) 727 9321 Website: birth.asu.edu



