

# Development of Syngas Oxy-Combustion Turbine for Use in Advanced sCO<sub>2</sub> Power Cycles

University Turbine Systems Research - Project Review Meeting




DE-FE0031929

November 9, 2021



# Program Overview

- Build upon existing conceptual design and sizing work from DE-FE0031620 – “Development of Oxy-fuel Combustion Turbines with CO<sub>2</sub> Dilution for Supercritical Carbon Dioxide (sCO<sub>2</sub>) Based Power Cycles”
  - Update Design and Cycle from that award for a Syngas Fired cycle rather than Natural Gas (able to be co-fired)
- Southwest Research Institute (Prime) – Stefan Cich, Jeff Moore, Florent Bocher
  - Turbine Design, Turbomachinery Testing with sCO<sub>2</sub>, existing test loops and support equipment, material evaluation
- 8Rivers Capital, LLC – Jeremy Fetvedt
  - Facility with Commercial Potential for a 21<sup>st</sup> Century Power Plant
- Air Liquide – Bhupesh Dhungel
  - Combustion analysis and development. Performance Assessment
- General Electric GRC – Thomas Vandeputte
  - Turbomachinery design and seal development
- Electric Power Research Institute – George Booras
  - Techno Economic Assessment of the 21<sup>st</sup> Century Power Plant and industry insight into market potential
- Purdue University – Guillermo Paniagua
  - Aero design and testing with existing aerothermal test rigs
- University of Central Florida – Jayanta Kapat
  - Heat transfer expertise with sCO<sub>2</sub> and existing test rigs




# Program Overview

- Project Total: \$6,417,610
- Budget Period 1 Total: \$2,026,851
- Budget Period 2 Total: \$2,562,422
- Budget Period 3 Total: \$1,828,337


[illegible]

# Program Overview

- Three Step Design Approach
  - Budget Period 1 – Conceptual Design
    - Turbine case and rotor, aerodynamic flowpath, and combustor layout with initial analysis and calculations to justify that the design can meet cycle requirements
  - Budget Period 2 – Preliminary Design
    - Updated design of all critical components (1<sup>st</sup> stage blade and vane, combustor, turbine case and rotor). All will undergo more detailed analysis and confirmation based on updated test data for key risk areas
  - Budget Period 3 – Detailed Design
    - Final analysis and manufacturing drawings to confirm design will meet final cycle model requirements and also allow for cost estimates of critical components
- All designs will be evaluated based on existing design codes and standards: API 612, API 684, ASME VIII-2, ASME B31-1 & 3




# Program Overview





# Program Overview



# Program Overview – Key Risk Items

## 1. Turbine Layout (Task 1.2, 1.4, and 1.5)

- Large scale, industrial high-pressure turbine (315 bar) with high-pressure oxy-fuel combustor in a closed-loop system
  - Closed-loop system → addition of pipe loads due to thermal growth acting on all critical components
  - While the system does produce its own CO<sub>2</sub>, need to prevent CO<sub>2</sub> leakage to the atmosphere
  - Due to size, there is a desire for a horizontal split casing for ease of maintenance → high pressure metal-to-metal face seal at split joint
  - Easier maintenance → option for cheaper internal high temperature materials that can be replaced periodically to improve performance and reduce overall cost
- Industrial gas turbines – Higher temperature at lower pressures in an open-loop system
- Steam turbines – Lower temperatures and pressures

## 2. Sealing Technology (Task 1.4)

- End seals, internal seals, blade to stator seals, split case sealing, balance piston, axial face seal
- For leakage to atmosphere: end seals and high temperature case sealing
  - End seals will see around 30 bar. Longer labyrinth seals can be implemented for comparable leakage to face seal. Labyrinth seals can also be designed with a lower pressure reservoir for re-injection at 30 bar
  - Case will see 315 bar

## 3. High Temperature Blade Materials (Task 1.6)

- Smaller blades lead to manufacturing challenges. Potential for Additive Manufacturing (AM) of turbine blades
- Evaluate properties of AM materials vs Castings
- Evaluate impact of Syngas byproducts on materials in the high-pressure and high-temperature environment

## 4. Thermal Barrier Coatings (Task 1.6)

- Similar to blade materials, necessary to look at impact on material performance from byproducts in syngas
- Due to operating nature of this technology, look at thermal cyclic performance of TBCs

## 5. Heat Transfer Coefficients for high relative mach # process flow and high Reynold's number cooling flow (Task 1.3)

- Predicted cooling flow will be at Reynolds # > 250,000
- Need to evaluate impact on heat transfer performance with sCO<sub>2</sub> to determine design limits and what kind of enhancements will be required to effectively cool blades and vanes
- More efficient cooling → less cooling flow and higher efficiency or easier to manufacture materials

# BP1 – Technical Summary



- Task 1.2 – Initial Syngas Combustion Cycle
  - Modify a 100% Natural gas Oxy-Combustion Cycle with syngas. Requires addition of Gasifier and Cleanup
  - Look at impact of various syngas (high-CO & high-H<sub>2</sub>) fuels and evaluate performance
- Task 1.3 – Heat Transfer Validation
  - Fundamental heat transfer test rig (impingement and pin-fin) design, manufacturing, and commissioning
  - High-flow, high-Re # representative heat transfer test rig (internal blade passages & representative blade) design and review
  - Assessment of internal cooling options and how they can be applied and validated
- Task 1.4 – Turbine Conceptual Design
  - 1D Meanline flowpath design that will meet aero, cycle, and mechanical requirements
  - Optimization of 1<sup>st</sup> Stage Vane & Blade flowpath
  - Conceptual design of turbine rotor, case, seals, and thermal management
- Task 1.5 – Combustor Conceptual Design
  - Detailed assessment of Combustor layout that will fit into the chosen case layout
  - Update analysis to account to different fuels, downstream stator vanes, and non-uniform spacing as required by the case
- Task 1.6 – Material Testing
  - Evaluation of potential materials that will be used in the final turbine design along with test plan to validate the materials
  - Procurement of high temperature equipment for autoclave and cyclic thermal testing



# Task 1.2 – Cycle Model

- Two main impacts on cycle model when compared to a Natural Gas Oxy-Combustion Cycle
  - Addition of Gasifier and Syngas Cleanup. These impact the overall cycle performance as they are a direct efficiency loss. Turbine parameters are held constant (Inlet temperature, pressure, and volume flow). This is possible due to majority of flow being recycled  $\text{CO}_2$
  - Evaluation of Syngas fuels (high- $\text{CO}$  & high- $\text{H}_2$ ) vs Natural Gas. Look at impact on mass flow, temperatures, and efficiency
- While the turbine performance is not impacted by changing fuels, the combustor performance is significantly impacted
  - Fuel flow rate increases by 4-5X
  - Oxygen flowrate decreases by 50%
  - In order to maintain proper combustor performance, Fuel and Oxygen flowrates need to be consistent
  - Look at options for multiple nozzles and pre-mixing with recycled  $\text{CO}_2$
- Turbine Design Conditions:
  - Flow rate: 30,000  $\text{m}^3/\text{hr}$
  - Pressure: 315 bar
  - Temperature: 706C (Recycle Flow sections)
  - Fuel Nozzle: 1,042  $\text{m}^3/\text{hr}$  (High- $\text{H}_2$  Syngas)
  - Oxygen Nozzle: 6,000  $\text{m}^3/\text{hr}$  (100%  $\text{CH}_4$ )
  - Power: 450  $\text{MW}_{\text{mech}}$




|                     |       | NG        | 2.45<br>CO:H2 | 0.9 CO:H2 |
|---------------------|-------|-----------|---------------|-----------|
| FUEL-IN             | kg/hr | 38,843    | 204,771       | 191,320   |
|                     | m3/hr | 224.9     | 962.8         | 1,041.4   |
| LHV                 | MJ/kg | 50.0      | 9.8           | 10.3      |
|                     | MWt   | 539.8     | 558.2         | 547.6     |
| OXI-IN              | C     | 687.0     | 695.8         | 705.8     |
|                     | kg/hr | 890,365   | 682,145       | 691,070   |
|                     | m3/hr | 6,013     | 4,645         | 4,754     |
| RECYC-IN            | C     | 687.2     | 695.8         | 706.0     |
|                     | kg/hr | 2,055,954 | 2,166,745     | 2,125,727 |
|                     | m3/hr | 13,076    | 13,883        | 13,765    |
| TURB-IN             | C     | 1,149.9   | 1,150.1       | 1,150.4   |
|                     | bar   | 305.0     | 305.0         | 305.0     |
|                     | kg/hr | 2,985,162 | 3,053,660     | 3,008,117 |
|                     | m3/hr | 29,559    | 29,551        | 29,553    |
| % diff into turbine | kg/hr | Baseline  | 2.3%          | 0.8%      |



# Task 1.3 – Heat Transfer Validation

## Task 1.3.1 – High Reynolds Number $\text{sCO}_2$ Test Rig Design




- Design a high flow  $\text{sCO}_2$  heat transfer rig that can evaluate different types of internal HTC enhancements for blade cooling flow
- Critical to understand total error in measurements
- Lower  $dT$  and Length  $\rightarrow$  Large Errors
- Single pass leads to 15-20°C Temperature Rise. Looking at multi-pass option
- Important to avoid near dome temperatures with high variations in fluid properties.
- Currently looking at operating around 200°C for the cold flow and around 525°C for the hot flow.



# Task 1.3 – Heat Transfer Validation

## Task 1.3.2 – Impingement and Pin-Fin Assessment


- Evaluate potential areas for various heat transfer enhancements (pins, fins, impingement, serpentine, surface roughness)
- Manufacturing options impact potential features. Currently looking at AM parts. Key questions on AM
  - Internal surface roughness?
  - Accuracy of internal features (pins, fins, serpentine)
  - Minimum diameter for impingement cooling holes (Trial Prints → 0.030" Diameter)
- Due to method of attachment, central fed serpentine with leading edge impingement cooling will be ideal




# Task 1.3 – Heat Transfer Validation

## Task 1.3.3 – Rig Adaption for sCO<sub>2</sub>


- Impingement Test Section
  - This test will involve a single jet with a heated copper plate
  - Heat transfer will be measured by measuring required energy input into the copper plate to maintain temperature
  - Current limitations allow for a single hole to be tested, but that geometry can be changed with the modular plate on the inside
- Pin-Fin Test Section
  - Test section will be inside a pressurized cylinder to reduce dP across test section
  - Modulus test section that will allow for the testing of various pin-fin arrays
- Preliminary goal is to compare to air tests and look at trends with sCO<sub>2</sub>. This will allow for use of existing data to aid in design optimization
- Testing in BP3 will be focused on mimicking geometry inside the updated blade



Pin-Fin Test Section



Impingement Test Section











# Task 1.4 – Turbine Conceptual Design

## Task 1.4.1 – Turbine Meanline Layout



- With updated cycle modeling complete, early work was focused on updating the Turbine Meanline Layout and picking the optimal flowpath for this turbine
- Original design was a very high level layout and needed to be updated with more time and funding along with more trade studies
  - Model Updates
    - Added cooling flow per stage
    - Performed thermo balance between each stage with added cooling flow
    - Included updated assumptions for secondary leakages
  - Model Trade Studies
    - Higher Stage Count
      - Benefits: Taller blades, smaller seal diameters (less leakage), higher aero efficiency, and lower velocities at the exhaust leading to less pressure recovery in the diffuser
      - Negatives: Smaller hub diameter (reduced rotor stiffness), longer axial span (reduced rotor stiffness), and increased cooling flow
- Rotordynamic concerns ruled out the 8 stage design
- Manufacturing and performance concerns ruled out 4 and 5 stage due to blade height
- 6-Stage design chosen**















# Task 1.4 – Turbine Conceptual Design

## Task 1.4.2 – 3D Modeling and Analysis of 1<sup>st</sup> Stage

- 3D Models and Meanline produced by GE are passed to Purdue for Optimization
- Purdue is performing optimization sweeps by creating a parameterized linear model that matches the 3D smooth model closely
- Parameters of Concern:
  - Optimization focus: Sweep, stacking, lean, stagger, Camber, Span
  - Aeromechanical Focus: LE and TE Radius, Number of Blades, Max Lean and curvature
- Current plan is to run optimization studies and look at impact on mechanical performance and manufacturing to impose additional limits as necessary
- Optimization will look at improving aero efficiency and reducing heat flux to the blade





| Baseline  | Maximum Lean (-15 deg)  | Maximum Lean (+15 deg)   | Maximum Stagger Differential  |
|---|---|--|---|
|   |   |   |   |
|  |  |  |  |



# Task 1.4 – Turbine Conceptual Design







## Task 1.4.5 – Conceptual Layout

- Main focus of BP1 has been on updating the case layout with the chosen aerodynamic flowpath. The main changes to the layout at the beginning of the program
  - Evaluation of Split Case concept with supporting FEA (simplify assembly and disassembly procedure)
  - Updating of Diffuser Flowpath to reduce pressure drop and determine if additional axial or radial span is required (improve efficiency)
  - Updated rotor model with new axial span and decreased hub diameter
  - Attachment methods for internal hot components
  - Move most connections to the bottom half of the case
- At the end of BP1, the team will host a Conceptual Design Review to look over the design and provide necessary action items that will need to be addressed in BP2






# Task 1.4 – Turbine Conceptual Design




# Task 1.5 – Combustor Conceptual Design

- Syngas requires more fuel (mass flow) and less oxygen (mass flow). This leads to different flow velocity if using the same nozzle as a 100% CH<sub>4</sub> design
- With matching nozzles, the flame is moved far outside the can and is not properly attached. This leads to incomplete combustion and larger variation in properties at firing plane
- Velocities will have to be slowed down through the mixing of CO<sub>2</sub> in the fuel and oxygen flows upstream of the combustor can
- With same velocities, syngas will have a temperature spread around 60°C higher than 100% methane (open annulus)




°C



Syngas dT=203C





°C



Natural Gas dT=143C





100% Methane




°C

High-CO w/ Same Nozzle





°C

High-CO w/ Same Velocity



# Task 1.5 – Combustor Conceptual Design

- It was determined that the Combustor model should include stator vanes to look at impact on temperature distribution
- Stator Vanes provide a significant flow resistance ( $\sim 40$  bar pressure drop) and lessen the temperature distribution by  $164^\circ\text{C}$
- Mass averaged temperature is currently around  $1140^\circ\text{C}$ . Will need to adjust fuel and recycle flows to reach  $1150^\circ\text{C}$  average temperature entering the stator vanes






# Task 1.6 – Material Testing

## Task 1.6.1 – Material Selection

- Initial Material work was focused on establishing a baseline list of materials that could potentially be used in this turbine based on previous research and published data
- This required an initial understanding of where these materials would be used and what kind of conditions they would be seeing
- The primary areas are: Combustor liner, 1<sup>st</sup> stage vane, 1<sup>st</sup> stage blade, 1<sup>st</sup> stage blade tip, and exhaust plenum
  - If using an unshrouded blade design, the blade tip will not be coated with a TBC and will be exposed to much hotter temperatures while seeing much lower stresses
- All areas are exposed to the hot combustion flow with syngas byproducts
- All other areas of the turbine will be seeing clean, cooler, recycled CO<sub>2</sub> flow and will be buffered

|   | Location                        | Temperature (°C) | Pressure (bar) | Mechanical requirements | Coatings |
|---|---------------------------------|------------------|----------------|-------------------------|----------|
| 1 | Combustor liner                 | 980              | 305            | Standard                | Yes      |
| 2 | 1 <sup>st</sup> stage vane      | 1150             | 305            | Standard                | Yes      |
| 3 | 1 <sup>st</sup> stage blade     | 1100             | 256            | High strength           | Yes      |
| 4 | 1 <sup>st</sup> stage blade tip | 1100             | 256            | High strength           | No       |
| 5 | Turbine exhaust plenum          | 764              | 30             | Standard                | No       |





# Summary – Key Decisions

- To have an effective co-fired system between Natural Gas and Syngas, the combustor fuel & oxygen nozzles will require mixing flow from Recycled CO<sub>2</sub> or lower temperature sources to control flow velocity into the combustor
- Turbine can be designed for steady inlet conditions: Volume Flow, Temperature, and Pressure
- For better heat transfer assessment, the team will design a serpentine style test section to reduce measurement error and better mimic blade internals
- The blades will be designed to be manufactured through AM technology and will include heat transfer enhancements through pin-fins near the TE and impingement cooling on the LE. This will require a detailed understanding of limits through AM and also other manufacturing methods as back up
- For the 300 MWe 21<sup>st</sup> Century Power Plant, the team has chosen a 6 Stage Axial Turbine that is optimal from a cost, performance, and mechanical perspective
- Unshrouded and Shrouded Blade designs will be explored. While not typical the 1<sup>st</sup> stage of gas turbines, there is a chance that shrouded blades could be effective for the 1<sup>st</sup> stage of this turbine
- Labyrinth seals will be sufficient for the current target end seals. Hole pattern seals will be required for the balance piston
- The team is pursuing a horizontally split-case design to improve on turbine maintenance
- The turbine can be directly coupled to a generator without the need for a flexible coupling
- Turbine blades can be attached with circumferential dove tails to simplify the turbine rotor and reduce manufacturing cost

# Questions?

