

Regional Analysis of Dry Cooling Retrofits on NGCC Using IECM



Haibo Zhai^a and Ed Rubin^b


^a University of Wyoming, Laramie, WY

^b Carnegie Mellon University, Pittsburgh, PA

Integrated
Environmental
Control
Model



May 10, 2021



Contractor Author Legal Disclaimer



This project was funded by the United States Department of Energy, National Energy Technology Laboratory, in part, through a site support contract. Neither the United States Government nor any agency thereof, nor any of their employees, nor the support contractor, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Authors and Contact Information



Haibo Zhai¹ and Ed Rubin²

¹University of Wyoming, 1000 East University Ave, Laramie, WY 82071

²Carnegie Mellon University, 5130 Wean Hall, Pittsburgh, PA 15213

Project Objectives



- Estimate the potential water savings benefit of retrofitting dry cooling systems at existing natural gas combined cycle (NGCC) power plants currently using wet cooling towers in a water-stressed (dry/arid) region
- Estimate the cost and cost-effectiveness of such retrofits
- Identify potential shortfalls in regional net generating capacity due to the derating impact of dry cooling retrofits

Project Scope

- Expand a prior study of dry cooling retrofits at coal-fired (PC) power plants to now analyze existing NGCC power plants using wet cooling towers in the study region
- Define the case study region to include three western U.S. states: Arizona, Colorado, and New Mexico
- Evaluate potential reductions in net generating capacity on both an annual and monthly average basis under current conditions

NGCC Power Plants Modeled

Plants in Arizona	<ul style="list-style-type: none">• West Phoenix (2 units)• Kyrene (1 unit)• Santan (2 units)• Desert Basin (1 unit)• Harquahala Generating Project (1 unit)	<ul style="list-style-type: none">• Red Hawk (1 unit)• Griffith Energy LLC (1 unit)• Gila River Power Block 3 (1 unit)• Mesquite Generating Station Block 1 (1 unit)
Plants in Colorado	<ul style="list-style-type: none">• Cherokee (1 unit)• Rocky Mountain Energy Center (1 unit)	
Plants in New Mexico	<ul style="list-style-type: none">• Luna Energy Facility (1 unit)	

Total = 12 plants and 14 units modeled


Data Attributes and Sources

Category	Parameters	Database(s)
Unit attributes	Nameplate capacity (gas turbine, steam turbine and the total), online year	National Electric Energy Data System; Energy Information Administration (EIA) Form 860
	Cooling system type	EIA Form 923
	Gross and net generation, gross and net heat rates (annual averages)	Velocity Suite
	Natural gas prices	Velocity Suite
Monthly unit operating information	Gross and net generation, gross and net heat rates	Velocity Suite
Ambient conditions	Air dry-bulb temperature, relative humidity, air pressure	National Climatic Data Center

All data are for calendar year 2017.

Configure and Model Existing Units in Integrated Environmental Control Model (IECM)

- In the Integrated Environmental Control Model (IECM), an existing unit is specified by attributes including unit type, age, nameplate capacity (gas and steam turbines), steam cycle heat rate, net plant heat rate, annual electricity generation, and ambient air conditions.



CONFIGURE SESSION: Plant Design

Configuration: Typical New Plant

Post-Combustion Controls

CO₂ Capture: None

Water and Solids Management

Cooling System: Wet Cooling Tower

Note: Options in gray are accessible only after other required options are selected.

SET PARAMETERS: Overall Plant Performance

Title	Unc	Value	Calc	Min	Max	Default
Number of Gas Turbines		1.66				2
Gross Electrical Output (MWg)		292	<input checked="" type="checkbox"/>	100	2000	Calc
<i>(See Power Block to set these values.)</i>						
Capacity Factor (%)	<input type="checkbox"/>	40.5		1e-15	100	75
Plant Location		US Midwest Region		Menu	Menu	US Midwe...
<i>(US Midwest States: IA, IL, IN, KY, MI, MN, MO, ND, NE, OH, SD, WI, WV)</i>						
<i>(See Plant Location in CONFIGURE SESSION to set this value.)</i>						
Ambient Air Temperature (Dry Bulb Average) (°F)	<input type="checkbox"/>	77.9	<input type="checkbox"/>	15	100	Calc
Ambient Air Pressure (Average) (psia)	<input type="checkbox"/>	14.1	<input type="checkbox"/>	12	15	Calc
Relative Humidity (Average) (%)	<input type="checkbox"/>	31.2	<input type="checkbox"/>	0	100	Calc
Ambient Air Humidity (Average) (lb H ₂ O/lb dry air)	<input type="checkbox"/>	0.006586	<input checked="" type="checkbox"/>	0	0.03	Calc
Water Life Cycle Assessment Enabled?	<input type="checkbox"/>	Yes		Menu	Menu	Yes

Source: CMU/UW

Configure and Model Existing NGCC Units with Wet Cooling Tower Systems

Steam Generator Parameters

SET PARAMETERS: Power Block: Steam Cycle Performance

Title	Unc	Value	Calc	Min	Max	Default
<u>Heat Recovery Steam Generator</u>						
HRSG Outlet Temperature (°F)	<input type="checkbox"/>	193	<input type="checkbox"/>	150	500	250
Steam Cycle Heat Rate, HHV (Btu/kWh)	<input type="checkbox"/>	9900	<input type="checkbox"/>	6000	1.1e+04	9000
Adjusted Steam Cycle Heat Rate, HHV (Btu/kWh)	<input type="checkbox"/>	9900	<input checked="" type="checkbox"/>	6000	1.5e+04	Calc
Cooling Water Temperature Rise (°F)	<input type="checkbox"/>	20	<input checked="" type="checkbox"/>	10	50	Calc
Auxiliary Heat Exchanger Load (*1) (%)	<input type="checkbox"/>	1.41	<input checked="" type="checkbox"/>	0	20	Calc
<u>Steam Turbine</u>						
Total Steam Turbine Output (MWg)	<input type="checkbox"/>	121.9	<input checked="" type="checkbox"/>	0	2000	Calc
<u>Power Block Totals</u>						
Power Requirement (% MWg)	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>	0	15	Calc
(*1) % Primary Steam Cycle						

Ambient Conditions

SET PARAMETERS: Water Systems: Performance

Title	Unc	Value	Calc	Min	Max	Default
<u>Wet Cooling Tower</u>						
Ambient Air Temperature (Dry Bulb Average) (°F)	<input type="checkbox"/>	77.9	<input type="checkbox"/>	15	100	Calc
Air Wet Bulb Temperature (Average) (°F)	<input type="checkbox"/>	59.22	<input checked="" type="checkbox"/>	15	100	Calc
Cooling Water Inlet Temperature (°F)	<input type="checkbox"/>	90	<input type="checkbox"/>	50	120	90
Cooling Water Temperature Drop (°F)	<input type="checkbox"/>	20	<input checked="" type="checkbox"/>	10	50	Calc
Cycles of Concentration	<input type="checkbox"/>	4	<input type="checkbox"/>	2	20	4
Tower Drift Loss (*1) (%)	<input type="checkbox"/>	0.001	<input type="checkbox"/>	0	0.1	0.001
Auxiliary Cooling Load (*2) (%)	<input type="checkbox"/>	1.41	<input checked="" type="checkbox"/>	0	20	Calc
Tower Overdesign Factor (% total load)	<input type="checkbox"/>	0	<input type="checkbox"/>	0	20	0
(*1) % Recirculating Water						
(*2) % Primary Steam Cycle						
Power Requirement (% MWg)	<input type="checkbox"/>	0.7093	<input checked="" type="checkbox"/>	0	15	Calc

Source: CMU/UW

Key Results for Existing NGCC Units with Wet Cooling Towers (CY 2017)




Study Unit ID	1	2	3	4	5	6	7	8	9	10	11	12	13	14
Air dry bulb temp. (°F)	77.9	77.9	77.9	77.9	77.9	64.5	77.9	77.9	77.9	77.9	77.9	63.5	51.4	51.4
Air relative humidity (%)	31.2	31.2	31.2	31.2	31.2	33.2	31.2	31.2	31.2	31.2	31.2	41.3	52.6	52.6
Unit age in 2020 (years)	19	17	18	15	14	18	19	16	18	17	17	14	5	16
Nameplate capacity (MW)	135.6	570	292	622.1	290.2	654.2	646.3	441.6	573.1	691.5	619	650.3	624.8	684.7
Net capacity (MW)	120.6	519.3	284.1	610.5	285	637.9	610.6	432.7	551.6	679.1	608.2	638.7	614.2	637.9
Net plant efficiency (HHV,%)	40.1	42.3	46.0	46.4	45.7	46.7	42.5	47.0	45.8	46.6	48.1	44.6	48.6	40.9
Capacity factor (%)*	21.0	44.5	40.5	43.1	42.0	35.0	19.4	13.7	43.0	33.9	44.8	45.3	57.2	35.7
Net generation (BkWh/yr)	0.222	2.026	1.009	2.307	1.049	1.957	1.037	0.520	2.079	2.015	2.388	2.536	3.080	1.996
Water consumption (gallons/MWh)	320	306	300	357	336	286	350	248	260	322	289	302	215	272

* Based on nameplate capacity

Model Existing NGCC Units Retrofitted with Dry Cooling Systems



- Replace wet cooling tower with a dry air-cooled condenser (ACC) system
 - Same nameplate capacity and capacity factor as before



Source: CMU/UW

Model Existing NGCC Units Retrofitted with Dry Cooling Systems (continued)

- ACC design based on annual average ambient conditions
- ACC capital cost amortized over remaining life of the unit as of 2020 (based on a 30-year NGCC unit life)



SET PARAMETERS: Water Systems: Performance

Title	Unc	Value	Calc	Min	Max	Default
<u>Air Cooled Condenser</u>						
Peak Ambient Air Temp (Dry Bulb) (°F)	<input type="checkbox"/>	77.9	<input type="checkbox"/>	15	120	90
Ambient Air Temperature (Dry Bulb Average) (°F)	<input type="checkbox"/>	77.9	<input type="checkbox"/>	15	100	Calc
Inlet Steam Temperature (°F)	<input type="checkbox"/>	125.2	<input checked="" type="checkbox"/>	100	160	Calc
Fan Efficiency (%)	<input type="checkbox"/>	80	<input type="checkbox"/>	50	100	80
Condenser Plot Area (per cell) (sq ft)	<input type="checkbox"/>	1180	<input type="checkbox"/>	538.2	2691	1186
<u>Steam Cycle</u>						
Turbine Back Pressure (inches Hg)	<input type="checkbox"/>	3.988	<input checked="" type="checkbox"/>	2	8	Calc
Auxiliary Heat Exchanger Load (*) (%)	<input type="checkbox"/>	5	<input checked="" type="checkbox"/>	0	20	Calc
(*) % Primary Steam Cycle						
Air Cooled Condenser Power Requirement (% MWg)	<input type="checkbox"/>	0.9385	<input checked="" type="checkbox"/>	0	6	Calc

Source: CMU/UW

Key Results for Existing NGCC Units Retrofitted with ACCs (CY 2017)




Study Unit ID	1	2	3	4	5	6	7	8	9	10	11	12	13	14
Nameplate capacity (MW)	135.6	570	292	622.1	290.2	654.2	646.3	441.6	573.1	691.5	619	650.3	624.8	684.7
Net capacity (MW)	119	512.3	280	599.9	280.3	632.4	600.9	427.4	544.8	668.4	599.4	633	612.5	635.9
Net plant efficiency (HHV, %)	39.6	41.7	45.4	45.5	45.0	46.3	41.9	46.4	45.3	45.9	47.4	44.2	48.4	40.7
Capacity factor (%)*	21.0	44.5	40.5	43.1	42.0	35.0	19.4	13.7	43.0	33.9	44.8	45.3	57.2	35.7
Net electricity generation (BkWh/yr)	0.219	1.998	0.9941	2.266	1.032	1.94	1.021	0.5133	2.053	1.983	2.354	2.514	3.071	1.99
Water consumption (gallon/MWh)	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Increase in Levelized Cost of Energy (LCOE) (2017 \$/MWh)	13.6	4.8	5.7	5.3	5.6	6.2	13.7	12.6	4.4	6.6	4.5	4.4	1.9	5.0
Percent increase in LCOE **	24.2	13.3	15.9	17.1	17.2	18.3	31.8	29.7	13.5	20.3	14.6	14.4	5.9	13.8

* Based on nameplate capacity

**Relative to pre-retrofit, assuming capital cost of all existing plant equipment is fully amortized before and after retrofit

Cost of Water Savings by Dry Cooling Retrofit*

Unit-Level Results



* Based on nominal water price of \$1.13/kgal


Regional Averages:

- 100% drop-in unit-level water consumption
- \$6.7/MWh (18%** increase in LCOE)
- \$22.5 per thousand gallons of water saved
- Costs increase for difficult retrofits and decrease for higher water prices

**Based on fully amortized plants

Source: CMU/UW

Water Savings Supply Curves for NGCC and Pulverized Coal (PC) Plants




- The unit cost of water saved at NGCC plants is higher than for PC plants, mainly because of lower NGCC capacity factors.
- Differences in cooling duty, amortization period and other site-specific factors also contribute to higher costs at NGCC units.


Source: CMU/UW

Monthly Change in Net Unit Capacity for NGCC and PC Retrofit Cases

Existing NGCC Units



Existing PC Units



Source: CMU/UW

Summary of Changes in Net Regional NGCC Capacity with Dry Cooling Retrofits

Average monthly decrease in net regional NGCC capacity:

- 23 MW to 167 MW on an absolute basis, or
- 0.3% to 2.2% on a relative basis
- Largest decreases in capacity occur in June and July

Annual average decrease in net regional NGCC capacity:

- 86 MW, or 1.2% of total regional NGCC capacity with wet cooling
- This is higher than the average decrease of 0.8% for PC units, due mainly to higher steam cycle heat rates at NGCC units

In Summary

- This work has quantified the potential water savings benefit of dry cooling system retrofits at NGCC plants now using wet cooling towers in a water-stressed region.
- Also quantified tradeoffs in terms of higher cost and shortfalls in net generating capacity.
- Together with prior analysis of coal-fired plants, these results can be used to better inform water use strategies and policies for power plants in a water-stressed region.
- Further analysis and additional data are needed to assess impacts for shorter time periods (e.g., daily, hourly).

Acknowledgements



The authors would like to thank Eric Grol¹, Travis Shultz², Briggs White¹, Marc Turner^{1,3}, and Mark Woods^{1,4} for their support and assistance in performing this work.

¹National Energy Technology Laboratory, 626 Cochran's Mill Rd, Pittsburgh, PA 15236

²National Energy Technology Laboratory, 3610 Collins Ferry Rd, Morgantown, WV 26505

³NETL Support Contractor, Leidos, 250-C, Curry Hollow Rd, Pittsburgh, PA 15236

⁴NETL Support Contractor, KeyLogic Systems, 3168 Collins Ferry Rd, Morgantown, WV 26505

Questions/ Comments

VISIT US AT: www.NETL.DOE.gov

 @NETL_DOE

 @NETL_DOE

 @NationalEnergyTechnologyLaboratory

CONTACT:

Eric Grol

Eric.Grol@netl.doe.gov

