



# Co-Gen Wastewater Treatment for Coal-Fired Energy Plants

---

DOE-NETL Integrated Project Review Meeting  
Water Management  
DE-FE0031669  
May 10, 2021



# Co-Gen Wastewater Treatment for Coal-Fired Energy Plants Project

- Type of Contract:
  - DOE Co-Op (DOE/NETL)
- Period of Performance:
  - October, 2018 to March, 2021
- Total Contract Value:
  - \$748.8K PLUS \$187.2K Cost Share



Produced Water  
Proof-of-Concept Test



Produced Water (Inlet),  
Condensed steam (Outlet)


# Project Objectives

- Show clear, economic solution for FGD wastewater treatment supported by detailed analyses and trade studies
  - Review system configuration options
  - Select an optimized solution
- Complete experiments to document the solubility, transport and/or capture of Critical Pollutants of Concern (CPoC) species
  - Liquid and gas phase
  - Information will be essential to guide work on the first objective and determine economic options for CPoC removal

# Project Approach

- Innovative process will reduce the net cost of water treatment
  - Process has similar CAPEX to current chemical/biological systems
  - Generate power to offset capital investment and operational expenses
  - Portion of the wastewater stream will be heated and filtered and then used as a working fluid in a turbine
- Verify concept makes economic sense
  - Complete system modeling and economic assessment of options
  - System study and economic evaluation will define the most attractive system configuration
- Address a key implementation risk
  - Investigate additives in the case that some CPoC are not readily separated from the steam stream
  - Complete Filter Testing and Analysis
    - Size/Design/Procure/Fabricate Test System


# Proposed System Configuration





# Hardware Assembly

- Test input – simulated or actual FGD water
- Heat water to conditions similar to direct steam generator system
- Filter steam/combustion stream with candle filters as planned
- Evaluate success capturing CPoC




# Testing Summary – Simulated FGD Water

- Focused on Effluent Limitation Guidelines from the 2015 Rule
  - Hg & Se - added As, Nitrates, other pollutants in later tests
- Completed 12 simulated water filtering tests
  - Examined three nozzles and three filters
  - Selected filter and nozzle for actual FGD water testing
  - Typically captured >83% of the water and solids (vapor small/not measured)
- Optimized test apparatus through simulated water testing
- Typical TDS results - Before ~27,000 ppm; After ~234 ppm
  - Se meets release criteria
  - Hg does not meet release criteria – very stringent
  - As meets criteria
  - Nitrates higher than release criteria
- Water available for re-use in the facility – reduce fresh water needed

# Solids Summary


## Broad size distribution good for candle filter





# Solids Summary

## Particle size analysis by XRD



# Testing Summary – Actual FGD Water

- Completed 2 tests on AEP produced water and one test on EPRI-1.
  - Utilized a guard bed of HGR carbon to address mercury content in vapor phase.
  - Ran AEP a second time due to a wet filter cake and solids migrating through the filter.
- TDS reduction
  - EPRI-1 6,570 ppm before; 100 ppm after
  - AEP Test 2 – 18,000 ppm before; 240 ppm after
- Critical Pollutants of Concern
  - Se meets release criteria
  - Hg does meet criteria for effluent water
    - Hg HGR carbon treatment for vapor
  - As meets criteria
  - Nitrates met criteria
- Water available for re-use in the facility – reduce fresh water needed

# System Performance - CPoC

	TDS		Se		Hg		As		Nitrates	
	Initial	After	Initial	After	Initial	After	Initial	After	Initial	After
AEP **	20,000	5700	0.180	0.1060	0.00333	<.0002	0.0098	<.0010	<1.8	1.41
AEP (2)	18,000	240	0.142	0.0039	0.00200	.000098	0.0093	0.0014	<89	<0.89
EPRI_1	6,570	100	0.094	<.0025	0.00094	.000093	0.0043	<0.001	<900	<9
Req't *	Not applicable		0.0075 mg/L		.000159 mg/L		0.00598 mg/L		1.3 mg/L	

Black = initial values or not applicable/unknown/reference, Red = does not meet, blue = meets

\* EPA 2015 rule

\*\* Filter breached by liquid – operational issue, not a valid test

- Cr increased in each test, ranged from 0.37-3.09 mg/L vs 0.1 mg/L requirement for EPA drinking water
- Ph ranged from 1.66-2.37, too low to release

# Summary of Effluent Results

## Mercury Analysis

	Synthetic Feed Water, mg/L	Hg Gas Phase No Guard (sorbent), ug/L gas	Hg Gas Phase With Guard (sorbent), ug/L gas	% Reduction
AEP1	0.00333	0.001244	0.0005627	0.54766881
AEP2	0.00202	0.00158	0.000095	0.94025892
EPRI1-1	0.000936	0.000102	0.00003	0.70588235

- Water and solid samples indicate Hg in vapor form as feared/expected
- EPRI1-1 passed criteria without need for treatment.
- AEP2 passes criteria after treatment with HGR carbon.

# Summary

- Candle filter system captures majority of water contaminants
- TDS reduction to  $< \sim 250$  ppm
- Critical Pollutants of Concern
  - Se meets release criteria
  - Hg meets criteria
    - Treat vapor with HGR carbon treatment
  - As meets criteria
  - Nitrates met criteria in one case
- Water available for re-use in the facility – reduce fresh water needed - or release
  - Ph is low – need to adjust prior to release
  - Cr is high – leaching from un-passivated tubing?
- Need to complete economic assessment to show viability

# Next steps

- Complete analysis of results
- Complete TEA
  - Modify system model to include HGR Carbon addition
- Complete final report



# Acknowledgment

- This material is based on work supported by the Department of Energy Award Number DE-FE0031669.

# Disclaimer

- This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.