



**ENGINEERED
PRODUCTS GROUP**

ASME BPVC CODE-COMPLIANT HEATER DESIGN & FABRICATION USING INCONEL 740H

March 10, 2021

Matthew Hauth, P.E. – Engineering Manager

Dustin Stanley – Vice President, Operations

Daniel Washburn – Quality Control

Background & Experience

- Founded in 1987 in Tulsa, OK w/ manufacturing located in Chanute, KS.
- More than 30 years of experience in boiler & pressure vessel design and manufacturing:
 - Superheater, reheater, & economizer elements & headers
 - HRSG coils & harps
 - +170 combined cycle projects
 - +1700 pressure part modules
 - Thousands of ASME code welds
 - Carbon steel
 - Low chrome allows (1¼-Cr & 2¼-Cr)
 - 9 Chrome: T9 & T91
 - AWS G-Classified T21
 - 300-series, 400-series, & Duplex stainless steels
 - Inconel™ & Hastalloy™



Quality Assurance

- Shop Qualifications
 - ASME Section I – Power Boilers
 - ASME Section VIII, Div. 1 – Pressure Vessels
 - ASME B31.1 – Power Piping
- Quality system based in ISO 9001 elements
- CWI & Level II Inspectors
- Non-Destructive Examinations
 - Radiography (RT, X-ray), Liquid Penetrant Testing (PT), Ultrasonic Testing (UT), Magnetic Particle Testing (MT), Fluoroscopic
 - PMI
 - Helium Leak Detection
 - Hydrostatic & Pneumatic testing

Heater Coil Design


- Design Conditions:
 - MAWP = 4000-psig / 275.8 barg
 - Design Temps = 1,125°F – 1,375°F / 607.2°C – 746.1°C
- 1.5" (38.1mm) OD tubes w/ spiral wound, 304SS & 409SS welded fins
- 4", 8", 12" Pipe headers w/ Grayloc (clamp style) connections to supply/return piping
- Headers, end plates, tubes, & flanges are all 740H material
- Total # of Welds:
 - 1,296 tube-tube (butt, thin) welds
 - 288 tube-header set-on style (corner, thin-thick) welds
 - 4 header end plate (corner, thick) welds
 - 4 vent/drain set-on nozzle (corner, thin-thick) welds
 - 2 flange-header (butt, thick) welds

Heater Coil Design, cont'd

- Floating coil design to minimize thermal expansion stress in tubes and headers
- Cast tubesheets (Nickel-Chrome alloy) support coil at even intervals, allow tubes to freely slide through supports
- Welded fin parameters (height, pitch, style (solid vs. serrated) & material) used to control tube metal temperature at various sections through the coil: balance heat absorption & tube metal temperature.
- Optimus / Special Metals developed and tested continuous fin welding procedures to ensure effective bonding of stainless fin strip to 740H tube.

Header Coil – Weld Joint Examples

- Tube to Tube butt welds (thin wall)



Header Coil – Weld Joint Examples

- Tube to Header set-on style corner joint welds (thin-thick wall)



Header Coil – Weld Joint Examples

- Header End Plate set-in corner joint welds (thick wall)



Header Coil – Weld Joint Examples

- Vent/Drain Nozzle Set-on style corner welds (thin-thick wall)



Header Coil – Weld Joint Examples

- Flange to Header butt welds (thick wall)



Welding Procedures (WPS)

- Weld procedures developed in accordance with ASME Code Case 2702-3
 - Applicable version at time of order origination
- Types of Weld Procedures
 - 740H-740H
 - 740H-dissimilar (P8, P43, P45)
- Welding Process: GTAW
 - Pulsed MIG not used in coil fab
- Inert gas purge required (He-Ar mixture) of coil internal volume
 - Coil opening closures critical to establishing a complete and thoroughly purged environment

Welder Qualification Testing (PQR)

- Testing per ASME Code Case 2702-3 and all applicable reference spec's
- Destructive testing performed
- 2 welders qualified for headers welding
- 6 welders qualified for tube welding



Non-Destructive Examination (NDE) of Welded Joints

- All NDE performed in accordance with ASME Section V
- Types of NDE performed:
 - Visual: Internal root checks on tube to header & tube butt welds
 - Liquid Penetrant Testing (PT) on finished welds
 - Radiograph Testing (RT) of all butt welds
 - Phased Array Ultrasonic Testing (PAUT) of all tube butt welds (supplementary test to RT)



Non-Destructive Examination (NDE) of Welded Joints

- Hydrostatic test per ASME Section I
 - Test performed after coil completion
 - Minimum test pressure = $1.5 \times \text{MAWP} = 6000 \text{ psig}$
 - Alternate test pressure = 7,299 psig
 - Pressure calculated to simulated equivalent stress ratios on material at test temperature (ambient) vs. operating temperatures

Heat Treatment during Fabrication

- Requirements per Code Case 2702 – “all material must be supplied in solution heat treated and aged condition”
- After cold-forming strains exceed 5%, solution annealing must be performed to entire parts (tube bends)
- Material may only be welded in aged condition.
- Tubes to be finned were delivered in aged condition
- Tubes to be cut up for bends and header pipe were delivered in solution annealed condition
 - Reduces strain and wear on cutting, bending, and drilling operations to cold work tubes and drill headers in non-aged condition
 - Following tube bending and header drilling, tubes were re-annealed and aged. Headers did not required re-annealing, just aging.
- Once all components had been heat treated to aged condition, coil welding assembly could begin
- After completion of all 740H coil welding, entire coil needed PWHT
 - *See pictures on following slide*

740H Completed Coil PWHT

- PWHT performed per Code Case 2702
- 1,400°F – 1,500°F (760°C – 815°C)
- Min. 4 hour soak up to 2 inch (50 mm) thickness
 - Add 1-hour per add'l 1 inch (25 mm) of thickness



Linear Indications (Cracks) in 740H Production Welds

- Following PWHT, several tube welds were found to contain small cracks
- PT, air test w/ soap bubbles, RT used to confirm crack locations
- Repairs to cracked welds made per developed procedure (see next slide)
- Cracks could not simply be ground out and remade as per typical with carbon or stainless steels due to tube ID contaminants



Weld Repair Procedure

- Following PWHT, several cracks in tube butt welds were discovered
- Repair procedure developed per following:
 - Cut tube on either side of bad weld (allows for tube ID cleaning) & prep tube ends
 - Weld new tube “pup” piece in per applicable WPS
 - PT/RT new welds
 - PWHT new welds per Code Case 2702 (local PWHT acceptable in this instance)
 - PT/RT welds following PWHT

Challenges with 740H Fabrication

- Material toughness (cutting, drilling, bending)
- Welder qualification
- Intricate welding & inter-pass cleaning procedure
- Delayed cracking in thin-walled tube butt welds

Success with Inconel 740H Fabrication

- 1st large scale application of an age hardenability alloy in a pressure vessel/heater in the world
- Demonstration of large-scale manual welding of Inconel 740H in compliance with ASME Boiler & Pressure Vessel Code
 - Successful welder qualification testing of multiple ASME Code welders
 - More than 1,600 ASME BPVC code compliant welds made and inspected
 - **ZERO** inspection or cracking issues with thick-walled welds (4 end plates and 2 flanges to headers)
 - **ZERO** inspection or cracking issues with thin/thick-walled tube/nozzle to header welds (292 welds)
 - **ZERO** inspection or cracking issues with dissimilar metal welds, i.e. 740H to 347H stainless (4 welds)
 - Delayed/Post-PWHT cracking accounts for only **3%** of all tube butt welds made (39/1312 welds)