Integration of Energy Storage in Fossil Energy Power Plants (ES-FE) Market Analysis



Ivonne Peña-Cabra, Ph.D. NETL support contractor



Overview



Energy Storage and Fossil Energy Power Plants







- Impact
 - Informs stakeholders of benefits of storage-enhanced flexible FE power plants
 - Enables plant power operators to understand market opportunities
 - Prepares groundwork for better market rules for hybrid assets in the power system
- Regions
 - PHASE I Mid-Continent (MISO) and Electric Reliability Council of Texas (ERCOT)
 - PHASE II California Independent System Operator (CAISO), and Pennsylvania, Jersey, Maryland Power Pool (PJM)



- Description
 - ES coupled with FE is important as it can provide operational benefits to the power plant generator and can be valuable to the whole system
 - Short-term storage: Added flexibility
 - Long-term storage: Contributes to maintaining system's reliability
 - Potential revenues streams should be evaluated from Ancillary Services, Wholesale Electricity, and Capacity Markets by pairing ES with FE
 - Revenues depend on market and policy conditions in PJM and CAISO





Themes Service Market rules for interconnection and participation in **Additional Revenue** the capacity, electricity and Ancillary Services markets. Reduce or avoid tear/wear costs, potentially extending the power plant lifetime and reducing emissions **Avoided Costs** through smoother operation -Re-purposing power plants as storage assets -Incentives and state and federal policies and targets that are beneficial to ES investment Other Opportunities -Identification of additional services and revenue streams coming from other markets, creating favorable conditions for ES-FE concepts (e.g. production or storage of hydrogen)

How can ES favor FE power plants in the short and medium term?



Approach



Step 1. Select Region Region selection based on six criteria	Step 2. Create ES-FE Database On-ground and new/upcoming ES-FE configurations	Step 3. Quantify Opportunities Comprehensive analysis of each region using policy, regulatory, and market characteristics	Step 4. Identify Other Opportunities for ES-F
C1. Considerable current fossil generation C2. Presence of such technology that supports ES-FE pairings soon (5 years)	Update of on-ground projects list	Perform revenue analysis of wholesale electricity, capacity and AS markets	Describe repurposing opportunities
C3. Extent of measures supporting storage	Include awarded		
C4. Presence of variable renewable energy (VRE)-balancing	concepts under FOA 2332	Identify policy and	Describe market conditions that favor
C5. Existence of H ₂ market	Describe projects and technologies that are	supporting co-located and/or hybrid storage	FE-H ₂ concepts
C6. Battery-tocus current snapshot			





- Standardized dataset of ES-FE projects created from
 - Environmental Information Administration (EIA)-860/923 Data*
 - Sandia Global Energy Storage Database
 - Lawrence Berkeley National Laboratory Online Hybrid and Energy Storage Projects Dataset
 - Hitachi Energy Velocity Suite
 - Awarded concepts from NETL's Funding Opportunity Announcement (FOA) 2332
 - Potential re-purposed assets via web search
- Dataset features
 - Identifiers for associating with original dataset (plant identification [ID], generator ID, storage unit ID)
 - Plant information, i.e., plant name, location, project type (co-located/hybrid/standalone), project status, etc.
 - Plant technical details
 - For storage unit (capacity, discharge rate, technology)
 - For power plant (capacity, heat rate, efficiency, technology)
 - Storage services provided, e.g., load following, frequency regulation, arbitrage

*EIA 923 was included for Phase I





Dataset at a Glance

	On-the-Ground ES-FE Projects	Pilot Projects	Combined Generating (MW)	Combined Storage (MWh)	Max Duration (hours)	Most Common Power Tech	Most Common Storage Tech
Continental U.S.	35	32	5337.5	425.6	13.33	Petroleum Liquid, NGCT	Lithium-ion Battery
CAISO	14	5	802.3	122.8	13.33	NGCT	Lithium-ion Battery
PJM	3	8	237.9	14	8	-	Lithium-ion Battery

- 16 unique states with on the ground ES-FE projects
- 7 unique power unit technologies
- 7 unique storage unit subtypes*
- Most common pilot project storage tech: Surface storage (Hydrogen)

*Only 3 storage unit tech types (Batteries, Thermal, Electro-Mech.)



Step 2: Create ES-FE Dataset

Storage Duration for Co-located + Hybrid



In the U.S. over 5,000 MW of FE power capacity have integrated about 400 MWh of storage capacity



- 8+ hour duration
 - Massachusetts, New York, California
 - 5 storage units, 4 Li-ion, 1 Chilled water thermal storage
 - Paired with natural gas (NG) combined cycle (CC), petroleum liquids
- 4–7 hour duration
 - California, Arizona, Hawaii
 - 5 storage units, 4 Li-ion battery, 1 Chilled water thermal storage
 - Paired with NGCC, NG combustion turbine (CT), petroleum liquids, other NG
- 1–3 hour duration
 - 14 states
 - ~23 storage units, Li-ion, and 1 NG compressed air

Data from EIA 860 (2019)

Lesfer I MMaps have data only on co-located and hybrid storage, but durations are shown for standalone as well.





Analysis: Annual Revenues from Participation of ES in Different Markets

- Participation in capacity market
 - The ES component provides capacity value and the FE power plant is compensated for it
 - Applying rules that exist to single technology assets if no rules are yet enacted for hybrid assets
 - Using capacity auction clearing prices
- Participation in wholesale electricity market via price arbitrage
 - The ES component allows FE power plant to make rents out of the capacity to defer discharge
- Participation in ancillary services (AS) market
 - The ES component provides balancing services and the FE power plant is compensated for it
 - Revenue estimates for provision of one single AS throughout the year
- Value-stacking algorithm
 - Conducting both AS and price arbitrage

Base Case ES component specification:

- Storage capacity: 10 MW (ES capacity of existing ES-FE is 10–30 MW)
- Duration: 1 hour (AS are an hourly service, and arbitrage peaks also last an hour)



- **NETIONAL** ENERGY TECHNOLOGY LABORATORY

Highlights: Accrued Revenues from Existing Markets

• **Capacity provision** revenues in PJM range approximately \$5.5–60/kW-yr, depending on the area of connection, and on the effective load carrying capability (ELCC) class rating of the ES component of the ES-FE. CAISO does not have a capacity market, and the ES advantage is to release the FE from the obligation of provision of capacity availability





- PJM has a formal forward-looking capacity market to procure resource adequacy
 Capacity payment (\$/MW) = Capacity Clearing Price (\$/MW) x UCAP
- The elements of the capacity market (also called Reliability Pricing Model [RPM] auction) are
 - 1. <u>PRODUCT</u>: Capacity is procured three years before it is needed through a competitive auction
 - The product that is offered/transacted and delivered is Unforced Capacity (UCAP), the metric for capacity value
 - Traditionally, for all generation resources

UCAP = ICAP x (1-EFORd)

 After the Federal Energy Regulatory Commission (FERC) approval of PJM's revisions to Open Access Transmission Tariff and Reliability Assurance Agreement (December 2021), intermittent resources:

UCAP = Effective Nameplate Capacity x ELCC Class Rating x Performance Adjustment

- 2. <u>PRICE</u>: Locational pricing for capacity that varies to reflect limitations on the transmission system
- 3. <u>DEMAND</u>: A variable resource requirement curve, which is the demand formula used to set the price paid to market participants for capacity and the amount of capacity



NATIONAL ENERGY TECHNOLOGY LABORATORY

UCAP = Effective Nameplate Capacity x ELCC Class Rating x ELCC Resource Performance Adjustment

2024/2025 BRA ELCC Class Ratings

ELCC Class	ELCC Class Rating for 2024/2025 BRA
Onshore Wind	16%
Offshore Wind	37%
Solar Fixed Panel	36%
Solar Tracking Panel	54%
4-Hour Storage	82%
6-Hour Storage	97%
8-Hour Storage	100%
10-Hour Storage	100%
Solar Hybrid Open Loop – Storage Component	82%
Solar Hybrid Closed Loop – Storage Component	82%
Hydro Intermittent	46%
Land Gas Intermittent	60%
Hydro with Non-pumped Storage*	96%

- To develop revenue estimates, ES is considered a co-located, separate asset from the FE power plant
- Upper bound of ELCC rating of ES of ES-FE was set to 80%
- New class ratings can appear. In this case, the operator of the hybrid asset is responsible for submitting information to PJM to accredit its ELCC Class Rating
 - Lower bound of ELCC rating of ES of ES-FE was set to 30% for potential hybrid ES-FE (conservative)

*PJM performs an ELCC analysis for each individual unit in this class. The value shown is a representative value provided for informational purposes; data from PJM, (2021) "2024/2025 BRA Effective Load Carrying Capability (ELCC) Class Ratings" https://www.pjm.com/-/media/planning/res-adeq/elcc/elcc-class-ratings-for-2024-2025.ashx



Estimates of Capacity Provision in PJM via ES-FE TECHNOLOGY

Capacity payment (\$/MW) = Capacity Clearing Price (\$/MW) x UCAP

UCAP = Effective Nameplate Capacity x ELCC Class Rating x ELCC Resource Performance Adjustment

	UCAP (per MW installed)		Capacity payment (per day, \$/MW)		Capacity payment (annual, \$/MW)		
LDA/External Source Zone	UCAP (/MW-installed), lower bound*	UCAP (/MW-installed), upper bound*	Lower bound, Annual Revenues (\$/MW-day)	Upper bound, Annual Revenues (\$/MW-day)	Lower bound, Annual Revenues (\$/MW-yr)	Upper bound, Annual Revenues (\$/MW-yr)	
RTO	0.3	0.8	\$15.0	\$112.0	\$5,475	\$40,880	
MAAC	0.3	0.8	28.7	112.0	10,489	40,880	
EMAAC	0.3	0.8	29.4	132.6	10,716	48,393	
WMAAC	0.3	0.8	28.7	112.0	10,489	40,880	
PS	0.3	0.8	29.4	163.4	10,716	<mark>\$59,653</mark>	
NORTH	0.3	0.8	29.4	163.4	10,716	59,653	
оотн	0.3	0.8	29.4	132.6	10,716	48,393	
PCO	0.3	0.8	28.7	112.0	10,489	40,880	
ATSI	0.3	0.8	15.0	137.1	5,475	50,028	
ATSI- EVELAND	0.3	0.8	15.0	137.1	5,475	50,028	
OMED	0.3	0.8	20.7	156.4	7,551	57,101	
BGE	0.3	0.8	38.0	160.2	13,852	58,488	
PL	0.3	0.8	28.7	112.0	10,489	40,880	
AYTON	0.3	0.8	15.0	112.0	<mark>\$ 5,475</mark>	40,880	
DEOK	0.3	0.8	21.5	112.0	7,850	40,880	





Analysis: Annual Revenues from Participation of ES in Different Markets

- Participation in capacity market
 - The ES component provides capacity value and the FE power plant is compensated for it
 - Applying rules that exist to single technology assets if no rules are yet enacted for hybrid assets
 - Using capacity auction clearing prices
- Participation in wholesale electricity market via price arbitrage
 - The ES component allows FE power plant to make rents out of the capacity to defer discharge
- Participation in AS market
 - The ES component provides balancing services and FE power plant is compensated for it
 - Revenue estimates for provision of one single AS throughout the year
- Value-stacking algorithm
 - Conducting both AS and price arbitrage

Base Case ES component specification:

- Storage capacity: 10 MW (ES capacity of existing ES-FE is 10–30 MW)
- Duration: 1 hour (AS are an hourly service, and arbitrage peaks also last an hour)



NE NE IECHNOLO LABORATO

Highlights: Accrued Revenues from Existing Markets

 Participation in the wholesale market and AS markets provide, at most, annual revenue streams of ~\$74/kW for PJM (coming from provision of regulation services) and ~\$54/kW for CAISO (coming from price arbitrage)



Price Arbitrage (PA)-Only: Base Case Results for ES of 2-Hour Duration



U.S. DEPARTMENT OF

=:(c)



- Revenues vary by month and year. PJM has more steady revenues than CAISO
- Annual ranges for CAISO: \$31–44/kW and PJM: \$16–28/kW in base case
- Average values for CAISO: \$36/kW and PJM: \$22/kW in base case

Data sources: Hitachi Energy Velocity Suite for PJM and S&P Capital IQ Pro for CAISO (averaged across NP15, SP15, ZP26)



NATIONAL

TECHNOLOGY

Value Stacking (PA + AS): Results



- Comparing revenues
 - Stacking revenue ranges
 \$5–65/kW in PJM and \$10– 54/kW in CAISO*

IATIONAL

TECHNOLOGY

- Both regions have comparable revenues under current model setup and data availability
- Arbitrage + Regulation is most profitable in PJM
- Stacking revenues in CAISO are driven entirely by arbitrage*

*Based on Velocity Suite hourly price data for CAISO AS.



Technology Lifetimes

NATIONAL ENERGY TECHNOLOGY LABORATORY

How Often to Operate the ES Component for the Three Use-Cases



Lifetime data from PNNL's Storage Database



Technology Lifetimes



How Often to Operate the ES Component for the Three Use-Cases (cont'd)





Highlights



- To some extent, FE power generators can monetize short duration storage (SDS) technologies additions via the traditional electricity market mechanisms. However, costs can be as high as 2x to 10x higher than expected revenues
 - PJM's max: approx. \$5.5-60/kW (capacity) + \$74/kW (wholesale/AS)
 - CAISO's max: \$54/kW (wholesale/AS)
 - Annualized TOC: \$113-760/kW (2-hr storage technologies)
- The revenue gap, the difference between annual costs and annual revenues, is still significant for the SDS use cases. Li-ion batteries and redox flow batteries are the two technologies with the lowest gap between annual revenues and annual costs, when considering price arbitrage and AS provision
 - Even under conservative assumptions: no consideration of impacts of supply chain challenges in costs of the technologies, perfect market information, 100% roundtrip efficiency



Technology Overnight Costs

Annualized Costs Depend on Lifetime





Costs of 2-hour duration storage technologies



Comparing PJM Annualized Revenues to Costs



Annualized Revenues for Three Use Cases Are Not Sufficient to Cover Costs



- When the three use cases PA-only, AS-only, and stacking are compared against costs of ES technologies, none of these justify the investment
- The longer life-time of Vanadium Redox (up to 15 years) compared to the other technologies, is a comparative advantage, and results in a smaller revenue-costs gap



Comparing CAISO Annualized Revenues to Costs



Annualized Revenues for Three Use Cases Are Not Sufficient to Cover Costs



- When the three use cases PA-only, AS-only, and stacking are compared against costs of ES technologies, none of these justify the investment
- The longer life-time of Vanadium Redox (up to 15 years) compared to the other technologies, is a comparative advantage, and results in a smaller revenue-costs gap



Disclaimer

NATIONAL ENERGY TECHNOLOGY LABORATORY

This project was funded by the United States Department of Energy, National Energy Technology Laboratory, in part, through a site support contract. Neither the United States Government nor any agency thereof, nor any of their employees, nor the support contractor, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.



Thank You

VISIT US AT: www.NETL.DOE.gov





CONTACT: Eric Shuster Eric.Shuster@netl.doe.gov





Step 2: Create ES-FE Dataset

Storage Duration for Co-located + Hybrid

Storage Duration by Tech Type





- 8+ hour duration
 - Massachusetts, New York, California
 - 5 storage units, 4 Li-ion, 1 thermal storage
 - Paired with NGCC petroleum liquids
- 4–7 hour duration
 - California, Arizona, Hawaii
 - 5 storage units, 4 Li-ion battery, 1 thermal (University of Arizona)
 - Paired with NGCC, NGCT) petroleum liquids, other NG
- 1–3 hour duration
 - 14 states
 - ~23 storage units, Li-ion, and 1 NG compressed air

Data from EIA 860 (2019) Maps have data only on co-located and hybrid storage, but durations are shown for standalone as well



Capacity Provision in PJM

13:(4)

NATIONAL ENERGY TECHNOLOGY LABORATORY

Capacity payment (\$/MW) = Capacity Clearing Price (\$/MW) x UCAP



- Base residual auction (BRA) results shown are for auctions that happened before new ELCC framework
- Range ~\$50–200/MWday

* RTO resources include resources from External Source Zones. **In 2021/2022 BRA, system's marginal clearing prices was \$140/MW-day. The difference corresponds to the locational price adder

***In 2022/2023 BRA, system's marginal clearing price was \$50/MW-day. The difference corresponds to the locational price adder

Data from PJM, (2022) "Capacity Market (RPM)" https://pjm.com/markets-and-operations/rpm.aspx

Capacity Market in CAISO

- CAISO does not operate a formal capacity market
- CAISO uses a mandatory resource adequacy requirement
 - Requires that load serving entities procure 115 percent of their aggregate system load on a monthly basis
 - Each supply resource is obliged to be available
 - It is incentivized via the Resource Adequacy Availability Incentive Mechanism (RAAIM)
 - Resource adequacy (RA) resources that fail to meet the threshold are subject to a penalty, while resources that exceed the threshold may receive a payment

CAISO's reserve margin forecast







RAAIM



Penalties and payments between generators and CAISO, under RAAIM

Month and Year	Total Non-Availability	Total Availability	Flexible Average	System Average
	Charge (Penalty)	Incentive Payment	Actual Availability*	Actual Availability*
Oct 2019–Dec 2021	Cost of \$1,050,000–6,267,000	Payment of \$1,050,000–3,188,710	94–98%	91–98%

*Starting from May 2018, the ISO reports the system RA average actual availability and flexible RA average actual availability separately

- Hybrids are not required to participate adding ES to become an ES-FE hybrid makes the asset exempt of the requirement
- The monetary benefits for ES-FE could be then avoided expected penalties (charges) that apply for stand-alone FE power plants
 - No public information of how often a FE power plant is charged with penalties in RAAIM
 - ES is considered not to bring an economic value for FE power plants under the RAAIM



Contacts



NETL

- Rigel Woodside
 Rigel.Woodside@netl.doe.gov
- Erik Shuster Erik.Shuster@netl.doe.gov
- John Brewer

John.Brewer@netl.doe.gov

NETL Support Contractors

- Ivonne Peña-Cabra Ivonne.Penacabra@netl.doe.gov
- Smriti Sharma Smriti.Sharma@netl.doe.gov
- Clare Callahan
 Clare.Callahan@netl.doe.gov
- Kirtan Jani kijani@deloitte.com

