



# Net-zero power Long duration energy storage for a renewable grid

Michael Geyer, Malta Inc.  
Co-President of the Long Duration Energy Storage Council

*Thermal-Mechanical-Chemical Energy Storage Workshop  
Washington, August 3-4<sup>th</sup> 2022*





# The Long Duration Energy Storage (LDES) Council was launched at COP26



Signing of statements of intent and launch ceremony



Introduction to the Council




Networking lunch

# 50+ Leading Companies Have Joined the LDES Council to Accelerate Decarbonization




# Key Principles of the LDES Council



**The LDES Council is an independent body with its own governance structure, with the mission to accelerate energy decarbonization through the scale-up of LDES**




# In 2022, the Council will build upon 2021 insights supported by the expertise and engagement of its growing membership



# Inaugural analytical report released in November 2021

**Net-zero power:** Long duration energy storage for a renewable grid



## Findings: LDES will play a major role in net-zero power systems

Renewable penetration and LDES cost-down potential...

**60-70%**

% renewables of overall capacity for widespread LDES deployment

... leads to widescale LDES deployment and positive business cases

**1.5-2.5 TW**

Total deployed LDES by 2040

**USD 1.5-3 tr**

Total investment in LDES capex required by 2040

**~60%**

LDES cost reduction expected by 2040, driven by scale, innovation and supply chain improvements

**3-15%**

IRR range for example modelled LDES applications<sup>1</sup>


**>50%**

LDES as portion of all installed power flexibility capacity in 2040

1. Excluding potential improvement from implementing market mechanisms, regulatory adjustments, and carbon prices

# The LDES Council leverages the deep expertise of its member base to publish insights on the topic of energy flexibility

## Flagship 2021 net-zero power report (November 2021)




<https://ldescouncil.com/assets/pdf/LDES-brochure-F3-HighRes.pdf>

## A path toward full grid decarbonization with 24/7 clean power purchase agreements (May 2022)



[https://ldescouncil.com/assets/pdf/2205\\_Ides-report\\_247-ppas.pdf](https://ldescouncil.com/assets/pdf/2205_Ides-report_247-ppas.pdf)

## Policy toolbox report (June 2022)




To be published June 21, 2022

# Flexibility is critical for decarbonisation of power systems

## Adoption curve of longer flexibility durations accelerates at 60-70% RE penetration

Storage duration, hours at rated power



Source: Advanced Research Projects Agency–Energy

## RES integration leads to new system challenges



Power supply and demand not always in balance



Transmission flow changes potentially require costly and lengthy transmission upgrades



Retirement of conventional, synchronous generators creates need for new sources of grid support services, e.g., reactive power, inertia



# LDES typically offers two major value propositions

## Energy shifting



Time horizon	Role of storage	Typical solution
Intraday	Balance variable daily generation with load	8-24 hours LDES
Multiday, multiweek	Support multi-day imbalances Absorb surplus generation to avoid grid congestion	24+ hours LDES
Seasonal duration	Support during seasonal imbalances Mitigate extreme weather events	Hydrogen



## Grid services



### Grid services offered by LDES

**Inertia**

**Fast frequency response (FFR)**

**Primary/secondary/tertiary reserve**

**Reactive power/voltage control**


**Short circuit level improvement**

**System restoration/ black start**

*Note: services are technology-specific*

# Long Duration Energy Storage deployed in different contexts


## LDES unlock many different use cases



### Energy shifting



### Grid services




### Optimising transmission & distribution investment



### Firming renewable PPAs

### Supporting island grids



### Supporting industries with remote and unreliable grids

# Many technological approaches tackle the same fundamental need

## Thermal (heating/cooling)

Store energy thermally to release electricity and heat (e.g. Stirling engines, molten salt)



## Mechanical

Store gravitational potential or kinetic energy (e.g., PSH, gravity based, CAES, LAES, Liquid CO<sub>2</sub>)



## Electrochemical

Batteries of different chemistries that store electrical potential energy (e.g., air-metal, flow batteries)




## Chemical

Store energy in chemical bonds (e.g., H<sub>2</sub>, power to gas to power)



# Cost performance is expected improve sharply (-60% by 2040), boosting capacity deployment

LDES capex evolution vs. power capacity additions



## Insights

Cost reduction driven by

- Scale effects
- Technology advancements
- Increasing supply chain efficiency


# Average system duration increases over time

Global LDES TAM by year and archetype by system share

Duration of system: ■ 8-24h ■ 24+h


## GW

Cumulative installed power capacity




## TWh

Cumulative installed energy capacity



## USD bn

Cumulative capex investment



2030
























35

2040

# Significant opportunity for LDES across major power markets

Summary of bulk power modeling results in key regions

■ Before 2030 ■ 2030–40

Modeled markets	Cumulative LDES installed power capacity, GW	Cumulative LDES installed energy capacity, TWh	Average installed duration, hours	
			2030	2040
 US	 440–600	 30–40	15–20	70–75
 Europe <sup>1</sup>	 140–290	 5–20	20–30	50–60
 India	 125–250	 15–25	8–10	95–130
 Japan	 40–80	 1–5	14	35–90
 Australia	 20–40	 0.5–1	15	25
 Chile	 10–15	 0–0.5	10–15	18
 Extrapolation to RoW	 1–230 490–840	 0–5 20–40	14	63
<b>Total</b>	 1,300–2,300	 80–135	14	64


1. Europe incl. UK

Source: McKinsey Power Model






# Europe needs long duration synchronous storage




## Fullfillment of the 10% interconnection target in 2020

[https://eepublicdownloads.entsoe.eu/clean-documents/tyndp-documents/TYNDP2018/rgip\\_CSW\\_Full.pdf](https://eepublicdownloads.entsoe.eu/clean-documents/tyndp-documents/TYNDP2018/rgip_CSW_Full.pdf)



[https://cincodias.elpais.com/cincodias/2017/07/10/companias/1499700974\\_956333.html](https://cincodias.elpais.com/cincodias/2017/07/10/companias/1499700974_956333.html)

# Example Spain: 15GW new synchronous generation open in Spanish Grid



Almost 15.000MW excess capacity available for synchronous generators like Malta PHES

[https://www.ree.es/sites/default/files/01\\_ACTIVIDADES/Documentos/AccessoRed/Presentacion\\_SG\\_CG\\_10Sept20.pdf](https://www.ree.es/sites/default/files/01_ACTIVIDADES/Documentos/AccessoRed/Presentacion_SG_CG_10Sept20.pdf)

**MGES**  
(Generadores síncronos conectados sincronamente)

**MPE**  
(Generadores conectados de forma "no síncrona")

**RED ELÉCTRICA DE ESPAÑA**  
Grupo Red Eléctrica

Dirección General de Operación  
Fecha de publicación: 1 de julio de 2021

Información sobre capacidad de acceso [MW] disponible y ocupada en los nudos de la red de transporte

Nombre y tensión del nudo	Comunidad Autónoma	POSIBLE CONEXIÓN		CRITERIO DE POTENCIA DE CORTOCIRCUITO (MW)				CRITERIO ESTÁTICO				CRITERIO DINÁMICO				SITUACIÓN NUDO						CAPACIDAD DE ACCESO DISPONIBLE A LA RED DE TRANSPORTE		
		Posición en red de transporte	Posición en red de distribución	Capacidad de acceso nodal	Binutos	Margen no ocupado	Capacidad de acceso nodal	Zona con capacidad compartida a la que pertenece el nudo	Margen no ocupado	Capacidad de acceso nodal	Zona con capacidad compartida a la que pertenece el nudo	Limitación interna por configuración del nudo	Margen no ocupado	Capacidad de acceso otorgada MGES	Capacidad de acceso otorgada MPE	Capacidad de acceso admitida solicitud y pendiente resolver MGES	Capacidad de acceso admitida solicitud y pendiente resolver MPE	Capacidad no disponible MGES a la red de transporte	Capacidad no disponible MPE a la red de transporte	MOTIVO capacidad no disponible	Criterio limitante MGES	Capacidad de acceso disponible para MGES [MW]	Criterio limitante MPE	Capacidad de acceso disponible para MPE [MW]
SAUCELLE 220	Castilla y León	✓	✓	878	878	497	226	906	0	635	257	0	635	257	14	0	0	226	226	Concurso por resolución SEE	E_Nudo	0	E_Nudo	0
SAX 400	Comunidad Valenciana	✓	✓	1.595	973	2.529	1.987	803	0	803	281	0	803	281	0	542	0	281	281	Concurso por resolución SEE	D_Nudo	0	D_Nudo	0
DEGORBE 220	Comunidad Valenciana	✓	✓																		E_Nudo	0	E_Nudo	0
DEGOVA 400	Castilla y León	✓	✓																		D_Nudo	0	D_Nudo	0
SENTMENAT 400	Cataluña	✓	✓																		D_Nudo	0	D_Nudo	0
LA SERNA 220	Cataluña	✓	✓																		D_Nudo	0	D_Nudo	0
LA SERNA 400	Navarra	✓	✓																		D_Nudo	0	D_Nudo	0
LA SERNA 220	Navarra	✓	✓																		D_Nudo	0	D_Nudo	0
DES VELLES 66	Baleares	✓	✓																		WSCR	0	WSCR	0
DESQUE 220	Aragón	✓	✓																		E_Nudo	144	E_Nudo	144
SOL GASA 220	Galicia	✓	✓																		E_Nudo	0	E_Nudo	0
SOL ENPOR 220	País Vasco	✓	✓																		E_Nudo	0	E_Nudo	0
SERO 220	Asturias	✓	✓																		E_Nudo	0	E_Nudo	0
SILLEDA 400	Galicia	✓	✓																		E_Nudo	0	E_Nudo	0
SIMANCAS 220	Madrid	✓	✓																		E_Nudo	0	E_Nudo	0
SOLBES 220	Galicia	✓	✓																		E_Nudo	0	E_Nudo	0
SOLLER 66	Baleares	✓	✓																		WSCR	0	WSCR	0
SOLORZANO 400	Cantabria	✓	✓																		WSCR	0	WSCR	0
SOLORZANO 220	Cantabria	✓	✓																		WSCR	100	WSCR	100
SON MOIX 220	Baleares	✓	✓																		D_Nudo	0	D_Nudo	0
SON MOIX 66	Baleares	✓	✓																		WSCR	0	WSCR	0
SON OMS 66	Baleares	✓	✓																		E_Nudo	0	E_Nudo	0
SON OLANCHO 66	Baleares	✓	✓																		E_Nudo	0	E_Nudo	0
SON PARDO 66	Baleares	✓	✓																		E_Nudo	0	E_Nudo	0
SON REUS 220	Baleares	✓	✓																		E_Nudo	0	E_Nudo	0
SON REUS 66	Baleares	✓	✓																		E_Nudo	0	E_Nudo	0
SOTO DE RIBERA 400	Asturias	✓	✓																		E_Nudo	0	E_Nudo	0
SOTO DE RIBERA 220	Asturias	✓	✓																		WSCR	0	WSCR	0
SUBIRATIS 220	Cataluña	✓	✓																		E_Nudo	0	E_Nudo	0
SUBIRATIS 220	Galicia	✓	✓																		WSCR	424	WSCR	424
T. RETAMAR 220	Madrid	✓	✓																		E_Nudo	0	E_Nudo	0
TABARA 400	Castilla y León	✓	✓																		D_Nudo	0	D_Nudo	0
TABERNAS 400	Andalucía	✓	✓																		D_Nudo	0	D_Nudo	0
TABERNAS 220	Andalucía	✓	✓																		WSCR	0	WSCR	0
TABERNAS 220	Cataluña	✓	✓																		E_Nudo	0	E_Nudo	0
TABIELLA 220	Asturias	✓	✓																		WSCR	940	WSCR	940
TABILERO 66	Canarias	✓	✓																		D_Nudo	24	D_Nudo	24
TACORONTE 66	Canarias	✓	✓																		D_Nudo	0	D_Nudo	0
TAFALLA 220	Navarra	✓	✓																		E_Nudo	0	E_Nudo	0
TAGORO 66	Canarias	✓	✓																		E_Nudo	0	E_Nudo	0

[https://www.ree.es/sites/default/files/12\\_CLIENTES/Documentos/Capacidad\\_de\\_acceso\\_a\\_RdT\\_ED\\_1sep21.pdf](https://www.ree.es/sites/default/files/12_CLIENTES/Documentos/Capacidad_de_acceso_a_RdT_ED_1sep21.pdf)


# Spain's National Energy and Climate Plan (PNIEC)



MINISTERIO  
PARA LA TRANSICIÓN ECOLÓGICA



## 2030 RENEWABLE ELECTRICITY: 74%



**Note:** the exact breakdown of power generation will depend on the evolution of cost, deployability and performance of each technology (or combination of technologies).

- **57 GW of new RES capacity** (28,5 GW PV, 22,3 GW wind, 5 GW CSP, 0,8 GW biomass, 0,5 GW hydro).
- **6 GW of new storage** (3,5 GW pumped hydro, 2,5 GW batteries) + CSP inherent storage.
- **No new fossil capacity needed**
- **Coal phase-out by market mechanisms 2025-2029**









# Prospects for Long Duration Energy Storage in Germany

05/07/2022



# Deploying LDES would reduce power system costs, increase renewable energy utilization and reduce hydrogen consumption

Key results of modelling the use of LDES in the German power system

1	Lower power system costs		A power system with 15 GW of LDES by 2045 has a cumulated total system <b>cost advantage of around EUR 24 bn</b> (2025-2050) compared to a scenario without LDES
2	High sensitivity to H <sub>2</sub> price development		The study assumes rather low hydrogen prices, lifting the price assumption by 10% would <b>increase the economic benefit of LDES to EUR 40 bn (+ 67%)</b>
3	Higher utilization of renewable energy		LDES absorb renewable electricity by charging in hours in which renewables production exceeds demand; <b>curtailment can be reduced by up to 30%</b>
4	Lower natural gas use		LDES discharge in high price hours and thereby <b>reduce the amount of electricity generated by conventional gas plants</b> , and avoid CO <sub>2</sub> emissions
5	Less H <sub>2</sub> required in the power sector		LDES reduce the amount of power generated by H <sub>2</sub> -fuelled power plants which translates to a <b>13% decrease of H<sub>2</sub> required for the power sector until 2050</b>
6	Increasing profitability of LDES technologies		Some technologies will already become investible under optimal market conditions before 2030, and <b>profitable under indicative hurdle rates for unsupported projects by 2035</b>

# Executive Summary

A Net Zero power system by 2035 will see larger and more frequent periods with either excess or insufficient generation from renewable energy sources


This study shows that long-duration energy storage (LDES) technologies are an effective and cost-efficient way to avoid renewables curtailment, lower the amount of hydrogen required for the power sector, and reduce wholesale prices on average

While investments in LDES won't be profitable in the short term, we expect selected technologies to become profitable in the 2030s

## Executive Summary


Two power market scenarios are modelled for this study. The Baseline Scenario assumes a Net Zero power system to be achieved by 2035. The LDES Scenario is built on the same assumptions but also includes an additional **LDES capacity of up to 15 GW**. In turn, hydrogen peaker capacity buildout can be backloaded while maintaining the **same level of security of supply**.

Delta of installed capacity LDES vs. Baseline Scenario  
GW



The LDES Scenario has a **system cost advantage of around EUR 24 billion** compared to the Baseline Scenario. The cost reduction is mainly driven by savings in the wholesale market (50 bn) where discharging LDES substitute H<sub>2</sub>-fuelled power plants with very high marginal costs. Additional costs related to the roll-out of LDES assets (26 bn) are priced in.

Delta of system costs LDES vs. Baseline Scenario<sup>1</sup>  
Bn EUR (real 2021)




1) Savings in negative numbers, costs in positive numbers, 2) Annualised CAPEX of LDES investments with 4% interest rate



# The Baseline Scenario is characterised by government targets for renewables buildout and a net zero emission power sector by 2035


Installed renewable capacity - Baseline Scenario  
GW



- According to the EEG 2023 buildout targets, onshore wind and solar PV reach maximum capacities of 160 GW and 400 GW by 2040 while offshore wind buildout continues until 2045 to reach a total of 70 GW

Onshore wind Offshore wind Other RES¹ Solar

Installed flexible and baseload capacity - Baseline Scenario  
GW



- Both baseload and peaking capacities are characterised by the fuel switch in gas plants from natural gas to hydrogen
- From 2035 onwards, hydrogen CCGTs are the only main provider of baseload capacity. Flexible capacity is more diversified, consisting of hydrogen peakers, lithium-ion batteries, DSR, and emergency oil peakers


DSR Battery storage H2 peaker Peaking² Pumped storage Gas CCGT Lignite Other thermal³ Coal H2 CCGT

1) Includes hydropower and biomass, 2) includes gas OCGTs and oil peakers, 3) Including waste plants and on-site industrial thermal power plants.

# Fossil power generation is phased out by 2035 and substituted by renewables and hydrogen plants

Renewable electricity production - Baseline Scenario

TWh




- Wind offshore generation sees the largest proportional growth of all RES technologies with a more than 6-fold increase between 2025 and 2050
- Driven by the ambitious capacity expansion to 400GW, solar PV replaces wind onshore as the technology with the highest generation between 2035 and 2040

Onshore wind   Offshore wind   Other RES   Solar

Flexible and baseload production - Baseline Scenario

TWh




- The sharp decline in baseload generation between 2025 and 2035 is mainly caused by the phase out of coal and lignite capacity
- The transition from gas CCGTs and OCGTs to hydrogen CCGTs and peakers contributes to the reduction as well because the high price of hydrogen compared to natural gas reduces full load hours

Other thermal   Gas CCGT   Lignite   Hydrogen peaker  
Peaking   Coal   Hydrogen CCGT

# Additional LDES capacity allows to backload hydrogen peaker buildout without lowering security of supply

Installed capacity delta between LDES Scenario and Baseline Scenario

GW




## Capacity changes

- To optimise the system cost savings from LDES deployment, 12 GW of capacity are installed by 2035 and 15 GW by 2045
- The deployment of LDES capacity lowers the need for hydrogen fuelled peaker plants by over 4 GW in 2035 while achieving the same level of security of supply as in the Baseline Scenario
- By 2045, the level of hydrogen peaker capacity needed for an equal level of supply security is again identical to that of the Baseline Scenario due to a continued increase of the power demand
- The level of LDES capacity required to replace dispatchable hydrogen peaker capacity over the whole model horizon would not be the most cost efficient

# Integrating LDES into the power system would lower total costs by 23.7 billion Euros until 2050

System costs delta between the LDES Scenario and the Baseline Scenario<sup>1</sup>

Bn EUR (real 2021)



## Comments


- The reduction in overall system costs is driven by the lower average wholesale power prices in the LDES Scenario compared to the Baseline Scenario
- The savings from lower power prices are partially offset by increases in investment costs related to the roll-out of LDES capacities
- Fixed OPEX for LDES have a minor contribution to the difference in system costs

■ Fixed OPEX ■ CAPEX<sup>2</sup> ■ Variable Costs

1) Savings in negative numbers, costs in positive numbers, 2) Annualised CAPEX of LDES investments with 4% interest rate

# Deploying LDES reduces power generation from gas and hydrogen power plants and limits RES curtailment

Electricity production – Difference between LDES and Baseline Scenario  
TWh



## Three main effects from the introduction of LDES to the power system

- 1 Higher renewables utilization:** LDES absorb renewable electricity by charging in hours in which renewables production exceeds demand; curtailment can be reduced by up to 30%
- 2 Lower natural gas use:** LDES discharge in high price hours and thereby reduce the amount of electricity generated by conventional gas plants as well as the CO<sub>2</sub> emissions caused in the process
- 3 Lower need for hydrogen in the power sector:** After the transition from natural gas to hydrogen, LDES lower the amount of power generated by H<sub>2</sub>-fuelled plants which translates to a **13% reduction of hydrogen use** in the power sector. This reduction **decreases Germany's H<sub>2</sub> import dependence and mitigates risks in case of H<sub>2</sub> procurement bottlenecks**


LDES discharge in high price hours and thereby reduce the amount of electricity generated by dispatchable assets, saving natural gas and hydrogen. When charging, LDES absorb renewable power generation which would otherwise be curtailed.



# Some LDES technologies will already become investible under optimal market conditions in 2030, and be fully profitable in 2035

Internal rate of returns (IRR) forecast for six selected LDES technologies and three commercial operation dates (COD)

%




1) "22h" indicates the assumed maximum storage duration in hours

## Comments

- IRR behaviour varies between technologies and is heavily dependent on the assumed date of roll-out
- Improved IRRs in 2035 for emerging technologies such as iron flow and electro-thermal are driven by assumed CAPEX cost declines
- To fully exploit the savings potential on the system cost level, rollout of LDES capacity needs to start before IRRs reach common hurdle rates for unsupported projects
- To bridge this gap and incentivise investments in LDES projects before 2035, a more favourable market environment and policy support which recognises the value and need for LDES is required

# LCOS used to compare cost competitiveness of LDES in realistic operating conditions




## Insights

LCOS is comparable to LCOE and represents a tool for cost comparison of electricity storage

LCOS depends heavily on the operations of the system but allows a like-for-like comparison

# LDES likely cost-competitive for durations >6-8 hours

2030 energy storage LCOS competitiveness by duration for selected technologies (USD/MWh)




Source: LDES Council member technology benchmarking

## Insights

>8 hours duration, due to low energy capex, LDES offers lower LCOS

# LDES likely cost-competitive for discharge durations <100-150 hours


2030 energy storage LCOS competitiveness by duration for selected technologies (USD/MWh)



## Insights

Hydrogen turbines are likely competitive above 150 hours duration

# Today's power procurement through renewable PPAs still relies on fossil-based energy in many hours of the day






# 24/7 clean PPAs enable investments in systems for time-matched clean power supply – typically this includes storage

## Hybrid system as technical solution for 24/7 clean PPA

### Renewables generation

Often Solar and Wind, i.e., non-dispatchable generation



### Energy storage

Dispatchable energy storage enables supply when there is no direct renewable generation


### Off-taker

Procuring clean power on a granular time basis through 24/7 clean PPA backed by renewables and storage

## Time-matched clean supply

### Storage enables matching of clean power supply and demand


Clean power that is supplied for each unit of demand, measured at granular time intervals (e.g., 1 hour or less)



# Today, cost for 100% clean supply-demand matching often perceived as prohibitively expensive – LDES can help overcome this barrier

## RES + Storage LCOE for different levels of clean supply-demand matching, 2025

LCOE, USD/MWh




# Total market size for LDES can reach a 1.5 to 2.5 TW by 2040, supporting the required flexibility in net-zero power systems

Global LDES deployment through 2040

## GW

Cumulative installed power capacity



## TWh

Cumulative installed energy capacity



## USD bn

Cumulative capex investment




## Insights

USD ~50bn investments required over the next 5 years

2040 cumulative investment equal to the current global T&D investment made every 2-4 years

# Ways to engage with the LDES Council

## Download the full report



*Net-zero power systems: long duration energy storage for a renewable grid*

[www.ldescouncil.com](https://www.ldescouncil.com)

## Explore becoming a member / partner

### For the LDES Council

- Visit <https://www.ldescouncil.com/members>
- Reach out via email: [info@ldescouncil.com](mailto:info@ldescouncil.com)

## Visit our websites and follow us on social media



[www.ldescouncil.com](https://www.ldescouncil.com)



/LDES-Council



@LDESCouncil