

## Safeguarding Amines from Oxidation by Enabling Technologies

## DOE Contractors Meeting DE-FE0031861

Fred Closmann, Ph.D., The University of Texas at Austin

2023 Carbon Management Research Project Review Meeting August 28 – September 1, 2023



# Outline

- Project objectives and approach
- Project budget, structure, and performance dates
- Solvent oxidation sources
- NCCC pilot oxidation data (2023); focus on mitigation methods
- Conclusions



## Project objectives and approach

Develop technologies to mitigate oxidation of amines due to presence of  $O_2$  and  $NO_2$  in flue gas.

- Test solvent oxidation mitigation methods in lab
- Test promising oxidation mitigation technologies at UT Austin SRP (0.1  $MW_e$ ) Completed April 2022
- Test oxidation mitigation technologies at larger scale at National Carbon Capture Center, Wilsonville, AL (1 MW<sub>e</sub>) - Ongoing
- Perform economic analysis of oxidation mitigation strategies



## **Performance dates**

<b>Budget Period</b>	Start Date	End Date
1	March 1, 2020	May 31, 2021
2	June 1, 2021	April 30, 2022
3	May 1, 2022	March 31, 2024



## **Project budget (DE-FE0031861)**

Description	BP1 (\$)	BP2 (\$)	BP3 (\$)
Salaries (PI/staff/grad students/SRP)	342,316	416,116	278,123
Fringe	95,361	118,687	91,036
Travel	7,016	9,601	23,498
Equipment	230,100	5,000	102,657
Supplies	54,450	74,153	73,801
Tuition	38,658	39,435	40,260
Indirect/Overhead (56.5%)	282,015	349,766	263,549
Total by BP	1,049,915	1,012,759	872,924
Total cumulative	1,049,915	2,062,674	2,935,598
Total cost share	209,983	202,552	174,585



# Three oxidation mechanisms of interest































# **NCCC** campaign overview



## SRP and NCCC pilot plants

Parameter	SRP (UT Austin)	NCCC (Southern Co.)
Size equivalent (MW <sub>eq</sub> )	0.1	1.0
Solvent inventory (gal)	~350(a)	1500(b)
Abs diameter (inches)	16.8	25.3
Abs packing height (feet)	20	40
Abs sump $oldsymbol{ au}$ (min)	15(c)	6(d)
Flue gas source	Synthetic	Commercial - nat gas boiler or coal
Flue gas rate (Ib/hr)	3,000	8,000
CO <sub>2</sub> capture rate (MT/d)	1.5	6
Flue gas (NO <sub>2</sub> ) ppm	0 (added 1 ppm)	2.5 (nat gas boiler)

(a) Lean amine tank bypassed; (b) includes carbon bed loop; (c) at L = 4 gpm; (d) calc at L ~ 16 gpm (~3.5 gpm/ft<sup>2</sup>) & 3.5 ft liquid height.



# Gas phase monitoring data (2023)



## Gas phase monitoring points





## Flue gas monitoring data (FTIR)







The University of Texas at Austin

McKetta Department

of Chemical Engineering Cockrell School of Engineering



#### Flue gas monitoring data (PTR-TOF-MS)

#### Outlet to water wash (all data ppbv)

Date	Water wash Operation	NH <sub>3</sub>	PZ	Acetaldehyde		
7/21	Conventional	8,300 (6,600)	100 (180)	30 (2,670)		
7/31	Trickle bed + WWC	4,200	0.2	22		
8/7	Bed 3 + acid wash	165	0.1	45		

Data in () measured with FTIR.



#### Outlet to water wash (all data ppbv)

Date	Water wash Operation	NH <sub>3</sub>	PZ	Acetaldehyde		
7/21	Conventional	8,300 (6,600)	100 (180)	30 (2,670)		
7/31	Trickle bed + WWC	4,200	0.2	22		
8/7	Bed 3 + acid wash	165	0.1	45		

Data in () measured with FTIR.

- FTIR measuring NH<sub>3</sub> similar to TOF
- Other compounds interfere w/ FTIR measurement of acetaldehyde
- Acid wash reduced NH<sub>3</sub> by 95%



# **Degradation data (2023)**



## MNPZ by HPLC at NCCC (2023)





## MNPZ by HPLC at NCCC (2023)







The University of Texas at Austin

McKetta Department

of Chemical Engineering Cockrell School of Engineering



# **Dissolved oxygen stripping**

# **DO** measurements



The University of Texas at Austin

McKetta Department

of Chemical Engineering Cockrell School of Engineering









# Conclusions

- EDA is degradation product at greatest concentration (50 mmol/kg); decreasing with no mitigation (EDA oxidizes 5-10X faster than PZ; 2010)
- NO<sub>2</sub> prescrubbing
  - effective at reducing MNPZ accumulation
  - observed increase in all degradation products with prescrubbing offline
  - NO<sub>2</sub> absorbed/MNPZ formed ~ 4/1; observed 1/1 at SRP; carbon bed online at NCCC
- DO measurements
  - >95% DO consumption in abs + rich amine late in campaign degradation products oxidized
  - carbon bed added ~20 minutes to rich amine  $\tau$  DO near complete consumption before reaching heat exchangers/stripper (<0.03 mg/L)
  - N<sub>2</sub> sparging at 0.5 SCFM reduced DO better than 1 4 SCFM → design to reduce N<sub>2</sub> gas velocity to
    <25 fpm</li>
- Gas phase measurements
  - single stage water wash effective at controlling PZ (0.2 ppb) but not NH<sub>3</sub>
  - bed 3 + acid wash decreased  $NH_3$  by 95% (>8,000 ppb to <200 ppb)
- Overall PZ make-up rate ~0.48 kg/MT CO<sub>2</sub>

The University of Texas at Austin McKetta Department of Chemical Engineering Cockrell School of Engineering

## **Project participants**

Party	Person	Role
NETL	Krista Hill	Project Manager
UT-Austin	Dr. Gary Rochelle Dr. Fred Closmann	Principal Investigator Project Manager
GRAs	Chih-I Chen Ariel Plantz Miguel Abreu Athreya Suresh Ben Drewry	HGF - NO <sub>2</sub> studies Iron studies Pilot support Pilot support Flue gas stream measurements
SRP Staff	Dr. Frank Seibert JR Campos	Director SRP Operations technician
Honeywell	Carl Stevens Nathan Lozanoski Jeff Tyska	Technology development
NCCC	NCCC Team	Pilot implementation

Additional funding for NCCC pilot campaign: ExxonMobil, LAUNCH, Honeywell, and the Texas Carbon Management Program (UT).



# **Questions?**



## Solvent make-up rates

Solvent	Rate (kg/MT CO <sub>2</sub> )	Flue gas	CO <sub>2</sub> (%)	O <sub>2</sub> (%)	NO <sub>x</sub> /NO <sub>2</sub>	Facility	Author
CASTOR1, CASTOR 2	1.4	coal	12	NA	<65 ppm NO <sub>x</sub>	Esbjergvaerket, Denmark	Knudsen, 2009
CESAR1	0.45	coal (lignite)	15.2	5	6-8 ppm NO <sub>2</sub> , 100-160 ppm NO <sub>x</sub>	Niederaussem	Moser, 2022
CDRMax	0.15-0.2	CHP	3.7	14.9	11.3 NO <sub>x</sub>	TCM, Norway	Hall, personal comm. , 2023
MEA	0.8-1.6	CHP (NGCC)	3.6-4	13-14	<5 ppmv NO <sub>x</sub>	ТСМ	Morken, 2019
PZASTM	0.3/0.75	NGCC	4	12-14	<1 ppm	NCCC, Wilsonville, AL	Wu, 2021
<b>PZAS™</b>	0.6	synth NGCC	4	20	1 ppm	SRP, UT	Closmann, 2022
*PZAS™	0.48	NGCC	4	8	2.5 ppm	NCCC, Wilsonville, AL	UT, 2023

\*Based on PZ reduction in inventory over entire campaign.



#### UV-Vis absorbance at NCCC (2023)





#### Degradation products by cation IC at NCCC (2023)





- NGCC flue gas (4% CO<sub>2</sub>, 8% H<sub>2</sub>O) at ~110 °C from gas boiler
- Prescrub NO<sub>2</sub> to  $\leq$ 1 ppm with thiosulfate/sulfite
- Test N<sub>2</sub> sparging in absorber sump for DO removal
- Test carbon bed at slipstream rate of ~30 gpm
- Test acid wash for NH<sub>3</sub> control
- Bottom packed section pump-around intercooling

