

# GEN2NAS Solvents for CO<sub>2</sub> Capture from NGCC Plants

Technology Advancement & Commercialization Division, RTI International

Jak Tanthana

**DE-FE0032218**

2023 Carbon Management Research Project Review Meeting

August 28 – September 1, 2023

## Acknowledgement

This material is based upon work supported by the Department of Energy under Award Number DE-FE0032218.

## Disclaimer

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

## Objective:

Develop a novel GEN2NAS solvent that lower the cost of CO<sub>2</sub> capture at NGCC plants by 40% by solvent formulation and process configuration optimization.


## Key Metrics

- >97% capture rate
- SRD: 2.1-2.5 GJ/ton-CO<sub>2</sub>
- Low vapor pressure, < 0.05 kPa (MEA's)
- Technoeconomic and Environmental Health, and Safety (EHS) evaluation

## Specific Challenges

- Solvent scale-up
- Formulation optimization
- Process configuration

**Timeframe:** 04/01/23 - 09/30/24



	Federal	Cost Share	Total Costs
<b>Total</b>	<b>\$1,000,000</b>	<b>\$250,000</b>	<b>\$1,250,000</b>



**Lab-Scale Development & Evaluation (2010-2013)**  
Solvent screening and lab-scale evaluation  
0.0015 t-CO<sub>2</sub>/day (0.08 kW)



**GEN2NAS Lab-Scale Development & Evaluation (2023-2024)**  
Solvent screening and lab-scale evaluation  
0.0005 t-CO<sub>2</sub>/day (0.05 kW)



**Large Bench-Scale System (RTI, 2014-2016)**  
Demonstration of key process features and  $\leq 2.3$  GJ/t CO<sub>2</sub>  
0.11 t-CO<sub>2</sub>/day (6 kW)



**FLECCS Phase 1 – Dynamic CO<sub>2</sub> Capture (2021-2022)**  
Process intensification to enable flexible capture, reduce capital expense  
0.05 t-CO<sub>2</sub>/day (10 kW)



**Large Bench-Scale System (RTI, 2021)**  
Demonstration of key process features, handling of particulates, capture performance and energy usage  
0.02 t-CO<sub>2</sub>/day



**Pilot Testing at SSTU (NCCC, 2018)**  
Degradation, emission, and corrosion characterizations under real flue gas  
1.1 t-CO<sub>2</sub>/day (60 kW)



**FLECCS Phase 2 – Dynamic CO<sub>2</sub> Capture (2023-2025)**  
Process intensification to enable flexible capture, reduce capital expense  
100 t-CO<sub>2</sub>/day (10 MW)



**Process Intensified Pilot Testing for Cement Flue Gas (Texas, 2021-2024)**  
Process intensified absorbers to reduce CAPEX from cement flue gas capture  
1 t-CO<sub>2</sub>/day



**Engineering-Scale Validation at TCM (Norway, 2018-2022)**  
Pre-commercial demonstration  
AACE class 3 FEED study  
220 t-CO<sub>2</sub>/day (12 MW)



**Carbon Capture Plant FEED Study for Cement Plant (Texas, 2023-2024)**  
Full-scale FEED study with AACE class 3 for CEMEX's Balcones plant  
4000 t-CO<sub>2</sub>/day




## Key Technical Advantages

- CO<sub>2</sub> Capture Technology with substantially reduced energy consumption
- Minimum changes to existing process to realize NAS optimal performance
- Commodity-scale production ready

## Technology Status

- Completed technology demonstration at 12 MW Technology of Mongstad (TCM)
- Signed licensing agreement with SLB to accelerate the industrialization and scale-up of NAS technology



RTI evaluates wide range of low-cost, commercially-produced amines with the following characteristics:



- Low water solubility
- Low heat of absorption
- High working capacity
- Low regeneration temperature
- Low specific heat capacity
- Low heat of vaporization
- Low corrosion

## Areas for Improvement

- Amine emissions
- Simplified and intensified process configuration

## Lower the cost of CO<sub>2</sub> capture by:

- Solvent formulation – low water content, increase  $X_{solv}$
- Simplified gas polishing section - removing second wash and amine recovery unit
- Replace absorber with Rotating Packed-Bed (RPB)
- Replace Stripper with flash tanks



# Comparison of Cost and Performance against DOE Reference Cases

	B31A	B31B	RTI-Gen2NAS	RTI-Gen2NAS w/HP regeneration
CO <sub>2</sub> Capture Technology		Cansolv	Gen 2 NAS	Gen 2 NAS
Parasitic Energy Penalty, GJ/t-CO <sub>2</sub>		2.9	2.4	2.40
Solvent Regen Pressure (bar)		2.0	2	4.4
Combustion Turbine Power, MWe	477	477	477	477
Steam Turbine Power, MWe	263	213	222	222
<b>Total Gross Power, MWe</b>	<b>740</b>	<b>690</b>	<b>699</b>	<b>699</b>
CO <sub>2</sub> Capture/Removal Auxiliaries, kWe	-	11	8	8
CO <sub>2</sub> Compression, kWe	-	17	17	14
Balance of Plant, kWe	14	16	16	16
<b>Total Auxiliaries, MWe</b>	<b>14</b>	<b>44</b>	<b>42</b>	<b>38</b>
<b>Net Power, MWe</b>	<b>726</b>	<b>646</b>	<b>657</b>	<b>660</b>
NGCC Plant CAPEX (\$1000)	\$566,969	\$601,238	\$604,232	\$604,232
CC Plant CAPEX (\$1000)		\$619,914	\$310,529	\$310,529
Compression CAPEX (\$1000)		\$60,170	\$60,170	\$37,986
<b>TOTAL CAPEX (\$1000)</b>	<b>\$755,721</b>	<b>\$1,281,322</b>	<b>\$974,932</b>	<b>\$952,748</b>
NGCC Plant Capacity Factor	0.85	0.85	0.85	0.85
Fixed Charge Rate	0.0707	0.0707	0.0707	0.0707
TASC (\$MM)	756	1,700	1,293	1,264
FOPEX (\$MM)	19.5	41.3	31.6	31.6
VOPEX (\$MM)	10.9	31.9	23.3	23.3
FUEL (\$MM)	179.0	179.0	179.0	179.0
MWh	6,363,684	5,658,417	5,752,067	5,783,516
LCOE	\$ 43.3	\$ 70.8	\$ 60.3	\$ 59.6
<b>Cost of CO<sub>2</sub> Capture (\$/tonne-CO<sub>2</sub>)</b>	<b>\$ -</b>	<b>\$ 79.4</b>	<b>\$ 49.9</b>	<b>\$ 48.0</b>

- TEA based on NETL methodology outlined in the Baseline study
- All costs are on 2018 US\$ basis
- Natural gas-derived flue gas
- Absorber replaced with RPB
- Regenerator replaced with 2-stage flash

# Project Tasks and Outputs

Task	Task title	Start date	End date	Budget Period 1 (BP1)																	
				2023									2024								
				Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep
1.0	Project Management and Planning	04/01/23	09/30/24	█	█	█	█	█	█	█	█	█	█	█	█	█	█	█			
1.1	Project Management Plan	04/01/23	09/30/24																		
1.2	Technology Maturation Plan	04/01/23	09/30/24																		
2.0	Lab Testing of GEN2NAS	04/01/23	03/31/24	█	█	█	█	█	█	█	█	█	█								
2.1	Optimization of solvent blend	04/01/23	12/31/23																		
2.2	Lab-scale gas absorption testing of selected solvent blends	10/01/23	03/31/24																		
2.3	Characterization of pure solvent blend components	04/01/23	03/31/24																		
3.0	Kinetic Measurements of GEN2NAS	04/01/23	03/31/24	█	█	█	█	█	█	█	█	█	█								
4.0	RPB Testing	01/01/24	09/30/24									█	█	█	█	█	█	█			
4.1	Capture efficiency and Specific Reboiler Duty (SRD) measurements	01/01/24	06/30/24																		
4.2	Oxidative degradation measurements	04/01/24	09/30/24																		
5.0	Technoeconomic Assessment and Technology Maturation Plan Update	01/01/24	09/30/24									█	█	█	█	█	█	█			
<b>Milestone Log</b>		<i>(proposal table)</i>		A	B							C	D,E		F		G,H				
<b>Deliverables</b>		<i>(As noted)</i>	<i>(As noted)</i>	D1	D2			D10				D3	D4,D5		D6-D9		D11				
<b>Reporting</b>		<i>(See footnote.)</i>	<i>(See footnote.)</i>			Q			Q			Q		Q		Q					
<b>Project Meeting</b>		<i>(See footnote.)</i>	<i>(See footnote.)</i>	K			B										B				

Q = Quarterly report due one month after quarter's end; FR = Final report due three months after project end.


K = Project kick-off meeting; B = Project briefing (annual);

Perceived Risk	Prob-ability	Impact	Overall	Mitigation and Response Strategies
<b>Financial Risks</b>				
Cost share	Low	Moderate	Low	- RTI and Schlumberger have been approved individually by their institutions to provide the required amounts
Equipment replacement	Low	Moderate	Low	- RTI could use its capital equipment funds in FY23/FY24 to cover the cost of a replacement RPB if needed. - PNNL contract includes maintenance cost of PVT and WWC.
<b>Cost/Schedule Risk</b>				
Cost and availability of GEN2NAS components	Moderate	Moderate	Moderate	- The amine is used in the pharma industry as a precursor for an antifungal agent. - Diluent components needed for Task 2 are available commercially.
<b>Technical Risks</b>				
GEN2NAS physical properties and degradation	Low	Low	Low	- Thermal degradation is particularly sensitive to molecular structure, and the GEN2NAS amine does not contain the -OH functional group that leads to thermal degradation in alkanolamines. - The boiling point of the amine is high, indicating it should be even more stable than in previous NAS formulations - RTI has identified an antioxidant that can be used in the formulation to minimize oxidative degradation
Water management	Low	Moderate	Low	- Water balancing has now been proven for several non-aqueous formulas and is not expected to be an issue.

Perceived Risk	Prob-ability	Impact	Overall	Mitigation and Response Strategies
<b>Management, Planning, and Oversight Risks</b>				
Contractual/ performance/ intellectual property	Low	Moderate	Low	<ul style="list-style-type: none"> <li>- PNNL subcontract is being worked on</li> <li>- RTI has the ownership of the background IP.</li> <li>- SLB has also reviewed required proposal documents and does not anticipate any issues.</li> </ul>
<b>ES&amp;H Risks</b>				
Safety of GEN2NAS solvent	Low	Low	Low	<ul style="list-style-type: none"> <li>- GEN2NAS is formulated with components used in pharma that are deemed safe in their application to humans.</li> </ul>
<b>External Factor Risk</b>				
COVID-19 impacts	Moderate	Moderate	Moderate	<ul style="list-style-type: none"> <li>- The United States is emerging from the COVID-19 pandemic, and restrictions are being eased. However, some uncertainty exists with respect to seasonality that we may see in 2022–2024, which could affect the test schedule.</li> </ul>


#	Success Criteria
1	GEN2NAS RPB process can remove at least 97% CO <sub>2</sub> from simulated NGCC flue gas.
2	TEA based on experimental findings indicating a cost reduction of at least 40% in the cost of CO <sub>2</sub> capture compared with DOE Case B31B rev 4.

### CO<sub>2</sub> saturation station



- 8 separate saturation stations
- 10-20 ml sample size
- Adjustable CO<sub>2</sub> content and flow rates

### Chittick apparatus



- Determine sample CO<sub>2</sub> loading
- 3-5 ml per test
- Titration method
- CO<sub>2</sub> quantified by gas volume displacement

### Thermal conductivity measurement



- 20 ml sample size
- Temperature-controlled: 10-90 C
- Gas/liquid samples
- Ambient pressure cell

### Viscometer



- cup-spindle design
- Jacketed cup for temperature control
- Ambient pressure

## Setaram Calorimeter




- Determine heat capacity, heat of absorption
- Solid/liquid samples
- 10 ml per test

## ATR-FTIR



- 1 ml sample size
- Open cell measurement
- CO<sub>2</sub>/H<sub>2</sub>O suppression built-in
- Identify functional groups
- Measure at ambient condition

## Automated HP-VLE cell




- Generate VLE at different CO<sub>2</sub> partial pressures and temperatures
- Fully automated system
- 50 cc sample size
- 6 stations with multiple fee gases (CH<sub>4</sub>, C<sub>2</sub>H<sub>6</sub>, H<sub>2</sub>S, CO<sub>2</sub>, N<sub>2</sub>)
- Up to 120 C and 1,000 psig

## Lab-scale Gas Absorption System



- Continuous capture operation
- Fully automated system
- Qualitative energy evaluation
- Emission monitoring and quantification
- 400 ml sample
- Ambient pressure operation


## Pressure/Volume/Temperature (PVT) Cell




- comprehensive measurements of vapor-liquid equilibria (PTxy), mass transfer, and rheology on a single 50 mL sample



## Wetted-Wall Column (WWC)



- Part of the PVT cell
- Kinetic data is collected with an internal mini wetted-wall contactor, where controlled adjustments of the cell volume allow for measurements of CO<sub>2</sub> flux



**Absorber**  
3" Sch. 10 SS316  
(8.5 m height)  
Mellapak 350X

Temp: 30-55° C  
Pressure: Up to 200 kPa

Gas Vel: 0.33-1.5 m/s  
L: 15-75 kg/h

~185 kg CO<sub>2</sub>/day  
60-70 L of solvent

**Regenerator**  
3" Sch. 10 SS316  
(7.1 m height)  
Mellapak 350x



Temp :Up to 150° C

Pressure: Up to 1MPa



**Conditions for Experimental Data**

- Absorber: 37-40° C
- Regenerator: 87-115° C
- Pressure: 1.5-7.5 barg
- Kettle reboiler/Flash regeneration


- Continuous operation, fully-automated
- Wide range of feed gas compositions – both simulated and real flue gases
- Capture rate, SRD, emissions, degradations




- Update preliminary TEA and TMP
- Collaboration with CCSI<sup>2</sup>
  - Computational modeling to quantify effect of solvent properties (e.g., viscosity, thermodynamics) on equipment performance
  - Implement Uncertainty Quantification (UQ) work for assessment of risk associated with scale-up of process models
  - Explore use of Sequential Design of Experiment (SDoE) strategies to aid in data collection for model and sub-model validation







Amine	Cost, \$/g
A2	0.17
A1	0.95
A5	1.35
A4	0.95



## 2-component formulation (amine + diluent)



## 3-component formulation (2 amines + diluent)



- 65 formulations (5 amines + 12 diluents) were screened based on the chemical structure, viscosity, density, cost, availability, vapor pressure)
- An amine candidate, A2, shows significantly lower vapor pressure than 1<sup>st</sup> generation NAS and MEA
- Regeneration temp. and presence of water will be tested on these candidates
- The two-component formulation containing A2 as an amine component and D9 as a diluent was chosen as a prime candidate due to its low vapor pressure, low viscosity, high working capacity
- Three-component formulations containing A2 and another amine with diluent were chosen to be further screened alongside A2+D9.
- The three-component formulation was devised as another solvent screening and optimization strategy as it could improve the CO<sub>2</sub> absorption kinetics as well as CO<sub>2</sub> loading.

## Technical

- Cost reduction of 10X is possible even at bench scale
- Appreciation of differences in Coal vs. NGCC capture which led to re-prioritizing screening criteria
- Long lead-time items could be problematic
- Toxicity and vapor pressure of chemical components can be scarce at times

## Contract

- Initiate early on to minimize delay
- First-time NL as sub-contract with certain clauses to be reviewed and negotiated

## Budget:

- High inflation and changes in cost basis in recent years

### **This project**

- Screening formulations with 4 kPa CO<sub>2</sub> and 40 C.
- Down-select solvents to 2-3 formulations
- Determine VLE, Kg' (PNNL)
- Verify performance at bench-scale system: energy input, emissions, and operability
- Update TEA

### **After this project**

- Demonstrate performance in large-bench/pilot-scale (TRL 4-5)
- Process component optimization (intensified packing absorber/RPB/ashes)
- Evaluate emission/degradation/toxicity studies
- Solvent scale-up and supply chain evaluation



- Financial support provided by DOE NETL under DE-FE0032218
- DOE Project Manager:
  - Dylan Leary
- SLB: Technical assistant/TEA/Cost-share contribution

**Thank you  
Questions?**