


# Retrofittable Advanced Combined Cycle Integration for Flexible Decarbonized Generation



#### Acknowledgment

This report was prepared by General Electric's Gas Power division with funding from the US Department of Energy, Office of Fossil Energy and Carbon Management, Carbon Capture R&D Program in collaboration with sub recipients Linde and Southern Company plus subcontractor Kiewit. This material is based upon work supported by the Department of Energy under Award Number DE-FE0032131.

#### Disclaimer

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

#### **Document Classification**

This report is a Public Document.



# **Project Team**



#### **Contributors**

General Electric Gas Power

John Sholes (Principal Investigator), Dennis Bowin, Tiffany Camp, Todd Denman, Harvey Dunning, Brian Gallagher, Patrick Gallagher, Xiaojun Gao, Parag Kulkarni, Peter Murphy, Ray Pang, Brian Whitright, Michelle York

• Linde

Dirk Jarmus, Minish Shah, Torsten Stoffregen

Southern Company

John Carroll

Kiewit

Alan Donovan, Bryan Lofgreen, Bob Slettehaugh



# Agenda



**Project Site** 

**Results Summary** 

**Lessons Learned** 

**NGCC.CCS Performance** 

EGR Detailed Design

**EGR Overview** 

CO<sub>2</sub> Capture Island (ISBL) Detailed Design

CCS Plant Integration (OSBL) Detailed Design


Plant model screenshot



### **Project Site**

#### Existing 2x1 7FA.03 (COD 2001)


- "Arrowhead" Inlets w/ Evap Coolers
- Small Duct Burners
- Natural Gas Only
- Wet Cooling Tower
- GE D650 Steam Turbine
- Existing GT "Arrowhead" Inlets







New NGCC Layout with CCS and EGR





# **Results Summary**



#### **Performance Summary**

	Current NGCC Configuration (Pre-CCS)	NGCC + CCS Configurations (Post CCS)
Net NGCC HHV Performance	551.9 MW / 6,676 Btu/kWhr	556.9 MW / 7,660 Btu/kWhr
NGCC HHV Heat Consumption	3,684 MM Btu/hr	4,266 MM Btu/hr
CCS Aux Loads		39.2 MW
CO₂ Captured		482.7 kpph (5,255 tonne/day)
CCS Reboiler Specific Heat Duty		2.7 GJ/tonne CO₂ Captured

### **Cost Summary**

	2023 USD
CCS CapEx – Total Plant Cost	\$ 1,083 MM
CCS Fixed OpEx	\$ 3.3 MM
CCS Variable OpEx	\$ 29.2 MM
Cost of CO <sub>2</sub> Captured – Excluding Transport and Storage	\$ 100.2 / tonne CO <sub>2</sub>
Levelized Cost of Electricity (LCOE) – Including Transport and Storage	\$ 86.6 / MWhr



### Results – Detailed Cost Breakdown




### **Detailed Cost Summary**

Costs in Nov 2023 \$MM USD (+30%/-20%)									
	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	
	Base	EGR	GT	CCS ISBL	CCS ISBL	CCS OSBL	CCS OSBL	CCS Initial	Total
	Mods		Mods	Capt	Comp	CW	Other	Fill	
Equipment	23.03	41.58	47.34	169.19	60.90	27.18	46.81	29.94	446.0
Piping / Ducting		10.69		133.39	38.58	7.40	29.12		219.2
Foundations		3.95	1.46	17.24	5.60	4.43	17.35		50.0
Civil / Structural		12.28	3.64	76.44	15.11	8.54	41.67		157.7
Labor and Misc.	12.40	8.09	20.39	108.45	17.46	9.16	34.33	re-en-	210.3
Sub-Total TPC	35.43	76.59	72.83	504.70	137.65	56.70	169.28	29.94	1,083.1
Contingency	1.39	9.53	2.23	100.74	27.49	11.31	39.75		192.4
<b>Total Project Cost</b>	36.82	106.03	75.06	605.44	165.14	68.01	209.03	29.94	1,295.5
<b>Total Overnight Cost</b>									1,574.6
<b>Total As-Spent Cost</b>									1,716.4



### SoCo Barry FEED Results – Lessons Learned



#### **EGR**


- Large positive value added
- Reduces steam for CCS by 8%
- Reduces oxygen/oxidation in CCS Absorber
- Large reduction in footprint and cost of CCS Absorber
- Requires Flue Gas Clean-up to limit corrosion risk to GT
- Need to test with EGR ON and OFF

#### **Steam Supply**

- All Steam Supply for CCS requirements can be satisfied by NGCC
  - New ST crossover with control valves for primary supply point
- Multiple Steam sources are required for low loads
- Requires rigorous Steam Turbine protection
- Requires plan and controls mods for CCS trip what to do with steam
   Flue Gas
- Dampers need seal air for zero leakage assurance
- Blow-out panels a strongly recommended to protect HRSG if CCS trip
- Ducting is very expensive minimize lengths if possible Cooling Water
- Requires plan for CCS trip sudden increase in NGCC CW demand
   Plant
- 7F GT has uprates that fully counters the CCS MW loss (~75MW)
- Cold start needs CCS to get steam early modify GT startup
- Controls are critical, especially feed forward for trip & rapid loading
   CCS
- Reduce number of trains to further save cost
- Limit containment area to further save cost
- Detailed constructability review early



### **NGCC** Performance



Carbon In <sup>A</sup>		Carbon Out <sup>A</sup>		
	kg/hr (lb/hr)		kg/hr (lb/hr)	
Pipeline Gas	229,044 (504,956)	Stack Gas	11,523 (25,404)	
Air (CO <sub>2</sub> )	1,416 (3,122)	CO2 Product	218,938 (482,674)	
Total	230,461 (508,078)	Total	230,461 (508,078)	

A Calculations based on an 85% capacity factor

Carbon Input to Cycle (total for 2x1 7FA plant):

Inlet Air:	Standard Ambient	Air @ 75% relative humidity
Fuel to GT's	Pipeline Natural G	as (LHV = 20866.9 Btu/lb)
	95.69%vol	Methane (CH <sub>4</sub> )
	2.14%vol	Ethane (C <sub>2</sub> H <sub>6</sub> )
	0.80%vol	Carbone Dioxide (CO <sub>2</sub> )
	0.62%vol	Propane (C <sub>3</sub> H <sub>8</sub> )
	0.29%vol	Butane (C <sub>4</sub> H <sub>10</sub> )
	0.28%vol	Nitrogen (N <sub>2</sub> )
	0.11%vol	Hexane (C <sub>6</sub> H <sub>14</sub> )
	0.07%vol	Pentane (C <sub>5</sub> H <sub>12</sub> )
	TT7':1 1000/	1 2 1

With 100% complete combustion, produces 2.73662 lb CO<sub>2</sub> per lb fuel

Air Flow to G1's	4,846,176 lb/hr	3,122 lb/hr CO <sub>2</sub>
Fuel to GT's	184,518 lb/hr fuel	504,956 lb/hr CO <sub>2</sub>
EGR Recirculation Flow (40%)	3,145,096 lb/hr	338,718 lb/hr CO <sub>2</sub>
GT Exhaust Flow	8,175,790 lb/hr	846,796 lb/hr CO <sub>2</sub>
HRSG Exhaust	8,175,790 lb/hr	846,796 lb/hr CO <sub>2</sub>
Flow to EGR (40%)	3,270,316 lb/hr	338,718 lb/hr CO <sub>2</sub>
Flow to CCS System	4,905,474 lb/hr	508,078 lb/hr CO <sub>2</sub>
Captured CO2		482,674 lb/hr CO <sub>2</sub> (95% Capture)
CCS Absorber Exhaust	4,336,276 lb/hr	25,404 lb/hr CO <sub>2</sub>

 Net CO2 inlet
 508,078 lb/hr CO2


 Net CO2 captured
 482,674 lb/hr CO2

 Net CO2 exhaust
 25,404 lb/hr CO2

Annual CO<sub>2</sub> Capture 1.6302 MM Metric tonnes/yr (based on 7446 hr/yr operation)




### EGR – Detailed Design






#### **EGR Overview**

SoCo DOE FEED: 2x1 7F, 95% capture, 40% EGR



EGR delivers \$43MM TPC cost savings (~3.3% of the TPC)

#### EGR improves NPV by ~\$80MM




EGR assessment shows ~\$80MM net NPV improvement with EGR applied



# CO<sub>2</sub> Capture Island (ISBL)


- 2 Trains (1 for each GT)
- Common loading/unloading stations
- Common Cooling Water system






# CCS Plant Integration (OSBL) Detailed Design

- 2 Trains (1 for each GT)
- Common loading/unloading stations
- Common Cooling Water system





# CCS Plant Integration (OSBL) 3-D Model





# Thank You



Questions?