

# **A High Efficiency, Modular Pre-combustion Capture System for 21<sup>st</sup> Century Power Plant Poly-generation Process (Contract No. DE-FE0031926)**



**Ambal Jayaraman, PhD  
Gokhan Alptekin, PhD  
Michael Bonnema**

**TDA Research, Inc.**

**Prepared for  
NETL Annual Review  
Meeting**

**Pittsburgh, PA**

**August 7, 2024**

**TDA Research Inc. • Golden, CO • [www.tda.com](http://www.tda.com)**

# Project Objectives



## Project Duration


**Start Date = October 1, 2020**

**End Date = September 30, 2025**

|       | DOE Share   | Cost Share | Total       |
|-------|-------------|------------|-------------|
| BP 1  | \$886,187   | \$221,547  | \$1,107,734 |
| BP 2  | \$792,419   | \$198,105  | \$990,524   |
| BP 3  | \$1,321,394 | \$330,348  | \$1651,742  |
| Total | \$3,000,000 | \$750,000  | \$3,750,000 |

- **The objective is to demonstrate techno-economic viability of a modular coal-to-energy-and-chemicals process with a focus on syngas treatment and processing**
  - A high temperature PSA adsorbent/WGS process is used for CO<sub>2</sub> removal
  - A fixed-bed TSA based sulfur removal system will be used to remove H<sub>2</sub>S
  - High temperature contaminant removal process to remove any contaminants
- **Project Tasks**
  - Design a fully-equipped slipstream test unit with 10 SCFM treatment capacity
  - Demonstrate the operation of the integrated system in achieving high CO<sub>2</sub> and contaminant removal efficiency
  - Detailed design of the integrated system
  - High fidelity process design and economic analysis


# Process Schematic



- **Warm gas removal of CO<sub>2</sub>, sulfur and contaminants improve efficiency**
- **Reducing the use of excess steam improves power cycle efficiency**
  - Lower energy consumption to raise the steam
- **Process intensification could potentially reduce the number of hardware components and cost**

# TDA's Approach – Carbon Capture

- In conventional coal-to-hydrogen or coal-to-power applications, a multi-stage WGS process with inter-stage cooling is used
  - WGS is an equilibrium-limited exothermic reaction
- Water is supplied at concentrations well above required by the reaction stoichiometry to completely shift the CO to CO<sub>2</sub>
- Excess water is also used to suppress carbon formation





## ***3-stage WGS unit as described in the DOE/NETL-2007/1281***

- In our process, the WGS catalyst is combined with a high temperature CO<sub>2</sub> adsorbent to achieve high CO conversion at low steam:carbon ratios
- Reduced water addition increases process efficiency

# TDA's Sorbent

- TDA uses a mesoporous carbon with surface functional groups that remove CO<sub>2</sub> via strong physical adsorption
  - CO<sub>2</sub>-surface interaction is strong enough to allow operation at elevated temperatures
  - Because CO<sub>2</sub> is not bonded via a covalent bond, energy input for regeneration is low
- Heat of CO<sub>2</sub> adsorption is **4.9 kcal/mol** for TDA sorbent
  - Net energy loss in sorbent regeneration is similar to Selexol; much higher IGCC efficiency can be achieved due to high temperature CO<sub>2</sub> capture
- Favorable material properties
  - Pore size is tuned to 10 to 100 Å
  - Mesopores eliminates diffusion limitations



US Patent 9,120,079, Dietz, Alptekin, Jayaraman "High Capacity Carbon Dioxide Sorbent", US 6,297,293; 6,737,445; 7,167,354  
US Pat. Appl. 61790193, Alptekin, Jayaraman, Copeland "Pre-combustion CO<sub>2</sub> Capture System Using a Regenerable Sorbent"

# Sorbent Development Work





*TDA 0.1 MW pre-combustion carbon capture unit installed at the National Carbon Capture Center*

- **0.1 MW<sub>e</sub> test in a world class IGCC plant to demonstrate full benefits of the technology**
  - Field Test #1 at NCCC (2017)
  - Field Test #2 at Sinopec Yangtzi Petrochemical Plant, Nanjing, Jiangsu Province, China (2019)
- **Full operation scheme**
  - 8 reactors and all accumulators
  - Utilize product/inert gas purges
  - H<sub>2</sub> recovery/CO<sub>2</sub> purity



*Yangtzi Petro-chemical Plant*

# Integrated WGS/CO<sub>2</sub> Capture System





- Following repurposing of the Wabash River IGCC plant and decommissioning of PSDF at NCCC, we identified Praxair R&D Center (Tonawanda, NY) as a test site
  - Integrated with OTM on natural gas
- Two test campaigns were completed at Praxair

- An overall CO conversion >98% was achieved
- By coupling the WGS with the CO<sub>2</sub> sorbent and water injection, we were able to operate the beds at 200°C but achieve the equilibrium CO conversion of a 40°C cooler bed

# Integrated WGS/CO<sub>2</sub> Field Test System


- **Regenerable sulfur sorbent skid will be upstream of the other two skids to desulfurize the syngas**
- **CO<sub>2</sub> PSA will shift the CO and selectively remove CO<sub>2</sub>**
- **CO<sub>2</sub> from the PSA will be purified using TDA's catalytic oxidation and oxygen scavenger system**





# CO<sub>2</sub> Sorbent/WGS Catalyst Multiple Cycle Tests


Breakthrough Curves  
Reactor Pressure Comparion




— 150 PSIG - 80    — 150 PSIG - 90    — 150 PSIG - 100    — 150 PSIG - 110    — 150 PSIG - 120  
 — 250 PSIG - 150    — 250 PSIG - 155    — 250 PSIG - 160    — 250 PSIG - 165    — 250 PSIG - 170  
 — 300 PSIG - 178    — 300 PSIG - 180    — 300 PSIG - 183    — 300 PSIG - 184    — 300 PSIG - 186  
 — 350 PSIG - 270    — 350 PSIG - 275    — 350 PSIG - 280    — 350 PSIG - 285    — 350 PSIG - 290  
 — 450 PSIG - 340    — 450 PSIG - 350    — 450 PSIG - 360    — 450 PSIG - 370    — 450 PSIG - 380  
 — 500 PSIG - 445    — 500 PSIG - 455    — 500 PSIG - 465    — 500 PSIG - 475    — 500 PSIG - 485

- At 500 psi, the WGS/CO<sub>2</sub> sorbent bed achieved 6.2 % wt. CO<sub>2</sub> capacity and 99% CO conversion (far exceeding our Milestone M1.1 target of 4% wt. CO<sub>2</sub> capacity at 500 psi)
- We completed over 700 adsorption/ desorption cycles with the integrated WGS/CO<sub>2</sub> capture bed
- Previously we had demonstrated life over 32,000 cycles with stable performance

CO Conversion



CO<sub>2</sub> Capacity




# CO<sub>2</sub> Sorbent/WGS Catalyst Test System

- We replaced the sorbent/WGS catalyst in all 8 beds
- Utilized a new sorbent/spring retention system to help stabilize the sorbent and prevent movement
- System was powered up and ready for testing




# Design of Regenerable Sulfur Sorbent System



- **2 bed system**
  - One is adsorbing while the other is regenerating
  - $\text{H}_2\text{S}$  is removed during adsorption by reacting with metal oxides to form metal sulfides
  - Regeneration occurs by reacting  $\text{O}_2$  with metal sulfides to form  $\text{SO}_2$
- **Electric heaters on inlet gas to achieve required adsorption and regeneration operating temperatures**
- **Deliver a constant stream of desulfurized syngas to the integrated  $\text{CO}_2/\text{WGS}$  system**


# Manufacturing and Qualification of the Regenerable Sulfur Sorbent

- Completed over 500 adsorption/regeneration cycles
- 3.0 wt% was maintained throughout the test




# Regenerable Sulfur Sorbent Test System

- Dual bed regenerable sulfur sorbent system is currently being lab tested as part of FAT
- Sulfur removal will be measured using a lead acetate tape analyzer




# Design of CO<sub>2</sub> Purification System

- CO<sub>2</sub> purification skid includes a catalytic oxidizer with a REDOX based oxygen scavenger to meet the CO<sub>2</sub> purity requirements
- Catalytic Oxidation removes hydrocarbons and other combustibles (e.g., CO, CH<sub>4</sub>, H<sub>2</sub>)
  - Operates at slightest excess stoichiometric amounts of oxygen
  - Adiabatic, multi-staged design with intercoolers for heat management
- Oxygen Scavenging system polishes excess O<sub>2</sub> to < 10 ppm
  - Regenerable mixed metal oxide based chemical looping process
  - Oxidation step captures O<sub>2</sub>; Reduction with inlet gas regenerates the sorbent
  - Oxygen sorbent will be regenerated using the H<sub>2</sub> in incoming CO<sub>2</sub>



# TDA's O<sub>2</sub> Scavenger Sorbent

- The oxygen scavenger was tested for nine cycles verifying consistent breakthrough capacity at <10 ppmv O<sub>2</sub> in the outlet
- Tested the effect of regen temperature, residence time, inlet oxygen concentration, presence of CO
- Uptake is 3.8%-w O<sub>2</sub> with a breakthrough time of 6.2 hours



| Oxygen Sorbent Design Conditions |               |
|----------------------------------|---------------|
| GHSV, 1/hr                       | 3,000 – 6,300 |
| Inlet O <sub>2</sub> , ppmv      | 1,000 – 4,000 |
| Inlet Temp, deg C                | 400 - 450     |
| Bed L/D                          | 2.7           |

# CO<sub>2</sub> Purification Test System

- System is currently being lab tested before shipment to GTI
- Trace O<sub>2</sub> in the CO<sub>2</sub> product stream will be measured using an electrochemical analyzer





# Testing Schedule

- We will be shipping the test systems in mid August to GTI in Des Plaines IL for testing using biomass derived syngas
- Testing is scheduled to start the beginning of September



# Process Design and System Analysis with Poly-generation Options

DOE Baseline  
Rev. 4 Study  
Basis

\$2018 basis

| Operating Scenario                                       | Max Power     | Mid Power     | Min Power     | Mean over<br>24 hr day |
|--|---------------|---------------|---------------|------------------------|
| Operating Scenario as Fraction of 24 hr day              | 0.25          | 0.5           | 0.25          |                        |
| Power Block Power as Fraction of Max Power               | 1.00          | 0.80          | 0.65          |                        |
| Increase in CC Heat Rate over Max Power Scenario, Factor | 0             | 0.04          | 0.1           |                        |
| <b>GROSS POWER GENERATED (AT GENERATOR TERMINALS),</b>   |               |               |               |                        |
| GAS TURBINE POWER  | 88,000        | 70,400        | 57,200        | 71,500                 |
| STEAM TURBINE POWER                                      | 66,657        | 53,326        | 43,327        | 54,159                 |
| SYNGAS EXPANDER POWER                                    | 1,644         | 1,315         | 1,069         | 1,336                  |
| CO2 VENT EXPANDER  | -             | -             | -             | -                      |
| TOTAL POWER  | 156,301       | 125,041       | 101,596       | 126,995                |
| <b>AUXILIARY LOAD SUMMARY, kW<sub>e</sub></b>            |               |               |               |                        |
| TOTAL AUXILIARIES  | 73,763        | 75,520        | 76,693        | 75,374                 |
| <b>NET POWER, kW<sub>e</sub></b>                         | <b>82,538</b> | <b>49,521</b> | <b>24,903</b> | <b>51,621</b>          |
| <b>COPRODUCT (NH<sub>3</sub>)</b>                        |               |               |               |                        |
| ST/D   | 959           | 1,096         | 1,191         | 1,085                  |
| TONNE/D  | 869           | 994           | 1,080         | 984                    |
| <b>TOTAL (ELECTRIC + COPRODUCT) ENERGY, kW</b>           |               |               |               |                        |
|  | 308,866       | 308,214       | 306,135       | 307,857                |
| <b>ELECTRICITY / COPRODUCT ENERGY RATIO</b>              |               |               |               |                        |
|  | 0.365         | 0.191         | 0.089         | 0.201                  |
| <b>NET PLANT EFFICACY, % HHV</b>                         |               |               |               |                        |
|  | 47            | 47            | 47            | 47                     |
| THERMAL INPUT, kW <sub>t</sub> HHV                       |               |               |               |                        |
|  | 652,542       | 652,542       | 652,542       | 652,542                |
| <b>CARBON CAPTURED, %</b>                                |               |               |               |                        |
|  | 95.8          | 95.8          | 95.8          | 95.8                   |

|                                  |        |      |      |      |       |       |
|----------------------------------|--------|------|------|------|-------|-------|
| Electricity Credit               | \$/MWh | 64.5 | 71.7 | 78.9 | 107.2 | 152.3 |
| NH3 RSP with CO <sub>2</sub> T&S | \$/ST  | 884  | 870  | 855  | 798   | 708   |

Cost of CO<sub>2</sub> capture including T&S is \$40.6/tonne CO<sub>2</sub>

# Acknowledgements

---

- **NETL, Project Managers, Andrew Jones, Dr. Elliot Roth, Dr. Nicole Shamitko-Klingensmith (current)**
- **Zach El Zahab, GTI**
- **Dr. Ashok Rao**

Disclaimer: "This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof."