# **Pigman** College of Engineering University of Kentucky<sub>®</sub>

Institute for Decarbonization and **Energy Advancement** at PPL R&D Center

## **DE-FE0032134, Dual-loop Solvent-based CCS for Negative CO<sub>2</sub> Emissions with Lower Cost**

## UK Dual Loop Approach for Point Source Treated Flue Gas with <100 ppm CO<sub>2</sub>



#### Building on DAC with H<sub>2</sub> Production Technology □ Inorganic, solvent-based $\Box$ Electrochemical regeneration with H<sub>2</sub> and O<sub>2</sub> production $\Box$ 7,700 kg CO<sub>2</sub>/year Demo at EW Brown

Generating Station, a PPL Corporation Facility, 350 kg H<sub>2</sub>/year, 470 W Regenerator, 2025-2026

□ DAC Hub Feasibility Study, ≥3,500 tonne  $CO_2$ /year per capture location with 160 tonne H<sub>2</sub>/year and 1040 kW regenerator







Building on Point Source Technology

- □ Solvent-independent process
- □ Engineering Scale, 15 TPD, Since 2015 at EW Brown Generating Station, a PPL Corporation Facility
- □ 3 TPD, Nucor Steel Gallatin, 2025
- □ 9.3 TPD, Vitro Architectural Glass,
- □ 215 TPD, Cane Run Generating Station (CRGS), a PPL Corporation Facility, 20230
- □ 1.7M TPY, CRGS, FEED complete 8/2025





### Bench Demonstration at 0.1 MWth Unit



 $\Box 3/1/2022$  to 11/30/2025**□**Resulting TRL 4 Existing UK CO<sub>2</sub> Capture Unit Applied and UK WLS Solvent as Primary Loop □Polishing Loop Designed, Integrated, Operational and Being Tested □Variable CO<sub>2</sub> Capture Efficiency in the Primary Loop TEA, LCA, EH&S Upcoming

## Continuous Mode Operation with Electrochemical Regenerator



#### Demonstrated Treated Flue Gas with Lower CO<sub>2</sub> Than Air

—Primary Loop Outlet CO2 Concentration (vol%) Primary Loop Inlet CO2 Concentration (vol%) -Polishing Loop Exit CO2 Concentration (ppm) — Polishing Loop Inlet CO2 Concentration (ppm)



#### Economic Benefit

	RC B31B.95	UK IDEA Dual Loop CO <sub>2</sub> Capture Process Applied to NGCC	
Combustion Turbine Power, MWe	477	471	The UKy Process operates GT at high backpressure to eliminate the flue gas boost fan
Steam Turbine Power, MWe	212	220.7	Extra 5.34 MWe from lower steam extraction to the primary loop @1020 Btu/lb CO <sub>2</sub> Captured, and extra steam produced from high thermal energy

CO <sub>2</sub> Capture/Romval Auxiliaries, KWe	14400	6500	Less BOP from elimination of DCC and associated cooling duty, as well as the elimination of boost fan
CO <sub>2</sub> Compression, kWe	18900	17090	CO <sub>2</sub> produced from electro-regenerator will be purifized and compressed separately
Balance of the Plant, kWe	16042	16372	Assume same
Electrochemical Regenerator, kWe	N/A	32301	Calculated based on $CO_2$ duty and electrolyzer efficiency
CO <sub>2</sub> Purification and Compression at Electro- generator Outlet, kWe	N/A	2907	Esimtaed for separating $CO_2$ (70%) and $O_2$ using 9% of Electrochemical Regeneration Power
H <sub>2</sub> Dehydronation and Compression, kWe	N/A	1615	Esimtaed using 5% of Electrochemical Regeneration Power
Net Power, MWe	640	615	
NGCC Plant Cost, in 1000\$	610070	610070	Same base plant
CCS Island Cost, in 1000\$	495733	311915	Reduction from UKy CCS process features
subtotal	1105803	921985	
Captial Cost per net kW	1729	1499	Total captial divided by the net power output, a 13.3% reduction
CO <sub>2</sub> Captured, kg/hr	223718	248073	10.8% increase
Hydrogen Produced, kg/hr	N/A	502	0.69 mole $H_2$ /mole $CO_2$ based on the electro-regenerator efficiency
CO <sub>2</sub> Captured from Air, tonne/hr	N/A	1.96	99.8% capture efficieny is equivilant at 82 ppm $CO_2$ from NGCC
Natural Gas Cost, in 1000\$	152160	152160	Same generating unit
Annual Operating Cost, in 1000\$	27088	27088	Assume same for simplification
Credit from Hydrogen Sale, in 1000\$	N/A	29913	$H_2$ sale price @ \$8/kg for water eletrolysis grade and 85% capacity
Credit from CO <sub>2</sub> Negative Emission, in 1000\$	N/A	1459	CO <sub>2</sub> price @ \$100/tonne and 85% capacity
Subtotal of O&M Cost. Annually	179248	147876	a 17.5% reduction



#### **Preliminary TEA**



#### Effect of H<sub>2</sub> Sales Price

#### Cost of $CO_2$ Capture (\$/tonne $CO_2$ )

\$45.3/tonne \$42.4/tonne \$39.5/tonne \$36.5/tonne \$33.6/tonne 25% Reduction from 2022 B31B.97

#### Cost of CO<sub>2</sub> Avoided (\$/tonne CO<sub>2</sub>)

\$51.4/tonne \$50.6/tonne \$47.0/tonne \$39.9/tonne \$43.5/tonne 27 % Reduction from 2022 B31B.97



# Acknowledgements

#### Mariah Young and Ron Munson, US DOE NETL



#### The work presented is funded primarily by US

#### DOE NETL under cooperative agreement DE-



#### Corporation is also gratefully acknowledged.







