



MIXED-SALT PROCESS (MSP) FOR CO₂ CAPTURE IN NGCC SYSTEMS AT $\geq 95\%$ CAPTURE:

HIGHLY EFFICIENT REGENERATION MODULE
FOR CARBON CAPTURE SYSTEMS IN
NATURAL GAS COMBINED CYCLE

Net-zero Flexible Power: High Capture Rate Project Review Meeting

PI: Indira Jayaweera, SRI

Presented by Elisabeth Perea, SRI

June 6, 2024 11:15-11:35 AM



DOE Contract # FE0032135


Outline



- MSP Background
- Project Objectives
- Technology Approach for $\geq 95\%$ Capture
- Impacts of Operating at High Capture Rate
- Challenges and R&D Needs to Maintain High Capture Rate

Current SRI Carbon Capture Project Portfolio

Funding: 80% DOE, 20% Cost-share (~10% Cash, ~10% In-kind)



PBI-membrane for Hydrogen recovery

Development and Testing of a High-Temperature PBI Hollow-Fiber Membrane Technology for Pre-Combustion CO₂ Capture. DOE-NETL: DE-FE0031633
Team - PBI Performance Products, and Enerfex




Mini-pilot: (MSP Application for NG)

Highly Efficient Regeneration Module for Carbon Capture Systems in Natural Gas Combined Cycle Applications. DOE-NETL: DE-FE0032135
Team- BH, Trimeric, and OLI Systems



Mini-pilot: Advanced Solvent

Mixed-Salt Based Transformational Solvent Technology for CO₂ Capture. DOE-NETL: DE-FE0031597
Team - OLI Systems, Technical University of Denmark, SINTEF, and BH



Engineering Demonstration of MSP at 0.5 MWe scale

Engineering-Scale Demonstration of the Mixed-Salt Process (MSP) for CO₂ Capture. DOE-NETL: DE-FE0031588
Team - BH, NCCC, Trimeric, OLI Systems, Epic Systems

CO₂ Utilization: Microbial processes for CO₂ to food



Current MSP Project Objectives



- **Demonstrate the Mixed-salt process (MSP) for capturing CO₂ from dilute sources such as natural gas (NG) power plants at 95% or better efficiency.**
- **Project scope includes:**
 - Design and fabrication of a highly efficient regeneration module capable of providing a deep-lean absorption solution.
 - Integration of the advanced stripper with the existing absorption modules of the large-bench scale MSP system.
 - Testing of the integrated system at SRI site using a simulated flue gas stream equivalent to about 10 kWe.
 - Data collection for detailed techno-economic analysis (TEA)

Mixed-Salt Process (MSP)

Process Summary

- Uses inexpensive, industrially available material (potassium and ammonium salts)
- No solvent degradation
- Has the potential for easy permitting in many localities
- Uses known process engineering
- Accelerated development possible

Demonstrated Benefits (by testing and modeling)








- Enhanced CO₂ capture efficiency
- High CO₂-loading capacity
- High-pressure release of CO₂ (10-12 bar)
- Reduced energy consumption (For 90% capture, 1.9-2.2 MJ/kg-CO₂ for PC-based applications, 2.9 MJ/kg-CO₂ for NG-based applications)

Expected Additional Benefits

- Capture from low-concentration CO₂ sources
- > 95% capture possible
- Removes common acid pollutants and particulates



K₂CO₃-NH₃-CO₂-H₂O system




Simplified Process Flow Diagram


Approach for Generating Lean Solutions for high Efficiency CO₂ Capture in NG Flue Gas



Regenerator vapor and liquid composition of selected species



Regenerator modification to include the flash-stripper



- In the modified system, partially ammonia-lean lean solvent is extracted from the bottom of the regenerator and sent through the flash-stripper to recover more ammonia for efficient absorber 1 operation.
- Potassium-rich lean solvent is directed to absorber 2.

Current Status



- We have completed parametric and steady state data collection and steam use measurements for operation at a high capture rate in the large bench system at SRI (pictured below)
- OLI Systems optimized the flowsheet model to generate a heat and mass balance (H&MB) for comparison to DOE case 31B Rev. 4.
- Trimeric is currently finalizing the techno-economic analysis (TEA)



Analytical and Control Systems




Absorbers



Regenerator

Regenerator block of the SRI large bench scale system with new flash stripper



Modeling the flash stripper performance to determine optimal operating conditions



Series 1: Pressure variation at fixed NH₃ evaporation)

Case	10-2	10-4	10-6	10-8	10-10	10-11.5
*Column Calculation Method	Equil	Equil	Equil	Equil	Equil	Equil
Regenerator Duty, MJ/KgCO ₂	1.96	1.96	1.95	1.95	1.95	1.95
NH ₃ Stripper Duty, MJ/KgCO ₂	1.02	1.02	1.01	1.01	1.01	1.01
Flash Stripper Duty, MJ/KgCO ₂	0.25	0.34	0.40	0.43	0.31	0.22
Total Duty, MJ/KgCO ₂	3.23	3.31	3.36	3.39	3.27	3.18
*Flash Stripper Pressure, atm	2	4	6	8	10	11.5
Flash Stripper Bottom T, C	96	114	126	136	142	145
*Flash Stripper Gas NH ₃ , % of Feed	10	10	10	10	10	10

Series 2: Pressure variation at fixed temperature

Case	140-4	140-6	140-8	140-10	140-11.5
*Column Calculation Method	Equil	Equil	Equil	Equil	Equil
Regenerator Duty, MJ/KgCO ₂	1.97	1.96	1.95	1.95	1.95
NH ₃ Stripper Duty, MJ/KgCO ₂	0.75	0.89	0.99	1.02	1.03
Flash Stripper Duty, MJ/KgCO ₂	1.41	0.90	0.51	0.30	0.20
Total Duty, MJ/KgCO ₂	4.13	3.75	3.44	3.27	3.18
*Flash Stripper Pressure, atm	4	6	8	10	11.5
*Flash Stripper Bottom T, C	140	140	140	140	140
Flash Stripper Gas NH ₃ , % of Feed	89	48	16	8	4

Series 3: NH₃ evaporation variation at fixed pressure

Case	10	19	29	34	39	41	43	48	58
*Column Calculation Method	Equil	Equil	Equil	Equil	Equil	Equil	Equil	Equil	Equil
Regenerator Duty, MJ/KgCO ₂	1.95	1.95	1.95	1.956	1.95	1.95	1.95	1.96	1.96
NH ₃ Stripper Duty, MJ/KgCO ₂	1.01	0.98	0.95	0.93	0.92	0.91	0.91	0.89	0.87
Flash Stripper Duty, MJ/KgCO ₂	0.22	0.22	0.21	0.21	0.22	0.22	0.23	0.25	0.30
Total Duty, MJ/KgCO ₂	3.18	3.15	3.11	3.096	3.089	3.088	3.090	3.10	3.13
*Flash Stripper Pressure, atm	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5
Flash Stripper Bottom T, C	145	151	157	160	162	163	164	166	170
*Flash Stripper Gas NH ₃ , % of Feed	10	19	29	34	39	41	43	48	58


Varied the flash stripper pressure and the % of NH₃ vaporized from the flash stripper feed stream within the process model to observe the effect on the total system reboiler duty

Parametric Testing at Large Bench Scale

Key Test Parameters

- Regenerator and Flash stripper T,P
- Flash stripper on/off
- Liquid recycle rate (L/G: 2.5 to 8 range)
- Gas flow rate (300 to 600 LPM)

95% or greater CO₂ capture rate achieved with and without a flash stripper





Run #	Total gas flow rate (LPM)	Regenerator		Flash stripper (On/Off)	Flash		CO ₂ capture % ABS 1 + ABS 2
		P (bar)	T (°C)		T (°C)	(bar)	
4	400	7.8	125 to 140	Off	NA	NA	89.8
6				On	113	3.2	95.8
8				Off	NA	NA	95.6
9				On	105	2.1	96.2
10				Off	NA	NA	96.8
11				On	114	3.3	98.1
14		Off		NA	NA	95.1	
15		On		94	1.6	96.6	
22		Off		NA	NA	96.5	
23		On		95	12	96.4	
25		Off		NA	NA	99.3	
27		On		101	2	99.7	
30		Off		NA	NA	99.1	
31		300		6.9	On	92	1.8
38	9.9		Off	NA	NA	97.3	
40	9.7		On	102	2.4	98.4	
41	9.9			97	2	95.2	
42	350	10.1	On	114	3.3	91.2	
43		9.8		96	2.8	90.2	
44	9.7	126		4.6	89.2		
45	9.7	116		3	87.8		
46	9.8	103		3.2	90.4		
47	9.7	79		1.8	92		
48	9.7	Off		NA	NA	93.4	
49	9.8			102	2.6	94.8	
50	9.7	On		111	3.7	96.3	
51*	9.7			109	3.6	95.8	
52	450		9.9	103	2.7	96.1	
53			9.8	103	2.7	96.4	
54	500		9.8	105	2.9	95.3	
55	550		10.7	102	3	94.4	
56			10	102	3	93.9	



CO₂ Capture Rate, Gas Flow Rate and Ammonia Slip



- Ammonia slip = ammonia exiting the top of Absorber 2. This ammonia is re-absorbed in the water wash and then recovered in an ammonia stripper column and recycled back to the absorbers.
- A higher ammonia slip results in a higher reboiler duty for the ammonia stripper.




- 95% - 99% CO₂ capture (for NG flue gas simulating feed streams) was easily achieved during the initial testing of the integrated system.
- Ammonia slip from Absorber 2 at 400 slpm flow rate is below 14,000 ppm for 95% CO₂ capture for 5 M (> 6 molal) alkalinity MSP solutions
- Ammonia slip from Absorber 2 at 400 slpm flow rate is around 20,000 ppm for 95-96% CO₂ capture for 6 M (>7 molal) alkalinity MSP solutions
- We selected 450 slpm for the first series of steady state testing

Steady State Operation at >95% Capture

- Flash stripper operating for these runs
- Cumulative run time to date: 280 hrs.
- Test runs 68 to 75: 450 LPM and at L/G ratio of 3.5 for steady-state testing.


95% or greater CO₂ capture rate achieved with flash stripper for ~200/280 hours




Run #	Gas Flow rate (LPM)	L/G	Regenerator conditions		Flash stripper conditions		ABS 1 + ABS 2	
			P (bar)	Bottom T(°C)	T (°C)	P (bar)		
58	600	2.5	9.7	125-140	102	2.5	91.5	
59	500	3.2			104	2.7	95.1	
60					113	3.9	94.4	
61					91	1.7	93.6	
62	450	3.5			102	2.6	96	
63					114	4.0	96.1	
64					93	1.8	96.3	
65	550	3			102	3.3	92.7	
66	500	2.5			102	2.8	96.7	
67		3.2			92	1.8	97.1	
68	450	3.5			102	2.7	96.6	
69					102	2.7	96.6	
70					101	2.7	96.5	
71					103	2.7	97.6	
72					101	2.5	98.2	
73					103	2.6	98	
74					102	2.1	99.3	
75					102	2.2	98.7	
76*	370	4.2			140-160	103	2.1	99.2
77	450	3				103	2.2	98.5
78**	360	4				102	2.1	99.6
79	450	4.5			130-140	102	3.2	98
80		3				99	2.4	97.9
81						102	3.9	90.7
82						101	4.8	90.5

*CO₂ feed concentration ~20% **CO₂ feed concentration ~ 18%

Achievement of >95% Capture at Large Bench Scale



The effect of gas flow rate and regenerator temperature on the capture rate. FS pressure range (2 to 3 bar at 103 °C)



A plot illustrating the effect of FS pressure on the capture rate at the FS operating temperature of 103°C.

- 95% - 97% CO₂ capture (for NG flue gas simulating feed streams) was easily achieved by regenerating at temperatures between 130 to 140 °C.
- >98% can be achieved by using high alkalinity solution or by increasing the regeneration temperature to 160°C.
- Identified the FS operation conditions to achieve >95%:
 - 2 to 3 bar at 103 °C / 5-6 bar 120 °C / ~11 bar at 160 °C (40% ammonia evaporation)

Result of Flowsheet Modeling for the TEA



>95% capture rate from natural gas flue gas is achievable with the Mixed-Salt Process with 3.14 MJ/kgCO₂ total reboiler duty.

Summary of conditions:

CO₂ Feed: 4%

CO₂ Capture: 95.4%

CO₂ Purity: 99.1%

Flash-Stripper: 11.5 atm

Flash-stripper T: 160 °C

Flash-Stripper NH₃ recovery: 34%

Regenerator T: 133 °C

Regenerator P: 12 atm



Total Reboiler Duty: 3.14 MJ/kg CO₂

(Energy) Cost Impact of Increased Capture Rate: Total Heat Duty vs. Capture Rate



MSP-NG-Flash Stripper: Case including the flash stripper to strip ammonia from the ammonia-rich lean stream, minimizing the ammonia stripper duty.

MSP-NG-Single Absorber: Case where there is no flash stripper and only one lean stream removed from the regenerator. This case has CAPEX benefits because only one absorber column is required.



Challenges/Benefits for High Capture Rate Operation



- Impacts of operation at higher capture rate are concentrated in the ammonia stripper.
 - Ammonia stripper reboiler duty increases with increased capture rate
 - Improvements to ammonia/water separation would be a major enabling breakthrough.
- However, the base MSP process (absorbers/regenerator) is robust and easily capable of operation at high capture rates.

Challenges/Benefits for Flexible Operation

- The response of plant operating parameters to dynamic scenarios would be necessary to fully characterize the MSP under flexible operating conditions
 - Cold and warm start-ups to assess the performance and ramp-up time of the MSP
 - Simple reboiler steam decoupling and reintroduction to assess the minimum capture rates achieved during turndown
- Promising intrinsic benefits of MSP:
 - High-pressure MSP regenerator is small and would heat up quickly
 - Solvent flow rates in the MSP can easily be adjusted and MSP has been demonstrated at a wide range of L/G ratios

Schedule for Completion



Task Name	Start	Finish
Task 6.0 – Final System Modeling and Techno-Economic Analysis (TEA)	Mon 10/2/23	Mon 9/30/24
Subtask 6.1 –Modeling and Test Data Comparison	Mon 10/2/23	Fri 5/31/24
Subtask 6.2 –Optimized CC Unit Integration with the Power Pant and TEA	Mon 10/2/23	Mon 9/30/24
TEA Preparation- on going (Trimeric)	Tue 2/6/24	Thu 6/6/24
TEA Information Review- ongoing (SRI)	Tue 2/6/24	Thu 6/13/24
TEA Review/Comments (DOE)	Fri 6/14/24	Fri 9/13/24
Final TEA Update (SRI and Trimeric)	Mon 9/16/24	Mon 9/30/24
Subtask 6.3 –Technology Maturation Plan (TMP)	Mon 7/1/24	Wed 7/31/24
<i>Final Report</i>	Mon 7/1/24	Mon 9/30/24



Disclaimer:

This presentation includes an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.



Thank you!

Contact:

Dr. Indira Jayaweera

indira.jayaweera@sri.com

1-650-859-4042