### Techno-Economic Analysis of Hydrogen Production and Compressed Air Energy Storage from Variable Renewable Energy



Troy Teel<sup>1,2</sup>, Kyle Buchheit<sup>1,2</sup>, Sandeep Pidaparti,<sup>1,2</sup>, Bob Stevens<sup>1</sup> <sup>1</sup>NETL <sup>2</sup> NETL Support Contractor





#### The Challenge

 Increased utilization of (unreliable and interruptible) variable renewable energy (VRE) causes instability to the nation's electrical grid.

#### **Project Proposal**

• Use excess VRE to generate hydrogen ( $H_2$ ) and compressed air and store them until needed for grid stability through on-demand,  $H_2$ -fueled power generation.

#### **Objectives**

- Understand the value of integrating electrolysis hydrogen production, hydrogen gas turbines, and compressed air energy storage (CAES) in a high VRE environment.
- "Off-the-shelf" or near-future technology should be considered for the system, such as the commercial proton exchange membrane (PEM) electrolyzer Siemens Silyzer 300 and one of two variations of the CAES system from Siemens Energy.



## **Project Concept**

#### Background

### Green CAES by Bechtel [2]

- Existing CAES (Alabama, Germany) uses natural gas fuel (with carbon emissions)
- Utilize H<sub>2</sub>-fueled turbine instead
- Turbine generates power and pre-heats compressed air
- Smaller scale: ~40 MWe

### Siemens CAES system with H2 [1]

- Larger scale: ~160 MWe
- Equipment identified
- Air flow requirements provided

### <u>NETL System</u>

- Added the PEM electrolyzer and H<sub>2</sub> turboexpander generator to the Siemens System
- PEM electrolyzer size based on required hydrogen (no excess for market sales)





### **Project Concept**

NATIONAL ENERGY TECHNOLOGY LABORATORY

#### **Diagram Overview – Dynamic Representation**

- VRE generates the H<sub>2</sub> via PEM electrolysis and powers the air/H<sub>2</sub> storage compression
- Two storage components
  - Electrolyzer H<sub>2</sub>
  - Compressed air
- H<sub>2</sub> burner to pre-heat stack air is needed
- Cycle time: 16 hr. charge and 8 hr. discharge



Source: NETL



#### **Discharge Mode**

- Air-expansion power generation [1]:
  - Siemens SST-800 Modified steam turbine generator
  - Required air flow rate of 320 lbm/s (145 kg/s)
  - Two-stage, HP/IP heated air expansion
  - Exhaust discharges to the low pressure H<sub>2</sub> combustion turbine generator



CAES Discharge				
Discharge Time, hrs	8			
Maximum Cavern Pressure, bar (psia)	150 (2176)			
Minimum Cavern Pressure, bar (psia)	100 (1450)			
Isothermal Cavern Temperature, °C (°F)	50 (122)			
Air Flow Rate, kg/s	145 [1]			
Working Volume: Cycle Mass Flow, kg	4,176,000			
1 <sup>st</sup> Stage Expander Inlet, °C, bar (°F, psia)	540, 140 (1004, 2030) [1]			
2 <sup>nd</sup> Stage Expander Inlet, °C, bar (°F, psia)	530, 48 (986, 696) [1]			
3 <sup>rd</sup> Stage Expander Inlet to CGT, °C, bar (°F, psia)	410, 24 (770, 348) [1]			



NATIONAL ENERGY TECHNOLOGY LABORATORY

#### Discharge Mode (continued)

- Combustion Turbine Generator
  - Siemens SGT-800
  - 45 62 MWe (simple cycle power generation) [3]
  - ✤ 90-124 MWe (without inlet air compression requirements)
  - Operating limits with hydrogen fuel [3]:
    - Currently 75 vol%  $H_2$  capability with dry low emission burner
    - Aim to reach 100 vol%  $H_2$  by 2030
    - 100 vol%  $H_2$  with wet low emission burner
  - H<sub>2</sub> fuel requirement is 4,540 kg/hour
  - Turbine exhaust preheats compressed air and compressed hydrogen
- H<sub>2</sub> Turboexpander Generator
  - H<sub>2</sub> stream preheater required
  - H<sub>2</sub> outlet pressure is 24 bar (348 psia)
  - Set 98% mechanical efficiency with generator



#### Charge Mode – Hydrogen

- H<sub>2</sub> Production
  - Siemens Silyzer 300 Electrolyzer [4]
  - 75.5% efficiency
  - 14 kg of H<sub>2</sub> per hour per module
  - 0.73 MW/hr. of electricity per module
  - Deionized water consumption ~10 liters per kg hydrogen
  - Required production is  $H_2$  turbine generator 2,270 kg of  $H_2$ /hour [3] plus burner  $H_2$
- H<sub>2</sub> Compression
  - Suction at 80°C (176°F) and atmospheric pressure
  - Discharge at 100–50 bar (1450–2175 psia)
- H<sub>2</sub> Storage
  - Options varied: cavern and above-ground tanks
  - Temperature depends on storage system





#### Charge Mode – Air

- Charge Air Compression
  - Siemens STC-GV: one motor with 2 cases (LP/HP)
- Air Storage Cavern
  - CAES system is diabatic (no thermal storage system)
  - Maximum pressure of 150 bar (2176 psia)
  - Set minimum cavern pressure of 100 bar (1450 psia) – based on a similar operating ratio of the existing caverns
  - Max de-pressure rate of 10 bar/hr (145 psig/hr.) [5]
  - As such, the de-pressure rate is 6.25 bar/hr (91 psi/hr)

CAES Charge				
Charge Time, hours	16			
Inlet Air Pressure, bar (psia)	1 (14.676)			
Inlet Air Temperature, °C (°F)	15 (59)			
Air Flow Rate (kg/s)	72.5*			
Interstage Air Temperature, °C (°F)	38 (100)			
Discharge Air Pressure, bar (psia)	100-150 (1450-2176)			
Discharge Air Temperature, °C (°F)	38 (100)			
Low Pressure Stages	6 [1]			
LP Compression Isentropic Eff, %	87			
High Pressure Stages	2 [1]			
HP Compression Isentropic Eff, %	87			

\* Based on half of the Siemens discharge design rate [1]



### **Cavern Storage**

#### **Cavern Design**



- The literature search reveals a range of pressure-depth design factors depending upon the application.
- The design factor for the  $\rm H_2$  cavern is at least 4.8% more conservative than air caverns.

Application		Maximum Salt-Mined Cavern Design Factor (bar/m [psi/ft])
H <sub>2</sub> Cavern [6]	Murray et al. (SHASTA)	0.156 (0.69)
Air Cavern [5]	Pacific Northwest Laboratory, 1982	0.1639 (0.725)
Air Cavern [1]	Siemens Energy	0.181 (0.8)



### **Cavern Storage**

#### Salt-Mined Cavern Sizing Results



Sizing Criteria	Air Cavern	H <sub>2</sub> Cavern
Maximum Air Operating Pressure, bar (psia)	150 (2176)	150 (2176)
Maximum Allowable Working Pressure, Assuming an Overdesign Factor Similar to Huntorf Plant, bar (psia)	215 (3108)	215 (3108)
Maximum Salt-mined Cavern Design Factor, bar/m depth	0.1639	0.156
Minimum Top of Cavern Depth, m (ft)	1, <b>457 (4</b> ,780)	1,524 (5,000)
Calculated Cavern Diameter, m (ft)	22.6 (74)	12.5 (42)
Calculated Cavern Height, m (ft)	113 (370)	62.5 (210)
Calculated Cavern Volume, m <sup>3</sup> (ft <sup>3</sup> )	47,040 (1,661,100)	8,220 (290,350)
Minimum Bottom of Cavern Depth, m (ft)	1,570 (5,150)	1,588 (5,210)

#### ✤ Cavern depths range 4,800–5,200 ft.

Air and H<sub>2</sub> salt-mined caverns are feasible. The calculated depth requirements are comparable to existing caverns.



### **Case Summary**

#### H<sub>2</sub> Storage Options



- All cases are based on the H<sub>2</sub> storage
- Case 0 has H<sub>2</sub> salt-dome storage cavern at 150 bar (2,176 psi) charged
- Case 0A has H<sub>2</sub> above ground storage at 150 bar (2,176 psi) charged
- Case 1 has H<sub>2</sub> above ground storage at 500 bar (7,252 psi) charged
- Case 0B is an economic scenario based on Case 0 with no electrolyzer capital expense or calculated operation and maintenance (O&M); instead, H<sub>2</sub> is generated at a fixed O&M cost per kg.



## **Performance Highlights**



**Major Rotating Equipment and Power Impacts** 

- HP air expander power declines during discharge.
- $H_2$  turboexpander power is constant with above ground storage at 500 bar.

	Case 0	Case 0	Case 1	Case 1	Unit
		Charging Mode	500 Dui	250 501	
CAES Air Compressor	38,600	35,440	38,600	35,440	kWe
PEM H <sub>2</sub> Production Unit	175,200	175,200	175,200	175,200	kWe
H <sub>2</sub> Compressor	8,080	7,370	10,350	8,980	kWe
Net Plant Power <sup>A</sup>	-224,440	-220,490	-226,730	-222,130	kWe
	Di	scharging Mode			
HP Air Expander Power	<mark>29,700</mark>	<mark>20,900</mark>	29,700	20,900	kWe
IP Air Expander Power	18,800	18,800	18,800	18,800	kWe
H <sub>2</sub> Turboexpander Generator	3,800	2,800	<mark>4,700</mark>	<mark>4,700</mark>	kWe
Combustion Turbine Power	128,100	128,200	128,100	128,200	kWe
Total Gross Power	180,400	170,700	181,300	172,600	kWe
Total Auxiliary Load	3,000	2,970	3,010	2,980	kWe
Net Plant Power	177,400	167,730	178,290	169,620	kWe
Average Net Plant Power	172,	565	173,	955	kWe

<sup>A</sup> The net power is reduced for economic Case 0B by the PEM electrolyzer power (175.2 MWe)



# **Economic Analysis**

#### **Assumption Summary**

- Capacity factor = 90%
- Financial factors
  - Same as natural gas combined cycle (NGCC) baseline cases
  - Fixed charge rate (FCR) = 0.0707
  - Ratio of total as-spent cost/total overnight cost (TASC/TOC) = 1.093
- Each case has start of discharge (end of charge) and end of discharge (start of charge). The power generation is averaged
- Equipment is sized for the largest demand (not the average)
- PEM membrane stack replacement is an O&M expense
  - Stack life of 7 years [7]
  - Replacement cost is 15% of the membrane total plant cost (TPC) [7]
- Assume no cost VRE in all cases
  - VRE cost sensitivity is analyzed





#### **Capital Cost Comparison**

• The  $H_2$  system, mainly the  $H_2$  storage option, is the primary difference.

Cost Account Description TPC (\$/1,000)	Case 0 H <sub>2</sub> Salt-Dome Storage Cavern (150 bar)	Case 0A H <sub>2</sub> Aboveground Storage Vessels (150 bar)	Case 1 H <sub>2</sub> Aboveground Storage Vessels (500 bar)
Feedwater & Misc. Balance of Plant Systems	\$11,188	\$11,188	\$11,401
CAES Air System	\$116,468	\$116,468	\$116,547
H <sub>2</sub> System	<mark>\$104,855</mark>	<mark>\$126,676</mark>	<mark>\$185,132</mark>
Combustion Turbine & Accessories	\$15,192	\$15,192	\$15,192
Heat Recovery, Ductwork, & Stack	\$20,197	\$20,207	\$20,249
Cooling Water System	\$11,950	\$11,950	\$12,214
Accessory Electric Plant	\$155,655	\$155,655	\$156,706
Instrumentation & Control	\$32,533	\$32,533	\$32,620
Improvement & Site	\$15,519	\$15,519	\$15,555
Buildings & Structure	\$5,126	\$5,126	\$5,139
Total	\$488,682	\$510,513	\$570,755





### Economic Results – CAES same (all cases)

#### **Capital Cost Breakdown**



- CAES cavern is based on H<sub>2</sub> cavern cost (adjusted for depth and volume).
- Remainder of CAES system is based on steam generation equipment.

TPC Breakdown Cost Component (\$1,000)	Case 0 H <sub>2</sub> Salt-Dome Storage Cavern (150 bar)	Case 0A H <sub>2</sub> Aboveground Storage Vessels (150 bar)	Case 1 H <sub>2</sub> Aboveground Storage Vessels (500 bar)	Case 0B H <sub>2</sub> Salt-Dome Storage Cavern (150 bar)
	CAES – Ai	r System		
CAES Air (Charge) Compressor	\$83,341	\$83,341	\$83,341	\$83,341
CAES Air Cavern [8]	\$12,344	\$12,344	\$12,344	\$12,344
HP/IP Air (Discharge) Expanders	\$15,171	\$15,171	\$15,171	\$15,171
HP/IP Air Expanders Accessories	\$192	\$192	\$192	\$192
CAES Air System Piping	\$4,027	\$4,027	\$4,027	\$4,027
Air Compression Foundations	\$1,392	\$1,392	\$1,392	\$1,392
Total CAES Air System	\$116,468	\$116,468	\$116,468	\$116,468





#### Capital Cost Breakdown (continued)

• H<sub>2</sub> storage option is the primary difference (except for Case 0B).

TPC Breakdown Cost Component (\$1,000)	Case 0 H <sub>2</sub> Salt-Dome Storage Cavern (150 bar)	Case 0A H <sub>2</sub> Aboveground Storage Vessels (150 bar)	Case 1 H <sub>2</sub> Aboveground Storage Vessels (500 bar)	Case 0B H <sub>2</sub> Salt-Dome Storage Cavern (150 bar)
	H <sub>2</sub> Sys	stem		
PEM $H_2$ Production [7]	\$82,433	\$82,433	\$82,433	-
H <sub>2</sub> (Charge) Compression	\$8,142	\$8,142	\$9,925	\$8,142
H <sub>2</sub> Storage Cavern [8]	<mark>\$2,282</mark>	\$O	\$O	<mark>\$2,282</mark>
H <sub>2</sub> Aboveground Storage	\$O	<mark>\$24,103</mark>	<mark>\$80,343</mark>	\$0
H <sub>2</sub> Turboexpander Generator	\$1,978	\$1,978	\$2,345	\$1,978
H <sub>2</sub> In-Line Stack Burner	\$9,721	\$9,721	\$9,721	\$9,721
H <sub>2</sub> Compression Foundations	\$299	\$299	\$365	\$299
Total H <sub>2</sub> System	\$104,855	\$126,676	\$185,132	\$22,422



#### **Cost of Storage**

NATIONAL ENERGY TECHNOLOGY LABORATORY

- H<sub>2</sub> cavern cost is dependent upon pressure, depth, and storage mass
- CAES cavern is based on H<sub>2</sub> cavern cost (adjusted for depth and volume)
- Aboveground vessel cost is dependent upon pressure and storage mass

	Air Salt-Dome Storage Cavern	H <sub>2</sub> Salt-Dome Storage Cavern	H <sub>2</sub> Aboveground Storage Vessels	H <sub>2</sub> Aboveground Storage Vessels
Maximum Pressure, bar	150	150	150	500
Cavern Depth, m	1,457–1,570	1,524–1,588	-	-
Stored Mass, kg	8,355,378	100,802	100,802	100,802
Storage TPC, \$1000	\$12,344	\$2,282	\$24,103	\$80,343
Cavern Cost, \$/kg <del>s</del> tored	<b>\$1.48</b>	\$22.64	-	-
Vessel Cost, \$/kg H <sub>2</sub> stored	-	-	\$239	\$797





#### Levelized Cost Comparison

• Case OB results are based on an  $H_2$  generated cost of \$2/kg  $H_2$ .

	Case 0 H <sub>2</sub> Salt-Dome Storage Cavern (150 bar)	Case 0A H <sub>2</sub> Aboveground Storage Vessels (150 bar)	Case 1 H <sub>2</sub> Aboveground Storage Vessels (500 bar)	Case 0B H <sub>2</sub> Salt-Dome Storage Cavern (150 bar)
Capacity Factor	90%	90%	90%	90%
Capital	\$50,812,301	\$53,076,989	\$59,326,492	\$50,220,219
Fixed	\$16,982,018	\$17,697,587	\$19,672,172	\$14,280,054
Variable	\$8,170,386	\$8,463,177	\$9,282,985	\$5,798,651
Fuel (H <sub>2</sub> )	0	0	0	<mark>\$36,787,096</mark>
Annual Air Stored, kg	1,524,856,474	1,524,856,474	1,524,856,474	1,524,856,474
Air LCOS (\$/kg Air)	\$0.05	\$0.05	\$0.06	\$0.07
Annual H <sub>2</sub> Stored, kg	18,396,407	18,396,407	18,396,407	18,396,407
H <sub>2</sub> LCOS (\$/kg H <sub>2</sub> )	\$4.13	\$4.31	\$4.80	\$5.82
Annual Net kWh (100%)	503,889,800	503,889,800	507,948,600	503,889,800
LCOE (\$/MWh)	\$150.76	\$157.25	\$173.80	\$212.52



**LCOE Sensitivity to VRE Price** 



- Cases assume VRE is at no cost.
- VRE price varied \$-30.66–225/MWh; LCOE varies \$71.70–730.88/MWh







#### **LCOE Sensitivity to Cavern TPC**

- Percentage of Cavern TPC varied 10–150%; LCOE varies \$148.51–152.00
- Purchasing a suitable, existing cavern at a fraction of the new cavern cost is reflected by the line left of 100% Cavern TPC.





NATIONAL ENERGY TECHNOLOGY LABORATORY

**LCOE Sensitivity to Electrolyzer TPC** 

• Percentage of Electrolyzer TPC varied 50–150%; LCOE varies \$143.73–157.78





NATIONAL ENERGY TECHNOLOGY LABORATORY

#### LCOE Sensitivity to H<sub>2</sub> Price

• The cost of generated  $H_2$  varied \$2–10/kg; LCOE varies \$212.52–504.54





### Conclusions

NATIONAL ENERGY TECHNOLOGY LABORATORY

- Air and H<sub>2</sub> salt-mined caverns are feasible (where salt domes exist with sufficient depths); calculated depth requirements are comparable to existing caverns.
- The proposed Siemens system (existing and near-future equipment) can meet the project's power generation objective.
- While facilities with above ground H<sub>2</sub> storage generate roughly 1% more power output than facilities with H<sub>2</sub> storage caverns, H<sub>2</sub> storage caverns are significantly more economical than above-ground vessels
- VRE price has a greater influence on LCOE than electrolyzer cost or cavern costs.



### Disclaimer



This project was funded by the Department of Energy, National Energy Technology Laboratory an agency of the United States Government, through a support contract. Neither the United States Government nor any agency thereof, nor any of its employees, nor the support contractor, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.



# **Questions?**

#### VISIT US AT: www.NETL.DOE.gov

@NETL\_DOE



@NationalEnergyTechnologyLaboratory

CONTACT: Robert W. Stevens Robert.Stevens@netl.doe.gov



### Support Contractor Contacts



- Kyle Buchheit
  - Kyle.Buchheit@NETL.DOE.GOV
- Troy Teel
  - Troy.Teel@NETL.DOE.GOV
- Sandeep Pidaparti
  - Sandeep.Pidaparti@NETL.DOE.GOV



### References

#### - NATIONAL ENERGY TECHNOLOGY LABORATORY

#### **TEA of H<sub>2</sub> Production and CAES From VRE**

- [1] R. Bailie, "Compressed Air Energy Storage (CAES)," presented at Thermal-Mechanical-Chemical Energy Storage Workshop, San Antonio, TX, USA, Aug. 10-11, 2021. Available: Unknown (pfd file)
- [2] J. Gulen, "Green CAES with Hydrogen," presented to DOE, Virtual presentation, Sep. 6, 2022. Available: Unpublished (pdf file)
- [3] Siemens Energy, "Hydrogen Decarbonization Calculator." Accessed: Dec. 28, 2023. Available: https://www.siemensenergy.com/global/en/home/products-services/solutions-usecase/hydrogen/hydrogen-decarb-calculator.html
- [4] Siemens Energy, "Hydrogen Power Plants Service & Solutions. Accessed Dec. 11, 2023. Available: https://p3.aprimocdn.net/siemensenergy/555f5c7e-a98c-428e-9f2b-b03601098bec/SE-HyPP-ipdf-July2021pdf\_Original%20file.pdf
- [5] R. D. Allen, T. J. Doherty, and R. L. Thorns, "Geotechnical Factors And Guidelines For Storage Of Compressed Air In Solution Mined Salt Caverns," U.S. Department of Energy Pacific Northwest Laboratory, Richland, WA, USA, Report No. PNL-4242, 1982.
- [6] Murray, E. et al., 2018. Salt Cavern Appraisal for Hydrogen and Gas Storage. Oxfordshire (England): Energy Technologies Institute.
- [7] "Current Central Hydrogen Production from Polymer Electrolyte Membrane (PEM) Electrolysis (2019) version Nov 2020," National Renewable Energy Laboratory, 2020. Object name current-central-pem-electrolysis-version-nov20.xlsm. Accessed: Apr. 10, 2024. Available: https://www.nrel.gov/hydrogen/h2a-production-models.html
- [8] S. K. Mishra, S. Ganguli, G. Freeman, M. Moncheur de Rieudotte, and N. Huerta, Local-Scale Framework for Techno-Economic Analysis of Subsurface Hydrogen Storage, SAND2023-1724049/PNNL-35058; U.S. DOE, Sandia National Laboratories and Pacific Northwest National Laboratories: Richland, WA, 2023.

