

Cost and Performance Baseline for Fossil Energy Plants, Volume 1: Bituminous Coal and Natural Gas to Electricity, Revision 4



Alexander Zoelle¹, R.J. James², Travis Shultz², Timothy Fout², Mark Woods³, Marc Turner¹

August 28, 2019

¹Leidos, ²U.S. DOE/NETL, ³KeyLogic Systems, Inc.



Solutions for Today | Options for Tomorrow



DISCLAIMER

This presentation was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof

NETL Cost and Performance Baseline for Fossil Energy Plants: Bituminous Baseline




- Presents cost and performance estimates of near-term commercial offerings for coal- and natural gas-fired power plants, both with and without current technology for carbon capture and sequestration (CCS)
 - Integrated gasification combined cycle (IGCC) (7 cases: 4 with capture and 3 without capture)
 - Pulverized coal (PC) (4 cases: 2 with capture and 2 without capture)
 - Natural gas combined cycle (NGCC) (2 cases: 1 with capture and 1 without capture)
- Consistent and transparent design basis and analysis methodology
- Results represent an independent assessment of the power systems considered
- Significant vendor input for performance and capital cost estimates
- Black & Veatch “bottom up” approach to developing capital and operation and maintenance (O&M) estimates

NETL Cost and Performance Baseline for Fossil Energy Plants: Purpose and Use



- **NETL internal uses**
 - Provides a consistent basis to compare existing and developing technologies
 - Informs development of research and development (R&D) goals and targets
 - Guides potential Department of Energy (DOE) investment by quantifying prospective benefits of successful R&D, and for advancing technologies within the DOE Office of Fossil Energy (FE) programs
- **External uses—other agencies (Environmental Information Administration [EIA], Environmental Protection Agency [EPA]), academia, and industry partners)**
 - Reference for technoeconomic analysis (TEA)
 - Benchmark current state-of-the-art (SOA) technology performance and cost, as well as tracking technology development across report revisions
 - Reference for plant configurations, emissions, sub-system descriptions, and others

Tracking Technology Development Through Legacy Report Revisions



NETL Cost and Performance Baseline for Fossil Energy Plants: QGESS Documents



- In addition to the Bituminous Baseline Report, there are a number of supporting documents available that detail underlying assumptions, methodologies, and approaches
 - Documentation in these sources provides the transparent, repeatable approach
- **Quality Guidelines for Energy System Studies (QGESS)**
 - “Detailed Coal Specifications,” “Specifications for Selected Feedstocks”
 - “Fuel Prices for Selected Feedstocks”
 - “Process Modeling Design Parameters”
 - “Cost Estimation Methodology for NETL Assessments of Power Plants”
 - “CO₂ Transport and Storage Costs in NETL Studies”
 - “Performing a Techno-economic Analysis for Power Generation Plants”
 - Others

Regulatory Drivers and Other Relevant Study Assumptions

- **Cases configured to be compliant with key regulatory requirements**
 - Utility Mercury and Air Toxics Standards (MATS)
 - New Source Performance Standards (NSPS)
 - Effluent Limitation Guidelines (ELG)
 - Presumed Best Available Control Technology (BACT)
- **Cases presented are for a generic midwestern, greenfield site**
 - Site specific considerations (e.g., soil issues, water discharge and use restrictions, seismic data, local code for height/noise) are generalized and assumed to not be impactful
- **Performance and cost estimates assume baseload operation**
 - Plant designs do not specifically account for part load, ramping, or similar off-design considerations
 - Levelized cost of electricity (LCOE) results do not account for market pressures relating to these plant operating conditions
- **NETL currently developing reference cases that specifically address flexible plant operation¹**

Bituminous Baseline Study, Revision 4



Technical Updates

- Updated bituminous coal characteristics, reducing chlorine content to 1,671 ppmw
- Implemented ELG regulation compliance systems for PC and IGCC cases
 - PC – spray dryer evaporator
 - IGCC – brine concentrator and crystallizer
- PC net plant electrical output updated from 550 MW_{net} to 650 MW_{net}
 - Size selection driven by updated NGCC output, and supported by Black & Veatch
- Updated the mercury control system with data provided by United Conveyor Corporation (UCC)
- Updated CO₂ capture system cost and performance for PC and NGCC capture cases
- Revised CO₂ compression model to avoid operation near the vapor dome
- Updated combustion turbine (CT) and steam turbine (ST) performance estimates for NGCC cases (2017 vintage)
- Updates to IGCC cases included:
 - Water gas shift (WGS) and COS reactor, air separation unit (ASU), steam turbine, Selexol system

Study Matrix

Case Configuration

Case	Unit Cycle	Steam Cycle, psig/°F/°F	Combustion Turbine	Gasifier/Boiler Technology	H ₂ S Separation	Sulfur Removal	Particulate Matter (PM) Control	CO ₂ Separation ^A	Process Water Treatment
B1A	IGCC	1,800/1,050/1,050	2 x State-of-the-art 2008 F-Class	Shell	Sulfinol-M	Claus Plant/Sulfur	Cyclone, candle filter, and water scrubber	N/A	Vacuum flash, brine concentrator, crystallizer
B1B		1,800/1,000/1,000			Selexol			Selexol 2 nd stage	
B4A		1,800/1,050/1,050		CB&I E-Gas™	Refrigerated MDEA		Cyclone, candle filter, and water scrubber	N/A	
B4B		1,800/1,000/1,000			Selexol			Selexol 2 nd stage	
B5A		1,800/1,050/1,050		General Electric Power (GEP) Radiant	Selexol		Quench, water scrubber, and acid gas removal (AGR) adsorber	N/A	
B5B		1,800/1,000/1,000						Selexol 2 nd stage	
B5B-Q		1,800/1,000/1,000						GEP Quench	
B11A		PC		2,400/1,050/1,050	N/A		Subcritical PC	N/A	
B11B	3,500/1,100/1,100		Supercritical (SC) PC	N/A		Cansolv			
B12A						N/A			
B12B	Cansolv								
B31A	NGCC	2,400/1,085/1,085	2 x State-of-the-art 2017 F-Class	Heat Recovery Steam Generator (HRSG)	N/A	N/A	N/A	N/A	N/A
B31B								Cansolv	

Study Matrix

Case Configuration (cont'd)

Case	Unit Cycle	Steam Cycle, psig/°F/°F	Combustion Turbine	Boiler Technology	NOx Removal	Hg Removal	Sulfur Removal	PM Control	CO ₂ Separation ^A	Process Water Treatment
B11A	PC	2,400/1,050/ 1,050	N/A	Subcritical PC	Selective Catalytic Reduction (SCR)	Dry sorbent injection (DSI)/ activated carbon injection (ACI), co-benefit capture	Wet FGD/ Gypsum	Baghouse	N/A	Spray dryer evaporator
B11B									Cansolv	
B12A		3,500/1,100/ 1,100		SC PC					N/A	
B12B									Cansolv	
B31A	NGCC	2,400/1,085/ 1,085	2 x State-of-the-art 2017 F-Class	HRSG	SCR	N/A	N/A	N/A	N/A	N/A
B31B									Cansolv	

Performance Summary



Case Name	IGCC							PC				NGCC	
	Shell		E-Gas™ FSQ		GEP R+Q			Subcritical		Supercritical		State-of-the-art 2017 F-Class	
	B1A	B1B	B4A	B4B	B5A	B5B	B5B-Q	B11A	B11B	B12A	B12B	B31A	B31B
CO ₂ Capture Rate (%)	0	90	0	90	0	90	90	0	90	0	90	0	90
PERFORMANCE													
Gross Power Output (MWe)	765	696	763	742	765	741	685	687	776	685	770	740	690
Auxiliary Power Requirement (MWe)	125	177	122	185	131	185	186	37	126	35	120	14	44
Net Power Output (MWe)	640	519	641	557	634	556	499	650	650	650	650	727	646
Coal Flow Rate (lb/hr)	435,418	467,308	456,327	482,173	464,732	482,580	482,918	492,047	634,448	472,037	603,246	N/A	N/A
Natural Gas Flow Rate (lb/hr)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	205,630	205,630
HHV Thermal Input (kW _t)	1,488,680	1,597,710	1,560,166	1,648,535	1,588,902	1,649,926	1,651,082	1,682,291	2,169,156	1,613,879	2,062,478	1,354,905	1,354,905
Net Plant HHV Efficiency (%)	43.0%	32.5%	41.1%	33.8%	39.9%	33.7%	30.2%	38.6%	30.0%	40.3%	31.5%	53.6%	47.7%
Net Plant HHV Heat Rate (Btu/kWh)	7,940	10,497	8,308	10,101	8,554	10,118	11,287	8,832	11,393	8,473	10,834	6,363	7,159
Raw Water Withdrawal (gpm)	4,127	5,080	4,357	5,197	4,799	5,512	6,286	6,485	10,634	6,054	9,911	2,902	4,773
Process Water Discharge (gpm)	922	1,075	944	1,103	1,033	1,123	1,218	1,334	3,090	1,242	2,893	657	1,670
Raw Water Consumption (gpm)	3,206	4,005	3,413	4,093	3,766	4,389	5,068	5,151	7,544	4,811	7,018	2,245	3,103

Performance Summary – PC and NGCC



Case Name	PC				NGCC	
	Subcritical		Supercritical		State-of-the-art 2017 F-Class	
	B11A	B11B	B12A	B12B	B31A	B31B
CO ₂ Capture Rate (%)	0	90	0	90	0	90
PERFORMANCE						
Gross Power Output (MWe)	687	776	685	770	740	690
Net Power Output (MWe)	650	650	650	650	727	646
Coal Flow Rate (lb/hr)	492,047	634,448	472,037	603,246	N/A	N/A
Natural Gas Flow Rate (lb/hr)	N/A	N/A	N/A	N/A	205,630	205,630
HHV Thermal Input (kW _t)	1,682,291	2,169,156	1,613,879	2,062,478	1,354,905	1,354,905
Net Plant HHV Efficiency (%)	38.6%	30.0%	40.3%	31.5%	53.6%	47.7%
Raw Water Consumption (gpm)	5,151	7,544	4,811	7,018	2,245	3,103

Emissions Summary – PC and NGCC



Case Name	PC				NGCC	
	Subcritical		Supercritical		State-of-the-art 2017 F-Class	
	B11A	B11B	B12A	B12B	B31A	B31B
CO ₂ Capture Rate (%)	0	90	0	90	0	90
EMISSIONS						
CO ₂ Emissions (lb/MWh-gross)	1,691	193	1,627	185	741	80
SO ₂ Emissions (lb/MWh-gross)	0.67	-	0.65	-	0.01	-
NO _x Emissions (lb/MWh-gross)	0.70	0.70	0.70	0.70	0.02	0.02
PM Emissions (lb/MWh-gross)	0.09	0.09	0.09	0.09	0.01	-
Hg Emissions (lb/MWh-gross)	3.00E-06	3.00E-06	3.00E-06	3.00E-06	-	-

Capital and O&M Cost Estimation




- Capital cost results are broken into 14 accounts, and further partitioned by relevant sub-systems
 - 2018\$ estimation basis
 - Itemized owner's costs
- Total costs for equipment through total as-spent costs (TASC) are reported
- O&M tables breakout fixed, variable, and fuel costs, as well as initial and daily consumable rates

Case: B12B		- SC PC w/ CO ₂				Estimate Type: Conceptual		Cost Base: Dec 2018			
Plant Size (MW, net): 650		Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost	
Item No.	Description			Direct	Indirect			Process	Project	\$/1,000	\$/kW
4.13	Secondary Air System	\$2,571	\$0	\$1,465	\$0	\$4,035	\$706	\$0	\$711	\$5,453	\$8
4.14	Induced Draft Fans	\$5,479	\$0	\$3,122	\$0	\$8,601	\$1,505	\$0	\$1,516	\$11,622	\$18
4.15	Major Component Rigging	\$93	\$0	\$53	\$0	\$146	\$26	\$0	\$26	\$197	\$0
4.16	Boiler Foundations	\$0	\$399	\$351	\$0	\$751	\$131	\$0	\$132	\$1,014	\$2
	Subtotal	\$309,869	\$399	\$176,913	\$0	\$487,181	\$85,257	\$0	\$85,866	\$658,303	\$1,013

Case: B12B		- SC PC w/ CO ₂				Cost Base: Dec 2018	
Plant Size (MW, net): 650		Heat Rate-net (Btu/kWh): 10,834		Capacity Factor (%): 85			
Operating & Maintenance Labor							
Operating Labor				Operating Labor Requirements per Shift			
Operating Labor Rate (base):	38.50	\$/hour	Skilled Operator:	2.0			
Operating Labor Burden:	30.00	% of base	Operator:	11.3			
Labor O-H Charge Rate:	25.00	% of labor	Foreman:	1.0			
			Lab Techs, etc.:	2.0			
			Total:	16.3			
Fixed Operating Costs							
						Annual Cost	
						(\$)	(\$/kW-net)
Annual Operating Labor:						\$7,161,008	\$11,024
Maintenance Labor:						\$15,797,590	\$24,319
Administrative & Support Labor:						\$5,739,649	\$8,836
Property Taxes and Insurance:						\$49,367,468	\$75,997
Totals:						\$78,065,715	\$120,175
Variable Operating Costs							
Maintenance Material:							
				Consumption			
				Initial Fill	Per Day		
Water (/1000 gallons):	0	7,136					
Makeup and Waste Water Treatment Chemicals (ton):	0	21.3					
Brominated Activated Carbon (ton):	0	1.56					
Enhanced Hydrated Lime (ton):	0	39.9					
Limestone (ton):	0	700					
Ammonia (19 wt%, ton):	0.00	69.0					
SCR Catalyst (R ³):	17,414	15.9					
CO ₂ Capture System Chemicals*			Proprietary				
Triethylene Glycol (gal):	w/equip.	544					
Subtotal:							
Waste Disposal							
Fly Ash (ton)	0	657					
Bottom Ash (ton)	0	146					
SCR Catalyst (R ³):	0	16					
Triethylene Glycol (gal):		544					
Thermal Reclaimer Unit Waste (ton)	0	3.51					
Prescrubber Blowdown Waste (ton)	0	52.1					
Subtotal:							
By-Product							
Gypsum (ton)	0	1064					
Subtotal:							
Variable Operating Costs Total:							
Illinois Number 6 (ton):	0	7,239					
Totals:							

Description	\$/1,000	\$/kW
Pre-Production Costs		
6 Months All Labor	\$14,349	\$22
1 Month Maintenance Materials	\$2,323	\$4
1 Month Non-Fuel Consumables	\$3,322	\$5
1 Month Waste Disposal	\$999	\$2
25% of 1 Months Fuel Cost at 100% CF	\$2,860	\$4
2% of TPC	\$49,367	\$76
Total	\$73,221	\$113
Inventory Capital		
60-day supply of fuel and consumables at 100% CF	\$28,700	\$44
0.5% of TPC (spare parts)	\$12,342	\$19
Total	\$41,042	\$63
Other Costs		
Initial Cost for Catalyst and Chemicals	\$2,612	\$4
Land	\$900	\$1
Other Owner's Costs	\$370,256	\$570
Financing Costs	\$66,646	\$103
Total Overnight Costs (TOC)	\$3,023,051	\$4,654
TASC Multiplier (IOU, 35 year)	1.154	
Total As-Spent Cost (TASC)	\$3,488,911	\$5,371

PC and NGCC Capital Cost Results



- PC and NGCC capital estimates represent AACE Class 4
 - PC uncertainty range is -15%/+30%
 - NGCC uncertainty range is -15%/+25%
- Recent experience with NGCC allows for a tighter uncertainty range compared to PC
- The methodology for calculating COE will be detailed in the QGESS¹

Cost of Electricity Methodology

- Revision 4 will utilize an updated cost of electricity (COE) methodology

- Transition from *project* approach to *corporate* approach
- Reporting an LCOE
- Real dollar basis

- Relevant parameter updates will include:

- Tax rates
- Debt/equity splits
- Fuel price and transport and storage cost

Parameter	Rev3 Value	Rev4 Value
Coal Price, \$/MMBtu, \$/tonne	2.94 (68.54) – 2011\$	2.23 (51.96) – 2018\$
Natural Gas Price, \$/MMBtu	6.13 – 2011\$	4.42 – 2018\$
CO ₂ Transport & Storage Cost, \$/tonne	11.0 – 2011\$	10.0 – 2018\$

Conclusions and Takeaways

- NETL's Bituminous Baseline Report presents a transparent and independent assessment of the cost and performance of near-term commercial offerings for coal- and natural gas-fired power plants, both with and without CCS
- The report serves many purposes including to benchmark SOA technology, guide DOE R&D, develop technology goals, and identify opportunities for beneficial R&D investment, among others
- Performance estimates are based on significant sub-system vendor input
- Cost estimates are generated with a "bottom-up" approach, and based on recent and historical engineering, procurement, and construction (EPC) experience with power plant projects

Conclusions and Takeaways (cont'd)

- The study methodology is well-documented and reproducible via supplemental QGESS references that provide guidance on model development, parameter selection, cost evaluation, LCOE calculation methodology, and several other key areas
- The absolute capital estimates (and future LCOE results) reported are not developed in an effort to match any single real-world project scenario; rather, the value of the results are that they are developed on a consistent basis, and facilitate technology comparison

Thank You



Alexander Zoelle

Alexander.Zoelle@netl.doe.gov

Robert James

Robert.James@netl.doe.gov

Travis Shultz

Travis.Shultz@netl.doe.gov

Tim Fout

Timothy.Fout@netl.doe.gov

Mark Woods

Mark.Woods@netl.doe.gov

Visit us at www.netl.doe.gov