Initial Engineering Design of a Post-Combustion CO<sub>2</sub> Capture System for Duke Energy's East Bend Station Using Membrane-Based Technology DE-FE0031589

**Dr. Des Dillon** EPRI, Sr. Technical Leader

**Dr. Sai Gollakota** NETL, Federal Project Manager

Carbon Capture, Utilization, Storage and Oil and Gas Technologies Integrated Review Meeting August 29<sup>th</sup> 2019







# **Project Overview**

#### Funding

- Federal Share:
- Non-Federal Share:
- TOTAL

<u>\$ 406,485</u> <u>\$ 2,031,729</u>

\$ 1,625,244

- Project Performance Dates
  - 04/06/2018 to 03/31/2020
- Project Participants
  - Prime:
    - Electric Power Research Institute
  - Sub-contractors:
    - Membrane Technology and Research
      - Trimeric
    - Nexant Inc.
      - Bechtel
  - Site Host:
    - Duke Energy



#### Project Objective

 Perform an initial engineering design and cost estimate for a commercial-scale, membrane-based, post-combustion CO<sub>2</sub> capture system retrofit to Duke Energy's 600MWe coal-fired East Bend Unit.



# Background - MTR Polaris Membrane

- MTR has developed a CO<sub>2</sub> selective polymeric membrane material and module - the MTR Polaris membrane
- This provides higher CO<sub>2</sub>
  permeance for post
  combustion flue gas
  applications than existing
  polymeric membranes



Images Courtesy of MTR



#### Background – Membrane Module

- Membranes are widely used for desalination and natural gas sweetening
- The largest existing systems are similar in scale to those required for a 550MWe coal fired power plant

www.epri.com







#### Images Courtesy of MTR



### Background - Low Pressure Drop Modules

Compact modular system design using high permeance membranes



www.epri.com

#### MTRs CO<sub>2</sub> Capture Development to Date



Images Courtesy of MTR



#### Advantages of the Membrane Capture Process

- Simple, passive operation with no chemical handling, emissions, or disposal issues
- Membrane not effected by O<sub>2</sub>, SO<sub>x</sub> or NO<sub>x</sub>; co-capture possible
  - $-O_{2}$ , SO<sub>x</sub> or NO<sub>x</sub> permeate and therefore impact the overall process design
- Modular technology high volume manufacturing to lower cost, pre-assembled, containerized skids
- No steam use  $\rightarrow$  no modifications to existing boiler/turbines
- Near instantaneous response; high turndown possible
- Very efficient at partial capture (40-60% CO<sub>2</sub> recovery)



### Challenges of the Membrane Capture Process

- Develop a design that will <u>minimize the impact</u> on the power plant by disrupting as little of the existing facilities as possible.
  - Also shorten the amount of downtime before the plant can resume normal operations
- Develop a design that will <u>minimize the cost</u> of each tonne of captured CO<sub>2</sub> while also maintaining the net 600 MW output of the East Bend Station (EBS).
  - This will be done by optimizing the percentage of CO<sub>2</sub> captured (~60%) and by adding a natural-gas-fired combustion turbine (CT) or possibly a combined cycle to offset the new auxiliary loads



# Initial Conceptual Flow Diagram Partial CO<sub>2</sub> Capture with 2 Stage Membrane Process









### Technical Approach 1/2

- Following a data gathering task that will include several site visit to the EBS, a preliminary process design will be developed for <u>one</u> Post Combustion Capture (PCC) system which captures CO<sub>2</sub> from the entire flue gas stream of the power plant.
- This <u>preliminary</u> design will then be subjected to a series of analyses to examine various options for minimizing the cost of CO<sub>2</sub> capture on a \$/tonne-captured basis.
- The analysis will also examine several options for providing the PCC system's auxiliary power via a CT-based power plant.
- Once an optimized process design has been identified, that design will be detailed and documented in a complete Process Design Package (PDP).





#### Technical Approach 2/2

- As part of this effort a HAZOP and constructability review of the design will be conducted.
- The PDP data will be used to carry out a techno-economic analysis that will include a +/-30% accuracy capital cost estimate as well as an estimate of the first year cost of electricity and \$/tonne cost of CO<sub>2</sub> capture for the retrofitted power plant.
- The marginal operating cost of the retrofitted plant with also be calculated and used in a unit dispatch model to predict how the retrofit will impact how often the coal plant is called on to operate.



### **Project Schedule**

TASK NAME:	DATES:	DATES: BUDGET PERIOD 1:					BUDGET PERIOD 2:																		
	Start	End	Α	Μ,	I J	A	S	0	) N	D	J	F	I	A	Μ	J	J	Å	S	0	Ν	D	J	F	Μ
TASK 1: Project Management and Planning (EPRI lead)	4/1/2018	3/31/2020																							
1.1Project and Risk Management (EPRI)			M1	<b>M</b> 2						D	Р													ŀ	411
1.2 Financial and Project Reporting (EPRI)					Q	11		Q	)2		Q3	3		Q4			Q5			Q6			Q7		
1.3 Technology Maturation Plan (MTR)				ľ	13																				
																		-							
TASK 2: Develop Design Basis document (Nexant Lead)	4/1/2018	9/30/2018					M	4										÷							_
TACK 2. E-t-Link Dana Cana Madal (Namat Land)	71112010	012012040			_			_	_		<b>C</b>		_					÷							
TAON 3: Establish Dase Case Model (Nexant Lead)	111/2010	313012010					193	<b>-</b>			J							÷							-
TASK 4: System analysis of Integration options (EPRI Lead)	8/1/2018	04/31/2019											-					T							_
4.1 Opitmize CO2 Capture Plant Design (MTR)	0.112010	0.00.0000			+		+	+				+						1					-+	$\neg$	_
4.2 Evaluate Options for Aux Power (EPRI, Nexant)				$\vdash$	+			+			+	+	$\vdash$					1	<u> </u>				-+	$\rightarrow$	_
4.3 Finalize Design Configuration (EPRI , MTR, Nexant)					+	+							-	MG				1						$\neg$	_
						_		_				-						1	-						_
DECISION POINT: Examine and Review Retrofit Options	1/31/2019	4/15/2019											Ļ	DP				1							
TASK 5: Finalize Overall Retrofit PC Design (EPRI Lead)	3/1/2019	9/30/2019																+							
5.1Design Package of the Membrane CCS System (MTR)		7/30/2019														$\rightarrow$	-M7								
5.2 Design Package for BOP & Aux. Power (EPRI & Nexant)	XXX	9/30/2019														•		->	•X						
5.3 Preliminary HAZOP Review (Nexant, Bechtel, MTR & Duke)		10/30/2019																20	•	M8					
5.4 Constructibility Review (Nexant , Bechtel & Duke)		10/30/2019																11		M9					
													_					-							
TASK 6: Techno-Economic Analysis (EPRI Lead)	8/1/2019	12/31/2019																-						$ \rightarrow $	
6.1 Capital Cost Estimation of Integrated PCC Design (Nexant)		10/30/2019																-		M10	D			$\square$	
6.2 O&M Cost Estimation of Integrated PCC Design (Nexant, EPRI)		10/30/2019																-		X			$ \rightarrow $	$\square$	
6.2 TEA and Dispatch Analysis (EPRI & DUKE)		12/31/2019																-							
	1110000	010410000		<u> </u>														÷							FF
TASK 7: Final Report Preparation (EPRI Lead)	1/1/2020	3/31/2020																							FH

12



#### **Key Accomplishments**

- 1. Host site agreed to EPRI team's proposed capture system's auxiliary power source
- 2. Identified all electrical loads and initiated refinement of the power demands for the full-scale  $CO_2$  membrane capture system
- 3. Completed membrane arrangement and CO<sub>2</sub> processing unit flow diagram and developed preliminary equipment list
- Completed a comprehensive review of process cooling requirements and verified that the preliminary layout of the overall retrofit plant will fit the space available



# **Key Accomplishment 1** Host site agreed to EPRI team's proposed capture system's auxiliary power source

- The retrofit team prepared and presented to site hosts Duke Energy an assessment of 4 auxiliary power options for the membrane capture system.
- A single Gas Turbine Simple Cycle Power island was recommended as best suited for the East Bend station application
- Duke Energy accepted the project team's recommendation. This represents a significant decision point in the project plan.



# Supplying the Membrane System Power Requirements

- Unlike solvent PCC systems No steam requirement, but power is required to drive the membrane systems fans, blowers, vacuum compressors pumps and CO<sub>2</sub> compression
- 4 ways to supply power have been considered:
  - Option 1: New natural gas-fired simple cycle,
  - Option 2: New natural gas-fired combined cycle
  - Option 3: New simple cycle with HRSG steam to the coal plant FWH
  - Option 4: Auxiliary power supplied from the existing coal station
- Examine which option is best suited for MTR PCC integration implementation at EBS



#### Aux Power Option 1: New natural gas-fired simple cycle





#### Aux Power Option 1: New natural gas-fired simple cycle





#### Aux Power Option 1: New natural gas-fired simple cycle





ELECTRIC POWER

www.epri.com

### Aux Power impact on cost of CO<sub>2</sub> Capture & COE



### **Results From Auxiliary Power Assessment**

- Similar cost of CO<sub>2</sub> capture for all integration options (within margin of error)
- Selection of best option may be based on overall ease of integration instead of cost
- Recommend simple cycle (Option 1) using single GE7F04 turbine
  - Lowest upfront cost of all the external power options considered
  - Allow phased implementation of feedwater preheat (Option 3)
  - Enough temperature & heat available for future EBS HP feedwater preheating if desired
  - Potential for future addition of a full size HRSG, should the owner at a later date, consider additional power export of value
  - GE 7F.04 was the old GE 7FA GT and its operation is well established commercially

20



# **Key Accomplishment 2** Identified all electrical loads and initiated refinement of the power demands for the full-scale CO<sub>2</sub> membrane capture system

- After selecting the power island, the retrofit team continued to optimize and refine the power load of the capture process to ensure they stay within the capabilities of the power island while maximizing CO<sub>2</sub> captured.
- The largest loads are blowers, membrane permeate compressors, refrigerant compressors and CO<sub>2</sub> pumps.
- In addition, the specific impacts of the East Bend site ambient conditions, flue gas water content, and air in-leakage from the power plant on the final capture system design have been examined.



# Summary of Aux Power and Cooling Water Requirements by Subsystem

Item	Normal Motor Power, MW	Cooling Water, gpm	Cooling Duty, MMBtu/hr
Flue Gas Blower	18.6		
DCC w/ DFGD	3.3	31,946	319.6
MTR – Total Power Consumption	130.0		
MTR – CW Load for Power Input		39,914	399.3
MTR – H <sub>2</sub> O Condensing CW Load		32,996	330.1
MTR – Misc. Utilities			
Dedicated CT System for PCC	1.6		
Dedicated CW System for PCC	5.6		
BOP	1.3		
Total	160.3	104,856	1,049.0

#### Note: Preliminary Numbers to Help facilitate the Aux Power selection (NOT FINAL RESULTS)

22



#### **Direct Contact Cooler**

- 2 trains to handle 100% of EBS flue gas (FG) from WFGD
- Each train consists of a FG blower; a DCC contactor with circulation pumps and plateand-frame heat exchangers; and the associated FG ducting
- Each contactor has two packed bed sections
  - Deep Flue Gas Desulfurization (DFGD) bottom bed to reduce the FG sulfur content down below 5 ppm with caustic scrubbing to meet CO<sub>2</sub> purity specifications (per QGES)
  - Direct Contact Cooler (DCC) top bed to cool the FG, minimizing its moisture content before feeding the MTR membranes





# **Key Accomplishment 3** Completed membrane arrangement and CO<sub>2</sub> processing unit flow diagram definition and preliminary equipment list

- MTR and Trimeric prepared detailed CO<sub>2</sub> and refrigeration process flow diagrams (PFD).
- Expanding on the original concept outline PFD, this detailed diagram shows the entire process including heat integration between flue gas, cold CO<sub>2</sub> process streams, and refrigerant streams as well as individual equipment items selected to facilitate capture.
- The PFD is being used used to engage with vendors for specific equipment items, performance and cost.



#### **PFD Development: Flue Gas Conditioning**



www.epri.com

#### PFD Development: CO<sub>2</sub> Purification Unit





### PFD Development: Refrigeration System





www.epri.com



#### Key Accomplishment 4

Completed a comprehensive review of process cooling requirements and verified that the preliminary layout of the overall retrofit plant will fit the space available

- The membrane capture system preliminary cooling water duty and the cooling water flow rate requirements have been defined as well as the design of the direct contact cooler.
- These allow the capture island's additional cooling towers to be sized and positioned.
- An initial layout of the cooling towers and the capture system (including its tie-ins to the existing station flue gas) has been drafted.
- This illustrates that the membrane retrofit can fit within the space available on the existing East Bend site.



#### East Bend Station Plot Plan



Wet FGDs





### East Bend Station w/ MTR PCC Plant Plot Plan



Note: Preliminary Layout (NOT FINAL RESULTS)



### MTRs CO<sub>2</sub> Capture Development – Current Projects









#### Together...Shaping the Future of Electricity





#### Acknowledgement and Disclaimer

#### Acknowledgement

This material is based upon work supported by the Department of under Award Number DE-FE0031589.

#### Disclaimer

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.



33

