



# **FE0000663: The Hydrogen Energy California (HECA) Project- Commercial Demonstration of IGCC with 90% CO<sub>2</sub> Capture**

**N “Maha” Mahasenan  
Principal Advisor- Policy & Strategy**

**NETL CO<sub>2</sub> Capture Technology Meeting  
September 16, 2010  
Pittsburgh, PA**

# HECA Project Overview



IGCC with fully integrated CO<sub>2</sub> capture based on GE Quench Gasification and GE 7F Syngas turbine technologies

Located in Kern County, California (west of Bakersfield), in close proximity to water, gas and transmission infrastructure

Adjacent to Occidental Elk Hills Field and CO<sub>2</sub> injection point for EOR & sequestration

Proximity to feedstock transloading (western bituminous coal and petcoke from CA refineries)

Low population density

# DOE CCPI-3 Award



- Selected in July 2009 based on January 2009 application under Clean Coal Power Initiative- Round 3
- Cooperative Agreement signed September 30, 2009
  - Overall Project Value \$2.8 billion  
(includes costs during demonstration phase but excludes all revenues)
  - DOE Cost Share \$308 million
- Milestone Dates:
  - Full Project Sanction 2012
  - Mechanical Completion 2015
  - Demonstration Phase/ Commercial Operation 2016

# Project Participants



**Hydrogen Energy California (HECA)** Project developer and recipient of DOE CCPI-3 Award

**Fluor** Among world's largest publicly-held engineering and construction contractors, and leader in the design of gasification facilities

**URS** Permitting and NEPA contractor; Respected technical expertise and work relationships with CEC, EPA and local APCD's.

**GE Energy** Leading provider of IGCC technology, equipment and supporting services

**Linde** AGR technology provider, leader in gas processing technologies

**Southern California Edison** Nationally recognized, environmentally responsible electric utility


**Occidental Petroleum (Oxy)** World leader in oil and gas production, largest CO<sub>2</sub> EOR operator in the US.

# HECA Project Objectives



- Commercial demonstration of IGCC with 90% CO<sub>2</sub> Capture
- Use hydrogen-rich syngas to generate 250+ MW net of low carbon base-load power
- 90% CO<sub>2</sub> capture: ~2 million tons for enhanced oil recovery and sequestration in adjacent oil fields
- Operate with feedstock flexibility by utilizing a range of feedstock from western bituminous coal to petroleum coke from CA refineries
- Preserve limited fresh water by utilizing 100% brackish water for plant needs, Zero Liquid Discharge (ZLD) technology and maximum internal water recycling


# Plant Configuration



# Achieving 90% Carbon Capture



## HE-CA Carbon Conversion Flow



- 90% carbon capture during normal steady state operation

# Technology Overview



## Two Project objectives guide technology selection:

- Demonstrate commercial scale IGCC with carbon capture operability at high capture rates and low emissions
- Prove associated economic viability; key aspect is ability to deliver a high reliability operating plant within a minimum period after initial startup

## Strategic approach:


- Where available, select proven technology operating within industry at equivalent capacities and design criteria to reduce the overall risk profile



# Achieving 90% CO<sub>2</sub> Capture: Shift Reaction



Shift reaction converts syngas into hydrogen-rich gas using sour shift catalyst:



Raw syngas from GE quench gasifiers meets the shift reactor moisture content: *no steam injection is required during shift stage(s)*

2 stages needed to meet the Project's 90% carbon capture objective; one at high temperature, and one at moderate temperature.

Proven Technology: Sour shift Cobalt-Molybdenum catalysts have been proven in chemical plants at similar scale and operating conditions.

# Acid Gas Recovery (AGR) Studies

## Hydrogen rich fuel stream (to the gas turbine):

- less than 5 ppmv total sulfur (compatible with state-of-the-art SCR and anticipated air permit requirement)
- CO and CO<sub>2</sub> limited to maintain 90% minimum removal of carbon from the raw syngas. The CO content is controlled by the upstream shift reactors while the CO<sub>2</sub> content is controlled by the AGR system.

## CO<sub>2</sub> stream (to the CO<sub>2</sub> compressor for EOR and storage):

- high purity CO<sub>2</sub> stream containing a max. of 1000 ppmv CO and a max. of 65 ppmv total S in order to support anticipated air permit requirements.
- The total CO<sub>2</sub> product includes a small proportion of CO<sub>2</sub> from the Sulfur Recovery Unit (SRU) Tail Gas Treating Unit (TGTU).

## Acid Gas stream (to the SRU for sulfur capture):

- minimum 45% H<sub>2</sub>S content in order to achieve SRU combustion temperatures

# AGR Study

## product specifications



<b>Treated Syngas (Hydrogen rich fuel)</b>	
Total Sulfur (H <sub>2</sub> S + COS)	5.0 ppmv (max)
CO <sub>2</sub>	2.5 mol % (max)
<b>CO<sub>2</sub> Pipeline Gas (Dry Basis)</b>	
Carbon Dioxide	> 97 mol % (min)
Hydrocarbons (CH <sub>4</sub> +) )	1.0 mol % (max)
Nitrogen	< 2.0 mol % (max)
Total Sulfur (H <sub>2</sub> S, & COS)	65 ppmv (max)
Carbon Monoxide	1000 ppmv (max)
Oxygen	10 ppmv (max)
Ammonia	1 ppmv (max)
Solvent (methanol)	200 ppmv (max)
<b>Acid Gas</b>	
Total Sulfur (H <sub>2</sub> S + COS) Concentration	45 mol % (min)

# Acid Gas Recovery Technology Evaluation



## MDEA, Selexol™, Rectisol® considered

- MDEA couldn't achieve <5ppm total sulfur in H<sub>2</sub> rich syngas

## Selexol™ vs Rectisol® lifecycle cost study undertaken

- consistent cost comparison methodology was applied by third party
- based on performance info and equipment sizing supplied by licensors
- Result: capital costs, operating costs and maintenance costs of the two options are similar and not considered determinative

## Technical evaluation performed

- A Selexol™ plant based in Kansas achieves the required project specifications for total sulfur in the treated gas but at a smaller scale than the HECA Project
- Rectisol® has more commercial operating experience at the same scale as the HECA project at or below the required project specifications for total sulfur

# Selexol™ vs. Rectisol®

## General Observations



- CO<sub>2</sub> capture specification drives the cost
- Rectisol® uses Methanol and operates at low temperature to increase CO<sub>2</sub> loading and reduce solvent circulation rate. Low temperature steel alloys required.
- Selexol™ may require higher alloy steel due to the water soluble nature of the solvent and CO<sub>2</sub> creating slightly acidic conditions. Wet CO<sub>2</sub> requires drying.
- Selexol™ solvent (DMPEG – Dimethyl ethers of Polyethylene Glycol) is a proprietary solvent while methanol is a commodity product.
- Selexol™ solvent loss is low because of low vapor pressure, less flammable, less toxic.

**Rectisol® selected: multiple operating units at similar scale to or below target H<sub>2</sub>S level**

# Acid Gas Recovery Rectisol® licensor evaluation



Further design studies undertaken with Rectisol® technology providers

- Same technical and lifecycle cost methodology used except with more detail
- Both licensors designs met the technical evaluation criteria (see below)
- Linde chosen on the basis of lower lifecycle cost [in this application](#)

## AGR LICENSOR EVALUATION CRITERIA

Commercially Proven Design  
Key References, experience  
Process Description, Process Flow Diagrams  
Battery Limits H&MBs  
Utilities, Effluents & Emissions  
Availability & Reliability Data  
Flexibility of CO<sub>2</sub> recovery  
Metallurgical Issues  
Product Specifications (Syngas, CO<sub>2</sub>, Acid gas)

Impurities in Syngas addressed  
Methanol Solvent Makeup  
Removal of Methanol from CO<sub>2</sub> Product  
Inherently Safe Design  
Design Complexity  
Plot & Elevation  
Sized Equipment List  
Specialty Equipment Cost  
O & M Costs  
Licensing Fees and PDP Cost  
PDP Timetable

# HECA Project Progress



## Engineering Progress


- Signed GE License Agreement, completed Process Design Package
- Selected AGR, SRU and Water Treatment vendors
- Open solicitations : ASU and MAC (Main Automation Contractor)

## Application for Certification (AFC) with CEC

- May 2009: submitted “Application For Certification”
- Aug 2009: “data adequacy” achieved
- Sept 2009: Information hearing and HECA site visit completed
- Over 150 data requests addressed, 3 public workshops
- June 2010: Preliminary Determination of Compliance issued by San Joaquin Valley Air Pollution Control District
- August 2010: Preliminary Staff Assessment (Part 1) issued

## NEPA Review

- Public scoping meeting held on April 14, 2010 in Bakersfield, CA
- CEC is Cooperating Agency for NEPA Process



[www.hydrogenenergycalifornia.com](http://www.hydrogenenergycalifornia.com)