

# Sixth Annual Conference on Carbon Capture & Sequestration

*Steps Toward Deployment*

*CCS Economic Analyses*

## **Outlook for Carbon Capture from Pulverized Coal and Integrated Gasification Combined Cycle Power Plants**

Jared Ciferno, NETL

Julianne Klara, NETL

John Wimer, NETL

May 7-10, 2007 • Sheraton at Station Square • Pittsburgh, PA



# Analyses Conducted Across Various Energy Technologies

New construction  
CO<sub>2</sub> Capture Ready

Retrofit Existing Plants  
Co-sequestration

## *Coal Gasification (IGCC)*

Selexol  
H<sub>2</sub>/ CO<sub>2</sub> Membrane  
Chemical Looping  
Solid & Liquid Sorbents

## *Pulverized Coal*

Amine Scrubbing  
Ammonia Scrubbing  
Solid Sorbents  
CO<sub>2</sub> Membrane

## *Oxyfuel Combustion*

Cryogenic Air Sep. Unit  
O<sub>2</sub> Membranes  
Compact Boilers  
Advanced Steam Cycles  
Chemical Looping



*Pathways to Zero Emissions*



# CO<sub>2</sub> Capture from Fossil Energy Power Plants

## **-Report Contains-**

Subcritical Pulverized Coal

Supercritical Pulverized Coal

Integrated Gasification Combined  
Cycle

Natural Gas Combined Cycle

## Cost and Performance Comparison Baseline for Fossil Energy Power Plants

DOE/NETL-401/053106



**Volume 1: Bituminous Coal and Natural Gas to Electricity  
Draft Final Report**

April 2007



# Study Matrix

Plant Type	ST Cond. (psig/°F/°F)	Gasifier/ Boiler	Acid Gas Removal/ CO <sub>2</sub> Separation / Sulfur Recovery	CO <sub>2</sub> Cap
IGCC	1800/1050/1050 (non-CO <sub>2</sub> capture cases)	GE Energy	Selexol / - / Claus	
			Selexol / Selexol / Claus	90%
	1800/1000/1000 (CO <sub>2</sub> capture cases)	ConocoPhillips (E-Gas)	MDEA / - / Claus	
			Selexol / Selexol / Claus	88% <sup>1</sup>
	1800/1000/1000 (CO <sub>2</sub> capture cases)	Shell	Sulfinol-M / - / Claus	
			Selexol / Selexol / Claus	90%
PC	2400/1050/1050	Subcritical	Wet FGD / - / Gypsum	
			Wet FGD / Econamine / Gypsum	90%
	3500/1100/1100	Supercritical	Wet FGD / - / Gypsum	
			Wet FGD / Econamine / Gypsum	90%

<sup>1</sup> CO<sub>2</sub> capture is limited to 88% by syngas CH<sub>4</sub> content



# Economic Assumptions

<b>Startup</b>	<b>2012</b>
<b>Plant Life (Years)</b>	<b>20</b>
<b>Capital Charge Factor</b>	
<b>High Risk</b>	
<b>(All IGCC, PC/NGCC with CO<sub>2</sub> capture)</b>	<b>17.5</b>
<b>Low Risk</b>	
<b>(PC/NGCC without CO<sub>2</sub> capture)</b>	<b>16.4</b>
<b>Dollars (Constant)</b>	<b>2007</b>
<b>Coal (\$/MM Btu)</b>	<b>1.80</b>
<b>Capacity Factor</b>	
<b>IGCC</b>	<b>80</b>
<b>PC/NGCC</b>	<b>85</b>

---


# **IGCC Power Plant**

## ***Current State*** **with and without CO<sub>2</sub> Capture**



# Current Technology

## IGCC Power Plant



### Process Design Assumptions:

**Dual Train:** 2 gasifiers, 2 Comb. Turbine, 1 Steam Turbine

**Oxygen:** 95% O<sub>2</sub> via Cryogenic ASU, ~4-7% Air Extraction from combustion turbine


**Turbines:** Advanced F-Class Turbine - 232MWe  
N<sub>2</sub> dilution employed to full extent in all cases  
Humidification/steam injection used only when necessary to meet syngas specification of ~120 Btu/scf LHV

**Steam:** 1800psig/1050°F/1050°F



# Pre-Combustion Current Technology

## IGCC Power Plant with CO<sub>2</sub> Scrubbing





# GE Energy IGCC Performance Results

	GE Energy	
CO <sub>2</sub> Capture	NO	YES
Gross Power (MW)	770	745
Auxiliary Power (MW)		
Base Plant Load	23	23
Air Separation Unit	103	121
Gas Cleanup/CO <sub>2</sub> Capture	4	18
CO <sub>2</sub> Compression	-	27
<b>Total Aux. Power (MW)</b>	<b>130</b>	<b>189</b>
<b>Net Power (MW)</b>	<b>640</b>	<b>556</b>
Heat Rate (Btu/kWh)	8,922	10,505
Efficiency (HHV)	<b>38.2</b>	<b>32.5</b>
Energy Penalty <sup>1</sup>	-	<b>5.7</b>

Steam for WGS,  
Selexol Unit

↑ in ASU air comp.  
load w/o turbine  
integration

Includes H<sub>2</sub>S/CO<sub>2</sub>  
Removal in Selexol  
Solvent

<sup>1</sup>CO<sub>2</sub> Capture Energy Penalty = Percent points decrease in net power plant efficiency due to CO<sub>2</sub> Capture



Cost and Performance Comparison Baseline for Fossil Energy Power Plants, U.S. Department of Energy—National Energy Technology Laboratory, Draft Final Report, May 2007

# IGCC Performance Summary

	GE Energy		E-Gas		Shell	
CO <sub>2</sub> Capture	NO	YES	NO	YES	NO	YES
Gross Power (MW)	770	745	742	694	748	693
<b>Auxiliary Power (MW)</b>						
Base Plant Load	23	23	25	26	21	19
Air Separation Unit	103	121	91	109	90	113
Gas Cleanup/CO <sub>2</sub> Capture	4	18	3	15	1	16
CO <sub>2</sub> Compression	-	27	-	26	-	28
<b>Total Aux. Power (MW)</b>	<b>130</b>	<b>189</b>	<b>119</b>	<b>176</b>	<b>112</b>	<b>176</b>
<b>Net Power (MW)</b>	<b>640</b>	<b>556</b>	<b>623</b>	<b>518</b>	<b>636</b>	<b>517</b>
<b>Efficiency (%HHV)</b>	<b>38.2</b>	<b>32.5</b>	<b>39.3</b>	<b>31.7</b>	<b>41.1</b>	<b>32.0</b>
<b>Energy Penalty<sup>1</sup></b>	<b>-</b>	<b>5.7</b>	<b>-</b>	<b>7.6</b>	<b>-</b>	<b>9.1</b>

<sup>1</sup>CO<sub>2</sub> Capture Energy Penalty = Percent points decrease in net power plant efficiency due to CO<sub>2</sub> Capture

**CO<sub>2</sub> Capture decreases net efficiency by ~5-9 percentage points**



# IGCC Economic Results Summary

	GE Energy		E-Gas		Shell	
CO <sub>2</sub> Capture	NO	YES	NO	YES	NO	YES
<b>Plant Cost (\$/kWe)</b>						
Base Plant	1,323	1,566	1,272	1,592	1,522	1,817
Air Separation Unit	287	342	264	329	256	336
Gas Cleanup/CO <sub>2</sub> Capture	203	414	197	441	199	445
CO <sub>2</sub> Compression	-	68	-	69	-	70
<b>Total Plant Cost (\$/kWe)</b>	<b>1,813</b>	<b>2,390</b>	<b>1,733</b>	<b>2,431</b>	<b>1,977</b>	<b>2,668</b>
<b>Capital COE (¢/kWh)</b>						
Capital COE (¢/kWh)	4.53	5.97	4.33	6.07	4.94	6.66
<b>Variable COE (¢/kWh)</b>						
Variable COE (¢/kWh)	3.27	3.94	3.19	4.08	3.11	3.97
<b>Total COE (¢/kWh)</b>						
Total COE (¢/kWh)	<b>7.80</b>	<b>9.9</b>	<b>7.52</b>	<b>10.2</b>	<b>8.05</b>	<b>10.6</b>
<b>Increase in COE (%)</b>						
Increase in COE (%)	-	<b>27</b>	-	<b>35</b>	-	<b>32</b>

## IGCC CO<sub>2</sub> capture results in:

Increase in Capital Cost (TPC) ~ \$577—691/kW

Increase in COE ~2.1—2.6 cents/kWh (~ ↑30%)




# IGCC with CO<sub>2</sub> Capture Key Points

1. Gasifier design (dry feed vs. slurry, quench vs. heat exchanger) has large influence on water-gas shift steam requirement, steam turbine output and net plant efficiency
2. Average COE without CO<sub>2</sub> capture = 7.8 cents/kWh
3. Average COE with CO<sub>2</sub> capture = 10.2 cents/kWh
4. Average CO<sub>2</sub> mitigation cost = \$26/ton CO<sub>2</sub> removed  
(\$33/ton CO<sub>2</sub> avoided)




# Technology Options to Decrease IGCC CO<sub>2</sub> Capture Costs

## *Example* Gas Separation Membranes



# Possible Integrations of Membranes into IGCC Plant




## Membrane Advantages:

1. Compact and modular—unit operation versus complex process
2. Can be put in more than one place
3. Produce CO<sub>2</sub> at pressure
4. Opportunities for Co-capture



# CO<sub>2</sub> Capture Economics for IGCC



A—IGCC w/o CO<sub>2</sub> Capture

D—Selexol w/ Co-Storage of H<sub>2</sub>S/CO<sub>2</sub>

G—Selexol w/ O<sub>2</sub> Membrane

J—Advanced Sorbent w/ O<sub>2</sub>/WGS Membranes

L—Chemical Looping w/ Co-Storage

O—Co-Production w/ SOFC and H<sub>2</sub> Membrane

\*NG at \$5.54/MM Btu

B—Selexol Scrubbing

E—Advanced Sorbent w/ Co-Storage of H<sub>2</sub>S/CO<sub>2</sub>

H—Selexol w/ WGS Membrane

K—Advanced Sorbent w/ O<sub>2</sub>/WGS Membranes, Co-storage

M—Co-Production w/ H<sub>2</sub> Membrane

C—Advanced Sorbent Scrubbing

F\*—Adv. Sorb. + Co-Production + Co-Storage

I—Selexol w/ O<sub>2</sub>/WGS Membranes

N—Co-Production w/ SOFC



---

# **Pulverized Coal Power Plant**

## ***Current State* CO<sub>2</sub> Capture Using Advanced Amines**


**Post-Combustion CO<sub>2</sub> Capture Baseline**





# Post-Combustion Current Technology

## *Pulverized Coal Power Plant with CO<sub>2</sub> Scrubbing*



### **Process Design Assumptions:**

#### **Steam:**

Subcritical → 2400psig/1050°F/1050°F  
 Supercritical → 3500psig/1100°F/1100°F

### **CO<sub>2</sub> Capture Challenges:**

1. Dilute Flue Gas (10-14% CO<sub>2</sub>)
2. Low Pressure CO<sub>2</sub>
3. 1.5 Million scfm
4. 17,000 ton CO<sub>2</sub>/day removed
5. Large Parasitic Loads (Steam + CO<sub>2</sub> Compression)

# Subcritical PC Performance

	Subcritical	
Coal Flow Rate	5,252	7,759
CO <sub>2</sub> Captured (Ton/day)	0	16,566
Gross Power (MW)	584	681
Auxiliary Power (MW)		
Base Plant Load	19	36
Forced + Induced Draft Fans	10	14
Flue Gas Cleanup	4	5
CO <sub>2</sub> Capture	-	24
CO <sub>2</sub> Compression	-	52
Total Aux. Power (MW)	33	131
Net Power (MW)	550	550
Efficiency (%HHV)	36.8	25.0
Energy Penalty (% Points)	-	11.8

48% Increase in Coal Flow Rate

Larger Base Plant

MEA Scrubbing

~17,000 TPD to 2,200 Psig

CO<sub>2</sub> Capture decreases net efficiency by ~12 percentage points



# Pulverized Coal Performance Summary

	Subcritical		Supercritical	
Coal Flow Rate	5,252	7,759	4,935	7,039
CO <sub>2</sub> Captured (Ton/day)	0	16,566	0	15,029
Gross Power (MW)	584	681	580	664
<b>Auxiliary Power (MW)</b>				
Base Plant Load	19	36	21	32
Forced + Induced Draft Fans	10	14	9	13
Flue Gas Cleanup	4	5	3	5
CO <sub>2</sub> Capture	-	24	-	21
CO <sub>2</sub> Compression	-	52	-	47
<b>Total Aux. Power (MW)</b>	<b>33</b>	<b>131</b>	<b>30</b>	<b>118</b>
<b>Net Power (MW)</b>	<b>550</b>	<b>550</b>	<b>550</b>	<b>546</b>
<b>Efficiency (%HHV)</b>	<b>36.8</b>	<b>25.0</b>	<b>39.1</b>	<b>27.2</b>
<b>Energy Penalty (% Points)</b>	<b>-</b>	<b>11.8</b>	<b>-</b>	<b>11.9</b>

**CO<sub>2</sub> Capture decreases net efficiency by ~12 percentage points**



# Pulverized Coal Economic Results Summary

	Subcritical		Supercritical	
CO <sub>2</sub> Capture	NO	YES	NO	YES
<b>Plant Cost (\$/kWe)</b>				
Base Plant	1,302	1,689	1,345	1,729
SOx and NOx Cleanup	246	323	229	302
CO <sub>2</sub> Capture	-	792	-	752
CO <sub>2</sub> Compression	-	89	-	85
<b>Total Plant Cost (\$/kWe)</b>	<b>1,548</b>	<b>2,893</b>	<b>1,574</b>	<b>2,868</b>
<b>Capital COE (¢/kWh)</b>				
	<b>3.41</b>	<b>6.79</b>	<b>3.47</b>	<b>6.74</b>
<b>Variable COE (¢/kWh)</b>				
	<b>2.99</b>	<b>4.63</b>	<b>2.86</b>	<b>4.34</b>
<b>Total COE (¢/kWh)</b>				
	<b>6.40</b>	<b>11.42</b>	<b>6.33</b>	<b>11.08</b>
<b>Increase in COE (%)</b>				
	<b>-</b>	<b>78</b>	<b>-</b>	<b>75</b>

**PC CO<sub>2</sub> capture results in:**

Increase in Capital Cost (TPC) ~ \$1,325/kW

Increase in COE ~5 cents/kWh (~ ↑77%)




# Pulverized Coal CO<sub>2</sub> Capture Key Points

1. **Advanced amine scrubbing technology for 90% CO<sub>2</sub> capture continues to be very energy intensive and costly**
  - Definite need for performance and cost improvements
2. **Average COE without CO<sub>2</sub> capture ~ 6.4 cents/kWh (versus 7.8 cents/kWh for IGCC)**
3. **Average COE with CO<sub>2</sub> capture ~11 cents/kWh (versus 10 cents/kWh for IGCC)**
4. **Average CO<sub>2</sub> mitigation cost = \$41/ton CO<sub>2</sub> removed (\$63/ton CO<sub>2</sub> avoided)**



# Technology Options to Decrease Pulverized Coal CO<sub>2</sub> Capture Costs

## *Example* Oxyfuel Combustion



### “Advanced Pulverized Coal Oxyfuel Combustion”

-Report Contains-  
Supercritical PC Oxyfuel  
Ultra-supercritical PC Oxyfuel  
Cryogenic and membrane  
oxygen  
Co-Sequestration (CO<sub>2</sub>/SO<sub>x</sub>)

# Pulverized Coal Oxyfuel Combustion

## Technology Opportunities


### Cheap Oxygen

Oxygen Membrane



### Advanced MOC

Reduce CO<sub>2</sub> Recycle  
Handle High Sulfur Con.



### Oxyfuel Boilers

Compact Boiler Designs  
Advanced Materials  
Advanced Burners


### Co-Sequestration

Remove FGD



Foster Wheeler, B&W, Alstom Power, Air Liquide, Air Products

# Driving Down Oxyfuel Combustion Costs



Sources:

1. *2007 Pulverized Coal Oxyfuel Combustion Power Plants*, U.S. Department of Energy—National Energy Technology Laboratory, Draft Final Report, April 2007
2. *Conceptual Design of Oxygen Based Pulverized Coal Boiler*, Foster Wheeler North America Corporation, developed for U.S. Department of Energy—National Energy Technology Laboratory, September 2006





# Thank You!

Email: [Jared.Ciferno@netl.doe.gov](mailto:Jared.Ciferno@netl.doe.gov)

Phone: 412-386-5862

**NETL Energy Analysis Link:**

[www.netl.doe.gov/energy-analyses](http://www.netl.doe.gov/energy-analyses)



# Design Basis: Bituminous Coal Type

## Illinois #6 Coal Ultimate Analysis (weight %)

	As Rec'd	Dry
Moisture	11.12	0
Carbon	63.75	71.72
Hydrogen	4.50	5.06
Nitrogen	1.25	1.41
Chlorine	0.29	0.33
Sulfur	2.51	2.82
Ash	9.70	10.91
Oxygen (by difference)	6.88	7.75
	100.0	100.0
HHV (Btu/lb)	11,666	13,126

# Environmental Targets

	IGCC <sup>1</sup>	PC <sup>2</sup>	NGCC <sup>3</sup>
SO <sub>2</sub>	0.0128 lb/MMBtu	0.085 lb/MMBtu	< 0.6 gr S /100 scf
NOx	15 ppmv (dry) @ 15% O <sub>2</sub>	0.07 lb/MMBtu	2.5 ppmv @ 15% O <sub>2</sub>
PM	0.0071 lb/MMBtu	0.017 lb/MMBtu	Negligible
Hg	> 90% capture	1.14 lb/TBtu	Negligible

<sup>1</sup> Based on EPRI's CoalFleet User Design Basis Specification for Coal-Based IGCC Power Plants

<sup>2</sup> Based on BACT analysis, exceeding new NSPS requirements

<sup>3</sup> Based on EPA pipeline natural gas specification and 40 CFR Part 60

